



Home > Nuclear Reactors > Operating Reactors > Reactor Oversight Process > Plant Summaries> Peach Bottom 2 > Quarterly Performance Indicators

Peach Bottom 2 – Quarterly Performance Indicators

1Q/2017 Performance Indicators


The solid trend line represents the current reporting period.

Licensee's General Comments: none

On this page:

- Unplanned Scrams (IE01)
- Unplanned Power Changes per 7000 Critical Hours (IE03)
- Unplanned Scrams with Complications (IE04)
- Safety System Functional Failures (MS05)
- Emergency AC Power Systems (MS06)
- High Pressure Injection Systems (MS07)
- Heat Removal Systems (MS08)
- Residual Heat Removal Systems (MS09)
- Cooling Water Systems (MS10)
- Reactor Coolant System Activity (BI01)
- Reactor Coolant System Leakage (BI02)
- Drill/Exercise Performance (EP01)
- Emergency Response Organization Drill Participation (EP02)
- Alert and Notification System Reliability (EP03)
- Occupational Exposure Control Effectiveness (OR01)
- RETS/OCDM Radiological Effluent Occurrence (PR01)
- Protected Area Equipment (PP01)

Unplanned Scrams per 7000 Critical Hrs



Thresholds: White > 3.0 Yellow > 6.0 Red > 25.0

Notes


Unplanned Scrams per 7000 Critical Hrs	2Q/15	3Q/15	4Q/15	1Q/16	2Q/16	3Q/16	4Q/16	1Q/17
Unplanned scrams	0	0	0	0	0	0	0	0
Critical hours	2184.0	2208.0	2161.3	2183.0	2184.0	2208.0	1797.1	2159.0

Indicator value	0	0	0	0	0	0	0	0
-----------------	---	---	---	---	---	---	---	---

TOP

Licensee Comments: none

Unplanned Power Changes per 7000 Critical Hrs



Thresholds: White > 6.0


Notes

Unplanned Power Changes per 7000 Critical Hrs	2Q/15	3Q/15	4Q/15	1Q/16	2Q/16	3Q/16	4Q/16	1Q/17
Unplanned power changes	1.0	0	0	0	1.0	0	0	2.0
Critical hours	2184.0	2208.0	2161.3	2183.0	2184.0	2208.0	1797.1	2159.0
Indicator value	1.8	1.8	1.6	0.8	0.8	0.8	0.8	2.5

▲ TOP

Licensee Comments: none

Unplanned Scrams with Complications



Thresholds: White > 1.0


Notes

Unplanned Scrams with Complications	2Q/15	3Q/15	4Q/15	1Q/16	2Q/16	3Q/16	4Q/16	1Q/17
Scrams with complications	0	0	0	0	0	0	0	0
Indicator value	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0

▲ TOP

Licensee Comments: none

Safety System Functional Failures (BWR)



Thresholds: White > 6.0

Notes

Safety System Functional Failures (BWR) 2Q/15 3Q/15 4Q/15 1Q/16 2Q/16 3Q/16 4Q/16 1Q/17


Safety System Functional Failures 0 0 0 0 0 0 0 0 1

Indicator value 1 1 0 0 0 0 0 0 1

[TOP](#)

Licensee Comments:
1Q/17: LER 2-17-001

Mitigating Systems Performance Index, Emergency AC Power System



Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4

Notes

Mitigating Systems Performance Index, Emergency AC Power System


	2Q/15	3Q/15	4Q/15	1Q/16	2Q/16	3Q/16	4Q/16	1Q/17
UAI (ΔCDF)	7.46E-09	4.45E-09	-1.57E-09	-5.70E-09	4.33E-09	1.66E-09	4.04E-09	-1.02E-08
URI (ΔCDF)	-8.00E-08	-8.08E-08	-1.26E-07	-1.25E-07	-1.26E-07	-1.24E-07	-1.27E-07	-1.29E-07
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	-7.20E-08	-7.60E-08	-1.30E-07	-1.30E-07	-1.20E-07	-1.20E-07	-1.20E-07	-1.40E-07

▲ TOP

Licensee Comments:

2Q/15: Changed PRA Parameter(s). Changed PRA Parameters based on PRA Model Update PB 2(3)14A; MSPI Basis Document Revision 11.

Mitigating Systems Performance Index, High Pressure Injection System



Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4

Notes

Mitigating Systems Performance Index, High Pressure Injection System


	2Q/15	3Q/15	4Q/15	1Q/16	2Q/16	3Q/16	4Q/16	1Q/17
UAI (Δ CDF)	-2.86E-08	-2.86E-08	-2.86E-08	-2.86E-08	-2.86E-08	-2.86E-08	-2.86E-08	-2.86E-08
URI (Δ CDF)	-4.51E-08	-4.36E-08	-4.36E-08	-4.36E-08	-4.36E-08	-4.36E-08	-4.36E-08	-4.36E-08
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	-7.40E-08	-7.20E-08	-7.20E-08	-7.20E-08	-7.20E-08	-7.20E-08	-7.20E-08	-7.20E-08

▲ TOP

Licensee Comments:

2Q/15: Changed PRA Parameter(s). Changed PRA Parameters based on PRA Model Update PB 2(3)14A; MSPI Basis Document Revision 11.

Mitigating Systems Performance Index, Heat Removal System



Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4

Notes

Mitigating Systems Performance Index, Heat Removal System


	2Q/15	3Q/15	4Q/15	1Q/16	2Q/16	3Q/16	4Q/16	1Q/17
UAI (Δ CDF)	-1.79E-08	-1.79E-08	-1.79E-08	-1.79E-08	-1.79E-08	-1.79E-08	-1.79E-08	-1.19E-08
URI (Δ CDF)	-3.76E-08	-3.62E-08	-3.62E-08	-3.62E-08	-3.62E-08	-3.62E-08	-3.62E-08	2.48E-09
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	-5.60E-08	-5.40E-08	-5.40E-08	-5.40E-08	-5.40E-08	-5.40E-08	-5.40E-08	-9.40E-09

▲ TOP

Licensee Comments:

2Q/15: Changed PRA Parameter(s). Changed PRA Parameters based on PRA Model Update PB 2(3)14A; MSPI Basis Document Revision 11.

Mitigating Systems Performance Index, Residual Heat Removal System



Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4

Notes

Mitigating Systems Performance Index, Residual Heat Removal System


	2Q/15	3Q/15	4Q/15	1Q/16	2Q/16	3Q/16	4Q/16	1Q/17
UAI (ΔCDF)	-8.65E-11	-1.34E-10	-1.35E-10	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
URI (ΔCDF)	-4.86E-10	-4.86E-10	-4.86E-10	-4.86E-10	-4.86E-10	-4.86E-10	-4.86E-10	-4.86E-10
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	-5.70E-10	-6.20E-10	-6.20E-10	-4.90E-10	-4.90E-10	-4.90E-10	-4.90E-10	-4.90E-10

▲ TOP

Licensee Comments:

2Q/15: Changed PRA Parameter(s). Changed PRA Parameters based on PRA Model Update PB 2(3)14A; MSPI Basis Document Revision 11.

Mitigating Systems Performance Index, Cooling Water Systems



Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4

Notes

Mitigating Systems Performance Index, Cooling Water Systems


	2Q/15	3Q/15	4Q/15	1Q/16	2Q/16	3Q/16	4Q/16	1Q/17
UAI (ΔCDF)	5.66E-09	5.32E-09	5.99E-09	5.57E-09	5.40E-09	5.44E-09	5.14E-09	5.20E-09
URI (ΔCDF)	-2.35E-09	-2.35E-09	-2.35E-09	-2.35E-09	5.18E-10	3.39E-09	3.26E-09	3.26E-09
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	3.30E-09	3.00E-09	3.60E-09	3.20E-09	5.90E-09	8.80E-09	8.40E-09	8.50E-09

▲ TOP

Licensee Comments:

2Q/15: Changed PRA Parameter(s). Changed PRA Parameters based on PRA Model Update PB 2(3)14A; MSPI Basis Document Revision 11.

Reactor Coolant System Activity



Thresholds: White > 50.0 Yellow > 100.0


Notes

Reactor Coolant System Activity	4/15	5/15	6/15	7/15	8/15	9/15	10/15	11/15	12/15	1/16	2/16	3/16
Maximum activity	0.000018	0.000022	0.000022	0.000019	0.000020	0.000020	0.000025	0.000021	0.000023	0.000023	0.000025	0.000020
Technical specification limit	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2
Indicator value	0	0	0	0	0	0	0	0	0	0	0	0
Reactor Coolant System Activity	4/16	5/16	6/16	7/16	8/16	9/16	10/16	11/16	12/16	1/17	2/17	3/17
Maximum activity	0.000021	0.000038	0.000026	0.000030	0.000026	0.000026	0.000023	0.000018	0.000020	0.000020	0.000020	0.000020
Technical specification limit	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2
Indicator value	0	0	0	0	0	0	0	0	0	0	0	0

▲ TOP

Licensee Comments: none

Reactor Coolant System Leakage



Thresholds: White > 50.0 Yellow > 100.0

Notes

Reactor Coolant System Leakage	4/15	5/15	6/15	7/15	8/15	9/15	10/15	11/15	12/15	1/16	2/16	3/16
Maximum leakage	1.770	1.900	1.920	1.900	1.890	1.890	1.780	1.780	2.880	1.750	1.750	1.750
Technical specification limit	25.0	25.0	25.0	25.0	25.0	25.0	25.0	25.0	25.0	25.0	25.0	25.0


Indicator value	7.1	7.6	7.7	7.6	7.6	7.6	7.1	7.1	11.5	7.0	7.0	7.0
Reactor Coolant System Leakage	4/16	5/16	6/16	7/16	8/16	9/16	10/16	11/16	12/16	1/17	2/17	3/17
Maximum leakage	1.930	2.000	2.000	1.930	1.890	1.950	1.880	1.740	1.750	1.760	1.760	1.790
Technical specification limit	25.0	25.0	25.0	25.0	25.0	25.0	25.0	25.0	25.0	25.0	25.0	25.0

Indicator value	7.7	8.0	8.0	7.7	7.6	7.8	7.5	7.0	7.0	7.0	7.0	7.2
-----------------	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----

TOP

Licensee Comments: none

Drill/Exercise Performance



Thresholds: White < 90.0% Yellow < 70.0%

Notes

Drill/Exercise Performance	2Q/15	3Q/15	4Q/15	1Q/16	2Q/16	3Q/16	4Q/16	1Q/17
Successful opportunities	43.0	10.0	30.0	80.0	76.0	23.0	7.0	72.0
Total opportunities	44.0	10.0	30.0	81.0	77.0	24.0	7.0	73.0


Indicator value 98.4% 98.7% 98.7% 98.3% 98.4% 98.1% 98.1% 98.6%

▲ TOP

Licensee Comments:

2Q/16: Error in data reporting. Does not affect color indicator.

ERO Drill Participation



Thresholds: White < 80.0% Yellow < 60.0%

Notes


ERO Drill Participation	2Q/15	3Q/15	4Q/15	1Q/16	2Q/16	3Q/16	4Q/16	1Q/17
Participating Key personnel	76.0	78.0	78.0	72.0	74.0	75.0	72.0	74.0
Total Key personnel	76.0	78.0	78.0	72.0	74.0	75.0	72.0	74.0

Indicator value **100.0% 100.0% 100.0% 100.0% 100.0% 100.0% 100.0% 100.0%**

▲ TOP

Licensee Comments: none

Alert & Notification System



Thresholds: White < 94.0% Yellow < 90.0%

Notes


Alert & Notification System	2Q/15	3Q/15	4Q/15	1Q/16	2Q/16	3Q/16	4Q/16	1Q/17
Successful siren-tests	1260	1356	1259	1261	1261	1261	1261	1260
Total sirens-tests	1261	1358	1261	1261	1261	1261	1261	1261

Indicator value 99.9% 99.9% 99.9% 99.9% 99.9% 100.0% 100.0% 100.0%

▲ TOP

Licensee Comments: none

Occupational Exposure Control Effectiveness



Thresholds: White > 2.0 Yellow > 5.0

Notes

Occupational Exposure Control Effectiveness 2Q/15 3Q/15 4Q/15 1Q/16 2Q/16 3Q/16 4Q/16 1Q/17


High radiation area occurrences	0	0	0	0	0	0	0	0
Very high radiation area occurrences	0	0	0	0	0	0	0	0
Unintended exposure occurrences	0	0	0	0	0	0	0	0
Indicator value	0	0	0	0	0	0	0	0

TOP

Licensee Comments:

3Q/15: Update to remove High Radiation Area Occurrence per NEI reporting criteria. There was no color or threshold change.

RETS/ODCM Radiological Effluent



Thresholds: White > 1.0 Yellow > 3.0

Notes

RETS/ODCM Radiological Effluent 2Q/15 3Q/15 4Q/15 1Q/16 2Q/16 3Q/16 4Q/16 1Q/17

RETS/ODCM occurrences 0 0 0 0 0 0 0 0

Indicator value 0 0 0 0 0 0 0 0

[TOP](#)

Licensee Comments: none

Although the Security Cornerstone is included in the Reactor Oversight Process assessment program, the Commission has decided that specific information related to findings and performance indicators pertaining to the Security Cornerstone will not be publicly available to ensure that security information is not provided to a possible adversary. Other than the fact that a finding or performance indicator is Green or Greater-Than-Green, security related information will not be displayed on the public web page.

Current data as of: May 5, 2017

Page Last Reviewed/Updated Wednesday, June 07, 2017