



Home > Nuclear Reactors > Operating Reactors > Reactor Oversight Process > Plant Summaries> Browns Ferry 3 > Quarterly Performance Indicators

Browns Ferry 3 – Quarterly Performance Indicators

2Q/2017 Performance Indicators


The solid trend line represents the current reporting period.

Licensee's General Comments: none

On this page:

- Unplanned Scrams (IE01)
- Unplanned Power Changes per 7000 Critical Hours (IE03)
- Unplanned Scrams with Complications (IE04)
- Safety System Functional Failures (MS05)
- Emergency AC Power Systems (MS06)
- High Pressure Injection Systems (MS07)
- Heat Removal Systems (MS08)
- Residual Heat Removal Systems (MS09)
- Cooling Water Systems (MS10)
- Reactor Coolant System Activity (BI01)
- Reactor Coolant System Leakage (BI02)
- Drill/Exercise Performance (EP01)
- Emergency Response Organization Drill Participation (EP02)
- Alert and Notification System Reliability (EP03)
- Occupational Exposure Control Effectiveness (OR01)
- RETS/OCDM Radiological Effluent Occurrence (PR01)
- Protected Area Equipment (PP01)

Unplanned Scrams per 7000 Critical Hrs



Thresholds: White > 3.0 Yellow > 6.0 Red > 25.0

Notes


| Unplanned Scrams per 7000 Critical Hrs | 3Q/15 | 4Q/15 | 1Q/16 | 2Q/16 | 3Q/16 | 4Q/16 | 1Q/17 | 2Q/17 |
|--|--------|--------|--------|--------|--------|--------|--------|--------|
| Unplanned scrams | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| Critical hours | 2208.0 | 2209.0 | 1327.5 | 2184.0 | 2208.0 | 2209.0 | 2159.0 | 2184.0 |

| Indicator value | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
|-----------------|---|---|---|---|---|---|---|---|
|-----------------|---|---|---|---|---|---|---|---|

TOP

Licensee Comments: none

Unplanned Power Changes per 7000 Critical Hrs



Thresholds: White > 6.0

Notes

| Unplanned Power Changes per 7000 Critical Hrs | 3Q/15 | 4Q/15 | 1Q/16 | 2Q/16 | 3Q/16 | 4Q/16 | 1Q/17 | 2Q/17 |
|---|------------|------------|------------|----------|----------|----------|----------|------------|
| Unplanned power changes | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 1.0 |
| Critical hours | 2208.0 | 2209.0 | 1327.5 | 2184.0 | 2208.0 | 2209.0 | 2159.0 | 2184.0 |
| Indicator value | 1.6 | 0.8 | 0.9 | 0 | 0 | 0 | 0 | 0.8 |


▲ TOP

Licensee Comments:

2Q/17: Data for April 2016 was changed due to counting excluded hours as included hours. No color change occurred as a result of this data change.

2Q/16: Data for April 2016 was changed due to counting excluded hours as included hours. No color change occurred as a result of this data change.

Unplanned Scrams with Complications



Thresholds: White > 1.0

Notes


| Unplanned Scrams with Complications | 3Q/15 | 4Q/15 | 1Q/16 | 2Q/16 | 3Q/16 | 4Q/16 | 1Q/17 | 2Q/17 |
|-------------------------------------|-------|-------|-------|-------|-------|-------|-------|-------|
| Scrams with complications | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |

| | | | | | | | | |
|------------------------|------------|------------|------------|------------|------------|------------|------------|------------|
| Indicator value | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
|------------------------|------------|------------|------------|------------|------------|------------|------------|------------|

▲ TOP

Licensee Comments: none

Mitigating Systems Performance Index, Emergency AC Power System



Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4

Notes

Mitigating Systems Performance Index, Emergency AC Power System

| | 3Q/15 | 4Q/15 | 1Q/16 | 2Q/16 | 3Q/16 | 4Q/16 | 1Q/17 | 2Q/17 |
|------------------------|------------------|------------------|------------------|------------------|------------------|------------------|------------------|------------------|
| UAI (ΔCDF) | 6.35E-08 | 7.81E-08 | 3.06E-08 | -3.78E-08 | -3.78E-08 | -3.78E-08 | -3.78E-08 | -3.78E-08 |
| URI (ΔCDF) | -1.04E-07 | -1.04E-07 | -6.04E-07 | -6.65E-07 | -6.51E-07 | -6.51E-07 | -6.51E-07 | -6.51E-07 |
| PLE | NO | NO | NO | NO | NO | NO | NO | NO |
| Indicator value | -4.00E-08 | -2.60E-08 | -5.70E-07 | -7.00E-07 | -6.90E-07 | -6.90E-07 | -6.90E-07 | -6.90E-07 |

▲ TOP

Licensee Comments:

4Q/16: Changed PRA Parameter(s). NDN-000-999-2010-0003 Revision 12 was updated to show the Failure to Run and Failure to Start basic event importances in each of the tables per CR 1110732-001. The Unit 3 MSPI Basis Document Revision 16 was approved on 9/30/2016 to reflect that change. This change allows the use of Option 2 to determine the FV/UR ratio as described in NEI 99-02, Appendix F 2.3.3. Previously, Option 1 was used with other ratio options shown with a strikethrough. The PRA UnR tables for EDG, HPCI, RCIC, RHR, and RHRSW were revised to reflect the change. Additionally, this revision incorporates the changes to the EECW System Description as required by CR 1202022.


3Q/16: Changed PRA Parameter(s). The MSPI Basis documents for all three units were revised to incorporate PRA changes. The PRA was updated to show the Failure to Run and Failure to Start basic event importance in each of the tables. This change allows the use of Option 2 to determine the FV/UR ratio as described in NEI 99-02, Section F 2.3.3. Previously, Option 1 as described in NEI 99-02 F2.3.3, was used with other ratio options shown with a strikethrough. The PRA UnR tables for EDG, HPCI, RCIC, and RHRSW were revised.

2Q/16: Unit 3: The CAFTA PRA Model Revision 7 was approved on 03/29/2016 with a corresponding MSPI Basis Document Revision 15 approved on 3/31/2016. The PRA model revision was a periodic update to the model which included a data update, HRA update and incorporating recent plant modifications. As a result of the PRA model change, the CDF, Fussel-Vesely and Basic Event Probabilities for all monitored trains and components were revised.

4Q/15: Risk Cap Invoked. The MSPI Risk Cap is invoked. The contribution from the highest worth single failure (2.34E-6) has been replaced by a value of 5E-7.

3Q/15: Risk Cap Invoked. The MSPI Risk Cap is invoked. The contribution from the highest worth single failure (2.34E-06) has been replaced by a value of 5.00E-07.

Mitigating Systems Performance Index, High Pressure Injection System



Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4

Notes

Mitigating Systems Performance Index, High Pressure Injection System

| | 3Q/15 | 4Q/15 | 1Q/16 | 2Q/16 | 3Q/16 | 4Q/16 | 1Q/17 | 2Q/17 |
|------------------------|------------------|------------------|------------------|-----------------|-----------------|-----------------|-----------------|-----------------|
| UAI (ΔCDF) | -3.59E-08 | -3.54E-08 | -3.25E-08 | -3.18E-09 | -2.74E-09 | -2.57E-09 | -2.66E-08 | -2.67E-08 |
| URI (ΔCDF) | -1.79E-07 | -1.79E-07 | -1.79E-07 | 2.83E-07 | 2.35E-07 | 2.35E-07 | 2.35E-07 | 2.35E-07 |
| PLE | NO | NO | NO | NO | NO | NO | NO | NO |
| Indicator value | -2.10E-07 | -2.10E-07 | -2.10E-07 | 2.80E-07 | 2.30E-07 | 2.30E-07 | 2.10E-07 | 2.10E-07 |

TOP

Licensee Comments:


4Q/16: Changed PRA Parameter(s). NDN-000-999-2010-0003 Revision 12 was updated to show the Failure to Run and Failure to Start basic event importances in each of the tables per CR 1110732-001. The Unit 3 MSPI Basis Document Revision 16 was approved on 9/30/2016 to reflect that change. This change allows the use of Option 2 to determine the FV/UR ratio as described in NEI 99-02, Appendix F 2.3.3. Previously, Option 1 was used with other ratio options shown with a strikethrough. The PRA UnR tables for EDG, HPCI, RCIC, RHR, and RHRSW were revised to reflect the change. Additionally, this revision incorporates the changes to the EECW System Description as required by CR 1202022.

3Q/16: Changed PRA Parameter(s). The MSPI Basis documents for all three units were revised to incorporate PRA changes. The PRA was updated to show the Failure to Run and Failure to Start basic event importance in each of the tables. This change allows the use of Option 2 to determine the FV/UR ratio as described in NEI 99-02, Appendix F 2.3.3. Previously, Option 1 as described in NEI 99-02 F2.3.3, was used with other ratio options shown with a strikethrough. The PRA UnR tables for EDG, HPCI, RCIC, RHR, and RHRSW were revised.

2Q/16: Unit 3: The CAFTA PRA Model Revision 7 was approved on 03/29/2016 with a corresponding MSPI Basis Document Revision 15 approved on 3/31/2016. The PRA model revision was a periodic update to the model which included a data update, HRA update and

incorporating recent plant modifications. As a result of the PRA model change, the CDF, Fussel-Vesely and Basic Event Probabilities for all monitored trains and components were revised.

Mitigating Systems Performance Index, Heat Removal System



Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4

Notes

Mitigating Systems Performance Index, Heat Removal System

| | 3Q/15 | 4Q/15 | 1Q/16 | 2Q/16 | 3Q/16 | 4Q/16 | 1Q/17 | 2Q/17 |
|------------------------|------------------|------------------|------------------|------------------|------------------|------------------|------------------|------------------|
| UAI (ΔCDF) | 5.73E-08 | 5.62E-08 | 1.65E-08 | -1.64E-08 | -1.22E-08 | -1.24E-08 | -1.35E-08 | 1.19E-08 |
| URI (ΔCDF) | -1.59E-07 | -1.59E-07 | -1.40E-07 | -7.10E-08 | -6.08E-08 | -6.08E-08 | -6.08E-08 | -6.08E-08 |
| PLE | NO | NO | NO | NO | NO | NO | NO | NO |
| Indicator value | -1.00E-07 | -1.00E-07 | -1.20E-07 | -8.70E-08 | -7.30E-08 | -7.30E-08 | -7.40E-08 | -4.90E-08 |

▲ TOP

Licensee Comments:


4Q/16: Changed PRA Parameter(s). NDN-000-999-2010-0003 Revision 12 was updated to show the Failure to Run and Failure to Start basic event importances in each of the tables per CR 1110732-001. The Unit 3 MSPI Basis Document Revision 16 was approved on 9/30/2016 to reflect that change. This change allows the use of Option 2 to determine the FV/UR ratio as described in NEI 99-02, Appendix F 2.3.3. Previously, Option 1 was used with other ratio options shown with a strikethrough. The PRA UnR tables for EDG, HPCI, RCIC, RHR, and RHRSW were revised to reflect the change. Additionally, this revision incorporates the changes to the EECW System Description as required by CR 1202022.

3Q/16: Changed PRA Parameter(s). The MSPI Basis documents for all three units were revised to incorporate PRA changes. The PRA was updated to show the Failure to Run and Failure to Start basic event importance in each of the tables. This change allows the use of Option 2 to determine the FV/UR ratio as described in NEI 99-02, Appendix F 2.3.3. Previously, Option 1 as described in NEI 99-02 F2.3.3, was used with other ratio options shown with a strikethrough. The PRA UnR tables for EDG, HPCI, RCIC, RHR, and RHRSW were revised.

2Q/16: Unit 3: The CAFTA PRA Model Revision 7 was approved on 03/29/2016 with a corresponding MSPI Basis Document Revision 15 approved on 3/31/2016. The PRA model revision was a periodic update to the model which included a data update, HRA update and

incorporating recent plant modifications. As a result of the PRA model change, the CDF, Fussel-Vesely and Basic Event Probabilities for all monitored trains and components were revised.

Mitigating Systems Performance Index, Residual Heat Removal System



Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4

Notes

Mitigating Systems Performance Index, Residual Heat Removal System

| | 3Q/15 | 4Q/15 | 1Q/16 | 2Q/16 | 3Q/16 | 4Q/16 | 1Q/17 | 2Q/17 |
|------------------------|-----------------|-----------------|-----------------|-----------------|-----------------|-----------------|-----------------|-----------------|
| UAI (ΔCDF) | 7.59E-08 | 1.13E-07 | 7.77E-08 | 1.03E-07 | 7.57E-08 | 3.60E-08 | 2.79E-08 | -3.63E-09 |
| URI (ΔCDF) | -3.35E-09 | 1.89E-07 | 4.93E-07 | 2.73E-07 | 2.73E-07 | 2.73E-07 | 2.73E-07 | 1.82E-07 |
| PLE | NO | NO | NO | NO | NO | NO | NO | NO |
| Indicator value | 7.30E-08 | 3.00E-07 | 5.70E-07 | 3.80E-07 | 3.50E-07 | 3.10E-07 | 3.00E-07 | 1.80E-07 |

▲ TOP

Licensee Comments:

4Q/16: Changed PRA Parameter(s). NDN-000-999-2010-0003 Revision 12 was updated to show the Failure to Run and Failure to Start basic event importances in each of the tables per CR 1110732-001. The Unit 3 MSPI Basis Document Revision 16 was approved on 9/30/2016 to reflect that change. This change allows the use of Option 2 to determine the FV/UR ratio as described in NEI 99-02, Appendix F 2.3.3. Previously, Option 1 was used with other ratio options shown with a strikethrough. The PRA UnR tables for EDG, HPCI, RCIC, RHR, and RHRSW were revised to reflect the change. Additionally, this revision incorporates the changes to the EECW System Description as required by CR 1202022.

3Q/16: Changed PRA Parameter(s). The MSPI Basis documents for all three units were revised to incorporate PRA changes. The PRA was updated to show the Failure to Run and Failure to Start basic event importance in each of the tables. This change allows the use of Option 2 to determine the FV/UR ratio as described in NEI 99-02, Appendix F 2.3.3. Previously, Option 1 as described in NEI 99-02 F2.3.3, was used with other ratio options shown with a strikethrough. The PRA UnR tables for EDG, HPCI, RCIC, RHR, and RHRSW were revised.


2Q/16: Unit 3: The CAFTA PRA Model Revision 7 was approved on 03/29/2016 with a corresponding MSPI Basis Document Revision 15 approved on 3/31/2016. The PRA model revision was a periodic update to the model which included a data update, HRA update and

incorporating recent plant modifications. As a result of the PRA model change, the CDF, Fussel-Vesely and Basic Event Probabilities for all monitored trains and components were revised.

1Q/16: Changed due to additional planned unavailability on RHR system piping flushing activities in December 2015. Change does not affect color of indicator.

4Q/15: 2.35 hours of planned UA due to RHR System piping flushing activities in Dec 2015. Late Entry, reference CR 1133184.

Mitigating Systems Performance Index, Cooling Water Systems



Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4

Notes

Mitigating Systems Performance Index, Cooling Water Systems

| | 3Q/15 | 4Q/15 | 1Q/16 | 2Q/16 | 3Q/16 | 4Q/16 | 1Q/17 | 2Q/17 |
|------------------------|-----------------|-----------------|-----------------|-----------------|-----------------|------------------|------------------|------------------|
| UAI (ΔCDF) | 1.06E-07 | 1.06E-07 | 1.08E-07 | 7.73E-08 | 6.62E-08 | 2.19E-08 | 2.06E-08 | 2.29E-08 |
| URI (ΔCDF) | -5.02E-08 | -5.02E-08 | -5.02E-08 | -2.89E-08 | -2.84E-08 | -2.84E-08 | -2.84E-08 | -2.84E-08 |
| PLE | NO | NO | NO | NO | NO | NO | NO | NO |
| Indicator value | 5.50E-08 | 5.50E-08 | 5.80E-08 | 4.80E-08 | 3.80E-08 | -6.50E-09 | -7.80E-09 | -5.50E-09 |

TOP


Licensee Comments:

4Q/16: Changed PRA Parameter(s). NDN-000-999-2010-0003 Revision 12 was updated to show the Failure to Run and Failure to Start basic event importances in each of the tables per CR 1110732-001. The Unit 3 MSPI Basis Document Revision 16 was approved on 9/30/2016 to reflect that change. This change allows the use of Option 2 to determine the FV/UR ratio as described in NEI 99-02, Appendix F 2.3.3. Previously, Option 1 was used with other ratio options shown with a strikethrough. The PRA UnR tables for EDG, HPCI, RCIC, RHR, and RHRSW were revised to reflect the change. Additionally, this revision incorporates the changes to the EECW System Description as required by CR 1202022.

3Q/16: Changed PRA Parameter(s). The MSPI Basis documents for all three units were revised to incorporate PRA changes. The PRA was updated to show the Failure to Run and Failure to Start basic event importance in each of the tables. This change allows the use of Option 2 to determine the FV/UR ratio as described in NEI 99-02, Appendix F 2.3.3. Previously, Option 1 as described in NEI 99-02 F2.3.3, was used with other ratio options shown with a strikethrough. The PRA UnR tables for EDG, HPCI, RCIC, RHR, and RHRSW were revised.

2Q/16: Changed PRA Parameter(s). Unit 3: The CAFTA PRA Model Revision 7 was approved on 03/29/2016 with a corresponding MSPi Basis Document Revision 15 approved on 3/31/2016. The PRA model revision was a periodic update to the model which included a data update, HRA update and incorporating recent plant modifications. As a result of the PRA model change, the CDF, Fussel-Vesely and Basic Event Probabilities for all monitored trains and components were revised.

Reactor Coolant System Activity



Thresholds: White > 50.0 Yellow > 100.0

Notes


| Reactor Coolant System Activity | 7/15 | 8/15 | 9/15 | 10/15 | 11/15 | 12/15 | 1/16 | 2/16 | 3/16 | 4/16 | 5/16 | 6/16 |
|---------------------------------|----------|----------|----------|----------|----------|----------|----------|----------|------|----------|----------|----------|
| Maximum activity | 0.000049 | 0.000060 | 0.000057 | 0.000044 | 0.000216 | 0.000035 | 0.000033 | 0.000048 | N/A | 0.000031 | 0.000040 | 0.000037 |
| Technical specification limit | 3.2 | 3.2 | 3.2 | 3.2 | 3.2 | 3.2 | 3.2 | 3.2 | 3.2 | 3.2 | 3.2 | 3.2 |
| Indicator value | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | N/A | 0 | 0 | 0 |

| Reactor Coolant System Activity | 7/16 | 8/16 | 9/16 | 10/16 | 11/16 | 12/16 | 1/17 | 2/17 | 3/17 | 4/17 | 5/17 | 6/17 |
|---------------------------------|----------|----------|----------|----------|----------|----------|----------|----------|----------|----------|----------|----------|
| Maximum activity | 0.000032 | 0.000064 | 0.000031 | 0.000029 | 0.000031 | 0.000031 | 0.000028 | 0.000023 | 0.000037 | 0.000037 | 0.000033 | 0.000045 |
| Technical specification limit | 3.2 | 3.2 | 3.2 | 3.2 | 3.2 | 3.2 | 3.2 | 3.2 | 3.2 | 3.2 | 3.2 | 3.2 |
| Indicator value | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |

TOP

Licensee Comments: none

Reactor Coolant System Leakage



Thresholds: White > 50.0 Yellow > 100.0

Notes

| Reactor Coolant System Leakage | 7/15 | 8/15 | 9/15 | 10/15 | 11/15 | 12/15 | 1/16 | 2/16 | 3/16 | 4/16 | 5/16 | 6/16 |
|--------------------------------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|
| Maximum leakage | 1.660 | 1.840 | 1.660 | 1.660 | 1.640 | 1.650 | 1.620 | 1.590 | 1.570 | 1.690 | 1.710 | 1.710 |
| Technical specification limit | 30.0 | 30.0 | 30.0 | 30.0 | 30.0 | 30.0 | 30.0 | 30.0 | 30.0 | 30.0 | 30.0 | 30.0 |


| Indicator value | 5.5 | 6.1 | 5.5 | 5.5 | 5.5 | 5.5 | 5.4 | 5.3 | 5.2 | 5.6 | 5.7 | 5.7 |
|--------------------------------|------------|------------|------------|------------|------------|------------|------------|------------|------------|------------|------------|------------|
| Reactor Coolant System Leakage | 7/16 | 8/16 | 9/16 | 10/16 | 11/16 | 12/16 | 1/17 | 2/17 | 3/17 | 4/17 | 5/17 | 6/17 |
| Maximum leakage | 1.700 | 1.710 | 1.700 | 1.670 | 1.740 | 1.760 | 1.720 | 1.730 | 1.670 | 1.650 | 1.650 | 1.660 |
| Technical specification limit | 30.0 | 30.0 | 30.0 | 30.0 | 30.0 | 30.0 | 30.0 | 30.0 | 30.0 | 30.0 | 30.0 | 30.0 |

| | | | | | | | | | | | | |
|------------------------|------------|------------|------------|------------|------------|------------|------------|------------|------------|------------|------------|------------|
| Indicator value | 5.7 | 5.7 | 5.7 | 5.6 | 5.8 | 5.9 | 5.7 | 5.8 | 5.6 | 5.5 | 5.5 | 5.5 |
|------------------------|------------|------------|------------|------------|------------|------------|------------|------------|------------|------------|------------|------------|

▲ TOP

Licensee Comments: none

Drill/Exercise Performance



Thresholds: White < 90.0% Yellow < 70.0%

Notes

| Drill/Exercise Performance | 3Q/15 | 4Q/15 | 1Q/16 | 2Q/16 | 3Q/16 | 4Q/16 | 1Q/17 | 2Q/17 |
|----------------------------|-------|-------|-------|-------|-------|-------|-------|-------|
| Successful opportunities | 50.0 | 74.0 | 34.0 | 43.0 | 94.0 | 6.0 | 36.0 | 58.0 |
| Total opportunities | 50.0 | 75.0 | 34.0 | 45.0 | 95.0 | 6.0 | 36.0 | 60.0 |


Indicator value **98.6% 98.3% 98.4% 98.1% 98.9% 98.9% 98.9% 98.5%**

▲ TOP

Licensee Comments:

4Q/15: During the November 2015 Emergency Preparedness Graded Exercise NRC Inspection, the NRC identified an error in the PI Data. Emergency Preparedness(EP) failed to count a classification and notification. EP reported 12/12 Drill and Exercise Performance (DEP) opportunities and the actual count is 14/14. Additionally, when Operations Training submitted their October LOR paper work, it included documentation of two "as founds" from September 2015 that were not previously reported. This brought the total DEP opportunities for September 2015 to 18/18. There is no color change associated with this update.

ERO Drill Participation



Thresholds: White < 80.0% Yellow < 60.0%

Notes


| ERO Drill Participation | 3Q/15 | 4Q/15 | 1Q/16 | 2Q/16 | 3Q/16 | 4Q/16 | 1Q/17 | 2Q/17 |
|-----------------------------|-------|-------|-------|-------|-------|-------|-------|-------|
| Participating Key personnel | 85.0 | 91.0 | 93.0 | 91.0 | 98.0 | 97.0 | 101.0 | 97.0 |
| Total Key personnel | 85.0 | 91.0 | 93.0 | 91.0 | 98.0 | 97.0 | 101.0 | 97.0 |

Indicator value **100.0% 100.0% 100.0% 100.0% 100.0% 100.0% 100.0% 100.0%**

▲ TOP

Licensee Comments: none

Alert & Notification System



Thresholds: White < 94.0% Yellow < 90.0%

Notes


| Alert & Notification System | 3Q/15 | 4Q/15 | 1Q/16 | 2Q/16 | 3Q/16 | 4Q/16 | 1Q/17 | 2Q/17 |
|-----------------------------|-------|-------|-------|-------|-------|-------|-------|-------|
| Successful siren-tests | 918 | 726 | 881 | 718 | 932 | 828 | 831 | 727 |
| Total sirens-tests | 936 | 728 | 902 | 728 | 936 | 832 | 832 | 728 |

Indicator value 99.3% 99.4% 98.7% 98.5% 98.9% 98.9% 99.4% 99.7%

▲ TOP

Licensee Comments: none

Occupational Exposure Control Effectiveness



Thresholds: White > 2.0 Yellow > 5.0

Notes


Occupational Exposure Control Effectiveness 3Q/15 4Q/15 1Q/16 2Q/16 3Q/16 4Q/16 1Q/17 2Q/17

| | | | | | | | | |
|--------------------------------------|----------|----------|----------|----------|----------|----------|----------|----------|
| High radiation area occurrences | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| Very high radiation area occurrences | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| Unintended exposure occurrences | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| Indicator value | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |

TOP

Licensee Comments: none

RETS/ODCM Radiological Effluent



Thresholds: White > 1.0 Yellow > 3.0

Notes

RETS/ODCM Radiological Effluent 3Q/15 4Q/15 1Q/16 2Q/16 3Q/16 4Q/16 1Q/17 2Q/17

RETS/ODCM occurrences 0 0 0 0 0 0 0 0

Indicator value 0 0 0 0 0 0 0 0

▲ TOP

Licensee Comments: none

Although the Security Cornerstone is included in the Reactor Oversight Process assessment program, the Commission has decided that specific information related to findings and performance indicators pertaining to the Security Cornerstone will not be publicly available to ensure that security information is not provided to a possible adversary. Other than the fact that a finding or performance indicator is Green or Greater-Than-Green, security related information will not be displayed on the public web page.

Current data as of: July 26, 2017

Page Last Reviewed/Updated Wednesday, June 07, 2017