



Home > Nuclear Reactors > Operating Reactors > Reactor Oversight Process > Plant Summaries> Farley 2 > Quarterly Performance Indicators

## Farley 2 – Quarterly Performance Indicators

### 2Q/2017 Performance Indicators


The solid trend line represents the current reporting period.

Licensee's General Comments: none

On this page:

- Unplanned Scrams (IE01)
- Unplanned Power Changes per 7000 Critical Hours (IE03)
- Unplanned Scrams with Complications (IE04)
- Safety System Functional Failures (MS05)
- Emergency AC Power Systems (MS06)
- High Pressure Injection Systems (MS07)
- Heat Removal Systems (MS08)
- Residual Heat Removal Systems (MS09)
- Cooling Water Systems (MS10)
- Reactor Coolant System Activity (BI01)
- Reactor Coolant System Leakage (BI02)
- Drill/Exercise Performance (EP01)
- Emergency Response Organization Drill Participation (EP02)
- Alert and Notification System Reliability (EP03)
- Occupational Exposure Control Effectiveness (OR01)
- RETS/OCDM Radiological Effluent Occurrence (PR01)
- Protected Area Equipment (PP01)

### Unplanned Scrams per 7000 Critical Hrs



Thresholds: White > 3.0 Yellow > 6.0 Red > 25.0

**Notes**


Unplanned Scrams per 7000 Critical Hrs	3Q/15	4Q/15	1Q/16	2Q/16	3Q/16	4Q/16	1Q/17	2Q/17
Unplanned scrams	0	0	0	1.0	0	0	0	0
Critical hours	2208.0	2080.2	2183.0	1453.8	2208.0	2209.0	2159.0	2184.0

Indicator value	0.9	0	0	0.9	0.9	0.9	0.9	0
-----------------	-----	---	---	-----	-----	-----	-----	---

TOP

Licensee Comments: none

### Unplanned Power Changes per 7000 Critical Hrs



Thresholds: White > 6.0


**Notes**

Unplanned Power Changes per 7000 Critical Hrs	3Q/15	4Q/15	1Q/16	2Q/16	3Q/16	4Q/16	1Q/17	2Q/17
Unplanned power changes	0	0	0	1.0	0	0	1.0	0
Critical hours	2208.0	2080.2	2183.0	1453.8	2208.0	2209.0	2159.0	2184.0
<b>Indicator value</b>	<b>0.9</b>	<b>0</b>	<b>0</b>	<b>0.9</b>	<b>0.9</b>	<b>0.9</b>	<b>1.7</b>	<b>0.8</b>

▲ TOP

Licensee Comments: none

**Unplanned Scrams with Complications**



Thresholds: White > 1.0


**Notes**

Unplanned Scrams with Complications	3Q/15	4Q/15	1Q/16	2Q/16	3Q/16	4Q/16	1Q/17	2Q/17
Scrams with complications	0	0	0	0	0	0	0	0
<b>Indicator value</b>	<b>1.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>

▲ TOP

Licensee Comments: none

### Safety System Functional Failures (PWR)



Thresholds: White > 5.0

**Notes**

Safety System Functional Failures (PWR) 3Q/15 4Q/15 1Q/16 2Q/16 3Q/16 4Q/16 1Q/17 2Q/17

Safety System Functional Failures 0 0 1 0 0 0 0 0


Indicator value 1 1 1 1 1 1 0 0

▲ TOP

Licensee Comments:

1Q/16: LER - 2015 005-00 Turbine Driven Auxiliary Feedwater in a Condition Prohibited by Technical Specifications due to a Design Issue per 10 CFR 50.73(a)(2)(v)(B)

### Mitigating Systems Performance Index, Emergency AC Power System



Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4

**Notes**

**Mitigating Systems Performance Index, Emergency AC Power System**


	3Q/15	4Q/15	1Q/16	2Q/16	3Q/16	4Q/16	1Q/17	2Q/17
UAI ( $\Delta$ CDF)	-3.76E-08	-3.75E-08	-3.03E-08	-3.01E-08	-1.78E-08	-1.78E-08	-2.55E-08	-1.29E-08
URI ( $\Delta$ CDF)	-5.60E-07	-5.60E-07	-2.47E-07	-2.47E-07	-1.41E-07	-1.42E-07	-2.10E-07	3.05E-07
PLE	NO	NO	NO	NO	NO	NO	NO	NO
<b>Indicator value</b>	<b>-6.00E-07</b>	<b>-6.00E-07</b>	<b>-2.80E-07</b>	<b>-2.80E-07</b>	<b>-1.60E-07</b>	<b>-1.60E-07</b>	<b>-2.40E-07</b>	<b>2.90E-07</b>

▲ TOP

Licensee Comments:

3Q/16: Changed PRA Parameter(s).

### Mitigating Systems Performance Index, High Pressure Injection System



Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4

**Notes**

**Mitigating Systems Performance Index, High Pressure Injection System**


	3Q/15	4Q/15	1Q/16	2Q/16	3Q/16	4Q/16	1Q/17	2Q/17
UAI (ΔCDF)	1.37E-07	1.40E-07	2.19E-08	2.07E-08	1.53E-08	1.20E-08	1.31E-08	1.27E-08
URI (ΔCDF)	-2.82E-08	-2.82E-08	-1.43E-08	-1.43E-08	-3.23E-09	-3.23E-09	-3.23E-09	-2.80E-09
PLE	NO	NO	NO	NO	NO	NO	NO	NO
<b>Indicator value</b>	<b>1.10E-07</b>	<b>1.10E-07</b>	<b>7.50E-09</b>	<b>6.30E-09</b>	<b>1.20E-08</b>	<b>8.80E-09</b>	<b>9.90E-09</b>	<b>9.90E-09</b>

▲ TOP

Licensee Comments:

3Q/16: Changed PRA Parameter(s).

### Mitigating Systems Performance Index, Heat Removal System



Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4

**Notes**

**Mitigating Systems Performance Index, Heat Removal System**

	3Q/15	4Q/15	1Q/16	2Q/16	3Q/16	4Q/16	1Q/17	2Q/17
UAI (ΔCDF)	2.35E-07	2.22E-07	1.09E-07	1.03E-07	1.28E-07	6.44E-08	5.06E-08	3.63E-08
URI (ΔCDF)	4.44E-07	4.44E-07	2.23E-07	2.23E-07	2.26E-07	2.26E-07	2.26E-07	1.42E-07
PLE	NO	NO	NO	NO	NO	NO	NO	NO
<b>Indicator value</b>	<b>6.80E-07</b>	<b>6.70E-07</b>	<b>3.30E-07</b>	<b>3.30E-07</b>	<b>3.50E-07</b>	<b>2.90E-07</b>	<b>2.80E-07</b>	<b>1.80E-07</b>


▲ TOP

Licensee Comments:

3Q/16: Changed PRA Parameter(s).

4Q/15: An evaluation is pending for the Nov 2015 failure on Unit 2 Heat Removal.

### Mitigating Systems Performance Index, Residual Heat Removal System



Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4

**Notes**

**Mitigating Systems Performance Index, Residual Heat Removal System**

	3Q/15	4Q/15	1Q/16	2Q/16	3Q/16	4Q/16	1Q/17	2Q/17
UAI (ΔCDF)	-7.74E-08	-7.74E-08	-7.60E-08	-7.60E-08	-3.01E-08	-3.01E-08	-3.01E-08	-2.53E-08
URI (ΔCDF)	-2.25E-07	-2.25E-07	-2.05E-07	-2.05E-07	-9.49E-08	-9.49E-08	-9.49E-08	-9.49E-08
PLE	NO	NO	NO	NO	NO	NO	NO	NO
<b>Indicator value</b>	<b>-3.00E-07</b>	<b>-3.00E-07</b>	<b>-2.80E-07</b>	<b>-2.80E-07</b>	<b>-1.20E-07</b>	<b>-1.20E-07</b>	<b>-1.30E-07</b>	<b>-1.20E-07</b>


▲ TOP

Licensee Comments:

3Q/16: Changed PRA Parameter(s).



### Mitigating Systems Performance Index, Cooling Water Systems



Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4

**Notes**

**Mitigating Systems Performance Index, Cooling Water Systems**


	3Q/15	4Q/15	1Q/16	2Q/16	3Q/16	4Q/16	1Q/17	2Q/17
UAI (ΔCDF)	2.33E-08	2.71E-08	3.82E-08	3.63E-08	3.59E-09	3.76E-09	2.25E-09	1.75E-09
URI (ΔCDF)	-2.12E-07	9.84E-08	-8.50E-08	-8.50E-08	1.83E-09	1.83E-09	1.83E-09	1.83E-09
PLE	NO	NO	NO	NO	NO	NO	NO	NO
<b>Indicator value</b>	<b>-1.90E-07</b>	<b>1.30E-07</b>	<b>-4.70E-08</b>	<b>-4.90E-08</b>	<b>5.40E-09</b>	<b>5.60E-09</b>	<b>4.10E-09</b>	<b>3.60E-09</b>

▲ TOP

Licensee Comments:

3Q/16: Changed PRA Parameter(s).

### Reactor Coolant System Activity



Thresholds: White > 50.0 Yellow > 100.0


**Notes**

Reactor Coolant System Activity	7/15	8/15	9/15	10/15	11/15	12/15	1/16	2/16	3/16	4/16	5/16	6/16
Maximum activity	0.000046	0.000042	0.000037	0.000043	0.000040	0.000045	0.000042	0.000046	0.000047	0.000042	0.000025	0.000023
Technical specification limit	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5
<b>Indicator value</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>
Reactor Coolant System Activity	7/16	8/16	9/16	10/16	11/16	12/16	1/17	2/17	3/17	4/17	5/17	6/17
Maximum activity	0.000041	0.000038	0.000035	0.000057	0.000034	0.000036	0.000034	0.000038	0.000042	0.000049	0.000047	0.000036
Technical specification limit	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5
<b>Indicator value</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>

▲ TOP

Licensee Comments: none

### Reactor Coolant System Leakage



Thresholds: White > 50.0 Yellow > 100.0

**Notes**

Reactor Coolant System Leakage	7/15	8/15	9/15	10/15	11/15	12/15	1/16	2/16	3/16	4/16	5/16	6/16
Maximum leakage	0.059	0.077	0.074	0.064	0.062	0.014	0.014	0.012	0.017	0.011	0.014	0.042
Technical specification limit	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0


<b>Indicator value</b>	<b>0.6</b>	<b>0.8</b>	<b>0.7</b>	<b>0.6</b>	<b>0.6</b>	<b>0.1</b>	<b>0.1</b>	<b>0.1</b>	<b>0.2</b>	<b>0.1</b>	<b>0.1</b>	<b>0.4</b>
Reactor Coolant System Leakage	7/16	8/16	9/16	10/16	11/16	12/16	1/17	2/17	3/17	4/17	5/17	6/17
Maximum leakage	0.024	0.020	0.016	0.013	0.016	0.010	0.011	0.013	0.050	0.090	0.104	0.018
Technical specification limit	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0

<b>Indicator value</b>	<b>0.2</b>	<b>0.2</b>	<b>0.2</b>	<b>0.1</b>	<b>0.2</b>	<b>0.1</b>	<b>0.1</b>	<b>0.1</b>	<b>0.5</b>	<b>0.9</b>	<b>1.0</b>	<b>0.2</b>
------------------------	------------	------------	------------	------------	------------	------------	------------	------------	------------	------------	------------	------------

▲ TOP

Licensee Comments: none

### Drill/Exercise Performance



Thresholds: White < 90.0% Yellow < 70.0%

#### Notes


Drill/Exercise Performance	3Q/15	4Q/15	1Q/16	2Q/16	3Q/16	4Q/16	1Q/17	2Q/17
Successful opportunities	59.0	22.0	84.0	39.0	37.0	6.0	35.0	64.0
Total opportunities	59.0	22.0	87.0	40.0	37.0	7.0	36.0	64.0

Indicator value                    99.0% 99.0% 98.6% 98.6% 98.6% 98.2% 97.7% 98.3%

▲ TOP

Licensee Comments: none

### ERO Drill Participation



Thresholds: White < 80.0% Yellow < 60.0%

#### Notes


ERO Drill Participation	3Q/15	4Q/15	1Q/16	2Q/16	3Q/16	4Q/16	1Q/17	2Q/17
Participating Key personnel	114.0	120.0	120.0	116.0	120.0	121.0	113.0	110.0
Total Key personnel	115.0	120.0	120.0	116.0	120.0	121.0	113.0	110.0

**Indicator value**                    **99.1% 100.0% 100.0% 100.0% 100.0% 100.0% 100.0% 100.0%**

▲ TOP

Licensee Comments: none

### Alert & Notification System



Thresholds: White < 94.0% Yellow < 90.0%

**Notes**


Alert & Notification System	3Q/15	4Q/15	1Q/16	2Q/16	3Q/16	4Q/16	1Q/17	2Q/17
Successful siren-tests	1150	1244	1152	1157	1152	1244	1155	1156
Total sirens-tests	1157	1246	1157	1157	1157	1246	1157	1157

**Indicator value**                    **99.5%** **99.6%** **99.6%** **99.7%** **99.7%** **99.7%** **99.8%** **99.8%**

▲ TOP

Licensee Comments: none

### Occupational Exposure Control Effectiveness



Thresholds: White > 2.0 Yellow > 5.0

**Notes**


**Occupational Exposure Control Effectiveness** 3Q/15 4Q/15 1Q/16 2Q/16 3Q/16 4Q/16 1Q/17 2Q/17

High radiation area occurrences	0	0	0	0	0	0	0	0
Very high radiation area occurrences	0	0	0	0	0	0	0	0
Unintended exposure occurrences	0	0	0	0	0	0	0	0
<b>Indicator value</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>

TOP

Licensee Comments: none

### RETS/ODCM Radiological Effluent



Thresholds: White > 1.0 Yellow > 3.0

**Notes**

**RETS/ODCM Radiological Effluent** 3Q/15 4Q/15 1Q/16 2Q/16 3Q/16 4Q/16 1Q/17 2Q/17

RETS/ODCM occurrences                    0    0    0    0    0    0    0    0

**Indicator value**                            0    0    0    0    0    0    0    0

▲ TOP

Licensee Comments: none

Although the Security Cornerstone is included in the Reactor Oversight Process assessment program, the Commission has decided that specific information related to findings and performance indicators pertaining to the Security Cornerstone will not be publicly available to ensure that security information is not provided to a possible adversary. Other than the fact that a finding or performance indicator is Green or Greater-Than-Green, security related information will not be displayed on the public web page.

*Current data as of: July 26, 2017*

*Page Last Reviewed/Updated Wednesday, June 07, 2017*