



Home > Nuclear Reactors > Operating Reactors > Reactor Oversight Process > Plant Summaries> Fermi 2 > Quarterly Performance Indicators

Fermi 2 – Quarterly Performance Indicators

2Q/2017 Performance Indicators


The solid trend line represents the current reporting period.

Licensee's General Comments: none

On this page:

- Unplanned Scrams (IE01)
- Unplanned Power Changes per 7000 Critical Hours (IE03)
- Unplanned Scrams with Complications (IE04)
- Safety System Functional Failures (MS05)
- Emergency AC Power Systems (MS06)
- High Pressure Injection Systems (MS07)
- Heat Removal Systems (MS08)
- Residual Heat Removal Systems (MS09)
- Cooling Water Systems (MS10)
- Reactor Coolant System Activity (BI01)
- Reactor Coolant System Leakage (BI02)
- Drill/Exercise Performance (EP01)
- Emergency Response Organization Drill Participation (EP02)
- Alert and Notification System Reliability (EP03)
- Occupational Exposure Control Effectiveness (OR01)
- RETS/OCDM Radiological Effluent Occurrence (PR01)
- Protected Area Equipment (PP01)

Unplanned Scrams per 7000 Critical Hrs



Thresholds: White > 3.0 Yellow > 6.0 Red > 25.0

Notes


Unplanned Scrams per 7000 Critical Hrs	3Q/15	4Q/15	1Q/16	2Q/16	3Q/16	4Q/16	1Q/17	2Q/17
Unplanned scrams	1.0	0	0	0	0	0	0	0
Critical hours	1799.1	867.1	2183.0	1969.9	2208.0	2088.3	1826.0	1748.4

Indicator value	1.8	2.1	1.0	1.0	0	0	0	0
-----------------	-----	-----	-----	-----	---	---	---	---

TOP

Licensee Comments: none

Unplanned Power Changes per 7000 Critical Hrs



Thresholds: White > 6.0


Notes

Unplanned Power Changes per 7000 Critical Hrs	3Q/15	4Q/15	1Q/16	2Q/16	3Q/16	4Q/16	1Q/17	2Q/17
Unplanned power changes	0	0	1.0	0	1.0	0	1.0	1.0
Critical hours	1799.1	867.1	2183.0	1969.9	2208.0	2088.3	1826.0	1748.4
Indicator value	0.9	1.1	1.0	1.0	1.9	1.7	1.7	2.7

▲ TOP

Licensee Comments: none

Unplanned Scrams with Complications



Thresholds: White > 1.0


Notes

Unplanned Scrams with Complications	3Q/15	4Q/15	1Q/16	2Q/16	3Q/16	4Q/16	1Q/17	2Q/17
Scrams with complications	1.0	0	0	0	0	0	0	0
Indicator value	1.0	1.0	1.0	1.0	0.0	0.0	0.0	0.0

▲ TOP

Licensee Comments: none

Safety System Functional Failures (BWR)



Thresholds: White > 6.0

Notes

Safety System Functional Failures (BWR) 3Q/15 4Q/15 1Q/16 2Q/16 3Q/16 4Q/16 1Q/17 2Q/17


Safety System Functional Failures 0 0 1 0 0 1 1 0

Indicator value 1 1 2 1 1 2 2 2

▲ TOP

Licensee Comments:
1Q/17: LER 2017-001

Mitigating Systems Performance Index, Emergency AC Power System



Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4

Notes


Mitigating Systems Performance Index, Emergency AC Power System

	3Q/15	4Q/15	1Q/16	2Q/16	3Q/16	4Q/16	1Q/17	2Q/17
UAI (Δ CDF)	7.23E-09	5.96E-09	1.15E-08	1.52E-08	1.22E-08	6.48E-09	1.31E-08	2.67E-09
URI (Δ CDF)	-3.37E-08	-3.37E-08	-7.74E-08	-7.74E-08	-7.74E-08	-7.74E-08	-7.74E-08	-7.74E-08
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	-2.60E-08	-2.80E-08	-6.60E-08	-6.20E-08	-6.50E-08	-7.10E-08	-6.40E-08	-7.50E-08

▲ TOP

Licensee Comments: none

Mitigating Systems Performance Index, High Pressure Injection System



Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4

Notes


Mitigating Systems Performance Index, High Pressure Injection System

	3Q/15	4Q/15	1Q/16	2Q/16	3Q/16	4Q/16	1Q/17	2Q/17
UAI (Δ CDF)	-2.63E-08	-2.63E-08	-2.15E-08	-2.15E-08	-2.15E-08	-2.15E-08	-2.15E-08	-2.15E-08
URI (Δ CDF)	-4.30E-08	-4.30E-08	-3.71E-08	-3.71E-08	-3.71E-08	-3.71E-08	-3.71E-08	-3.71E-08
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	-6.90E-08	-6.90E-08	-5.90E-08	-5.90E-08	-5.90E-08	-5.90E-08	-5.90E-08	-5.90E-08

▲ TOP

Licensee Comments: none

Mitigating Systems Performance Index, Heat Removal System



Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4

Notes

Mitigating Systems Performance Index, Heat Removal System


	3Q/15	4Q/15	1Q/16	2Q/16	3Q/16	4Q/16	1Q/17	2Q/17
UAI (ΔCDF)	-9.25E-10	-9.25E-10	-6.68E-10	-6.68E-10	-6.68E-10	-6.68E-10	-6.68E-10	-6.68E-10
URI (ΔCDF)	-2.33E-09	-2.33E-09	-1.54E-09	-1.55E-09	-1.55E-09	-1.55E-09	-1.55E-09	-1.55E-09
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	-3.30E-09	-3.30E-09	-2.20E-09	-2.20E-09	-2.20E-09	-2.20E-09	-2.20E-09	-2.20E-09

▲ TOP

Licensee Comments:

2Q/16: Changed PRA Parameter(s).

Mitigating Systems Performance Index, Residual Heat Removal System



Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4

Notes

Mitigating Systems Performance Index, Residual Heat Removal System

	3Q/15	4Q/15	1Q/16	2Q/16	3Q/16	4Q/16	1Q/17	2Q/17
UAI (Δ CDF)	3.23E-09	2.72E-09	9.64E-09	1.70E-09	1.28E-09	1.76E-09	-4.05E-10	-3.59E-10
URI (Δ CDF)	-4.30E-09	-4.30E-09	-1.08E-08	-1.08E-08	-1.08E-08	-1.08E-08	-1.08E-08	-1.08E-08
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	-1.10E-09	-1.60E-09	-1.10E-09	-9.10E-09	-9.50E-09	-9.00E-09	-1.10E-08	-1.10E-08

▲ TOP

Licensee Comments: none

Mitigating Systems Performance Index, Cooling Water Systems



Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4

Notes

Mitigating Systems Performance Index, Cooling Water Systems


	3Q/15	4Q/15	1Q/16	2Q/16	3Q/16	4Q/16	1Q/17	2Q/17
UAI (ΔCDF)	6.33E-09	6.35E-09	2.33E-09	2.92E-09	2.25E-09	3.09E-09	4.15E-09	1.26E-08
URI (ΔCDF)	-2.59E-10	-2.59E-10	-5.89E-10	-5.89E-10	-5.89E-10	-5.89E-10	-5.89E-10	9.47E-10
PLE	NO	NO	NO	NO	NO	NO	NO	NO

Indicator value **1.40E-08**

▲ TOP

Licensee Comments: none

Reactor Coolant System Activity



Thresholds: White > 50.0 Yellow > 100.0

Notes


Reactor Coolant System Activity	7/15	8/15	9/15	10/15	11/15	12/15	1/16	2/16	3/16	4/16	5/16	6/16
Maximum activity	0.000015	0.000011	0.000012	N/A	0.000006	0.000006	0.000007	0.000008	0.000008	0.000011	0.000009	0.000008
Technical specification limit	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2
Indicator value	0	0	0	N/A	0	0	0	0	0	0	0	0

Reactor Coolant System Activity	7/16	8/16	9/16	10/16	11/16	12/16	1/17	2/17	3/17	4/17	5/17	6/17
Maximum activity	0.000014	0.000011	0.000008	0.000015	0.000005	0.000016	0.000011	0.000019	0.000018	0.000008	0.000010	0.000009
Technical specification limit	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2
Indicator value	0	0	0	0	0	0	0	0	0	0	0	0

TOP

Licensee Comments: none

Reactor Coolant System Leakage



Thresholds: White > 50.0 Yellow > 100.0

Notes

Reactor Coolant System Leakage	7/15	8/15	9/15	10/15	11/15	12/15	1/16	2/16	3/16	4/16	5/16	6/16
Maximum leakage	1.660	1.660	1.650	0	1.750	1.680	1.650	1.640	1.640	1.640	1.650	1.650
Technical specification limit	25.0	25.0	25.0	25.0	25.0	25.0	25.0	25.0	25.0	25.0	25.0	25.0


Indicator value	6.6	6.6	6.6	0	7.0	6.7	6.6	6.6	6.6	6.6	6.6	6.6
Reactor Coolant System Leakage	7/16	8/16	9/16	10/16	11/16	12/16	1/17	2/17	3/17	4/17	5/17	6/17
Maximum leakage	1.630	1.610	1.610	1.650	1.660	1.660	1.650	1.650	1.660	1.700	1.840	1.710
Technical specification limit	25.0	25.0	25.0	25.0	25.0	25.0	25.0	25.0	25.0	25.0	25.0	25.0

Indicator value	6.5	6.4	6.4	6.6	6.6	6.6	6.6	6.6	6.6	6.8	7.4	6.8
-----------------	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----

TOP

Licensee Comments: none

Drill/Exercise Performance



Thresholds: White < 90.0% Yellow < 70.0%

Notes


Drill/Exercise Performance	3Q/15	4Q/15	1Q/16	2Q/16	3Q/16	4Q/16	1Q/17	2Q/17
Successful opportunities	53.0	22.0	24.0	46.0	41.0	56.0	18.0	100.0
Total opportunities	53.0	22.0	24.0	48.0	43.0	58.0	19.0	101.0

Indicator value 99.2% 99.5% 99.5% 99.2% 98.5% 97.9% 97.6% 97.8%

▲ TOP

Licensee Comments: none

ERO Drill Participation



Thresholds: White < 80.0% Yellow < 60.0%

Notes


ERO Drill Participation	3Q/15	4Q/15	1Q/16	2Q/16	3Q/16	4Q/16	1Q/17	2Q/17
Participating Key personnel	113.0	113.0	110.0	108.0	109.0	114.0	115.0	114.0
Total Key personnel	114.0	115.0	110.0	109.0	109.0	114.0	115.0	114.0

Indicator value **99.1% 98.3% 100.0% 99.1% 100.0% 100.0% 100.0% 100.0%**

▲ TOP

Licensee Comments: none

Alert & Notification System



Thresholds: White < 94.0% Yellow < 90.0%

Notes


Alert & Notification System	3Q/15	4Q/15	1Q/16	2Q/16	3Q/16	4Q/16	1Q/17	2Q/17
Successful siren-tests	186	186	182	186	186	185	185	185
Total sirens-tests	186	186	186	186	186	186	186	186

Indicator value **99.4%** **99.7%** **99.5%** **99.5%** **99.5%** **99.3%** **99.7%** **99.6%**

▲ TOP

Licensee Comments: none

Occupational Exposure Control Effectiveness



Thresholds: White > 2.0 Yellow > 5.0

Notes


Occupational Exposure Control Effectiveness 3Q/15 4Q/15 1Q/16 2Q/16 3Q/16 4Q/16 1Q/17 2Q/17

High radiation area occurrences	0	0	0	0	0	1	0	0
Very high radiation area occurrences	0	0	0	0	0	0	0	0
Unintended exposure occurrences	0	0	0	0	0	0	0	0
Indicator value	0	0	0	0	0	1	1	1

TOP

Licensee Comments: none

RETS/ODCM Radiological Effluent



Thresholds: White > 1.0 Yellow > 3.0

Notes

RETS/ODCM Radiological Effluent 3Q/15 4Q/15 1Q/16 2Q/16 3Q/16 4Q/16 1Q/17 2Q/17

RETS/ODCM occurrences 0 0 0 0 0 0 0 0

Indicator value 0 0 0 0 0 0 0 0

▲ TOP

Licensee Comments: none

Although the Security Cornerstone is included in the Reactor Oversight Process assessment program, the Commission has decided that specific information related to findings and performance indicators pertaining to the Security Cornerstone will not be publicly available to ensure that security information is not provided to a possible adversary. Other than the fact that a finding or performance indicator is Green or Greater-Than-Green, security related information will not be displayed on the public web page.

Current data as of: July 26, 2017

Page Last Reviewed/Updated Wednesday, June 07, 2017