## Official Transcript of Proceedings

## **NUCLEAR REGULATORY COMMISSION**

Title: Advisory Committee on Reactor Safeguards

516th Meeting

Docket Number: (not applicable)

Location: Rockville, Maryland

Date: Thursday, October 7, 2004

Work Order No.: NRC-023 Pages 1-433

NEAL R. GROSS AND CO., INC. Court Reporters and Transcribers 1323 Rhode Island Avenue, N.W. Washington, D.C. 20005 (202) 234-4433

	_
1	UNITED STATES OF AMERICA
2	NUCLEAR REGULATORY COMMISSION
3	+ + + +
4	ADVISORY COMMITTEE ON REACTOR SAFEGUARDS (ACRS)
5	+ + + +
6	516th MEETING
7	+ + + +
8	THURSDAY
9	OCTOBER 7, 2004
10	+ + + +
11	ROCKVILLE, MARYLAND
12	+ + + +
13	The meeting was convened in Room T-2B3 of Two
14	White Flint North, 11545 Rockville Pike, Rockville,
15	Maryland, at 8:30 a.m., Dr. Mario V. Bonaca, Chairman,
16	presiding.
17	MEMBERS PRESENT:
18	MARIO V. BONACA Chairman
19	GRAHAM WALLIS Vice Chairman
20	F. PETER FORD ACRS Member
21	RICHARD S. DENNING ACRS Member
22	THOMAS S. KRESS ACRS Member
23	GEORGE E. APOSTOLAKIS ACRS Member
24	GRAHAM M. LEITCH ACRS Member
25	DANA A. POWERS ACRS Member
į	•

MEMBERS PRESENT: (CONT.)  VICTOR H. RANSOM ACRS Member  STEPHEN L. ROSEN ACRS Member-at-Large  WILLIAM J. SHACK ACRS Member  JOHN D. SIEBER ACRS Member  NRC STAFF PRESENT:	
3 STEPHEN L. ROSEN ACRS Member-at-Large 4 WILLIAM J. SHACK ACRS Member 5 JOHN D. SIEBER ACRS Member 6 7 NRC STAFF PRESENT:	
4 WILLIAM J. SHACK ACRS Member 5 JOHN D. SIEBER ACRS Member 6 7 NRC STAFF PRESENT:	
JOHN D. SIEBER ACRS Member  NRC STAFF PRESENT:	
7 NRC STAFF PRESENT:	
7 NRC STAFF PRESENT:	
O TOUN TO INDUING Errogutive Disconting	
8 JOHN T. LARKINS Executive Director,	
9 ACRS/ACNW	
10 SAM DURAISWAMY Technical Assistant,	
11 ACRS/ACNW, Designated	
12 Federal Official	
13	
14	
15	
16	
17	
18	
19	
20	
21	
22	
23	
24	
25	

## PROCEEDINGS

1	PROCEEDINGS
2	(8:31 a.m.)
3	CHAIRMAN BONACA: Good morning. This
4	meeting now will come to order.
5	This is the first day of the 516th meeting
6	of the Advisory Committee on Reactor Safeguards.
7	During today's meeting, the Committee will consider
8	the following:
9	Safety Evaluation of the Industry
10	Guidelines Related to Pressurized Water Reactor Sump
11	Performance, Pre-Application Safety Assessment Report
12	for the Advanced CANDU 700 design, Proposed
13	Recommendations for Resolving GSI-185 "Control of
14	Recriticality Following Small-Break LOCAs in PWRs",
15	Mitigation System Performance Index Program, and
16	Preparation of ACRS Reports.
17	The first session is going to be
18	transmitted in the broadband TV throughout the
19	building.
20	This meeting is being conducted in
21	accordance with the Federal Advisory Committee Act.
22	Dr. John Larkins is the designated federal
23	official for the initial portion of the meeting.
24	We have received no written comments or
25	requests for time to make oral statements from a

member of the public regarding today's sessions.

A transcript of portions of the meeting is being kept. And it is requested that the speakers use one of the microphones, identify themselves, and speak with sufficient clarity and volume so that they can be readily heard.

I will begin now with some items of current interest.

First of all, Dr. Richard Denning has joined us an official member of the ACRS. I welcome you on board.

(Applause.)

CHAIRMAN BONACA: Secondly, you have in front of you a package of items of interest. I would like to point out on the second page, you will see there is the dates of the Nuclear Safety Research Conference. It's being held from October 25th to 27th at the Marriott at Metro Center. For those of you who are interested in attending, there is information in related to the conference here.

With that, I think we can move from the introduction to the first item on the agenda. That's the safety evaluation of the industry guidelines related to the pressurizer water reactor sump performance. And Dr. Wallis is going to lead us

6 1 through this presentation. 2 VICE CHAIRMAN WALLIS: I surely thank you, 3 Mr. Chairman, I will. 4 Good morning. 5 We're going to hear about the latest in a series of steps currently undertaken by the staff to 6 7 resolve GSI-191 concerning the potential for sump screen blockage during water recirculation following 8 9 a LOCA. 10 I remind you that the staff issued Reg 11 Guide 1.82, Ref 3, describing a set of requirements 12 and necessary calculations. In our letter, commented that it gave little guidance about how to 13 14 perform these calculations. 15 The staff recently issued a Generic Letter information 16 on the evaluations 17 We reviewed various versions of this licensees. letter and commented that the calculations depended on 18 19 quidance that was being prepared by NEI. NEI has now 20 supplied this guidance and we are here today to hear 21 the staff's response in the form of 22 evaluation report or SER. 23

I think it would be useful, both to us and to the staff, to bear in mind several matters which came up at the subcommittee meeting, which some of the

24

1 members didn't attend because it is only 2 subcommittee. I think this will help to put the 3 guidance and SER in perspective. 4 I invite the staff to correct me if 5 anything that I say is wrong. calculations using the 6 Item 1, 7 baseline method for a large break near a steam generator covered with insulation in a particular PWR 8 leads to generation of 14,000 cubic feet of debris, of 9 which 5,100 cubic feet gets to the sump screen. 10 11 This corresponds to 50 feet thickness of 12 debris on a 100 square foot screen, which is larger than is installed in some plants. 13 14 The staff's modification of the quidance 15 using this factor of 40 percent to change the damage pressure would increase the amount of debris. 16 17 Item 2, an effect which has been called the thin bed effect appears to really be the effect of 18 19 any layer of pure cal-sil or of fibers more or less 20 saturated with cal-sil or perhaps with some other 21 particular matter. It can occur anywhere in the 22 layers on the screen. 23 There was a single repeated Los Alamos 24 test in which a thickness of about 18 mils, or less

than half a millimeter of cal-sil mixed with a small

amount of fibers produced this effect.

1

2

3

4

5

6

7

8

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

25

Now 18 mils of cal-sil on a 100 square foot screen is a little over a gallon which is a volume of two inch thick insulation on a two inch pipe one foot long. It's about three times as much as we have here.

Item 3, many of the calculation procedures appear to be based on physics which may unrealistic. There are about a dozen unresolved technical issues which were raised the subcommittee.

Item 4, several parameters in the procedures and calculations appear to be based on a sparse database, sometimes a single experiment or even a single data point. For some materials like coating debris, there may be no database at all.

Item 5, the available database for some parameters does not encompass LOCA conditions. There are many uncertainties about how to apply a limited range of lab tests to realistic LOCA conditions.

If the staff restricts use to the range that has been validated, which appears to be its intent, the methods may be unusable without further extensive testing.

Item 6, there is no guidance for some

effects such as chemical or downstream effects. Plant 1 2 specific methods appear to be required. Now I said all this because I think we 3 4 need to put it in perspective and the staff needs to 5 respond to these issues which came up subcommittee meeting sometime today if they can do so. 6 7 Thank you very much. 8 MR. JOHNSON: Thank you. My name is Michael Johnson. I'm from the Office of the Nuclear 9 Reactor Regulation. And I'm joined by staff from NRR 10 11 and also staff from Research and also support from 12 LANL. We certainly appreciated the opportunity 13 14 to meet with the subcommittee last month. 15 appreciate the opportunity to meet with the full 16 committee today. 17 And, Dr. Wallis, we are certainly aware of the issues that you have raised. And we look to be 18 19 able to talk to those issues as we go through the 20 presentation. I want to open with some high level 21 22 overall comments. And then we'll move out throughout 23 the presentation. 24 As was pointed out, and the committee is well aware, GSI-191 is an important safety issue. And 25

1	was pointed out, we issued a bulletin following our
2	briefing. In August we issued a Generic Letter. A
3	central part of that Generic Letter is to have
4	licensees doing evaluation. And, of course, that the
5	
6	VICE CHAIRMAN WALLIS: I'm sorry to
7	interrupt. We don't have any handouts from you?
8	MR. JOHNSON: You don't have handouts from
9	me. That's correct.
10	VICE CHAIRMAN WALLIS: Are there going to
11	be no handouts? So we don't know what you're going to
12	say?
13	MR. JOHNSON: That's right.
14	VICE CHAIRMAN WALLIS: Oh, that's very
15	interesting. Thank you.
16	MR. JOHNSON: Of course a central part of
17	this Generic Letter we talk to the Generic Letter
18	as the industry's evaluation guideline. And we are
19	here today, of course, to talk about the staff's
20	evaluation, our safety evaluation of the industry
21	guidelines related to GSI-191.
22	I wanted to just make a point before we
23	get started and that is that I think the staff has
24	done a tremendous amount of work in terms of dealing
25	with this issue. And we're very proud of what the

staff has done.

And that tremendous amount of work, I think, includes interacting with the industry and external stakeholders at almost every stage of development of the industry's guidance report. It includes carefully reviewing the various final industry submittals that we had that formed the basis of the guidance report.

And so, again, the staff has done a tremendous amount of work on this activity. In addition, we worked very hard to consider the subcommittee's comments that were provided last month.

And we're going to try again in today's presentation to be able to focus in on what we heard as the major comments and what we've done in terms of revising the SE, where possible, to incorporate improvements.

In our presentation, what we plan to do is provide first of all a brief overall description of the approach at a very high level. Following that, Tom Hafera, who is going to come and is going to talk very briefly -- I think one of the things the subcommittee was interested in when we met with you was trying to get a practical feel for what actually happens when you apply the application methodology.

1 In fact, some of the numbers that you 2 talked about, the 14,000 and 5,000, we've taken a look 3 at that and Tom is going to be able to talk about the 4 LOCA accident and, in fact, where we think the 5 evaluation methodology takes you from our perspective. In addition to that, we're going to touch 6 7 on each of the major aspects of the safety evaluation. And for that, we're going to talk about what the 8 9 quidance report provides, we're going to talk about areas in which we found that there 10 11 additional constraints that were necessary or 12 additions that were necessary in the guidance. We're going to touch on issues raised by 13 14 the subcommittee again. And we're going to highlight 15 the changes that we made as a result in the staff safety evaluation. 16 17 Before I begin -- and so we're going to move into that -- but before we begin, I actually 18 19 wanted to make three points. The first was we look at the evaluation 20 21 methodology, which is really the guidance report and 22 the additional constraints that are captured and discussed in the safety evaluation as a package. 23 24 It's possible -- we talked about this last 25 month, we'll talk about it again today -- to identify

1 specific issues in individuals areas where limitations in testing or analysis or experience as a result of 2 3 those limitations, there are uncertainties. 4 But we believe that when you consider the 5 issues, those issues in the context of this overall approach, this overall package, that this package 6 7 provides reasonable assurance of adequate protection and, in fact, will result in real safety improvements 8 9 to the plants once that evaluation is done --10 VICE CHAIRMAN WALLIS: Oh, I'm going to ask you about --11 12 MR. JOHNSON: -- and plants put it --VICE CHAIRMAN WALLIS: -- that. 13 This 14 package provides reasonable assurance for protection. 15 There's no assessment in any of this about the consequences of using the guidance. Are you going to 16 17 do all that today? We haven't seen any of that. MR. JOHNSON: We're going to, again, talk 18 19 about where this evaluation package takes you. 20 have, in terms of the approach that we've used, looked 21 -- again, our primary focusing in reviewing what was 22 proposed by the industry was to step back and ask 23 ourselves in these various areas, in pulling together 24 this package, does the package provide the ability for

the staff to have reasonable assurance. And yes, we

are comfortable that it does.

MEMBER KRESS: How do you separate the package from individual issues? I mean the package is made up of these individual issues of which there are problems with. How do you reconcile that?

MR. JOHNSON: In fact, that's a very good question. And certainly what we did in terms of going through the package was to look at the individual pieces.

And, in fact, one of the criticisms that we've had from the industry, in fact, was that, you know, these areas, some of these areas are, you know, there was already, I guess, a perspective about how conservative the package was and that we looked in individual areas. And, perhaps, the way we ended up was a package that is stepping back, overall conservative.

Well, we were very mindful when we went through the individual issues to look at those individual issues. And we couldn't arbitrarily -- we could not blindly -- couldn't blindly rely on conservatisms in certain areas of the package to account for areas in other areas of the assessment where we don't have enough information. The coatings, Dr. Wallis pointed out, the coatings issue is one.

1 So what we did was in those areas, 2 looked where we couldn't provide -- couldn't find 3 justification, adequately justification of what was 4 provided to us, we looked at stepping back, taking an 5 approach that was conservative for that particular 6 area. 7 And then as you step back, that's what gives us confidence that across the spectrum, this 8 9 package does, in fact, this package, in fact, is sufficient for us to have adequate assurance that 10 11 these plants will operate in a manner that is more 12 safe once they've done the evaluation and once they've made the fixes. 13 14 VICE CHAIRMAN WALLIS: I don't see how an 15 evaluation makes any difference to the safety. still the same plant. You've just evaluated it. Now 16 17 you have to figure out what to do. Absolutely -- well --18 MR. JOHNSON: 19 VICE CHAIRMAN WALLIS: Until you've done 20 something, you haven't changed anything. 21 MR. JOHNSON: I agree with that. The end 22 of my sentence was the evaluation, they do 23 evaluation and make fixes that are necessary. 24 VICE CHAIRMAN WALLIS: Well, 25 separate the quality of the evaluation from the

actions that might be taken to assure this safety. It seems to me those are two different issues unless you can somehow -- maybe you can craft a couple of them in a convincing way. I'd love to see it but -
MR. JOHNSON: Let me come back to that point, if I can, because that actually touches on a point that I want to make.

The -- you know, the staff's primary focus, and I wanted to make this very clear, our primary focus was to look at the evaluation. We want to have clear criteria about what is needed in terms of the approach for the evaluation but what is acceptable to the staff in terms of that evaluation because no matter what fix gets implemented by the industry, we have to go back and be able to assure ourselves that, again, we have reasonable assurance of adequate protection, these plants are safer.

So we've been very focused on the evaluation. We've not been focused, it's not been the staff's responsibility to design, to identify the fixes, to design those fixes. And, in fact, we've not talked about that.

The industry will talk about that perhaps in the presentation that they make. Again, our focus has been on the evaluation methodology.

However, having said that, the industry guidance report and the staff's SE package provide for licensee consideration of a range of solutions from housekeeping and FME programs, for insulation change out or modification, for improving coatings and the coatings program, or modifying the sump design.

The approach also has in it the ability

The approach also has in it the ability for licensees to implement creative fixes, including backwash designs and active strainers.

There's a risk-informed piece of the alternative method that we'll talk about in the approach that provides the ability for licensees to rely on more realistic assumptions in the analysis of breaks -- for the analysis of breaks that are greater than the debris generation break size.

And for modifications --

MEMBER APOSTOLAKIS: Excuse me, Mike. I'm a little -- as I was reading the document, I was trying to understand what the risk-informed approach means. And I came to the conclusion that what the document meant was looking at systems, right, trying to cool the core essentially without maybe alternate ways of doing it.

And, again, reading the report and various comments from the subcommittee, especially the

subcommittee chairman, I saw the word uncertainty all over the place. Yet there was no effort to quantify this uncertainty. And then it occurred to me that this Agency really has pioneered the quantification of uncertainty in such difficult circumstances when it issued NUREG 1150.

So I'm wondering why this -- an approach that would try to quantify the uncertainties in the models and the assumptions about 40 percent, 15 percent, and so on, why this project did not attempt to do something like what NUREG 1150 did in quantifying uncertainties in severe accidents that were not smaller than this.

And yet they did it. They assembled experts. Is that because it's too expensive? Or different people are doing it? And why isn't that the kind of approach part of what we call risk-informed? Risk-informed is not just bringing other systems into the picture. It's quantifying the uncertainties that you have. And these uncertainties may be mechanistic models and mechanistic assumptions as it is here.

But when I read the section on risk-informed, they didn't say anything about that. It talked about cooling the core.

So am I off base here? Or should you

MR. JOHNSON: You've never been off  Dr. Apostolakis.  MEMBER APOSTOLAKIS: Oh, thank you  much, Mike. You can go on.  (Laughter.)  VICE CHAIRMAN WALLIS: Well, I'd lil  MEMBER APOSTOLAKIS: I'm sorry?  VICE CHAIRMAN WALLIS: The risk-info  part only refers to the accident sequence and  effect on safe temperatures in the containm  There's no effect whatever on any of the materia  this document about transported debris and  blockage.	very
Dr. Apostolakis.  MEMBER APOSTOLAKIS: Oh, thank you  much, Mike. You can go on.  (Laughter.)  VICE CHAIRMAN WALLIS: Well, I'd lil  MEMBER APOSTOLAKIS: I'm sorry?  VICE CHAIRMAN WALLIS: The risk-info  part only refers to the accident sequence and  effect on safe temperatures in the containm  There's no effect whatever on any of the materia  this document about transported debris and	very
MEMBER APOSTOLAKIS: Oh, thank you  much, Mike. You can go on.  (Laughter.)  VICE CHAIRMAN WALLIS: Well, I'd lil  MEMBER APOSTOLAKIS: I'm sorry?  VICE CHAIRMAN WALLIS: The risk-info  part only refers to the accident sequence and  effect on safe temperatures in the containm  There's no effect whatever on any of the materia  this document about transported debris and	-
much, Mike. You can go on.  (Laughter.)  VICE CHAIRMAN WALLIS: Well, I'd lil  MEMBER APOSTOLAKIS: I'm sorry?  VICE CHAIRMAN WALLIS: The risk-info  part only refers to the accident sequence and  effect on safe temperatures in the containm  There's no effect whatever on any of the materia  this document about transported debris and	-
(Laughter.)  VICE CHAIRMAN WALLIS: Well, I'd lil  MEMBER APOSTOLAKIS: I'm sorry?  VICE CHAIRMAN WALLIS: The risk-info  part only refers to the accident sequence and  effect on safe temperatures in the containm  There's no effect whatever on any of the materia  this document about transported debris and	ce
7 VICE CHAIRMAN WALLIS: Well, I'd lil 8 MEMBER APOSTOLAKIS: I'm sorry? 9 VICE CHAIRMAN WALLIS: The risk-info 10 part only refers to the accident sequence and 11 effect on safe temperatures in the containm 12 There's no effect whatever on any of the materia 13 this document about transported debris and	ce
MEMBER APOSTOLAKIS: I'm sorry?  VICE CHAIRMAN WALLIS: The risk-info  part only refers to the accident sequence and  effect on safe temperatures in the containm  There's no effect whatever on any of the materia  this document about transported debris and	
9 VICE CHAIRMAN WALLIS: The risk-info 10 part only refers to the accident sequence and 11 effect on safe temperatures in the containm 12 There's no effect whatever on any of the materia 13 this document about transported debris and	
part only refers to the accident sequence and effect on safe temperatures in the contains  There's no effect whatever on any of the material this document about transported debris and	rmod
effect on safe temperatures in the containm  There's no effect whatever on any of the materia  this document about transported debris and	
There's no effect whatever on any of the material this document about transported debris and	
this document about transported debris and	ent.
	l in
14 blockage.	sump
H .	
15 MEMBER APOSTOLAKIS: Yes, but that	was
16 part of my question.	
17 VICE CHAIRMAN WALLIS: That's absolu	tely
18 right. I think, Mike, isn't that true? That r	isk-
informed is not being applied to any of those part	s of
20 the problem.	
21 MR. JOHNSON: Yes, when we thought r	isk-
22 informed, and I do want to come back to the poi	nt I
was trying to make and go through that point, bu	.t
and we are going to talk about the alternative	
25 you talked about	that

1 VICE CHAIRMAN WALLIS: Yes, we've got to 2 I'm sure you have a lot to say. 3 MR. JOHNSON: Let me -- if I can just go 4 through and we'll touch on that --VICE CHAIRMAN WALLIS: Okay, I'm afraid --5 MR. JOHNSON: -- maybe and get to your 6 7 question. 8 VICE CHAIRMAN WALLIS: -- that you're 9 going to get questions, I'm sure, at some time. MR. JOHNSON: Absolutely, absolutely. 10 11 The point I wanted to make was we're not 12 focused on the evaluation -- we focused on the We've not been focused on the fixes. evaluation. 13 14 There's flexibility throughout this guideline for 15 creative fixes. There's flexibility in terms of the risk-informed alternative. 16 17 We want licensees to avail themselves of those but certainly the responsibility for the fix, 18 19 the responsibility for the fix rests with the 20 industry. 21 And the last point I wanted to make is, 22 you know, the staff has said and the Commission agrees 23 -- has agreed that it's time to move forward with 24 resolving GSI-191, which means placing 25 responsibility, again, on the industry for beginning

1 the evaluation and making changes to the sumps if 2 those changes are needed. 3 This issue --4 VICE CHAIRMAN WALLIS: I'm sorry. You resolve an issue by placing the responsibility on 5 somebody else? Is that how you resolve an issue? How 6 7 do you say -- isn't an issue resolved when sort of an 8 risk implications have been reduced or changed back to 9 an acceptable level or something? Isn't it -- it's not resolved until some 10 action is taken. You don't just resolve it by 11 12 studying it, do you? Absolutely. 13 MR. JOHNSON: 14 VICE CHAIRMAN WALLIS: So if you're smart 15 you can't say it's resolved by your studying some evaluation method until something has been done. 16 17 MR. JOHNSON: No, my point is that we've evaluated the issue to a point where we're ready to 18 19 transfer this issue over to the industry. We're ready 20 for licensees to begin the evaluation an to ultimately 21 make the fixes -- make fixes to their plants if those 22 fixes are indicated by the results of the evaluation. VICE CHAIRMAN WALLIS: Could we say this 23 24 is a step on the way to resolving the issue? 25 Yes, absolutely. MR. JOHNSON:

1	VICE CHAIRMAN WALLIS: Okay. Thank you.
2	MEMBER KRESS: Let me paraphrase what I
3	think I've heard. You're convinced that if you go
4	through this methodology and follow it properly, that
5	you will end up with a conservative assessment of the
б	effect of blockage on the net positive suction head so
7	that
8	MR. JOHNSON: Correct, that's correct.
9	MEMBER KRESS: Okay. So that's what we
10	need to look for is whether or not how you make
11	this judgment of the conservative.
12	MR. JOHNSON: Right, that's right.
13	MEMBER KRESS: Okay.
14	MR. JOHNSON: This issue has been on our
15	plate for 25 years. We were counting last night and
16	we came up with 25 years as the number.
17	VICE CHAIRMAN WALLIS: Well, that doesn't
18	resolve anything yet does it?
19	MR. JOHNSON: There are already vendors
20	we've spoken with who are out performing the
21	evaluation using the baseline, using the baseline and
22	the draft SE for plants, working on the evaluation and
23	engineering fixes to resolve the issue.
24	We heard at the subcommittee meeting that
25	there's at least one licensee who is anxious to move

forward with an active solution. And anxious for not 1 2 having further delays in our efforts. 3 So, again, Dr. Kress I think you're right. 4 My summary would be the evaluation that we have is a good evaluation and it will provide for reasonable 5 assurance of adequate protection once the evaluation 6 7 is done and fixes are made. The guidance is adequate to support that. And I hope that we get a letter from 8 the ACRS following this presentation and the rest that 9 10 you hear on this issue --11 Were you able to do MEMBER KRESS: 12 anything to accommodate the licensee who wanted to pursue an active thing? Or does he have to wait for 13 14 all this stuff to get resolved? 15 MR. JOHNSON: We have, in fact, one of the pleas of that individual who spoke at the subcommittee 16 17 meeting was to enable the active solution. We believe that the alternative we already 18 19 have in the SE, as proposed by the industry in the guidance report, the ability for licensees to employ 20 21 active solutions. 22 MEMBER KRESS: So he could go ahead and 23 proceed with that with assurance? 24 MR. JOHNSON: Absolutely. 25 MEMBER KRESS: Okay.

1 MEMBER APOSTOLAKIS: So did you answer my question, Mike, and I missed it or --2 3 MR. JOHNSON: We will answer --4 MEMBER APOSTOLAKIS: Oh, you will? Okay. 5 MR. JOHNSON: -- your question later. If there are no other questions, I would 6 7 -- is Dave Solorio -- Dave? Dave is going to talk 8 about the overall approach. MR. SOLORIO: Thanks, Mike. Good morning. 9 My name is Dave Solorio and I work in the Office of 10 11 Nuclear Reactor Regulation. I've been before a number 12 of you to talk about license renewal in the past. To provide an overall perspective for the 13 14 sump evaluation approach and lend perspective to the 15 presentations that will follow, my intention is to provide a quick summary of the major elements of the 16 17 staff's safety evaluation report to illustrate the process a pressurized water reactor licensee would use 18 19 to go through should it choose to use the NEI guidance 20 report and the staff's SER to perform a mechanistic evaluation of sump performance to respond to Generic 21 22 Letter 2004-02, Potential Impact of Debris Blockage on 23 Emergency Recirculation During Design Basis Event Pressurized Water Reactors. 24

My remarks will focus on the staff's SER.

And this slide that we've shown up here provides a process flow chart I'll use to illustrate the evaluation steps a licensee would go through.

Following my presentation, Mr. Tom Hafera will go over an example to illustrate how the SER could be used in evaluating sump performance.

The top half of the slide is a basic illustration of how we envision the industry's guidance report plus the staff's SER to be one vehicle by which a licensee could perform an evaluation of sump performance. I want to stress it is one way. Licensees are free to propose alternatives that the staff would be willing to review.

The end result of applying the guidance in these two documents would be a determination of whether the as-built sump design was sufficient or plant configuration changes were needed. Plant configuration changes could be resizing the sump or activities directed at limiting critical debris sources.

The bottom half of this slide illustrates the major evaluation areas in the staff's SER. I have designated by a small yellow circle, numbered one through seven, these steps. And obviously we would expect that the guidance report would be used in

1	parallel.
2	I did not show Chapter 5, Physical
3	Refinements, which discusses ways to reduce debris
4	sources mainly because there was not as many questions
5	on that section at the subcommittee meeting.
6	Staff presentations will follow mine and
7	they will be brief on several of these sections and
8	they are geared towards highlighting what we did to
9	respond to the questions received at the 922
10	subcommittee review of this topic.
11	A major concept to recognize in the
12	guidance report is that there is a baseline method, or
13	first step method, which is intended to be a quick and
14	easy way to reach a conclusion. But there are costs
15	in terms of fidelity. If the results show the margins
16	are not acceptable, refinements have been offered in
17	some areas, but not all, to obtain a more realistic
18	estimate.
19	Item 1, Section 3.3, first off, a licensee
20	needs to determine the break size and location that
21	generates the maximum debris insulation source term.
22	Item 2, Section 3.4
23	MEMBER APOSTOLAKIS: So what's the
24	frequency of that?
25	MR. SOLORIO: The frequency?

1	MEMBER APOSTOLAKIS: Yes.
2	MEMBER APOSTOLAKIS: I'm trying to
3	understand. I mean all this is conditional on a
4	break, right?
5	MR. SOLORIO: Yes. But what
6	MEMBER APOSTOLAKIS: Because somewhere
7	there in the report, you guys say this is a low
8	probability event.
9	MR. SOLORIO: Yes.
10	MEMBER APOSTOLAKIS: Therefore we can use
11	risk-informed approaches, which struck me as a very
12	strange statement.
13	MR. SOLORIO: Well, in
14	MEMBER APOSTOLAKIS: You can't use risk-
15	informed approaches if the probabilities are higher
16	than ten to the minus four or five? Anyway, that's an
17	editorial comment. But
18	mR. SOLORIO: Okay. Well, the guidance in
19	the NUREG 1(a)(2), Rev 3, and also what's transmitted
20	in the or its application in the guidance report by
21	the industry put together, is really to go off and
22	look in terms of what break sizes could you generate
23	the maximum debris
24	MEMBER APOSTOLAKIS: I under
25	MR. SOLORIO: not to factor in the

1	frequency of that break size.
2	MEMBER APOSTOLAKIS: I understand that.
3	But what is the frequency?
4	MR. SOLORIO: The frequency
5	MEMBER APOSTOLAKIS: Is the frequency of
6	a large LOCA?
7	MR. SOLORIO: Let me ask Donnie Harrison
8	that.
9	MR. JOHNSON: I think again you're asking
10	about an aspect we're going to get to the question
11	that you have about the alternative method and it's in
12	that method, the alternative method, where we look at,
13	for example, we establish the debris generation break
14	size based on work coming out of 50.46. That's what
15	we were sort of referring to as the risk-informed
16	approach.
17	MEMBER APOSTOLAKIS: But it should be down
18	
19	VICE CHAIRMAN WALLIS: George, can we move
20	on? I think
21	MR. SOLORIO: If we can hold it until
22	then.
23	VICE CHAIRMAN WALLIS: we have to move
24	on until we get to the risk-informed part.
25	MR. SOLORIO: Yes, I think that's

1	MEMBER APOSTOLAKIS: It's not the risk-
2	informed part.
3	VICE CHAIRMAN WALLIS: But we haven't got
4	to that discussion yet.
5	MEMBER APOSTOLAKIS: I understand but what
6	I'm asking is not risk informed.
7	VICE CHAIRMAN WALLIS: But we've got about
8	ten technical items to discuss first.
9	MEMBER APOSTOLAKIS: Well, Michael used
10	the expression adequate protection several times
11	earlier.
12	VICE CHAIRMAN WALLIS: I think you have a
13	very good point. But I'm just saying that
14	MEMBER APOSTOLAKIS: Okay.
15	VICE CHAIRMAN WALLIS: I think he's
16	going to get to it.
17	MEMBER APOSTOLAKIS: Okay.
18	VICE CHAIRMAN WALLIS: If he doesn't get
19	to it, you can ask it all again.
20	MEMBER APOSTOLAKIS: In a subtle way, you
21	are telling me to shut up.
22	(Laughter.)
23	MEMBER APOSTOLAKIS: Message received,
24	Graham.
25	MR. SOLORIO: Item 2, section 34, next the

1 break needs to be translated in terms of debris 2 generation. We get to debris generation through the 3 construction volumes or zone of influence as we refer 4 to it. 5 Special considerations are called out for coatings due to their ability to represent 6 7 additional volume of material that could, under optimal conditions, transport to the sump screen. 8 9 Lastly, refinements are available in this 10 area if necessary. 11 Item 3 deals with section 35, highlights 12 that not only must we be concerned with generated debris, but there are also debris sources already 13 14 lying around containment or easily washed off by a 15 break that can possibly be transported to the sump. section 36, highlights 16 4, 17 transport mechanisms that can be assumed in terms of how much of the generated debris can be expected to 18 19 make it to the sump. Should the licensee determine 20 that using the rough approximation methods of the 21 baseline yields large transport percentages, there are 22 refined methods that can be used to gain a more 23 realistic estimate. 24 Item 5 --25 VICE CHAIRMAN WALLIS: Now wait a minute.

1	There's a feedback loop. It says no thin fiber layer.
2	MR. SOLORIO: Oh.
3	VICE CHAIRMAN WALLIS: Do you understand
4	what that means?
5	MR. SOLORIO: Well, in response to your
6	comments from last subcommittee meeting, we've added
7	an attachment.
8	VICE CHAIRMAN WALLIS: Yes, but it says
9	thin particulate layer. There's nothing about a thin
10	fiber layer. You can have a fiber layer ten foot
11	thick and have a particulate layer of one mil. And I
12	understand that is the effect that we're talking
13	about.
14	MR. SOLORIO: Well, this
15	VICE CHAIRMAN WALLIS: Do you understand
16	that?
17	MR. SOLORIO: this triangle that you're
18	asking me about, I believe
19	VICE CHAIRMAN WALLIS: Well, the guidance
20	is very, very unequivocal about this thin bed effect.
21	MR. SOLORIO: Well
22	VICE CHAIRMAN WALLIS: And I'm just asking
23	you if you understand what is meant by this how do
24	they evaluate
25	MR. SOLORIO: Yes, we do Dr. Wallace. And

1	we are going to actually present a brief description
2	
3	VICE CHAIRMAN WALLIS: Oh, you are going
4	to present that, okay.
5	MR. SOLORIO: of that in one of the
6	slides that
7	VICE CHAIRMAN WALLIS: Thank you.
8	MR. SOLORIO: Let's see where was I.
9	Let's see, Item 4
10	MEMBER ROSEN: No, I don't understand
11	right there. If you answer the question yes, I
12	understand if you have a thin fiber layer, you go
13	right back to the beginning to step 2.
14	MR. SOLORIO: Well, what I meant to say,
15	and maybe it's confusing, if the licensee would say I
16	don't have a thin fiber layer
17	MEMBER ROSEN: Yes.
18	MR. SOLORIO: then there still there
19	needs to be you need to go back and look at
20	whatever debris source might equivalently create some
21	kind of a mat against your screen and lead to a head
22	loss.
23	VICE CHAIRMAN WALLIS: You keep going
24	around forever until you find a fiber layer?
25	MR. SOLORIO: No.

1	VICE CHAIRMAN WALLIS: That's what it
2	looks like.
3	MR. SOLORIO: It's just meant as a
4	feedback loop that is the licensee would ask that
5	would conclude that they don't have it, then they
6	would have to go back and assess it for other debris
7	sources.
8	MEMBER ROSEN: Well, diagrammatically it's
9	not very clear.
10	VICE CHAIRMAN WALLIS: So this is one of
11	the technical questions I guess. Shall we move on to
12	the
13	MR. SOLORIO: Sure.
14	MR. JOHNSON: Actually we added this.
15	This is not you won't see this diagram in the SE.
16	We simply put it up to talk about the various blocks.
17	VICE CHAIRMAN WALLIS: But it's supposed
18	to explain things to us. So
19	MR. JOHNSON: Yes.
20	VICE CHAIRMAN WALLIS: we can ask
21	questions about it?
22	MR. JOHNSON: Yes, absolutely.
23	MR. SOLORIO: Sure, sure.
24	Item 4, section 36, highlights the
25	transport mechanisms.

1 Let's see, item 5, section 37, is the kind 2 of what we've been waiting for step, the determination 3 the head loss across the sump screen which 4 ultimately tells you if you're done, for the most part 5 or if you have more work to do, which item 7 is meant to illustrate. 6 7 Item 6, section 7, is the kind of hold the horses step. Before you can make your final decision 8 9 if you're done or redesign as necessary, you have to consider for the effects of debris making it through 10 the sump screen and their effects on emergency core 11 12 cooling system components and the operation of them. VICE CHAIRMAN WALLIS: Why is additional 13 14 consideration of chemical effects in a feedback loop? 15 MR. SOLORIO: Yes, sir. If -- well, you are aware that we're running tests, the Office of 16 Research are funning tests to determine the impact of 17 the chemical effects. Licensees are -- we're going to 18 share that information with licensees. 19 20 The idea here is that if, in fact, this 21 testing shows there is an issue that needs to be 22 addressed, then you would have to go back and 23 determine or consider those chemical effects in your 24 debris, the regeneration step.

VICE CHAIRMAN WALLIS:

25

That same is true

1	of downstream effects. If further research shows that
2	metal pieces go through the screen and have some
3	downstream effect, then you have to do something about
4	that, too. I don't know if it's a feedback loop. But
5	it should be a box that is somewhere in the diagram.
6	MR. JOHNSON: That's right. And we
7	actually in box 7, in fact, upstream and downstream
8	is here in box 6.
9	MR. SOLORIO: And we already know that
10	there are concerns because we've seen testing in
11	certain plants where we've seen the effects of
12	downstream effects so we know it's a real issue.
13	VICE CHAIRMAN WALLIS: Are you going to
14	talk about that later? Are you going to talk about
15	each of these boxes later? Is this the outline of
16	your presentation?
17	MR. SOLORIO: We're going to talk about
18	the majority of them and
19	VICE CHAIRMAN WALLIS: Okay.
20	MR. SOLORIO: our decision and which
21	ones we talked about really stem from the questions
22	that the subcommittee asked.
23	VICE CHAIRMAN WALLIS: So I guess if you
24	don't visit one box
25	MR. SOLORIO: And we were going to talk

	30
1	VICE CHAIRMAN WALLIS: we can ask you
2	to visit it?
3	MR. SOLORIO: about this one.
4	MR. JOHNSON: We are going to talk about
5	downstream effects.
6	MR. SOLORIO: We are going to talk
7	VICE CHAIRMAN WALLIS: This is sort of an
8	
9	MR. SOLORIO: downstream effects.
10	VICE CHAIRMAN WALLIS: outline of your
11	presentation.
12	MR. SOLORIO: Yes, sir.
13	MEMBER APOSTOLAKIS: Now every year, Mike,
14	said that, you know, maybe individual pieces of this
15	are not too satisfactory but the overall approach is
16	acceptable between the NEI guidance report and the
17	staff's consideration.
18	So I assume then that Box No. 6, where you
19	are formulating possible additional design changes,
20	will be done at that level? That you will look at the
21	whole thing and say well, gee, you know, maybe they
22	ought to consider this design change. Is that
23	correct?
24	MR. SOLORIO: Yes.
25	MEMBER APOSTOLAKIS: You will not look at
I	

1	individual boxes. How would you do that? Is it an
2	integrated decision-making process in a deterministic
3	world? Is that what it is?
4	MR. JOHNSON: Well, let me be I'm not
5	quite sure that I understand your question. We the
6	Generic Letter requires that licensees provide the
7	results of their evaluation to us
8	MEMBER APOSTOLAKIS: Yes.
9	MR. JOHNSON: and their plans to make
10	any corrective action that they would make. So the
11	licensee would have gone through this exercise, figure
12	out whether or not
13	MEMBER APOSTOLAKIS: Yes.
14	MR. JOHNSON: they could redesign their
15	sump. They'll propose corrective action they'll
16	plan corrective actions. And our plan then going
17	forward is to audit some of those plants in terms of
18	the evaluation, in terms of what they actually put in
19	place to make sure that from our perspective, those
20	are acceptable.
21	But the licensee does the evaluation. The
22	licensee does the redesign using that evaluation to
23	assure that at the end, they have sufficient net
24	positive suction head so
25	MEMBER APOSTOLAKIS: But vou

1	MR. JOHNSON: they can provide long-
2	term cooling.
3	MEMBER APOSTOLAKIS: will review that?
4	MR. JOHNSON: We plan to audit those
5	results
6	MEMBER APOSTOLAKIS: Audit, okay.
7	MR. JOHNSON: and with the oversight
8	process going forward, we would look to see that be a
9	key feature or an ongoing feature, I should say, in
LO	terms of
L1	MEMBER APOSTOLAKIS: But my question is
L2	could there be a situation where you're maybe unhappy
L3	with Box No. 3 but then a licensee argues that we are
L4	so conservative in Box No. 4 that we really don't have
L5	to worry about Box No. 3?
L6	And you said earlier that it's really the
L7	big picture that counts. So could that be the case?
L8	And how will the decisions be made here? What's
L9	acceptable? And what's not?
20	MR. JOHNSON: Well, you know, conceivably
21	a licensee remember again, this is one acceptable
22	means. And so and, in fact, a licensee can come in
23	I would anticipate the licensees would
24	VICE CHAIRMAN WALLIS: Well, Michael,
25	you're missing the question. The question is you've

1 got all the boxes. And you're uncertain about them. 2 And some of them you're very uncertain about. 3 For instance, you know nothing, almost 4 next to nothing about chemical effects. How can you 5 give assurance that the entire picture is all right? Now I'm going to give you an analogy. It 6 7 occurs to me -- I take my car to the garage. And the 8 guy says well, your brakes are not very good and your 9 transmission is about to go and your engine is only firing on three cylinders. But the whole car is okay. 10 11 Is that an analogy that makes sense here? 12 What are you trying to say? MR. JOHNSON: Well, actually -- let me try 13 14 to answer your question but I thought actually your 15 question was a little bit different. With respect to chemical precipitation 16 effects, we recognize -- licensees -- and we told the 17 industry, the industry recognizes that at the end, 18 19 their fix is going to have to accommodate what comes 20 out of the testing that's going to -- that's ongoing. 21 And we'll get those insights around the end of the 22 year. 23 As they are doing the evaluation and 24 planning their fixes, they will need to accommodate 25 what comes out of that. If the answer is nothing,

1	then they're good. If
2	VICE CHAIRMAN WALLIS: You've said that
3	before. But, I mean, there is this basic question
4	that George is asking. And I don't think you're
5	addressing it.
6	MR. JOHNSON: Actually, I thought George's
7	question was I thought your question was how is the
8	staff going to decide these with respect to these
9	various aspects of the evaluation if it's okay. And
10	we do that all the time.
11	We look at staff evaluations and use our
12	engineering judgment to decide whether the
13	justification provided by the staff, whether the
14	alternate means is acceptable. And we make a decision
15	based on that. That's what
16	MEMBER APOSTOLAKIS: I understand that and
17	
18	MR. JOHNSON: what we do.
19	MEMBER APOSTOLAKIS: I'm
20	VICE CHAIRMAN WALLIS: Well, maybe we
21	should on. Are you finished? Are you going to talk
22	about all the boxes here?
23	MR. SOLORIO: I'm going to be done in
24	about a minute or less.
25	Let's see. I was just going to mention

1 that item 4A, section 6, is adjunct approach. Ιt 2 begins with brake selection for performance, sump 3 performance evaluations. It allows for more realistic 4 assumptions and use of risk insights. And, Dr. 5 Apostolakis, we have a presentation on that later. Item 7, while there may be areas where 6 7 additional study can help reduce conservatism, the approach in totality provides a comprehensive process 8 for evaluating sump performance. 9 And now I'll turn it over to Mr. Hafera if 10 11 there are no more questions. MEMBER FORD: Could I ask -- are you going 12 to discuss item 7 at all? 13 14 MR. SOLORIO: Well, actually through the 15 example that Mr. Hafera will give, he'll give some 16 practical consequences or ways or strategies a 17 licensee might use to address the issue. Okay, since I suspect we 18 MEMBER FORD: 19 won't have much time to do that, I just draw your 20 attention to there could be undesired consequences. If you remove circuit-based insulation, then you will 21 22 increase the danger of cracking of stainless steel 23 components underneath that insulation fully 24 discussed in Reg Guide 1.36.

MR. SOLORIO: Got it.

25

1	MEMBER FORD: Thank you.
2	VICE CHAIRMAN WALLIS: Are you going to
3	have some time here I don't know how long you're
4	taking on these various things but it doesn't look
5	like many slides so you're going to have to tell us if
6	you've got a lot to come and we've got to hold our
7	questions. I just don't know how to pace this
8	presentation. I'm sorry.
9	MR. JOHNSON: We'll try to help with that,
10	Dr. Wallis. We do want to move rather quickly.
11	MR. SOLORIO: Dr. Wallis, Tom has three
12	slides and the remaining presentation is 13 slides.
13	So
14	VICE CHAIRMAN WALLIS: Okay. We know all
15	this, don't we? Do we need to look at these slides?
16	Well, maybe we do? I don't know. The guidance
17	doesn't address
18	MR. SOLORIO: Operator problem.
19	MR. HAFERA: My name is Tom Hafera. I
20	work in Plant Systems Branch. And we seem to be
21	getting a lot of questions that are kind of expanded
22	on the sort of that are maybe not as well founded
23	in what actually happens during a LOCA.
24	So I want to go over that real quickly
25	with everybody. What I have here is a slide that

1	shows basically a plan view of a pressurized water
2	reactor. It shows a LOCA in progress. There's the
3	zone of influence there. There shows debris and how
4	it's going to be transported.
5	This is the sump
6	MEMBER APOSTOLAKIS: Where is the break?
7	MR. HAFERA: The break? The break would
8	be approximately right here.
9	MEMBER APOSTOLAKIS: Okay.
10	MR. HAFERA: Okay? There is the sump, the
11	little red box, okay?
12	VICE CHAIRMAN WALLIS: It's a tiny thing.
13	MR. HAFERA: It is a little tiny thing.
14	Here is your containment basement. There's a plan of
15	the containment basement. Containment basements are
16	typically about 130 feet in diameter. So it's about
17	the size of One White Flint North, okay?
18	Here's the sump. There's
19	VICE CHAIRMAN WALLIS: How big is the
20	sump?
21	MR. HAFERA: the sump right there. The
22	sump itself is typically around about 10 to 12 feet
23	square so it's about a 10 feet by 10 feet
24	VICE CHAIRMAN WALLIS: So that strainer
25	MR. HAFERA: sump.

1	VICE CHAIRMAN WALLIS: is a tiny thing.
2	MR. HAFERA: So it's a tiny thing, that's
3	correct.
4	VICE CHAIRMAN WALLIS: And it's going to
5	have
6	MR. HAFERA: So it is
7	VICE CHAIRMAN WALLIS: 53 pickup
8	MR. HAFERA: well, see this is
9	VICE CHAIRMAN WALLIS: loads of
10	fiberglass in it?
11	MR. HAFERA: in deference to Mr.
12	Andreycheck, I think he used
13	VICE CHAIRMAN WALLIS: I don't think
14	MR. HAFERA: his words were a little
15	bit exaggerated to achieve the shock effect that he
16	wanted. So and that's what we're going to try to
17	address, okay?
18	VICE CHAIRMAN WALLIS: So you're but
19	he's from industry and he's from Westinghouse. He
20	ought to know what he's talking about.
21	MR. HAFERA: That's correct. And I'm an
22	ex-operator and I should know what I'm talking about,
23	okay?
24	So there is the sump. And it's about 10
25	or 12 feet in diameter or 10 or 12 feet square. It

	13
1	shows a water level. That's a standard sunken sump.
2	There are also sump designs that are not sunk
3	VICE CHAIRMAN WALLIS: It's 10 foot
4	square?
5	MR. HAFERA: Basically.
6	VICE CHAIRMAN WALLIS: It's 100 square
7	foot on a floor level so 5,000 cubic feet of debris
8	would be 50 feet high in that box?
9	MR. HAFERA: Well, obviously you can't get
10	50 foot high in the box. The
11	VICE CHAIRMAN WALLIS: That's what
12	MR. HAFERA: box is only 10 feet deep.
13	VICE CHAIRMAN WALLIS: but, you see,
14	that's the sort
15	MR. HAFERA: Okay?
16	VICE CHAIRMAN WALLIS: of thing we're
17	up against it seems to me.
18	MR. HAFERA: Okay, so
19	VICE CHAIRMAN WALLIS: Okay, so you're
20	going to explain?
21	MR. HAFERA: I just want to explain so
22	everybody understand, you know, this is the basic
23	layout.
24	And this is the fundamental things that
25	we're looking for, things that we are going to look

1	for is how debris is moved around the containment and
2	transported, how it gets generated, how it ends up
3	getting in the little sump.
4	Notice how the arrows show the tortuous
5	path and there's many hold up places opportunities
6	to hold up debris, particularly large debris. And
7	notice that the sumps typically have multiple layers.
8	The one that we're really worried about is
9	this strainer here. So that's why you'll hear a lot
10	of us we talk about mainly we talk about small finds
11	and not so much large debris because large debris
12	typically gets caught up in these obstructions or it
13	gets caught up in trash racks.
14	MEMBER KRESS: But what is that arrow that
15	bypasses the strainer?
16	MR. HAFERA: The arrow that what?
17	MEMBER KRESS: Bypasses the strainer. No,
18	over to the right?
19	MR. HAFERA: This one?
20	MEMBER KRESS: Yes, no that one, yes.
21	MR. HAFERA: Well, this is just showing an
22	alternative design. A lot of other plants
23	MEMBER KRESS: Oh, I see.
24	MR. HAFERA: have them come out the
25	side.
ļ	I

1	MEMBER KRESS: I see, okay.
2	VICE CHAIRMAN WALLIS: So you're giving us
3	the impression that not much of the fibrous debris
4	gets to the sump?
5	MR. HAFERA: Hang on. Let me go forward.
6	VICE CHAIRMAN WALLIS: Okay, let's
7	MR. HAFERA: My second slide, let's talk
8	about large break LOCAs and just how a large break
9	LOCA progresses and what the fundamental numbers are.
10	I want you first of all, I have to say,
11	this is from a MELCOR code. MELCOR is a realistic
12	code. It's not a design-based code. So therefore
13	each plant is going to have different numbers than
14	these from a design basis standpoints. And this will
15	not match.
16	The other thing is these are bulk average
17	conditions. This is not plant specific. This doesn't
18	model any specific plant.
19	Okay, we have three phases. In a
20	pressurized water reactor, there are three phases to
21	a LOCA. There's a blowdown phase, an injection phase,
22	and a recirculation phase. Boiling water reactors
23	don't have an injection phase. They go straight from
24	a blowdown phase to a recirc phase.
25	You have to understand that our initial

conditions, the reactor coolant system pressure is 2,250, 530 degrees. Containment is basically zero pounds. And approximately about 110 degrees. That's our starting point.

Our LOCA is a very short term but a very violent event. It occurs in about 45 seconds, okay? Typically, your containment -- but the other thing to recognize is it's also a cool down event. Your reactor coolant system cools down rapidly. Your pressure goes down rapidly.

Within 45 seconds, you are well below high-pressure injection. You are below low-pressure injection system capacity. You're also within -shortly after that 45 seconds, you're going to get to shutdown conditions cold where have you the opportunity from an operational perspective to maybe on flows throttling back start or doing some operational things that could help mitigate this problem.

You also recognize approximately 45 seconds in, your break flow slows significantly. You no longer have large expanded jets. You have very short, very slow, low flows. And the quality is basically single phase 45 seconds into the event. Very short.

1

2

3

4

5

6

7

8

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

25

1	Containment pressure peak at about for
2	this example, 36 pounds in 20 second. Shortly after
3	that, it starts to come back down fairly rapidly. And
4	a lot of that has to do with whatever the plant's
5	containment spray system set point is, what their
6	ideal generator start time is because those are all
7	sequenced as part of their safety injection operation.
8	Containment temperature, you don't get to
9	500 degrees in containment
10	VICE CHAIRMAN WALLIS: Are you going to
11	give
12	MR. HAFERA: it's gets to
13	VICE CHAIRMAN WALLIS: us a lecture
14	MR. HAFERA: about 300 degrees
15	VICE CHAIRMAN WALLIS: I'm sorry, I'm
16	sorry, are you going to give us a lecture on LOCA or
17	are you going to talk about the issues of
18	MR. HAFERA: I'm going to tie this in on
19	my next slide.
20	VICE CHAIRMAN WALLIS: I'm sorry. Okay.
21	MR. HAFERA: My next slide, okay?
22	So you only get to about 300 300 peak
23	300 degrees peak. And then it begins to slow.
24	So the other thing a lot of that
25	temperature transient is so fast, a lot of that heat

1 doesn't get to translate and conduct to a lot of the 2 structural materials in the large components 3 containment. They end up equalizing at a fairly low 4 temperature, fairly rapidly. 5 Okay, after the violent event, the injection phase begins. Now this, again, this, for a 6 7 pressurized water reactor, they are pumping cold, clean water from a refueling water storage tank that 8 9 is typically very large and its design basis typically to make sure you get enough water on the containment 10 11 basement to make sure you have adequate NPSH. 12 So -- and notice this injection phase lasts a fairly significant amount of time. 13 14 seven minutes -- that gives a lot of opportunity as 15 this containment basement -- go back to my previous slide -- basically -- so this little sump fills almost 16 instantly, it's so rapidly filled. 17 And once that fills, after -- even while 18 19 the LOCA is going on, there's no velocity towards the The velocity is random, randomly distributed 20 sump. 21 throughout the 130 foot containment basement so --22 VICE CHAIRMAN WALLIS: Where does --23 MR. HAFERA: -- debris gets --24 VICE CHAIRMAN WALLIS: -- where does the 25 It all goes -water go?

1	MR. HAFERA: It goes to the basement.
2	VICE CHAIRMAN WALLIS: It makes a pool in
3	the basement.
4	MR. HAFERA: It goes to the pool in the
5	basement. It ends up it goes up and then it comes
6	down and it goes to the basement.
7	And then it's just randomly going around
8	the basement. There's
9	VICE CHAIRMAN WALLIS: So you
10	MR. HAFERA: random
11	VICE CHAIRMAN WALLIS: said the
12	MR. HAFERA: turbulence.
13	VICE CHAIRMAN WALLIS: sump fills
14	almost at once.
15	MR. HAFERA: Right.
16	VICE CHAIRMAN WALLIS: And the question
17	might be with what?
18	MR. HAFERA: With water. With water.
19	Okay, back to my so where was I so that just
20	goes to show, this is what you're pumping in. Safety
21	injection, spray flow again, it's all clean,
22	chemically-treated water, cold water. So that's your
23	initial source, your initial source.
24	And as I mentioned, containment pressure,
25	by the time now, as we go through the injection phase

1	and we start to get close to the recirculation phase,
2	these are the important parameters that come up down
3	here.
4	VICE CHAIRMAN WALLIS: The pool is the
5	pool on the floor of the building, not the pool in the
6	sump. The sump is full. And that's the pool on the
7	floor.
8	MR. HAFERA: Exactly, exactly. So there
9	are some key parameters there. When you go to
10	initiate recirculation, this example shows seven
11	pounds, seven pounds in containment. Saturation
12	temperature for seven pounds is about 230 degrees.
13	So, again, the pool temperature at 187 is
14	significantly sub-cooled at that point. That's a key
15	point to remember.
16	The other key point to remember is, again,
17	pool depth. Now what we have heard is some plants may
18	not necessarily be meeting their pool depth. And that
19	is going to be a big concern.
20	VICE CHAIRMAN WALLIS: Could you tell me
21	at 187 degrees what the NPSH has to be?
22	MR. HAFERA: Yes, I will.
23	VICE CHAIRMAN WALLIS: How many feet of
24	water?
25	MR. HAFERA: My next slide

1	VICE CHAIRMAN WALLIS: Thank you.
2	MR. HAFERA: my next slide, okay?
3	MR. JOHNSON: Why don't you
4	MR. HAFERA: Well, let me just finish this
5	last point, okay? Now I forgot what my last point
6	was.
7	(Laughter.)
8	MR. HAFERA: Oh, three and a half feet.
9	Pool depth is very important because pool depth
10	translates directly to turbulence or laminar flow.
11	The deeper the pool, the more laminar and quiescent
12	the flow is
13	VICE CHAIRMAN WALLIS: Can we avoid
14	MR. HAFERA: particularly near the
15	VICE CHAIRMAN WALLIS: that? I'm
16	MR. HAFERA: floor.
17	VICE CHAIRMAN WALLIS: sorry, could we
18	avoid qualitative statements please because the
19	guidance gives quantitative methods.
20	MR. HAFERA: Well
21	VICE CHAIRMAN WALLIS: And just talking
22	about things doesn't really help address these
23	MR. HAFERA: Okay.
24	VICE CHAIRMAN WALLIS: these methods.
25	So, you know, I like what you you're helping us get

1	a perspective but
2	MR. HAFERA: That's correct.
3	VICE CHAIRMAN WALLIS: vague statements
4	about there's a lot of turbulence doesn't mean
5	anything unless it's quantified.
6	MR. HAFERA: And now we're going to tie it
7	to how it effects the sump. My next slide please.
8	Now, again, this is an example exercising
9	our methodology in the safety evaluation
10	VICE CHAIRMAN WALLIS: How did you assume
11	10,000 square feet cubic feet where Mr. Andreycheck
12	gets 14,000 from one steam generator?
13	MR. HAFERA: I can't speak for Mr.
14	Andreycheck. All I can speak of for is our data
15	came from our parametric study for a typical
16	Westinghouse four-loop plant.
17	VICE CHAIRMAN WALLIS: Okay. And he
18	MR. HAFERA: Those were the that's
19	VICE CHAIRMAN WALLIS: from
20	Westinghouse?
21	VICE CHAIRMAN WALLIS: well, that's the
22	data that we got from Westinghouse, okay? From four-
23	loop dry as I mentioned we've got our data.
24	There's Westinghouse four loops, three loops, two
25	loops, there's ice condensers, there's sub-atmospheric

1	containments, there's BMW, there's CE plants.
2	We came up the Westinghouse four-loop
3	plant is what we feel is the limiting plant on a
4	large, dry containment, 10,000 cubic feet of and
5	we're assuming all the insulation on the steam
6	generator is fiber.
7	MEMBER SIEBER: Yes, and that's just one
8	loop because the loops are compartmentalized.
9	MR. HAFERA: Yes. Well, we're figuring
10	10,000 total.
11	MEMBER SIEBER: Yes, but you're only
12	the zone of influence only effects on loop.
13	MR. HAFERA: Exactly. Well, what I
14	assumed here, okay, is I assumed and if you look at
15	my first slide, everybody has that picture
16	MEMBER SIEBER: Don't go back.
17	MR. HAFERA: All right. Everybody has the
18	picture. I assumed at the first slide, it shows the
19	zone of influence encompassed 90 percent of the steam
20	generator
21	MEMBER SIEBER: Right.
22	MR. HAFERA: and one-quarter of the
23	remainder of containment because the containment is
24	compartmentalized.
25	MEMBER SIEBER: Right.

1	MR. HAFERA: So that's how I came up with
2	.9 and .25.
3	VICE CHAIRMAN WALLIS: The .9 times
4	MEMBER SIEBER: So this isn't that much
5	different than the Westinghouse
6	VICE CHAIRMAN WALLIS: Oh, it's very
7	different
8	MEMBER SIEBER: statement of
9	VICE CHAIRMAN WALLIS: the .9 times
10	MR. HAFERA: Okay
11	VICE CHAIRMAN WALLIS: 1,300 is 1,170.
12	MR. HAFERA:9 times 1,300 is 1,170,
13	.25
14	VICE CHAIRMAN WALLIS: That's about less
15	than a tenth
16	MR. HAFERA: so
17	VICE CHAIRMAN WALLIS: of what he said.
18	MR. HAFERA: again, so what I'm coming
19	up with is about 1,720 cubic feet.
20	VICE CHAIRMAN WALLIS: But he said he got
21	14,000 from one steam generator
22	MR. HAFERA: I can't
23	VICE CHAIRMAN WALLIS: with using the
24	zone of influence in the guidance. So you're off by
25	a factor of 10 from him. That's all I can say. I

1	don't know who is right.
2	MR. HAFERA: Exactly.
3	VICE CHAIRMAN WALLIS: It seems
4	MR. HAFERA: Exactly.
5	VICE CHAIRMAN WALLIS: very strange to
6	me that the guy who runs the plants or knows about the
7	plants comes up with a number that's a factor of 10
8	different from you. That says something about
9	uncertainty.
10	MR. HAFERA: Well, if you also recall
11	during that subcommittee meeting, Bruce Latellier
12	attempted to challenge in Mr. Andreychek and
13	VICE CHAIRMAN WALLIS: Yes, and Mr.
14	Andreycheck
15	MR. HAFERA: we ran out of time.
16	VICE CHAIRMAN WALLIS: asked because
17	I brought him right in front of me here.
18	MR. JOHNSON: But not to put too high a
19	hat on these differences, we're not showing this
20	because we want
21	VICE CHAIRMAN WALLIS: You're showing me
22	this because you want to
23	MR. JOHNSON: discredit
24	VICE CHAIRMAN WALLIS: convince of
25	something. And don't make excuses for it.

1	MR. JOHNSON: We want to give you a
2	practical perspective about how we think the
3	evaluation comes out.
4	VICE CHAIRMAN WALLIS: I understand.
5	MR. JOHNSON: That's all that is.
6	VICE CHAIRMAN WALLIS: I understand, Mike.
7	But just you've got to be straightforward. And if
8	your numbers are very different from somebody else,
9	that creates a quandary for us, doesn't it?
10	MR. JOHNSON: Yes, it does. We can back
11	our numbers up.
12	CHAIRMAN BONACA: Graham?
13	VICE CHAIRMAN WALLIS: Yes.
14	MR. LATELLIER: If I may, this is Bruce
15	Latellier from Los Alamos National Lab. The value of
16	1,700 cubic feet was represented about the 95th
17	percentile of many thousands of random break locations
18	placed around the volunteer plant piping system.
19	And that number of 2,000 to 2,500 cubic
20	feet is corroborated by a number of studies for large
21	break LOCA done earlier for the BWR study and done
22	primarily in a manual fashion using engineering
23	judgment.
24	VICE CHAIRMAN WALLIS: Thank you. So you
25	have some support there?

1 MR. LATELLIER: Yes. 2 VICE CHAIRMAN WALLIS: Thank you. 3 MR. HAFERA: If our use our methodology, 4 I'm going to go through this fairly quickly because we 5 do have a lot more to go through, this basically shows fractional values of what the 1,720 -- what happens to 6 7 it, how much of it becomes small finds, how much of it becomes large pieces, how they're transported up into 8 containment, washed back down, transported to active 9 pools, inactive pools, and eventually end up on the 10 11 sump screen. 12 VICE CHAIRMAN WALLIS: Excuse me. You're only talking about the fiberglass insulation on the 13 14 steam generator? You're not talking about coatings? 15 MR. HAFERA: That's correct. Because this is just a simplified approach to show how our method 16 17 works. Using this, 18 I come out with -- and 19 assuming a 100 square foot screen, which is a 20 representative number --21 VICE CHAIRMAN WALLIS: How uncertain are 22 things like these 90 percent goes to the upper level 23 and 10 percent goes to the lower level? Are these 24 just somebody's estimate? MR. HAFERA: Those are approximate number 25

1 that are in -- there are actual more accurate numbers in the SE, but I used the approximate value --2 MEMBER SIEBER: Are these numbers --3 4 VICE CHAIRMAN WALLIS: Bruce Latellier, once 5 MR. LATELLIER: again, those branching fractions, those transport 6 7 fractions are based on containment blowdown 8 calculations. And we've made the engineering approximation that the debris follows the proportion 9 of the fluid flow primarily. 10 11 We've done these calcs to confirm that the 12 velocities are high enough to actually effectively transport debris of this size. And it is, where 13 14 necessary, where possible I should say, it 15 supported by experimental evidence generated during 16 the BWR resolution for the entrapment on gradings, 17 washdown through gradings due to containment spray. So we tried at every opportunity to use 18 19 defensible data for the branching fractions for 20 transport analysis. Where that is not available, we 21 use conservative estimates. 22 VICE CHAIRMAN WALLIS: So about a third of 23 it gets to the screen? Something like that? 24 estimates. And if there is uncertainty, it could be

a half or something like that? So it's a significant

25

1	amount is the message I got
2	MR. HAFERA: So it's a significant
3	VICE CHAIRMAN WALLIS: from all this.
4	MR. HAFERA: amount. The bottom line
5	is it is a significant amount. We show 60 depth
6	VICE CHAIRMAN WALLIS: Right.
7	MR. HAFERA: which, again, would not
8	quite fill the sump but pretty close to filling that
9	sump back on my first slide.
10	VICE CHAIRMAN WALLIS: Right.
11	MR. HAFERA: If we use our correlation
12	and, again, there's a lot of assumptions and I'm using
13	ballpark numbers, I get a head loss of about 10 to 17
14	
15	VICE CHAIRMAN WALLIS: I'm going to
16	challenge that. I think it's a very important issue.
17	In the guidance, you accept that homogeneously mixing
18	the product caused them the fibrous is conservative.
19	And yet I read Los Alamos' report, and I
20	listen to Bruce, and I'm told that a thin layer of the
21	particles depositing on top of the fiberglass can
22	create a far bigger pressure drop.
23	So, you know, if you get a thin layer of
24	fiberglass which then filters out the particles like
25	a filter in a chemical plant, and you get a filter

problem than if you're going to distribute these particles uniformly through this great mass of fiber.  MR. HAFERA: That's correct.  VICE CHAIRMAN WALLIS: Isn't that true?  MR. HAFERA: And we did say that we're going to talk about  VICE CHAIRMAN WALLIS: And if I take that  MR. HAFERA: But again  VICE CHAIRMAN WALLIS: this cal-sil.  MR. HAFERA: But again  VICE CHAIRMAN WALLIS: this cal-sil.  MR. HAFERA: what that boils down to as  We get down here to our bottom line  VICE CHAIRMAN WALLIS: But you don't  convince me at all with this 10 to 17 feet. You've put assumptions in there which seem to be incompatible with what I'm learning about thin bed effects. And I learn more every day as I read more about it. It doesn't you know, it's not convincing to me.  MR. HAFERA: Okay. Well, again, we're going to discuss thin bed effects later. And that's just something  MEMBER ROSEN: Well, could I  MR. HAFERA: that has to be considered.	1	cake of the particles, you have an entirely different
MR. HAFERA: That's correct.  VICE CHAIRMAN WALLIS: Isn't that true?  MR. HAFERA: And we did say that we're  going to talk about  VICE CHAIRMAN WALLIS: And if I take that  300 pounds, it's a lot more than what I was waving  around earlier  MR. HAFERA: But again  VICE CHAIRMAN WALLIS: this cal-sil.  MR. HAFERA: what that boils down to as  we get down here to our bottom line  VICE CHAIRMAN WALLIS: But you don't  convince me at all with this 10 to 17 feet. You've  put assumptions in there which seem to be incompatible  with what I'm learning about thin bed effects. And I  learn more every day as I read more about it. It  doesn't you know, it's not convincing to me.  MR. HAFERA: Okay. Well, again, we're  going to discuss thin bed effects later. And that's  just something  MEMBER ROSEN: Well, could I	2	problem than if you're going to distribute these
VICE CHAIRMAN WALLIS: Isn't that true?  MR. HAFERA: And we did say that we're going to talk about  VICE CHAIRMAN WALLIS: And if I take that  300 pounds, it's a lot more than what I was waving around earlier  MR. HAFERA: But again  VICE CHAIRMAN WALLIS: this cal-sil.  MR. HAFERA: what that boils down to as  we get down here to our bottom line  VICE CHAIRMAN WALLIS: But you don't convince me at all with this 10 to 17 feet. You've put assumptions in there which seem to be incompatible with what I'm learning about thin bed effects. And I learn more every day as I read more about it. It doesn't you know, it's not convincing to me.  MR. HAFERA: Okay. Well, again, we're going to discuss thin bed effects later. And that's just something  MEMBER ROSEN: Well, could I	3	particles uniformly through this great mass of fiber.
MR. HAFERA: And we did say that we're going to talk about  VICE CHAIRMAN WALLIS: And if I take that  300 pounds, it's a lot more than what I was waving around earlier  MR. HAFERA: But again  VICE CHAIRMAN WALLIS: this cal-sil.  MR. HAFERA: what that boils down to as we get down here to our bottom line  VICE CHAIRMAN WALLIS: But you don't convince me at all with this 10 to 17 feet. You've put assumptions in there which seem to be incompatible with what I'm learning about thin bed effects. And I learn more every day as I read more about it. It doesn't you know, it's not convincing to me.  MR. HAFERA: Okay. Well, again, we're going to discuss thin bed effects later. And that's just something  MEMBER ROSEN: Well, could I	4	MR. HAFERA: That's correct.
going to talk about  VICE CHAIRMAN WALLIS: And if I take that  300 pounds, it's a lot more than what I was waving  around earlier  MR. HAFERA: But again  VICE CHAIRMAN WALLIS: this cal-sil.  MR. HAFERA: what that boils down to as  we get down here to our bottom line  VICE CHAIRMAN WALLIS: But you don't  convince me at all with this 10 to 17 feet. You've  put assumptions in there which seem to be incompatible  with what I'm learning about thin bed effects. And I  learn more every day as I read more about it. It  doesn't you know, it's not convincing to me.  MR. HAFERA: Okay. Well, again, we're  going to discuss thin bed effects later. And that's  just something  MEMBER ROSEN: Well, could I	5	VICE CHAIRMAN WALLIS: Isn't that true?
VICE CHAIRMAN WALLIS: And if I take that  300 pounds, it's a lot more than what I was waving around earlier  MR. HAFERA: But again  VICE CHAIRMAN WALLIS: this cal-sil.  MR. HAFERA: what that boils down to as  we get down here to our bottom line  VICE CHAIRMAN WALLIS: But you don't  convince me at all with this 10 to 17 feet. You've  put assumptions in there which seem to be incompatible  with what I'm learning about thin bed effects. And I  learn more every day as I read more about it. It  doesn't you know, it's not convincing to me.  MR. HAFERA: Okay. Well, again, we're  going to discuss thin bed effects later. And that's  just something  MEMBER ROSEN: Well, could I	6	MR. HAFERA: And we did say that we're
300 pounds, it's a lot more than what I was waving around earlier  MR. HAFERA: But again  VICE CHAIRMAN WALLIS: this cal-sil.  MR. HAFERA: what that boils down to as we get down here to our bottom line  VICE CHAIRMAN WALLIS: But you don't convince me at all with this 10 to 17 feet. You've put assumptions in there which seem to be incompatible with what I'm learning about thin bed effects. And I learn more every day as I read more about it. It doesn't you know, it's not convincing to me.  MR. HAFERA: Okay. Well, again, we're going to discuss thin bed effects later. And that's just something  MEMBER ROSEN: Well, could I	7	going to talk about
around earlier  MR. HAFERA: But again  VICE CHAIRMAN WALLIS: this cal-sil.  MR. HAFERA: what that boils down to as  we get down here to our bottom line  VICE CHAIRMAN WALLIS: But you don't  convince me at all with this 10 to 17 feet. You've  put assumptions in there which seem to be incompatible  with what I'm learning about thin bed effects. And I  learn more every day as I read more about it. It  doesn't you know, it's not convincing to me.  MR. HAFERA: Okay. Well, again, we're  going to discuss thin bed effects later. And that's  just something  MEMBER ROSEN: Well, could I	8	VICE CHAIRMAN WALLIS: And if I take that
MR. HAFERA: But again  VICE CHAIRMAN WALLIS: this cal-sil.  MR. HAFERA: what that boils down to as  we get down here to our bottom line  VICE CHAIRMAN WALLIS: But you don't  convince me at all with this 10 to 17 feet. You've  put assumptions in there which seem to be incompatible  with what I'm learning about thin bed effects. And I  learn more every day as I read more about it. It  doesn't you know, it's not convincing to me.  MR. HAFERA: Okay. Well, again, we're  going to discuss thin bed effects later. And that's  just something  MEMBER ROSEN: Well, could I	9	300 pounds, it's a lot more than what I was waving
VICE CHAIRMAN WALLIS: this cal-sil.  MR. HAFERA: what that boils down to as  we get down here to our bottom line  VICE CHAIRMAN WALLIS: But you don't  convince me at all with this 10 to 17 feet. You've  put assumptions in there which seem to be incompatible  with what I'm learning about thin bed effects. And I  learn more every day as I read more about it. It  doesn't you know, it's not convincing to me.  MR. HAFERA: Okay. Well, again, we're  going to discuss thin bed effects later. And that's  just something  MEMBER ROSEN: Well, could I	10	around earlier
MR. HAFERA: what that boils down to as  we get down here to our bottom line  VICE CHAIRMAN WALLIS: But you don't  convince me at all with this 10 to 17 feet. You've  put assumptions in there which seem to be incompatible  with what I'm learning about thin bed effects. And I  learn more every day as I read more about it. It  doesn't you know, it's not convincing to me.  MR. HAFERA: Okay. Well, again, we're  going to discuss thin bed effects later. And that's  just something  MEMBER ROSEN: Well, could I	11	MR. HAFERA: But again
we get down here to our bottom line  VICE CHAIRMAN WALLIS: But you don't  convince me at all with this 10 to 17 feet. You've  put assumptions in there which seem to be incompatible  with what I'm learning about thin bed effects. And I  learn more every day as I read more about it. It  doesn't you know, it's not convincing to me.  MR. HAFERA: Okay. Well, again, we're  going to discuss thin bed effects later. And that's  just something  MEMBER ROSEN: Well, could I	12	VICE CHAIRMAN WALLIS: this cal-sil.
VICE CHAIRMAN WALLIS: But you don't  convince me at all with this 10 to 17 feet. You've  put assumptions in there which seem to be incompatible  with what I'm learning about thin bed effects. And I  learn more every day as I read more about it. It  doesn't you know, it's not convincing to me.  MR. HAFERA: Okay. Well, again, we're  going to discuss thin bed effects later. And that's  just something  MEMBER ROSEN: Well, could I	13	MR. HAFERA: what that boils down to as
convince me at all with this 10 to 17 feet. You've  put assumptions in there which seem to be incompatible  with what I'm learning about thin bed effects. And I  learn more every day as I read more about it. It  doesn't you know, it's not convincing to me.  MR. HAFERA: Okay. Well, again, we're  going to discuss thin bed effects later. And that's  just something  MEMBER ROSEN: Well, could I	14	we get down here to our bottom line
put assumptions in there which seem to be incompatible with what I'm learning about thin bed effects. And I learn more every day as I read more about it. It doesn't you know, it's not convincing to me.  MR. HAFERA: Okay. Well, again, we're going to discuss thin bed effects later. And that's just something  MEMBER ROSEN: Well, could I	15	VICE CHAIRMAN WALLIS: But you don't
with what I'm learning about thin bed effects. And I  learn more every day as I read more about it. It  doesn't you know, it's not convincing to me.  MR. HAFERA: Okay. Well, again, we're  going to discuss thin bed effects later. And that's  just something  MEMBER ROSEN: Well, could I	16	convince me at all with this 10 to 17 feet. You've
learn more every day as I read more about it. It  doesn't you know, it's not convincing to me.  MR. HAFERA: Okay. Well, again, we're  going to discuss thin bed effects later. And that's  just something  MEMBER ROSEN: Well, could I	17	put assumptions in there which seem to be incompatible
doesn't you know, it's not convincing to me.  MR. HAFERA: Okay. Well, again, we're  going to discuss thin bed effects later. And that's  just something  MEMBER ROSEN: Well, could I	18	with what I'm learning about thin bed effects. And I
MR. HAFERA: Okay. Well, again, we're going to discuss thin bed effects later. And that's just something  MEMBER ROSEN: Well, could I	19	learn more every day as I read more about it. It
going to discuss thin bed effects later. And that's  just something  MEMBER ROSEN: Well, could I	20	doesn't you know, it's not convincing to me.
just something  MEMBER ROSEN: Well, could I	21	MR. HAFERA: Okay. Well, again, we're
MEMBER ROSEN: Well, could I	22	going to discuss thin bed effects later. And that's
	23	just something
MR. HAFERA: that has to be considered.	24	MEMBER ROSEN: Well, could I
	25	MR. HAFERA: that has to be considered.

1	MEMBER ROSEN: ask a specific question
2	about the row that says with 100 square foot screen,
3	small finds only
4	MR. HAFERA: Yes.
5	MEMBER ROSEN: yields an approximate
6	depth of six feet. Why do you think only small finds
7	will get in there when a fairly significant fraction
8	of the large pieces are transported? Are they not?
9	MR. HAFERA: Well, this shows and
10	basically, again, I rounded off the value that was in
11	the SE, but about 35 percent of the large find of
12	large pieces will get there.
13	MEMBER ROSEN: So why don't you think
14	MR. HAFERA: I didn't include them just
15	for the sake of this example. I didn't include
16	coatings, I didn't include concrete dust, I didn't
17	include a lot of things. This is just a
18	representative
19	MEMBER ROSEN: Well, this
20	MR. HAFERA: example.
21	MEMBER ROSEN: is a very unchallenging
22	example is what you've chosen.
23	MR. HAFERA: Okay.
24	MEMBER ROSEN: It's an example where
25	MR. HAFERA: But this is basically what

1	Mr. Andreycheck presented at the subcommittee.
2	MR. SOLORIO: And I think, Tom, what you
3	started by saying when you started your presentation,
4	we're just trying to show that it can be exercised, I
5	guess.
6	MR. HAFERA: Right.
7	VICE CHAIRMAN WALLIS: Well, it think it's
8	very revealing. You've got six feet of debris. Now
9	as I understand it, the tests that have been made have
10	involved an eighth of an inch of debris, and an inch,
11	and so focus on very thin layers of debris. And we're
12	going to take that knowledge base and extrapolate to
13	the six feet thick of debris.
14	We'd better be damn sure that we
15	understand what's going on if we're going to
16	extrapolate it like that.
17	MEMBER KRESS: Well, I think your result
18	tells you that that's not an acceptable result.
19	MR. SOLORIO: Right.
20	MR. HAFERA: That's right.
21	MEMBER KRESS: So you're not really going
22	to use that
23	MR. HAFERA: The bottom line is
24	MEMBER KRESS: number. It's something
25	that has to be done.

1	MR. HAFERA: We didn't get there.
2	MEMBER KRESS: Right.
3	MR. HAFERA: The bottom line is most
4	plants, you know, a head loss of 10 to 17 feet, most
5	plants only have a margin of two to five
6	VICE CHAIRMAN WALLIS: Yes, even with
7	MR. HAFERA: so they can't live with
8	this. So what's that telling them? That tells them
9	that they have to go do some type of design change.
10	And they're going to have to do some type of
11	remediation of that
12	VICE CHAIRMAN WALLIS: Now isn't this true
13	
14	MR. HAFERA: concern.
15	VICE CHAIRMAN WALLIS: that almost all
16	plants are going to reach this conclusion?
17	MR. HAFERA: What we've determined is most
18	likely most of them will.
19	VICE CHAIRMAN WALLIS: Yes, and so
20	MR. HAFERA: Most of them will.
21	VICE CHAIRMAN WALLIS: what's important
22	is to work on the fix
23	MR. HAFERA: Exactly.
24	VICE CHAIRMAN WALLIS: obviously. Not
25	all this analytical material.

1	MR. HAFERA: Right. But as a condition,
2	we can't go fix people's sump.
3	MEMBER SIEBER: You need to know the
4	VICE CHAIRMAN WALLIS: You need to know
5	things
6	MEMBER SIEBER: overall results
7	VICE CHAIRMAN WALLIS: but you
8	MEMBER SIEBER: to know whether
9	VICE CHAIRMAN WALLIS: already know an
10	awful lot. You already know an awful lot about the
11	problem.
12	MR. HAFERA: Okay. That
13	VICE CHAIRMAN WALLIS: It would seem clear
14	to me that people have got to be working hard on the
15	fix.
16	MR. JOHNSON: That was my opening that
17	was one of my opening points. That was number two of
18	my opening points.
19	MR. HAFERA: Exactly.
20	MEMBER SIEBER: Was that the analysis?
21	You don't know whether the fix is any good or not?
22	MR. JOHNSON: That was Number One of my
23	opening.
24	CHAIRMAN BONACA: Now you're going to take
25	us through some of the refinements, right?

1	VICE CHAIRMAN WALLIS: Yes, you're going
2	to take us through some
3	MR. HAFERA: Okay, so
4	CHAIRMAN BONACA: So we're going to see
5	how you're going to work on the baseline to take down
6	to the refinements? Okay.
7	MR. HAFERA: Right. Again, and I don't
8	think I'll even go over this too much. There are
9	plants out there that are all RMI plants so,
10	therefore, they don't have Nukon. And they wouldn't
11	get this large volume.
12	But basically what it shows is latent
13	debris, of and by itself, can produce a thin layer.
14	And the thin bed effect.
15	VICE CHAIRMAN WALLIS: Even with the RMI?
16	MEMBER SIEBER: Without any
17	MR. HAFERA: Without any
18	MEMBER SIEBER: without any insulation
19	
20	MR. HAFERA: without any insulation
21	whatsoever.
22	MEMBER SIEBER: contribution.
23	VICE CHAIRMAN WALLIS: That's a very
24	plant-specific thing. The plants have to
25	MR. HAFERA: That's a very right.

1	VICE CHAIRMAN WALLIS: Right. Now this
2	RMI, that's the point that we had in the subcommittee
3	was RMI is very good for this point of view. But if
4	some of it gets through the screen, what does it do to
5	the pump we were asking? Maybe the pump just eats it
6	up. But we didn't seem to know in the subcommittee
7	meeting.
8	MR. HAFERA: Well, the
9	VICE CHAIRMAN WALLIS: What is the
10	downstream effect going to be?
11	MR. HAFERA: downstream effects, and
12	again we have a presentation on that later
13	VICE CHAIRMAN WALLIS: You're going to get
14	to that, okay.
15	MR. HAFERA: but, again, that's an
16	engineer that can be engineered out.
17	MEMBER ROSEN: Did you just leave off by
18	mistake the head loss for the RMI latent fiber only
19	case? I don't see it.
20	MR. HAFERA: Yes, I didn't go so far as to
21	go to head loss with these two cases just to show
22	basically what the debris bed
23	MEMBER ROSEN: Well, you
24	MR. HAFERA: thickness is.
25	MEMBER ROSEN: told us it's 10 to 17

1	feet for the top case.
2	MR. HAFERA: Right.
3	MEMBER ROSEN: For the RMI latent fiber,
4	is it 10 to 17 feet also? Is it approximately the
5	same? Or I mean give me some feel for it
6	quantitatively what you would expect.
7	MR. HAFERA: Well
8	MR. SOLORIO: Wouldn't it be less, Tom,
9	because we're
10	MR. HAFERA: Yes.
11	MR. SOLORIO: dealing with less fiber?
12	MR. HAFERA: It would be significantly
13	less.
14	MEMBER KRESS: Unless you assume a thin
15	bed correlation.
16	MR. HAFERA: Yes, sir, Dr. Kress.
17	CHAIRMAN BONACA: What are the operator
18	actions you are referring to down there?
19	MR. HAFERA: Okay, yes, thank you. I'll
20	get to that real quick.
21	VICE CHAIRMAN WALLIS: Can we have a thin
22	bed with this latent fiber?
23	MEMBER KRESS: Well, that's undetermined
24	because we haven't characterized latent fiber.
25	VICE CHAIRMAN WALLIS: But you say you've
1	

1 got 1.7 inches and we were getting thin beds with an 2 eighth of an inch all through the document that you 3 reviewed. 4 MEMBER KRESS: It certainly seems possible 5 you could get it. It's possible. 6 MR. HAFERA: 7 VICE CHAIRMAN WALLIS: It's possible but 8 you don't know. So the plants have to do it all --9 they have to brush up all their stuff in the plant, do all their testing to find out if they can get a thin 10 11 bed. Is that what you expect them to do? 12 They have to evaluate MR. HAFERA: Yes. 13 14 VICE CHAIRMAN WALLIS: You want them to --15 MR. HAFERA: -- their containment. 16 VICE CHAIRMAN WALLIS: -- you're putting 17 an awful lot on these plants. MR. LATELLIER: If I may add, Dr. Wallis, 18 19 Bruce Latellier, we are assuming that latent fiber is 20 capable of forming a thin bed. And that's the reason 21 for Tom's example to show that based on a rough 22 estimate of total latent debris inventory and the 23 fibrous fraction that was characterized in the recent 24 LANL study, that there is potentially a substantial 25 amount of fiber present.

1	And they must assess their plant
2	cleanliness for that
3	VICE CHAIRMAN WALLIS: Thank you, Bruce.
4	MR. LATELLIER: contribution.
5	VICE CHAIRMAN WALLIS: That's a very good
6	point. So it means the staff is going to get it, if
7	they go through with all this, a whole lot of
8	submittals from plants explaining how they use the
9	vacuum cleaner and how they picked up all this stuff.
10	And all the tests they did. And they'll all be
11	different.
12	And you're going to somehow assess whether
13	or not there is a thin bed when we don't quite know
14	what a thin bed is and what causes it?
15	MR. HAFERA: Well, we know what a thin bed
16	is and what causes it. And we're going
17	VICE CHAIRMAN WALLIS: You don't.
18	MR. HAFERA: to present that later.
19	VICE CHAIRMAN WALLIS: Well, okay, maybe
20	you can convince me.
21	MR. HAFERA: Okay.
22	MEMBER ROSEN: Now I'm going away from
23	this chart with the idea that an RMI latent fiber only
24	bed is significantly less than 10 to 17 feet. And to
25	me significantly less it's a third of that or five

1	feet or something like that, which is still very
2	important.
3	MR. HAFERA: That's correct.
4	MEMBER ROSEN: Okay.
5	MR. HAFERA: That's correct. Very good
6	point.
7	So, again, just practical solutions here.
8	Practical solutions that plants could do. Double
9	jacketing their insulation. There's a low cost, low
10	tech solution that would really produce a large
11	effect. It really reduces the ZOI and it will reduce
12	that number quite significantly.
13	MEMBER ROSEN: Do you have a test that
14	shows that?
15	MR. HAFERA: Yes, we have tests that show
16	double jacketed insulation
17	MEMBER ROSEN: Ralph, could you speak to
18	that?
19	MR. HAFERA: that are not nearly as
20	susceptible to damage.
21	MR. ARCHITZEL: We showed the subcommittee
22	the OPG tests were done and that upped the cal-sil
23	from around 24 pounds to like around somewhere
24	around 250 or 300 pounds in offset seams on the double
25	coverage. So it was a tremendously significant

1	increase in destruction pressure.
2	MR. SOLORIO: That was Ralph Architzel.
3	MR. HAFERA: So that's a quick low tech
4	method that can have a big impact.
5	Modifying sump screens. We heard somebody
6	might want to use an active sump screen. We also know
7	that there are sump screen designs that aren't
8	susceptible to thin bed effects, stacked disks and
9	what have you.
10	And there are a number of other things
11	that can be done. Refining the zone of influence
12	model
13	VICE CHAIRMAN WALLIS: That might lead you
14	to getting bigger
15	MR. HAFERA: We're seeing that
16	VICE CHAIRMAN WALLIS: if you refine
17	it, it might get bigger.
18	MR. HAFERA: Well, the zone of influence
19	model is not necessarily real it doesn't correlate
20	real well at low pressures. So that could produce a
21	
22	VICE CHAIRMAN WALLIS: But it might
23	MR. HAFERA: significant impact.
24	VICE CHAIRMAN WALLIS: it might grow.
25	There's only inference if you learn more about it, it

1	might get bigger.
2	MR. HAFERA: It's possible. You could add
3	trash racks in barriers along the floors of
4	containment.
5	Operator actions, operators can take high
6	pressure injection systems out earlier, cool down the
7	plant faster, go to shut down cooling-type
8	recirculation faster, a lot of operator actions or
9	VICE CHAIRMAN WALLIS: Now these are all
10	the things
11	MR. HAFERA: potentially
12	VICE CHAIRMAN WALLIS: you think might
13	be done? These are things you think might be done?
14	Right? They're conjecture? These things that look
15	like reasonable candidates for thinking about?
16	MR. SOLORIO: Well, we know, Dr. Wallis,
17	from a conversation we've had with industry that
18	they're looking at increasing their sump screen sizes,
19	at least some contractors
20	VICE CHAIRMAN WALLIS: They're looking at
21	but I don't see any kind of design that says we've
22	made all the calculations and it looks as if this
23	thing will work. You're way a long way away from
24	that, right?
25	MR. JOHNSON: That's right. Again

VICE CHAIRMAN WALLIS: A long way from
MR. JOHNSON: we've
VICE CHAIRMAN WALLIS: anything
MR. JOHNSON: not
VICE CHAIRMAN WALLIS: that will work.
MR. JOHNSON: seen designs, right.
That's right.
MEMBER ROSEN: You're aware of the
difficulty of crediting operator actions during a LOCA
like this which is very different than things that
have operators that have been typically trained to
do.
CHAIRMAN BONACA: So they are not
MEMBER ROSEN: This is not a simple
MR. JOHNSON: Well, I think, again
MEMBER ROSEN: approach.
MR. JOHNSON: if you go back to the
LOCA does and how it progresses and when you're on
recirc and when your sump screen actually starts to
show degradation, you're talking long-term into the
event where you have time to plan it ahead of time.
And you have a your plant is already
cooled down. Your containment is already
depressurized. So you have a significant response
time.

1 MEMBER ROSEN: Well, I grant that. Ι 2 grant that. VICE CHAIRMAN WALLIS: I agree with that. 3 4 MEMBER ROSEN: But I also ask you to grant 5 the fact that the plant has just had a LOCA. This is not normal. 6 7 MR. JOHNSON: Oh, absolutely. 8 MEMBER ROSEN: This is not your normal day 9 at the plant. 10 MR. SOLORIO: No, you're right. MR. JOHNSON: No, it's a bad day in the 11 12 control room. VICE CHAIRMAN WALLIS: Can you give me --13 14 MR. JOHNSON: And I've had a few. 15 VICE CHAIRMAN WALLIS: -- estimate, now 16 we've been through some of these in the past, 17 historical events where the Agency has decided that action should be taken on some major issue. And then 18 19 there are various designs and they have to be approved 20 and all. 21 How long does it take to implement? To go 22 from now to doing all these calculations in the 23 plants, to designing things, and to actually implement 24 something, getting approval from the Agency, how long 25 does it typically take to do something like that?

1	MR. JOHNSON: Well, the schedule that we
2	have this is Mike Johnson, the schedule that we
3	have published and requested in the Generic Letter has
4	licensees completing their evaluation
5	VICE CHAIRMAN WALLIS: No, no, I'm not
6	really asking about that. I'm asking about say post-
7	TMI, there were some changes because lessons were
8	learned. Didn't it take quite a few years before
9	anything substantial happened in the plant? So I'm
10	just trying to put it in perspective.
11	MEMBER APOSTOLAKIS: He's not talking
12	about just the study.
13	MR. JOHNSON: You mean how long does it
14	take them to implement their changes?
15	VICE CHAIRMAN WALLIS: I'm looking for the
16	solution.
17	MEMBER APOSTOLAKIS: The solution itself.
18	VICE CHAIRMAN WALLIS: If you look down
19	the road about what steps if I were an engineer I
20	would have to take to get to a solution, how long it
21	would take. And I'm guessing it's something like ten
22	years. Am I wrong?
23	MR. SOLORIO: Well, I don't know if I can
24	answer TMI but, Rob Elliot, I mean how long did we
25	take to or did the industry take to implement the

1	fix for the BWRs?
2	MR. ARCHITZEL: We issued the Bulletin in
3	May of `96 and all the licensees completed their
4	modifications by the spring of `99.
5	VICE CHAIRMAN WALLIS: So it's three
6	years. So there's hope.
7	MR. ARCHITZEL: We gave them a year to
8	MEMBER SIEBER: Think about it.
9	VICE CHAIRMAN WALLIS: Okay.
10	MR. ARCHITZEL: do the evaluation and
11	then told them that plants starting in the spring of
12	the following year had to start completely hardware
13	modifications
14	VICE CHAIRMAN WALLIS: That's good.
15	That's
16	MR. ARCHITZEL: in their first outage.
17	VICE CHAIRMAN WALLIS: a historical
18	precedent and we can maybe extrapolate it to this
19	case.
20	MR. ARCHITZEL: And I suspect the vendors
21	that helped with the BWRs are probably going to try
22	and jump in on the PWRs, too. So there's probably a
23	lot of experience there.
24	VICE CHAIRMAN WALLIS: Thank you.
25	MR. JOHNSON: 2007 is our expectation in

1	this case.
2	VICE CHAIRMAN WALLIS: Well, I don't know
3	about what your expectation is. I'm just looking for
4	evidence that it has happened before.
5	MR. HAFERA: Okay. Well, that concludes
6	my high-level presentation. There's people who follow
7	me to provide more details in the specific areas and
8	hopefully get to some of the other more detailed
9	questions.
10	MEMBER APOSTOLAKIS: Why did it take 25
11	years, Mike? You say this has been around for 25
12	years?
13	MR. JOHNSON: There's a real good history
14	in front of the SE
15	MEMBER APOSTOLAKIS: Yes, I saw that.
16	MR. JOHNSON: that talks about it.
17	MEMBER APOSTOLAKIS: That's too long.
18	MR. JOHNSON: Right. Well, we learned
19	things at various stages. We took on a problem with
20	the boilers. We, at that time, recognized that 50
21	blockage wasn't going to be good for the peaks. What
22	we did and at that time, thought that we need to
23	have this mechanistic evaluation.
24	We had some events that caused us to
25	recognize that

1	MEMBER APOSTOLAKIS: So it was the
2	evidence?
3	MR. JOHNSON: that it was more of a
4	problem. So we've learned things over that time. But
5	we've ultimately dealt with the issues.
6	CHAIRMAN BONACA: Well, I mean, that's
7	right. I mean it's 25 years of inadequate
8	improvements. So we hope that this will be an
9	adequate improvement. And that's the thrust of our
10	comments, I believe.
11	MEMBER APOSTOLAKIS: How raised the issue,
12	do you remember?
13	MR. JOHNSON: I'm sorry?
14	MEMBER APOSTOLAKIS: Who raised the issue?
15	Who raised it?
16	MR. JOHNSON: Who raised the issue?
17	MEMBER APOSTOLAKIS: Yes.
18	MR. JOHNSON: Who raised the sump blockage
19	issue?
20	MEMBER APOSTOLAKIS: Twenty-five years
21	ago.
22	MR. JOHNSON: I honestly don't know the
23	answer to that.
24	MEMBER APOSTOLAKIS: Okay.
25	MR. ARCHITZEL: The sump blockage Ralph

1	Architzel the sump blockage issue was raised around
2	1979, right around TMI time initially.
3	VICE CHAIRMAN WALLIS: So this was a post-
4	TMI issue?
5	MR. ARCHITZEL: No, it wasn't. It was
6	actually before TMI. It was studied for about four or
7	five years until the `84 time frame because we have to
8	go back to USIA 43 but it was about five years before
9	it was resolved in `85. It might have been
10	VICE CHAIRMAN WALLIS: So that's more
11	historical information about how long it took to do
12	something. Okay.
13	MR. KOWALL: Good morning. My name is
14	Mark Kowall. I'm a reactor systems engineer in the
15	Plant Systems Branch.
16	This morning I'm going to discuss section
17	3.3 and 4.21 of the SER. These sections deal with the
18	break selection. And the overall process for
19	identifying the limiting break location.
20	MEMBER APOSTOLAKIS: Why are you doing
21	that? The subcommittee requested it?
22	MR. KOWALL: This is one of the major
23	areas. This was one of the blocks that Dave Solorio
24	had on his slide. I'll go through it very quickly.
25	Basically this section provides the

1	guidance and consideration for identifying the
2	limiting break location. The criteria used to
3	identify this location is the estimated head loss
4	across the sump screen.
5	There are really two key attributes that
6	I emphasize and those are the maximum amount of debris
7	transported to the sump and the worst combinations of
8	debris mixes transported to the sump. So and to
9	identify this limiting break location, you are really
LO	looking at what gets to the sump.
L1	MEMBER KRESS: And do we know how to
L2	determine what the worst combination is? Does that
L3	relate to the thin bed effect?
L4	MR. KOWALL: That relates to the thin bed,
L5	that's right.
L6	VICE CHAIRMAN WALLIS: And it relates to
L7	when it is transported, or how the stuff builds up, or
L8	whether you get a thin bed on top of fiberglass, or
L9	inside it, or on the bottom of it, or how well mixed
20	they are, and all that sort of stuff?
21	I don't see anything in the guidance that
22	tells you how to calculate those things.
23	MR. LATELLIER: Bruce Latellier. You're
24	correct in noting that there's very little time-
25	dependent advice on time-dependent debris hed

formation given in the guidance. The limits of our 1 2 ability to model transport do not -- just simply don't -- do not warrant a detailed effort in that regard. 3 4 However, there are important phases of the 5 accident sequence that can be considered, that being the high velocities during pool fill up, the spray 6 7 washdown, and finally the low velocity recirculation 8 phase. And if you think about those effects, the 9 10 first opportunity for accumulating very 11 quantities of large debris only occurs in the initial 12 depending phase. And on sump your configuration, for example, a horizontal arrangement 13 14 below grade, that's a very credible event where you'd 15 have a large, bulky homogenized bed. 16 VICE CHAIRMAN WALLIS: So you've got the large debris first. 17 That is one possibility. 18 MR. LATELLIER: Alternatively, if that large bed does not form, the 19 20 small suspended finds can continue to accumulate indefinitely to form the thin bed behavior that we're 21 22 most concerned about. 23 And so there's some important separations 24 in the accident sequence that allow us to think about 25 what are reasonable bed configurations.

1	VICE CHAIRMAN WALLIS: That was very
2	helpful, Bruce. And as I'm sitting here, I'm thinking
3	about how a beaver builds a dam, he puts the twigs in
4	first, he puts the large debris in first. And gets a
5	structure, which is your fiberglass.
6	And then he puts the mud on which is your
7	cal-sil or whatever. He builds himself a thin layer.
8	And he stops the water going through.
9	MEMBER ROSEN: Do we have a contract with
LO	him?
L1	(Laughter.)
L2	VICE CHAIRMAN WALLIS: I believe they have
L3	beavers at MIT.
L4	But, you see, this is the kind of thing
L5	that occurs to me. And I don't see anything in the
L6	guidance that tells you how to calculate those things.
L7	These are all sort of the beginnings of
L8	understanding of these things. And you're doing a
L9	great job. You guys are working very hard. It's just
20	a question of whether or not you're ready. Okay.
21	MR. KOWALL: The section also provides
22	considerations on the piping systems that need to be
23	considered, and break size. Basically all RCS piping
24	and attached piping.
25	And also secondary side breaks if they're

1 part of the licensing basis and rely on recirculation 2 must be considered. All phases of the accident scenario are 3 4 considered. This is an overall process. It's a 5 number of iterations for identifying the limiting break location. 6 7 Then section 4.2.1 provided or proposed the application of Branch Technical Position MEB 3-1 8 for break locations to consider. 9 Next slide. 10 VICE CHAIRMAN WALLIS: Can I ask you about 11 12 This I have a real problem with. And I asked this? at the subcommittee. 13 14 It says no guidance for plants that can 15 substantiate no thin fiber layer. So if they don't have a thin bed effect, there's no guidance for them. 16 MR. KOWALL: 17 Well --VICE CHAIRMAN WALLIS: So they're finished 18 19 and they can't use the guidance. 20 If there is a thin bed effect, they're 21 likely to be finished because they can't get the water 22 So how do they escape from this Catch 22? through. 23 MR. KOWALL: One of the -- I quess we 24 talked about this at the subcommittee meeting. One of 25 the examples of this was in the coatings area with the

1 assumptions on the particulate size for the coatings, 2 working toward -- or with thin bed, if a plant can substantiate they do not have a thin bed, the staff 3 4 has enhanced the --5 VICE CHAIRMAN WALLIS: Well, how can they substantiate they don't have a thin bed? Thin beds 6 7 sort of occur by luck. When you do an experiment --8 you do a lot of experiments and then gee whiz, we've 9 got a thin bed here. And it explains some anomalous 10 It's not something which is part of the technical knowledge. 11 12 So how on Earth are these folks going --They may not --13 MR. KOWALL: 14 VICE CHAIRMAN WALLIS: -- to establish --15 MR. KOWALL: -- that's true --VICE CHAIRMAN WALLIS: -- that they don't 16 have a thin bed? 17 MR. JOHNSON: We talked about it at the 18 19 subcommittee -- Mike Johnson. 20 VICE CHAIRMAN WALLIS: Yes, but we're 21 still talking about it because you haven't resolved 22 it. 23 MR. JOHNSON: Well, what we said was we 24 really don't believe that there are going to be 25 licensees who substantiate no thin bed. What we were

1	doing was looking at the guidance
2	VICE CHAIRMAN WALLIS: You don't
3	MR. JOHNSON: to make
4	VICE CHAIRMAN WALLIS: believe
5	MR. JOHNSON: sure that in
6	VICE CHAIRMAN WALLIS: that they will?
7	MR. JOHNSON: What we were doing is making
8	sure the guidance would handle that eventuality should
9	a plant come in an try to substantiate no thin bed,
10	how then would they implement the guidance? And so
11	that's what we're taking care of in this case.
12	MEMBER SIEBER: How would they
13	substantiate no thin bed?
14	MR. ARCHITZEL: Let me just point out
15	something here. It's not necessarily on the existing
16	designs but an all RMI plant, the idea was an all RMI
17	plant, perhaps with a modified design, with no fiber
18	in the plant except for the latent, with a modified
19	screen size, using the criteria we had in the guidance
20	report of the one-eighth inch could distribute that
21	over the one-eighths inch and demonstrate that
22	VICE CHAIRMAN WALLIS: But we know one-
23	eighth doesn't mean anything any more. We know from
24	Bruce Latellier's very clear explanation a thin bed
25	II

1	be an eighth of an inch.
2	MR. ARCHITZEL: No, no. I'm saying the
3	total fiber that is existing. So it doesn't matter.
4	VICE CHAIRMAN WALLIS: Well, if they don't
5	have as much as an eighth of an inch?
6	MR. ARCHITZEL: Over the modified square
7	
8	VICE CHAIRMAN WALLIS: Well, there is
9	another statement in your guidance that says cal-sil
10	can form a layer with no fibers at all.
11	MR. ARCHITZEL: Well, the plant may not
12	have cal-sil but the point is there are plants that
13	could do that calculation and demonstrate they don't
14	have a thin bed.
15	The other point is the plants could put in
16	modified strainer designs that are not susceptible to
17	the thin bed effect. There are two ways you get that.
18	MEMBER SIEBER: That's the only choice as
19	I see it because you can get a thin bed out of latent
20	fiber with no
21	MR. ARCHITZEL: But not necessarily
22	MEMBER SIEBER: RMI unless the screen
23	is huge in size.
24	MR. ARCHITZEL: Well, that's the point.
25	If the screen is 500 square feet, depending on your

1	latent, you might get or 800 or 1,000
2	MEMBER SIEBER: That's pretty tough
3	MR. ARCHITZEL: developing depending
4	on the geometry
5	MEMBER SIEBER: That's pretty tough
6	MR. ARCHITZEL: of the screen design
7	also.
8	MEMBER SIEBER: to do that in some of
9	these containers.
10	MR. ARCHITZEL: It depends on the latent
11	debris term if you're an all RMI plant. There is a
12	possibility that the condition exists is the only
13	point we're making so we have a provision for that.
14	The reason for that comment is if you have
15	that condition, where you have the modified the
16	real reason, the additional one, if you had a design
17	fix that is not susceptible to thin bed
18	VICE CHAIRMAN WALLIS: Guidance only
19	applies to plants that do have a thin bed effect. So
20	now you're saying that almost all plants are going to
21	have this thin bed effect.
22	MEMBER SIEBER: I think so.
23	VICE CHAIRMAN WALLIS: You say almost none
24	are going to substantiate they don't have it.
25	MR. ARCHITZEL: There would be a lot that

1	would substantiate they don't have thin bed because
2	VICE CHAIRMAN WALLIS: There would be?
3	MR. ARCHITZEL: because of the fix.
4	VICE CHAIRMAN WALLIS: After the fix?
5	MR. JOHNSON: After the fix.
6	VICE CHAIRMAN WALLIS: But now, you're
7	asking to assess now what's the state of it now?
8	MR. ARCHITZEL: Probably most of them
9	couldn't justify now
10	VICE CHAIRMAN WALLIS: We will find that
11	they all have thin beds now. Is that what we're going
12	to find?
13	MEMBER KRESS: Is there a substantial
14	database to back up your statement that some screens
15	are not so susceptible to thin bed effects? And I
16	presume these are the corrugated screens?
17	MEMBER SIEBER: Or vertical screens.
18	MEMBER KRESS: Vertical corrugated?
19	MR. ARCHITZEL: Disk strainers, et cetera,
20	and the testing was done. I mean that's the testing
21	that was used for the BWRs in those propriety screens.
22	MEMBER KRESS: That testing exists?
23	MR. ARCHITZEL: Yes.
24	MEMBER KRESS: Okay.
25	MR. KOWALL: And as a result of this

1 discussion from the subcommittee meeting, the staff 2 did add Appendix 8 to the Safety Evaluation Report 3 that discusses the thin bed. 4 VICE CHAIRMAN WALLIS: Yes, I have read 5 Appendix 8. And it describes some effects. MR. KOWALL: Yes, it gives examples --6 VICE CHAIRMAN WALLIS: It describes some 7 effects. 8 MR. KOWALL: -- of thin bed. It gives 9 10 examples of where this has occurred, events --11 VICE CHAIRMAN WALLIS: It doesn't give me 12 a clear recipe for predicting things. It describes all of the effects. It's very useful for saying this 13 14 is the state of knowledge. 15 But if I were to try to use it to develop design criteria and to evaluate my plant, I think I'd 16 have a lot of trouble. 17 The second exception the 18 MR. KOWALL: 19 staff took to section 3.3 was with respect to the 20 secondary break locations. The guidance report 21 proposed that secondary side break locations be 22 analyzed consistent with the current licensing basis. 23 The staff's position on this is that the 24 secondary side breaks should be analyzed consistent 25 with RCS piping, LOCA piping. And the basis for this

1 is that the current licensing basis does not consider 2 all the issues and concerns associated with this GSI-191. 3 4 Even though the secondary side analyses 5 not performed in accordance with 50.46, to demonstrate acceptance criteria of 50.46, if the sump 6 7 is relied on to mitigate the consequences of secondary side breaks, then licensees should identify limiting 8 9 locations and ensure that their sump will perform its intended function. 10 11 And this is consistent with the staff's 12 position in Reg Guide 1.82. It doesn't specifically distinguish between -- okay. 13 14 Additionally, the staff concluded that 15 it's not appropriate to evaluate only locations consistent with Branch Technical Position MEB 3-1. 16 We concluded this for a number of reasons. 17 It's not consistent with the requirements of 50.46. 18 19 The staff previously rejected this for the BWRs. consistent with Reg Guide 1.82 considerations. 20 And 21 this would also apply to secondary side breaks. VICE CHAIRMAN WALLIS: 22 Okay. Move on. 23 MR. ARCHITZEL: Мγ name is Ralph 24 Architzel. And I'll discuss the debris generation 25 section. I'll try to do it shortly. I'd like to make

1 one additional discussion on the other areas. 2 The guidance report uses the zone influence approach. 3 This is what the industry has 4 proposed founded in ANSI 58.2, Free Jet Expansion 5 Model. CHAIRMAN WALLIS: And you 6 VICE 7 perfectly happy with the model that's in ANSI? 8 MR. ARCHITZEL: We have written Appendix 9 I. We've modified Appendix I. It was proposed by the And we feel there are deficiencies 10 industry. 11 associated with that. There are theory deficiencies. 12 Overall when you take that model, we consider it conservative from a regulatory perspective. 13 14 VICE CHAIRMAN WALLIS: Did you look -- did 15 anyone look at the original document on which it is based, the ANSI model? Did they find that the conical 16 17 pressure distribution is simply assumed? 18 MR. ARCHITZEL: I'm not sure. We went --19 VICE CHAIRMAN WALLIS: Things like that? 20 I mean --21 MR. ARCHITZEL: -- back to --22 VICE CHAIRMAN WALLIS: -- did anvone 23 critical examine the basis of this model? Did anyone 24 critical examine knowledge about what happens in 25 supersonic flows? Or you just accept it? You accept

1	it as I mean I could see accepting a standard. I
2	mean it sounds authoritative.
3	MR. ARCHITZEL: We did do a critical look
4	at that standard. And that is Appendix 1. And we'll
5	move on to that.
6	VICE CHAIRMAN WALLIS: I have to read that
7	again because I think it's changed some more since
8	MR. ARCHITZEL: We did we last night
9	sent you another revision
10	VICE CHAIRMAN WALLIS: that's another
11	revision
12	MR. ARCHITZEL: of three
13	VICE CHAIRMAN WALLIS: last night,
14	fine.
15	MR. ARCHITZEL: pages additional
16	VICE CHAIRMAN WALLIS: That makes it
17	difficult for me to assess it.
18	MR. ARCHITZEL: I'm sorry?
19	VICE CHAIRMAN WALLIS: It makes me
20	difficult to assess something you sent me last night.
21	MR. ARCHITZEL: That wasn't the thought
22	behind I mean we tried to address the comments
23	(Laughter.)
24	MR. ARCHITZEL: you made earlier trying
25	to clarify what we feel are deficiencies relative to

1	the physics for that model. But if we step back from
2	it and ignore yes
3	VICE CHAIRMAN WALLIS: So you've now gone
4	to what we suggested you do some time ago. You've
5	actually gone to examine whether the model is good and
6	what its deficiencies might be. You're beginning to
7	do that? Is that so?
8	MR. ARCHITZEL: Well, we're accepting the
9	use of the model still.
10	VICE CHAIRMAN WALLIS: But now you're
11	examining its deficiencies, having accepted it?
12	MR. ARCHITZEL: For the application with
13	the precision we're talking about.
14	VICE CHAIRMAN WALLIS: So you bought the
15	car and now you're looking at what's wrong with it?
16	MR. LATELLIER: If I may add, the use of
17	the ANSI model was proposed by the industry.
18	VICE CHAIRMAN WALLIS: Yes.
19	MR. LATELLIER: Based somewhat on the
20	recommendation of Reg Guide 1.82, that the staff found
21	it to be an acceptable method. So, therefore, it is
22	incumbent on the staff to be totally comfortable and
23	convinced that it is appropriate for the use.
24	VICE CHAIRMAN WALLIS: Let's say this
25	clearly in all of this, a lot of education going

1	on. You guys are learning. Every time I hear anything
2	from you, there's new knowledge, new appreciation.
3	That is the way it's going. I appreciate that.
4	That's very good.
5	But, you know, the question is whether,
6	since you're in this great learning process about
7	these phenomena, you can make decisions based on
8	things which you may learn tomorrow are not
9	appropriate quite the way you thought they were.
10	That's what I'm concerned about. You're
11	in that learning process now and yet you are trying to
12	make decisions based on things which you have trouble
13	coming to grips with.
14	MR. ARCHITZEL: Well, I guess I'd phrase
15	the zone of influence situation as so conservative in
16	terms of what has been proposed
17	VICE CHAIRMAN WALLIS: How do you know
18	it's conservative?
19	MR. ARCHITZEL: Conservative relative to
20	the CFD examples that were proposed by the BWRs and
21	it's modeled on the destruction pressures as they are
22	measured. And then the assumption of anything with an
23	equivalent sphere being totally destroyed is where the
24	conservatism
25	VICE CHAIRMAN WALLIS: I agree. You

1	certainly have put some conservatisms in it, yes.
2	MR. ARCHITZEL: So that aspect seems to
3	cover anything
4	VICE CHAIRMAN WALLIS: And you have added
5	
6	MR. ARCHITZEL: from shock wave versus
7	being due to pressure and it's not really pressure,
8	it's really shock, the way we treat it and the way
9	it's transformed into an equivalent volume sphere
10	throws a tremendous conservatism into
11	VICE CHAIRMAN WALLIS: So the
12	MR. ARCHITZEL: this analysis.
13	VICE CHAIRMAN WALLIS: initial shock
14	wave that no one had analyzed, is that
15	MR. ARCHITZEL: Well, we saw on the shock
16	wave, we saw how it is a near term effect. And it can
17	go far. But basically we've never really resolved
18	whether the damage is caused by shock or caused by the
19	pressure or the mass flow into the damaged targets.
20	But we accept it.
21	VICE CHAIRMAN WALLIS: You have never
22	really resolved those issues? But you've made some
23	judgment about what's an acceptable damage pressure?
24	MR. ARCHITZEL: Yes.
25	MR. LATELLIER: It was never the intent of

1 the staff's experimental programs to develop a first 2 principles model of the damage mechanism. It's based on empirical evidence of damage at given spacial 3 4 locations within the jet as correlated by various 5 metrics that can be modeled. For example, the stagnation pressure or in 6 7 the case of the ANSI model, an impingement pressure that's arrived at by averaging the mass flux on a 8 9 large target. 10 VICE CHAIRMAN WALLIS: Well, again, we 11 don't have time to go into all that. 12 MEMBER RANSOM: Has there ever been any agreement in what they even mean by impingement 13 14 pressure? 15 MR. ARCHITZEL: Well, we heard you. we put some additional words in destruction pressure. 16 17 We're talking the same thing. It's that measured pressure at that face of that --18 19 VICE CHAIRMAN WALLIS: But with the state 20 of the art where you send me letters the night before 21 explaining things better, it seems to me this could 22 happen tomorrow, too, because it's a learning process. 23 And I appreciate that. You're doing a good job there. 24 just wonder if you don't have more 25 things to learn.

1	MR. ARCHITZEL: Well, I'd like to get
2	through this section as quickly
3	VICE CHAIRMAN WALLIS: Okay. I'm sorry,
4	I'm sorry, Ralph. You have to do it.
5	MR. ARCHITZEL: Yes, as I mentioned
6	before, we did use the transformed those freely
7	expanded jets into sphere. And that's a significant
8	conservatism of the approach, equivalent volume
9	spheres.
10	VICE CHAIRMAN WALLIS: Isn't that oh,
11	I'm sorry. Every time you say conservative, I'm going
12	to say what. But I'm sorry. We don't have time.
13	MR. ARCHITZEL: Yes, there could be long
14	distances
15	VICE CHAIRMAN WALLIS: There could be long
16	distance
17	MR. ARCHITZEL: Okay.
18	VICE CHAIRMAN WALLIS: you know, it
19	does
20	MR. ARCHITZEL: Under refinements proposed
21	by industry, I'd like to say that they did offer the
22	direct impingement refinement where the models don't
23	resize the jets. And we're accepting that. So they
24	can use those jets.
25	They used the debris-specific destruction

1	zones, which is probably what most plants will do
2	anyway, as opposed to the lowest damage pressure.
3	They allowed they proposed
4	simplification to an entire compartment. And we're
5	accepting that.
6	The other section we have on debris
7	generation is the characteristics, which have been
8	provided for construction, pressure, density, size,
9	and size distribution.
LO	Next slide please. Regarding the safety
L1	evaluation, we considered the guidance report approach
L2	acceptable. And we have noted some modifications.
L3	VICE CHAIRMAN WALLIS: Now the
L4	presentation that your colleague made where you had a
L5	number that was a tenth of what the Westinghouse men
L6	had, was that based on this 40 percent? Or based on
L7	the NEI guidance before you had modified it?
L8	MR. ARCHITZEL: I think the example we
L9	intended to use was using the destruction pressure
20	that would be six pounds. I don't know how
21	complicated
22	VICE CHAIRMAN WALLIS: Was it with your
23	modification? Or was it the NEI guidance?
24	MR. ARCHITZEL: It should have been the
25	

1	VICE CHAIRMAN WALLIS: Was the ten pounds
2	used or the six pounds?
3	MR. ARCHITZEL: It was just a gross
4	estimate because we got
5	VICE CHAIRMAN WALLIS: A gross estimate
6	really isn't very good on this problem is it?
7	MR. ARCHITZEL: It was the compartment
8	use. What we did was essentially use the compartment
9	model.
10	VICE CHAIRMAN WALLIS: Did you use your
11	modified destruction pressure or the NEI guidance
12	destruction pressure in arriving at 1,720 pounds of
13	cubic feet of debris?
14	MR. LATELLIER: It corresponds roughly to
15	the modified damage pressure.
16	VICE CHAIRMAN WALLIS: Because Mr.
17	Andreychek or whatever, it's garbled in the
18	transcript. And a much bigger zone of influence, you
19	emphasized that if you used your modified 40 percent.
20	That's why I'm bringing it up here.
21	MR. ARCHITZEL: Well, I think if you had
22	an open containment
23	VICE CHAIRMAN WALLIS: You're making the
24	zone of influence bigger with this 40 percent.
25	MR. ARCHITZEL: The 40 percent increases

1	the zone of influence. As the industry pointed out,
2	it can triple it, okay, because
3	VICE CHAIRMAN WALLIS: It can triple it?
4	MR. ARCHITZEL: Triple the zone of
5	influence.
6	VICE CHAIRMAN WALLIS: Triple the zone of
7	influence.
8	MR. ARCHITZEL: Depending on the way
9	you're going through the model. And the reason is
10	VICE CHAIRMAN WALLIS: Is that three times
11	the amount of debris? Or not?
12	MR. ARCHITZEL: It should because those
13	are the assumptions if there's that much when you go
14	out to that additional volume, you're limited by the
15	compartment. That's what I was saying earlier.
16	VICE CHAIRMAN WALLIS: So this factor of
17	three, which could be said to be sort of an
18	uncertainty that's you're compensating for is bigger
19	than these uncertainties about how much stuff gets
20	or about the same as the fraction that gets to the
21	screen of all the debris you created? So
22	MR. ARCHITZEL: Certainly big than the jet
23	well, and some of that can be done away by
24	industry can test for that effect. And they can also
25	get more robust material. Now one

1	VICE CHAIRMAN WALLIS: Well, these factors
2	of three and all that are all right if you're dealing
3	with a problem where you can show that you get 0.1
4	feet of water on the screen. But you've got five feet
5	of water head loss on the screen and it's just about
6	to begin to challenge your NPSH, factors of three
7	begin to make a big difference. I mean it could be 15
8	or it could be two. It makes all the difference in
9	the world to whether or not your pump
10	MR. ARCHITZEL: The input to an analysis
11	the licensees don't
12	VICE CHAIRMAN WALLIS: George was right
13	about uncertainties. Of course, George is right on
14	many things. But he was certainly right to focus on
15	uncertainties in this issue.
16	MEMBER APOSTOLAKIS: I see you are in a
17	good mood today.
18	(Laughter.)
19	MR. ARCHITZEL: Well, one thing we did
20	along those lines will be, as Dr. Apostolakis
21	mentioned, in the Appendix R we offer alternatives
22	like with this non-physical aspect of the NC model it
23	grows unbounded ways as you go to low pressures. We
24	do have a discussion where you can use empirical data

to drop that down. So it's available if industry

1	wants it. But we haven't approved that. It's very
2	conservative.
3	You can increase the destruction pressure
4	the conservatisms harness. There are ways to address
5	that factor of three you can test. So there are
6	things you can do about it. But it's usable now. And
7	well it's approvable, I guess, is the way to put it.
8	I think perhaps I'm done.
9	VICE CHAIRMAN WALLIS: Coatings, coatings,
10	coatings, please.
11	Now you have 10,000 square feet typically
12	of coatings in a plant, several mils thick.
13	MR. ARCHITZEL: I think it's 300,000
14	square feet.
15	VICE CHAIRMAN WALLIS: Three hundred
16	thousand?
17	MR. ARCHITZEL: Somewhere in there.
18	VICE CHAIRMAN WALLIS: Three hundred
19	thousand square feet? Thank you. I thought it was
20	10,000. Where did I get 10,000.
21	MR. ARCHITZEL: I think that was
22	PARTICIPANT: That's the debris.
23	VICE CHAIRMAN WALLIS: That's the ZOI.
24	MR. MURPHY: Excuse me. This is Mark
25	Murphy. Ten thousand square feet was the amount of

1	unqualified coatings that was volunteered by industry.
2	VICE CHAIRMAN WALLIS: So there are
3	300,000 in the plant.
4	MR. MURPHY: That's an approximate number.
5	VICE CHAIRMAN WALLIS: And you're going to
6	have a zone of so you're asking them to increase
7	the zone of influence because of uncertainties to 10D,
8	ten times down to the pipe. That's about as big as
9	the zone of influence for these other destructions,
10	right?
11	MR. ARCHITZEL: Say it's one-fourth the
12	containment of
13	VICE CHAIRMAN WALLIS: Now we're talking
14	about tens of thousands of square foot of coatings
15	which is several mils thick.
16	MS. LAURETTA: This is Angie Lauretta from
17	Plant Systems Branch, NRR. We're not asking them to
18	use the 10D. That is a default value. There is a
19	lack of data in this area.
20	VICE CHAIRMAN WALLIS: That's right. So
21	you're
22	MS. LAURETTA: We have no basis for
23	VICE CHAIRMAN WALLIS: with no basis,
24	they have to use 10D.
25	MS. LAURETTA: No, that is not

1	VICE CHAIRMAN WALLIS: What do
2	MS. LAURETTA: what the SER says.
3	VICE CHAIRMAN WALLIS: they use?
4	MS. LAURETTA: They need to come in with
5	the justification for whatever value they use.
6	VICE CHAIRMAN WALLIS: Oh, I thought you
7	had 10D. Where did 10D go?
8	MS. LAURETTA: That is an option.
9	VICE CHAIRMAN WALLIS: It is a default
10	value. Well, okay. If it's a default value, it's
11	essentially what you would accept. And they have to
12	justify anything else.
13	MS. LAURETTA: That is the only value we
14	have
15	VICE CHAIRMAN WALLIS: Okay, it's the only
16	value I have to go on, too, because I haven't done any
17	calculations, okay? So 10D is a big thing.
18	MS. LAURETTA: That is a
19	VICE CHAIRMAN WALLIS: It's like the
20	MS. LAURETTA: conservative
21	VICE CHAIRMAN WALLIS: zone of
22	influence we saw for the other debris. You've got
23	300,000 square feet of debris, several mils thick. It
24	doesn't take much mass to show that you can build up
25	a thin bed on almost anything, any size screen out

1	there.
2	Coatings I understand you're asking them
3	to assume are broken up to the grain size of the
4	individual stuff that went into the paint.
5	MR. ARCHITZEL: Actually I'd like to
6	correct that.
7	VICE CHAIRMAN WALLIS: They're very small.
8	MR. ARCHITZEL: We're not asking that at
9	all or proposed that.
10	VICE CHAIRMAN WALLIS: Where did that come
11	from?
12	MR. ARCHITZEL: And we're accepting that.
13	VICE CHAIRMAN WALLIS: Oh, you're
14	accepting that? Okay, we'll accepting or asking for,
15	it's the same thing to me.
16	MR. ARCHITZEL: Well, we might ask for
17	something different. And we could have a distribution
18	that was used.
19	VICE CHAIRMAN WALLIS: Well, don't
20	prevaricate on me. I'm sorry.
21	MR. ARCHITZEL: Okay.
22	VICE CHAIRMAN WALLIS: But look, you've
23	got 300,000, you've got 10,000, you've got very simple
24	math to show that if there is a thin bed of this
25	stuff, which is fine particulate, you're going to have

1	trouble.
2	And your decision to say you've now got to
3	use 10D or something like that rather than the 1,000
4	psi which they recommended has a profound effect on
5	this problem, this part of the problem. And there
6	seems to be no basis of understanding about what
7	coatings do to put filtration in on the bed.
8	So you're taking, well, I know Petrangelo
9	said that it's a big step into the dark in another
LO	context but this seems to be like another one of
L1	those, isn't it? I'm trying to help you to clarify
L2	where you are. I'm not trying to criticize you guys.
L3	I just want to bring out where I think you
L4	are in this problem.
L5	MR. ARCHITZEL: I believe the staff does
L6	recognize that there is data here we simply don't
L7	we don't have a defensible basis for either 1,000 psi
L8	damage pressure or a 10 psi damage pressure.
L9	I think it's rather misleading for the
20	industry to say that the staff has increased the size
21	by three orders of magnitude when, in fact, it should
22	be 100 percent based on the knowledge we have today.
23	VICE CHAIRMAN WALLIS: We should assume
24	all the coatings go to the screen?

MR. LATELLIER: There is no evidence to

1	support otherwise. That's why the staff is not
2	VICE CHAIRMAN WALLIS: Well, why does the
3	
4	MR. LATELLIER: endorsing
5	VICE CHAIRMAN WALLIS: staff not
6	MR. LATELLIER: the
7	VICE CHAIRMAN WALLIS: say that?
8	MR. LATELLIER: 1,000 psi damage
9	contour.
10	VICE CHAIRMAN WALLIS: Well, why does the
11	staff not then say that we're going to be conservative
12	since we know nothing and it all goes to the screen.
13	MR. ARCHITZEL: I'd like to correct that.
14	I mean we have a tremendously conservative alternate
15	position so we're not
16	VICE CHAIRMAN WALLIS: What can be more
17	conservative
18	MR. ARCHITZEL: going to
19	VICE CHAIRMAN WALLIS: than saying they
20	
21	MR. ARCHITZEL: it's not like steam
22	blowing breaks have not never happened in plants.
23	They've had steam blowing, they've had water breaks,
24	we know that all the coatings don't come off.
25	VICE CHAIRMAN WALLIS: But he just said

1 MR. ARCHITZEL: So we're not going to --2 VICE CHAIRMAN WALLIS: -- said you should 3 assume that it all comes off because we don't know 4 enough. 5 MR. ARCHITZEL: I'm not agreeing with We have some --6 that. 7 VICE CHAIRMAN WALLIS: You see but okay -so we've now established that there is internal debate 8 9 among the staff and its consultants about what they 10 know about these problems. Have we not? You disagree 11 with him. 12 MR. ARCHITZEL: Angie was the reviewer in Let me back out of it, okay. 13 14 Lauretta. 15 MS. LAURETTA: This is Angie Lauretta. are very much aware that there is a lack of data in 16 17 That is why in the SER we have asked that this area. licensees come in with justified values based on 18 19 experimental data or have provided a default value. 20 That is the only value we are able to justify 21 proposing. There --22 VICE CHAIRMAN WALLIS: So let me put that 23 in perspective. You guys do this on so many things. 24 You put it on the licensees. Now is each individual 25 licensee going to develop a technical base which is

1	bigger than you folks have with your consultants?
2	Each one of them? Or is it going to be some industry
3	consortium that's going to establish all these
4	knowledge bases which you don't have?
5	MS. LAURETTA: It's our responsibility to
6	review the guidance that was proposed by the industry.
7	It is our expectation that when they come in with a
8	proposal that they are able to justify what they
9	proposed.
10	VICE CHAIRMAN WALLIS: But if you I'm
11	sorry
12	MS. LAURETTA: We were not able to do that
13	in this
14	VICE CHAIRMAN WALLIS: but if you know
15	
16	MS. LAURETTA: case.
17	VICE CHAIRMAN WALLIS: nothing about
18	it, how can you evaluate what they propose?
19	MS. LAURETTA: They don't know anything
20	about it either.
21	VICE CHAIRMAN WALLIS: Well, that is a
22	very profound statement. Thank you.
23	(Laughter.)
24	MR. ARCHITZEL: I think with the time
25	we've argued about this, the next topic

1	PARTICIPANT: Let's move on.
2	MR. ARCHITZEL: I'd like to at this
3	point, generally we accepted the characteristics of
4	debris that's in the guidance report. There were some
5	modifications of particulates. And then as far as the
6	ACRS questions, I think I've already talked about the
7	we've revised we visited the destruction
8	pressure definition. We've changed this. Dr. Wallis
9	noticed Appendix I with its additional explanations.
10	VICE CHAIRMAN WALLIS: Is it going to
11	change tomorrow night?
12	MR. ARCHITZEL: We're done changing
13	Appendix I. We got them all unless we get additional
14	comments.
15	We may do a clean up on the definition of
16	destruction pressures through the document because
17	that was the point you made. But it's not going to be
18	anything other than editorial clean up on that
19	additional cleanup.
20	On the paint chip size, that was a
21	question that was raised by the ACRS for the no thin
22	bed analysis. We decided that we placed a
23	requirement that the paint chip size should be the
24	size of the screen openings. And that's what is in
25	the SE right now for that situation.

1	VICE CHAIRMAN WALLIS: That's bad. And
2	you're assuming that paint chips come which could
3	actually cover the screen?
4	MR. ARCHITZEL: We haven't done a
5	VICE CHAIRMAN WALLIS: That's like leaves
6	on the drain in a street?
7	MR. ARCHITZEL: No, actually what we have
8	we had that discussion
9	VICE CHAIRMAN WALLIS: Is that an analogy
10	of paint chips on this screen are like leaves
11	MR. ARCHITZEL: if you did it that way
12	and you
13	VICE CHAIRMAN WALLIS: like leaves on
14	a drain in the street, you've seen what they do to a
15	drain on the street?
16	MR. ARCHITZEL: Right, the point is
17	VICE CHAIRMAN WALLIS: The drain has bars
18	like a screen and a few leaves have to be dug off by
19	somebody coming by.
20	MR. ARCHITZEL: There's two ways to look
21	at it. Either you could look at it as a surface
22	coverage-type effect like the latent debris and the
23	placards. Or you could look at it like a correlation
24	problem.
25	We have been actively revising the

1 treatment in the SE to say with paint chips under this 2 condition, you could look at transport. 3 heavy. They don't necessarily transport. It's not in 4 the version you saw last time. 5 So we're trying to be practical because if we did take your approach, you're right with 100,000 6 7 square feet -- licensees aren't going to build 100,000 8 foot screens but then you can say how does it 9 transport? How is the head loss? You have to do an intelligent look at the head loss associated with 10 11 paint chips which isn't a coverage thing. It's more 12 how does it build up, it's own particulate. There is a need to examine that. 13 14 And I guess that's end of my part of the 15 presentation. 16 VICE CHAIRMAN WALLIS: All right. 17 you very much, Ralph. MS. LAURETTA: I'd like to add something. 18 19 I'd like to add that the reason we have decided to go 20 forward with this is because the 10D we have proposed 21 is something we have confidence in as a conservative 22 default. That's what --23 VICE CHAIRMAN WALLIS: Why do you have 24 confidence --25 MS. LAURETTA: -- enables us --

1	VICE CHAIRMAN WALLIS: why do you have
2	confidence in it as a conservative default. Why isn't
3	it 20D? Or 50? Or 100? Or 9.6?
4	MS. LAURETTA: Precedent.
5	VICE CHAIRMAN WALLIS: Possible?
6	MS. LAURETTA: Precedent.
7	VICE CHAIRMAN WALLIS: Precedent? You
8	mean you've made this
9	MS. LAURETTA: Well, it was done
10	VICE CHAIRMAN WALLIS: guess before?
11	MS. LAURETTA: The staff has established
12	the position with the BWRs and we are standing behind
13	what was done
14	VICE CHAIRMAN WALLIS: And do you know
15	MS. LAURETTA: and accepted
16	VICE CHAIRMAN WALLIS: what the basis
17	of that decision was? Why do you have this supreme
18	confidence that it is conservative?
19	MR. LATELLIER: If I can address some of
20	the history, I believe that the industry was very
21	proactive in offering the pressure wash data that they
22	have provided in Appendix A of the GR. This was a
23	high-pressure impingement environment unfortunately
24	that did not address relevant temperature ranges.
25	And there is a continuing debate about the

1 effect of both temperature and rapid temperature transients on the effects of coating and possible 2 3 delamination. For that reason, the staff is not 4 comfortable in endorsing the 1,000 psi damage contour 5 proposed by the industry. considered 6 However, we have t.hat. 7 information as approaching the relevant conditions that we're interested in. And we don't want to be --8 9 to impose an undue penalty by assuming 100 percent 10 failure. 11 However, we are also recognizing that 12 there is very little data to provide a defensible basis for either side of this issue. And essentially 13 14 we are asking for that information to be provided 15 either by individual licensees or by an industry 16 consortium, which has been the typical mode of 17 practice in the past. 18 VICE CHAIRMAN WALLIS: Now, Bruce, you're 19 almost writing my review for me. You've said there's 20 very little data to provide a defensible basis. 21 tending to reach that feeling myself. 22 You would simply be MR. LATELLIER: 23 emphasizing our concerns. 24 VICE CHAIRMAN WALLIS: But when you say

that and someone else says we're sure something is

1	conservative, I don't understand the logic.
2	MR. LATELLIER: As I've said, we've tried
3	to give due consideration to the information that has
4	been provided. That the pressure regimes are
5	relevant, the temperatures are not.
6	VICE CHAIRMAN WALLIS: I understand you're
7	doing the best you can with what you have. And that's
8	very appropriate. There's got to be a logical thread
9	in the argument if you just follow this by a layperson
LO	and someone who isn't as knowledgeable about it as you
L1	are.
L2	MR. MURPHY: This is Martin Murphy. I
L3	also want to point out that qualified coatings are
L4	tested at pressures and temperatures. And, therefore,
L5	it does give us confidence that coatings outside the
L6	zone of influence will be able to stay adhered in the
L7	event of an accident.
L8	VICE CHAIRMAN WALLIS: These are the
L9	qualified coatings which have been inspected and all
20	that sort of thing?
21	MR. MURPHY: That's correct.
22	VICE CHAIRMAN WALLIS: Okay. Let's move
23	on.
24	MR. WAGAGE: Good morning. My name is
25	Hanry Wagage. I'm going to present to you the staff

1 evaluation of debris transport section of the 2 quidance. 3 I recognize that we are pressed for time. 4 I'll quickly go through the presentation unless you 5 have questions. VICE Well, 6 CHAIRMAN WALLIS: this 7 conservative -- here we've got the word conservative 8 again. And I see 60 percent here, 15 percent there, 9 70 percent there. Is 10 MR. WAGAGE: I will --11 VICE CHAIRMAN WALLIS: -- this someone's 12 feeling that they are conservative values? Or are they -- again, Bruce said there's some sort of basis. 13 14 So I guess I'll leave it alone. Let's go on. 15 If I answer that question, MR. WAGAGE: what we did was to use the baseline quidance and 16 detailed analysis to calculate for the volunteer 17 Then we compared the results and then we 18 plant. 19 decided by going through detailed analyses this --20 VICE CHAIRMAN WALLIS: It seems to me that 21 the staff and its management should get together and 22 rigorously say what steps we're going to go through in 23 order to make the statement that something is or is 24 not conservative because this word is used so loosely

that I don't know what you mean. Maybe you do but --

1	MR. WAGAGE: What I mean by conservative
2	is that it gives a worse condition than the realistic
3	conditions.
4	VICE CHAIRMAN WALLIS: The worst? Worse
5	than what's realistic? Well, let's go
6	MR. WAGAGE: Realistic.
7	VICE CHAIRMAN WALLIS: on. I just made
8	my statement. Let's move on.
9	CHAIRMAN BONACA: This is for the baseline
10	calculation.
11	MR. WAGAGE: Yes. For the these are
12	the key points of the baseline guidance
13	CHAIRMAN BONACA: Yes, I understand.
14	VICE CHAIRMAN WALLIS: on debris
15	transport. This methodology is based on NUREG/CR-6762
16	log tree. The objective of this methodology is to
17	calculate the conservative higher mass of debris going
18	onto the sump screen.
19	We discuss different transport mechanisms
20	given the presentations before. It's important to
21	remember that baseline guidance assume only small fine
22	debris would transport onto the sump screen. Large
23	debris would stop by grading, radiological sensors,
24	and trash facts.
25	In sort of going through our detailed

1	analysis to get the final number, the baseline
2	guidance uses conservative fractions to quantify the
3	logic tree. These guidance are the two analytical
4	refinements brought through on pool debris transport.
5	They were
6	VICE CHAIRMAN WALLIS: Could we just move
7	on to the end of this. I mean you've said they're
8	conservative. You did actually modify their guidance
9	by having this 15 percent value? You only allowed
LO	them to hang out 15 percent in the pools, the remote
L1	pools or something? Why did you do that?
L2	MR. WAGAGE: Yes, that comes in the next
L3	slide under limitations, you've got the
L4	VICE CHAIRMAN WALLIS: Well, maybe that's
L5	what we need to discuss
L6	MR. WAGAGE: yes
L7	VICE CHAIRMAN WALLIS: otherwise we
L8	don't need to spend much time on this?
L9	MR. WAGAGE: Yes, actually we're talking
20	about the relocation into
21	VICE CHAIRMAN WALLIS: Your limitations.
22	MR. WAGAGE: inactive pools. The
23	baseline guidance assumed that the fraction of debris
24	moving into inactive pools is the fact on fraction of
25	inactive pools and the total sump pool. Inactive

1	pool, for example, is reactor cavity when water is
2	stagnant, which would not participate
3	VICE CHAIRMAN WALLIS: Debris gets in
4	MR. WAGAGE: and it would not come onto
5	the sump screen.
6	VICE CHAIRMAN WALLIS: That's what you
7	need is lots of inactive pools.
8	MR. WAGAGE: Yes, it's good but beside
9	it's very hard to base our analysis
10	VICE CHAIRMAN WALLIS: If you could divert
11	the debris to the inactive pools, you'd be in great
12	shape wouldn't you?
13	MR. WAGAGE: That's true, yes.
14	VICE CHAIRMAN WALLIS: And yet you're only
15	giving them 15 percent credit so there seems to be a
16	chance here to do something?
17	MR. WAGAGE: The reason of giving 15
18	percent limit is that this assumption of one fraction
19	is equal to the amount of debris moving to the
20	inactive pools has other assumptions in all, that the
21	debris is uniformly mixed with water. But that
22	doesn't ever happen.
23	So we wanted to limit that to 15 percent.
24	However, we let licensees come up with analysis
25	VICE CHAIRMAN WALLIS: What's the basis of

your 15 percent? Why wasn't it 25 or seven or zero?
MR. WAGAGE: We did the debris transport
for the volunteer plant.
VICE CHAIRMAN WALLIS: You ran the
computer program or something? And you said that in
the end with some sort of uncertainties statistically
you got 15 percent? Or you ran some sort of logical
MR. WAGAGE: Let me just finish
VICE CHAIRMAN WALLIS: validation of
this 15 percent or did it come from somewhere?
MR. WAGAGE: Let me first tell you what we
did. What we did was
VICE CHAIRMAN WALLIS: Did it come from
somewhere? Just tell me in about six sentences the
basis of the 15 percent that's believable.
MR. WAGAGE: The basis of the 15 percent
is the analysis we did for the volunteer plant using
the detailed analysis and the baseline guidance. The
the detailed analysis and the baseline guidance. The baseline guidance gave 14 percent for the volunteer
baseline guidance gave 14 percent for the volunteer
baseline guidance gave 14 percent for the volunteer plant and we came up for the volunteer plant, it's
baseline guidance gave 14 percent for the volunteer plant and we came up for the volunteer plant, it's close to 15 percent. We gave a round number of 15

1 VICE CHAIRMAN WALLIS: You had to come up with some number? 2 MR. WAGAGE: Some number we can base on --3 4 VICE CHAIRMAN WALLIS: That's why you --5 MR. WAGAGE: -- our basis is the volunteer plant analysis. 6 7 MR. SCHAFFER: Dr. Wallis, this is Clint Schaffer of Terry Corporation. I did a lot of the 8 transport analysis for the volunteer plant. 9 10 And our biggest concern with that model 11 that's in the NEI quidance was that it's not based 12 upon real physics. And we also don't have a survey on how big the inactive pools could be for the fleet of 13 14 plants out there. 15 So our only way of judging this was to evaluate the volunteer plant in detail, apply the 16 17 baseline guidance to that plant, and compare then side by side. In doing so, it was found that if we had a 18 19 15 percent inactive pool, that was okay for this one 20 plant. We were concerned about where to put the 21 22 limit so we just based it on that gauge. Fifteen 23 percent was okay for the one plant analyzed in detail. 24 And I think we have wording that says if 25 they can justify more, then let them do so. But we

1 had to cap it. CHAIRMAN BONACA: Wouldn't that number --2 3 let me finish -- the number depend on the relative 4 position of the breaks to the screen to the sump? 5 MR. SCHAFFER: It depends on a lot of all, it depends the 6 factors. First οf 7 compartmentalization around the break itself. Obviously if it's highly compartmentalized, you might 8 keep a lot of debris right there in the break zone. 9 Also a lot of the debris gets blown into 10 11 the upper reaches, which comes down at a later time. 12 The big concern is that the inactive pool might already be filled by the time a lot of the 13 14 debris comes to the sump pool. There are so many 15 factors involved. MEMBER ROSEN: Well, how did you deal with 16 17 the fact that the volunteer plant may, in fact, have better hold up of inactive pools then all the other 18 19 plants or many other plants? It seems to me that it 20 could be next to no hold up in some plants. 21 MR. SCHAFFER: Well, in the volunteer 22 plant, the analysis illustrated something like three 23 percent of the fibrous debris made it into the 24 inactive pool. And when it applied to baseline, there

was 14 percent.

1 So the baseline highly over-estimated the 2 inactive pool fraction here but see there's other places in the models where the NEI guidance is over-3 4 conservative. So we're actually trying to balance 5 over and under conservatisms of which you can't really quantify. 6 7 But here is one case where we could 8 quantify it as a package. Well, that's just mumbo-9 MEMBER ROSEN: jumbo to me. The idea that the volunteer plant could 10 11 demonstrate about 15 percent if good. And that's one 12 stake in the ground. But it's only a stake in the ground for that plant. And going back to saying well, 13 14 you know, there's a lot of conservatism in this 15 analysis, so some plant that really only can hold up three percent if going to have to deal with the 16 17 requisite amount of debris anyway really doesn't give me a lot of comfort. 18 19 MR. LATELLIER: Dr. Rosen, this is Bruce 20 Latellier. There is one important attribute of the 21 volunteer plant that needs to be understood. 22 This particular plant has an elevated 23 steam compartment cavity so that the sump pool is not 24 actually able to fill a significant fraction of the

It has an annular pool only.

sump.

1 Whereas most plants, the sump pool is on 2 the same level, the same elevation as the steam Therefore, the level of 3 generator compartments. 4 turbulence in this annular pool is much higher than 5 you might expect for other cases. And that gave us some confidence that our 6 7 residual hold up fraction was bounding. 8 MEMBER ROSEN: Well, that's helpful. 9 MR. LATELLIER: It was appropriately low. 10 MR. WAGAGE: During our presentation to 11 the ACRS subcommittee on thermal hydraulics two weeks 12 ago, we had a question on debris moving into the upper containment. The subcommittee asked justification for 13 14 fraction of debris moving into the 15 containment. The justification was that when they did 16 detailed analysis for the volunteer plant, it had less 17 -- it had significantly higher amount of debris moving 18 19 into the upper containment. The reason is that once 20 the debris moving into the upper containment, part of 21 that would not end up on the sump screen. 22 So based on our volunteer plant analysis, we accept that fraction of debris moving into the 23 24 upper containment in the baseline. 25 Thank you.

1 VICE CHAIRMAN WALLIS: Ι'm Now, 2 trying to see how we're pacing the presentation here. 3 We have some details on head loss and we have some 4 details on downstream effects, alternate evaluation. 5 And then there's going to be some wrap up from the Is that you total presentation? Or is there 6 7 another --8 MEMBER SIEBER: You have to do that all in three minutes. 9 10 PARTICIPANT: That's it. 11 VICE CHAIRMAN WALLIS: Okay, thank you. 12 This is Shanlai Lu from Plant MR. LU: I'm going to cover the SUS actions, head 13 14 loss section. It is an important section because this 15 issue comes from the head loss and we're hope we're ending at the head loss section because what's 16 automated design available, what's the exact head loss 17 if the plant makes the modification? 18 19 The question here is how you are going to 20 calculate the head loss across the screen with a given 21 debris bed. And ACRS questioned the NEI document and 22 the SER in terms of the user of NUREG/CR-6224. 23 especially last time, the industry asked a very simple 24 question. NUREG/CR-6224 correlation 25 And is am

empirical correlation. It has been validated against
test data. The temperature range for the test data is
between 60 to 125. Can the industry use it beyond
125? So that's one of the issues major issues
right now we're trying to address.
And the staff did a lot of analysis during
the past two weeks. We're trying to address this
issue. And the research and Bill Krotiuk did a lot of
work to just come up with the basis.
At this point, the staff is comfortable to
expand the application range of the temperature in
terms of temperature
VICE CHAIRMAN WALLIS: You have done more
experiments in the last week?
MR. LU: No, analysis.
VICE CHAIRMAN WALLIS: Why did you extend
the range to 220 when
MR. LU: Okay, that's one thing we are
trying to explain that to you. And I don't know
whether we can do it within three minutes.
VICE CHAIRMAN WALLIS: You did not do any
more experiments?
MR. LU: No.
VICE CHAIRMAN WALLIS: And yet you
extended a data range?

1 MR. LU: Correct. 2 VICE CHAIRMAN WALLIS: How did you do 3 that? 4 MR. LU: Correct. The data in question, 5 everybody believes that for the empirical correlation, you always have to stay within the test data range. 6 7 That was our position before. And then, of course, if you stay within 125 degree, you cannot make it. 8 9 Nobody can really use it. 10 Based on Tom Hafera's presentation, you 11 can see at least the 187 core temperature. So how can 12 you apply this correlation? If it cannot be applied any methodology? And the answer is no at this point, 13 14 okay? 15 So what we did, we just did -- Research did a sensitivity study trying to identify -- learning 16 17 what's the physical phenomenon which would stop us from using this correlation beyond 125 degree. 18 when we found the limiting physical phenomenon 19 actually is the air bubble formation seen --20 21 VICE CHAIRMAN WALLIS: Now wait a minute, 22 this is a new phenomenon that's never been studied 23 before. As I understand it, you get an anomalous 24 behavior of calcium silicate in one test at Los Alamos

at this temperature of 125. You don't know why it

1	happens. It may be due to some kind of rearrangement
2	of the particles or some kind of way in which they
3	interact. Who knows?
4	And you're going to extend that to 220
5	with out understanding what's going on? Are you going
6	to say it's due to air bubble formation which is a new
7	hypothesis?
8	MR. LU: Yes, that's right, that's the
9	physical yes.
10	VICE CHAIRMAN WALLIS: Am I
11	MR. KROTIUK: Dr. Wallis may I just
12	a moment please.
13	My name is Bill Krotiuk. I'm with the
14	Office of Research. What I did is that I looked at
15	made an assumption that the water upstream of the
16	screen was completely saturated with dissolved air.
17	And then using and the amount of that dissolved air
18	was basically came out of test data that was run
19	around 1975.
20	And as a result with the pressure drop
21	through the screen, there were two considerations.
22	One is that the pressure downstream of the screen had
23	to remain above the saturation temperature of the
24	water in the pool to prevent flashing
25	VICE CHAIRMAN WALLIS: To prevent loss of

1	NPSH for one thing.
2	MR. KROTIUK: Right, yes. And then the
3	second thing was to the assumption was made that
4	when you drop that pressure, that the amount of air
5	that was dissolved would come out of solution and form
6	a void. So that was the second criteria.
7	And the criteria was that the void
8	fraction on the downstream side of the screen had to
9	remain lower than three percent
10	VICE CHAIRMAN WALLIS: But Bill, Bill, I
11	think you've done a great job. But does it have to do
12	with the correlation, which for flow through of a bed.
13	MR. KROTIUK: Right.
14	VICE CHAIRMAN WALLIS: I mean bubbles come
15	out. That's a different phenomenon. Bubbles came out
16	in the Los Alamos tests. There were a whole lot of
17	bubbles dancing
18	MR. KROTIUK: That'S correct.
19	VICE CHAIRMAN WALLIS: underneath the
20	bed in their tests. You already have bubbles. That
21	was never analyzed by them as causing any effect
22	whatsoever.
23	MR. KROTIUK: Right.
24	VICE CHAIRMAN WALLIS: And the NUREG
25	correlation doesn't say anything about bubbles. I

1	don't want to cut you off but I don't see the
2	relevance in the production of bubbles.
3	MR. KROTIUK: Could I make one other
4	comment is that additionally I looked at the effect
5	of the properties of the water, meaning the viscosity
6	plus the density. And what happens as you increase
7	temperature, the viscosity reduces.
8	And it actually, the correlation then, you
9	know, it's directly proportional to viscosities, so
10	the pressure drop would actually decrease. So that's
11	the other consideration.
12	MEMBER SHACK: Did you do any calculations
13	to match against an observable temperature dependence
14	over the range for which you do have data?
15	MR. KROTIUK: Yes.
16	MEMBER SHACK: And your calculations
17	predict that dependence?
18	MR. KROTIUK: Yes basically yes.
19	MR. LU: Yes, I'm going to show you plot
20	here.
21	VICE CHAIRMAN WALLIS: And I thought there
22	was an uncertainty. The cal-sil specific area had to
23	be adjusted for each data point.
24	MR. LU: That's really what we need. If
25	it's within three percent, we can tolerate that. But

1	if it's beyond that
2	VICE CHAIRMAN WALLIS: I don't understand
3	what you're doing here. You're trying to claim that
4	you've extended the database. You have not. You have
5	extrapolated it to 220.
6	MR. LU: We can extend the application
7	range of the
8	VICE CHAIRMAN WALLIS: You've extrapolated
9	
LO	MR. LU: Extrapolated.
L1	VICE CHAIRMAN WALLIS: using
L2	assumptions.
L3	MR. LU: That's right, based on analysis.
L4	VICE CHAIRMAN WALLIS: You extrapolated an
L5	extraordinarily database.
L6	MR. LU: In terms of coming out of the
L7	water, there's actually a lot of data there.
L8	MEMBER ROSEN: What is the need for doing
L9	all this? It seems to me we're just talking about a
20	high temperature test.
21	MR. LU: Yes.
22	MEMBER ROSEN: Well, that's not beyond the
23	state of the art.
24	MR. LU: Yes, you are correct because the
25	major issue right now is first, of course, the

1	viscosity. But the viscosity drops if you have higher
2	temperature. And so that if you do drop and so the
3	test was what's the upper limit.
4	MEMBER ROSEN: Why don't you just do this
5	in a loop with a higher temperature? And stop all
6	this calculation.
7	MR. LU: And if we knew that it would
8	drop, if it remains in a single phase, we don't need
9	it to. Why? Why do we need to run a test if we know
10	what the outcome would be?
11	MEMBER ROSEN: Because a lot of people
12	don't believe that the way
13	MR. LU: They don't believe they need to
14	understand as why viscosity drops the temperature goes
15	higher.
16	MEMBER ROSEN: I think we understand that.
17	MR. LATELLIER: If I could add one
18	clarification. There are two important issues here
19	when we talk about the possible effects of
20	temperature. One, which the staff has focused on
21	recently, is simply the behavior of water properties
22	and its association with head loss. Those phenomenon
23	is an explicit part of the development of the
24	correlation.
25	The other aspects, which I believe Dr.

1 Wallis is focusing on, have to do with changes in the 2 bed morphology, how is it packed, how does it respond 3 to long-term immersion. There are a number of issues 4 that may be important. 5 We have tried to test to look for those effects in Nukon fiberglass beds. 6 And we have not 7 observed them over the limited test range 8 admittedly limited test range that we have. 9 Those effects largely fall into the 10 category of similar to those insulation types that 11 have not been tested. There are simply some 12 configurations that we don't -- have not fully investigated. And that will always be true. But I'd 13 14 like to keep those distinctions in mind. 15 VICE CHAIRMAN WALLIS: Well, I think -- I like what you say, Bruce, it's always very helpful. 16 17 But what I'm hearing from this presentation seems to be extraordinary. 18 19 You have -- if you look at the tests, some of these numbers like this 880,000 three to the minus 20 21 one is based on one data point of one test at one flow 22 rate with one composition of the bed and one thickness 23 at one temperature. You're going to extrapolate that 24 to something?

That's right. Right now we're

MR. LU:

1	trying to extrapolate just the temperature.
2	VICE CHAIRMAN WALLIS: I don't think you
3	want to dig the hole any deeper. I mean do you want
4	to go on with this presentation?
5	MR. LU: Okay, well, I think we have the
6	basis to why we can extrapolate the application range
7	of the correlation beyond 125. But at this point, the
8	calculation we can provide it to you.
9	The next item, and I understand it's also
LO	one of the major items the subcommittee raised is
L1	about a thin bed effect and also during the
L2	subcommittee presentation and Dr. Wallis you asked for
L3	at least one page of description, a physical
L4	description.
L5	VICE CHAIRMAN WALLIS: I was very happy to
L6	see a description in Appendix E, I think it is.
L7	MR. LU: Yes, that's
L8	VICE CHAIRMAN WALLIS: A boxed in
L9	description of
20	MR. LU: Exactly, that's what Clint
21	Schaffer did during the past two weeks with the staff
22	together. And they did Appendix
23	VICE CHAIRMAN WALLIS: I would say that
24	the cause is not yet known. It's hypothetical. But
25	it has been observed that a thin layer of a few mils

1	or less than a millimeter of particles, not a fibrous
2	bed, it's really the particulates the key thing,
3	causes a high head loss. You don't quite know why.
4	MR. LU: Okay.
5	VICE CHAIRMAN WALLIS: That is the
6	MR. LU: There is one thing I want to just
7	explain
8	VICE CHAIRMAN WALLIS: And this thin layer
9	can be any anywhere in the bed.
10	MR. LU: Yes.
11	VICE CHAIRMAN WALLIS: And there's nothing
12	magical about an eighth of an inch of fiberglass.
13	MR. LU: Right.
14	VICE CHAIRMAN WALLIS: There's nothing
15	magical about, you know, it being particularly thin
16	bed. It's just that a small amount of particulates,
17	if it gets together
18	MR. LU: Right.
19	VICE CHAIRMAN WALLIS: like the mud on
20	the beaver dam, can stop water going through.
21	MR. LU: Okay.
22	VICE CHAIRMAN WALLIS: Like the clay on
23	the
24	MEMBER SIEBER: You need some fibers.
25	MR. LU: You need the fiber to sustain.

MR. LU: To support.  MEMBER SIEBER: You need the fibers to start it.  VICE CHAIRMAN WALLIS: But there is fiber in cal-sil and cal-sil beds have been  MR. LATELLIER: Yes, cal-sil has its own fiber. That's the reason.  VICE CHAIRMAN WALLIS: And there's fibers in the debris on the floor of the plant and  MR. LU: That's right. So to form a thin bed, you have to at least have two parameters there. You have to have a particulate and you have the fiber.  VICE CHAIRMAN WALLIS: You have them there all the time in any plant.  MEMBER SIEBER: Yes.  MR. LU: That's right. But you may not have  VICE CHAIRMAN WALLIS: If you vacuum the floor and take out this and take out that  MR. LU: Right.  VICE CHAIRMAN WALLIS: You might not have them any more.  MR. LU: That's right. That's the reason	1	VICE CHAIRMAN WALLIS: That's really the
MR. LU: To support.  MEMBER SIEBER: You need the fibers to start it.  VICE CHAIRMAN WALLIS: But there is fiber in cal-sil and cal-sil beds have been  MR. LATELLIER: Yes, cal-sil has its own fiber. That's the reason.  VICE CHAIRMAN WALLIS: And there's fibers in the debris on the floor of the plant and  MR. LU: That's right. So to form a thin bed, you have to at least have two parameters there.  You have to have a particulate and you have the fiber.  VICE CHAIRMAN WALLIS: You have them there all the time in any plant.  MEMBER SIEBER: Yes.  MR. LU: That's right. But you may not have  VICE CHAIRMAN WALLIS: If you vacuum the floor and take out this and take out that  MR. LU: Right.  VICE CHAIRMAN WALLIS: You might not have them any more.		
MEMBER SIEBER: You need the fibers to start it.  VICE CHAIRMAN WALLIS: But there is fiber in cal-sil and cal-sil beds have been  MR. LATELLIER: Yes, cal-sil has its own fiber. That's the reason.  VICE CHAIRMAN WALLIS: And there's fibers in the debris on the floor of the plant and  MR. LU: That's right. So to form a thin bed, you have to at least have two parameters there. You have to have a particulate and you have the fiber.  VICE CHAIRMAN WALLIS: You have them there all the time in any plant.  MEMBER SIEBER: Yes.  MR. LU: That's right. But you may not have  VICE CHAIRMAN WALLIS: If you vacuum the floor and take out this and take out that  MR. LU: Right.  VICE CHAIRMAN WALLIS: You might not have them any more.		MP III: To support
start it.  VICE CHAIRMAN WALLIS: But there is fiber in cal-sil and cal-sil beds have been  MR. LATELLIER: Yes, cal-sil has its own fiber. That's the reason.  VICE CHAIRMAN WALLIS: And there's fibers in the debris on the floor of the plant and  MR. LU: That's right. So to form a thin bed, you have to at least have two parameters there.  You have to have a particulate and you have the fiber.  VICE CHAIRMAN WALLIS: You have them there all the time in any plant.  MEMBER SIEBER: Yes.  MR. LU: That's right. But you may not have  VICE CHAIRMAN WALLIS: If you vacuum the floor and take out this and take out that  MR. LU: Right.  VICE CHAIRMAN WALLIS: You might not have them any more.		
of vice Chairman Wallis: But there is fiber in cal-sil and cal-sil beds have been  MR. LATELLIER: Yes, cal-sil has its own fiber. That's the reason.  Vice Chairman Wallis: And there's fibers in the debris on the floor of the plant and  MR. LU: That's right. So to form a thin bed, you have to at least have two parameters there. You have to have a particulate and you have the fiber.  Vice Chairman Wallis: You have them there all the time in any plant.  MEMBER SIEBER: Yes.  MR. LU: That's right. But you may not have  Vice Chairman Wallis: If you vacuum the floor and take out this and take out that  MR. LU: Right.  VICE CHAIRMAN WALLIS: You might not have them any more.		
in cal-sil and cal-sil beds have been  MR. LATELLIER: Yes, cal-sil has its own fiber. That's the reason.  VICE CHAIRMAN WALLIS: And there's fibers in the debris on the floor of the plant and  MR. LU: That's right. So to form a thin bed, you have to at least have two parameters there. You have to have a particulate and you have the fiber.  VICE CHAIRMAN WALLIS: You have them there all the time in any plant.  MEMBER SIEBER: Yes.  MR. LU: That's right. But you may not have  VICE CHAIRMAN WALLIS: If you vacuum the floor and take out this and take out that  MR. LU: Right.  VICE CHAIRMAN WALLIS: You might not have them any more.		
MR. LATELLIER: Yes, cal-sil has its own fiber. That's the reason.  VICE CHAIRMAN WALLIS: And there's fibers in the debris on the floor of the plant and  MR. LU: That's right. So to form a thin bed, you have to at least have two parameters there. You have to have a particulate and you have the fiber.  VICE CHAIRMAN WALLIS: You have them there all the time in any plant.  MEMBER SIEBER: Yes.  MR. LU: That's right. But you may not have  VICE CHAIRMAN WALLIS: If you vacuum the floor and take out this and take out that  MR. LU: Right.  VICE CHAIRMAN WALLIS: You might not have them any more.	6	VICE CHAIRMAN WALLIS: But there is fiber
9 fiber. That's the reason.  10 VICE CHAIRMAN WALLIS: And there's fibers  11 in the debris on the floor of the plant and  12 MR. LU: That's right. So to form a thin  13 bed, you have to at least have two parameters there.  14 You have to have a particulate and you have the fiber.  15 VICE CHAIRMAN WALLIS: You have them there  16 all the time in any plant.  17 MEMBER SIEBER: Yes.  18 MR. LU: That's right. But you may not  19 have  20 VICE CHAIRMAN WALLIS: If you vacuum the  21 floor and take out this and take out that  22 MR. LU: Right.  23 VICE CHAIRMAN WALLIS: You might not have  24 them any more.	7	in cal-sil and cal-sil beds have been
in the debris on the floor of the plant and  MR. LU: That's right. So to form a thin bed, you have to at least have two parameters there.  You have to have a particulate and you have the fiber.  VICE CHAIRMAN WALLIS: You have them there all the time in any plant.  MEMBER SIEBER: Yes.  MR. LU: That's right. But you may not have  VICE CHAIRMAN WALLIS: If you vacuum the floor and take out this and take out that  MR. LU: Right.  VICE CHAIRMAN WALLIS: You might not have them any more.	8	MR. LATELLIER: Yes, cal-sil has its own
in the debris on the floor of the plant and  MR. LU: That's right. So to form a thin  bed, you have to at least have two parameters there.  You have to have a particulate and you have the fiber.  VICE CHAIRMAN WALLIS: You have them there  all the time in any plant.  MEMBER SIEBER: Yes.  MR. LU: That's right. But you may not  have  VICE CHAIRMAN WALLIS: If you vacuum the  floor and take out this and take out that  MR. LU: Right.  VICE CHAIRMAN WALLIS: You might not have  them any more.	9	fiber. That's the reason.
MR. LU: That's right. So to form a thin bed, you have to at least have two parameters there. You have to have a particulate and you have the fiber. VICE CHAIRMAN WALLIS: You have them there all the time in any plant.  MEMBER SIEBER: Yes.  MR. LU: That's right. But you may not have  VICE CHAIRMAN WALLIS: If you vacuum the floor and take out this and take out that  MR. LU: Right.  VICE CHAIRMAN WALLIS: You might not have them any more.	10	VICE CHAIRMAN WALLIS: And there's fibers
bed, you have to at least have two parameters there.  You have to have a particulate and you have the fiber.  VICE CHAIRMAN WALLIS: You have them there  all the time in any plant.  MEMBER SIEBER: Yes.  MR. LU: That's right. But you may not  have  VICE CHAIRMAN WALLIS: If you vacuum the  floor and take out this and take out that  MR. LU: Right.  VICE CHAIRMAN WALLIS: You might not have  them any more.	11	in the debris on the floor of the plant and
You have to have a particulate and you have the fiber.  VICE CHAIRMAN WALLIS: You have them there  all the time in any plant.  MEMBER SIEBER: Yes.  MR. LU: That's right. But you may not  have  VICE CHAIRMAN WALLIS: If you vacuum the  floor and take out this and take out that  MR. LU: Right.  VICE CHAIRMAN WALLIS: You might not have  them any more.	12	MR. LU: That's right. So to form a thin
VICE CHAIRMAN WALLIS: You have them there all the time in any plant.  MEMBER SIEBER: Yes.  MR. LU: That's right. But you may not have  VICE CHAIRMAN WALLIS: If you vacuum the floor and take out this and take out that  MR. LU: Right.  VICE CHAIRMAN WALLIS: You might not have them any more.	13	bed, you have to at least have two parameters there.
all the time in any plant.  MEMBER SIEBER: Yes.  MR. LU: That's right. But you may not  have  VICE CHAIRMAN WALLIS: If you vacuum the  floor and take out this and take out that  MR. LU: Right.  VICE CHAIRMAN WALLIS: You might not have  them any more.	14	You have to have a particulate and you have the fiber.
MEMBER SIEBER: Yes.  MR. LU: That's right. But you may not  have  VICE CHAIRMAN WALLIS: If you vacuum the  floor and take out this and take out that  MR. LU: Right.  VICE CHAIRMAN WALLIS: You might not have  them any more.	15	VICE CHAIRMAN WALLIS: You have them there
MR. LU: That's right. But you may not  have  VICE CHAIRMAN WALLIS: If you vacuum the  floor and take out this and take out that  MR. LU: Right.  VICE CHAIRMAN WALLIS: You might not have  them any more.	16	all the time in any plant.
19 have 20 VICE CHAIRMAN WALLIS: If you vacuum the 21 floor and take out this and take out that 22 MR. LU: Right. 23 VICE CHAIRMAN WALLIS: You might not have 24 them any more.	17	MEMBER SIEBER: Yes.
VICE CHAIRMAN WALLIS: If you vacuum the  floor and take out this and take out that  MR. LU: Right.  VICE CHAIRMAN WALLIS: You might not have  them any more.	18	MR. LU: That's right. But you may not
floor and take out this and take out that  MR. LU: Right.  VICE CHAIRMAN WALLIS: You might not have  them any more.	19	have
MR. LU: Right.  VICE CHAIRMAN WALLIS: You might not have them any more.	20	VICE CHAIRMAN WALLIS: If you vacuum the
VICE CHAIRMAN WALLIS: You might not have them any more.	21	floor and take out this and take out that
them any more.	22	MR. LU: Right.
	23	VICE CHAIRMAN WALLIS: You might not have
MR. LU: That's right. That's the reason	24	them any more.
II	25	MR. LU: That's right. That's the reason

1	we are saying that a thin bed effect is a very
2	important effect. It needs to be considered in head
3	loss calculation.
4	VICE CHAIRMAN WALLIS: I find this thin
5	bed thing something like religion.
6	MR. LU: It's
7	VICE CHAIRMAN WALLIS: You invoke it. You
8	invoke it. But and there is a description. At
9	least I've got a description of it.
10	MR. LU: Yes.
11	VICE CHAIRMAN WALLIS: But not seeing any
12	hard-nosed explanation of it, what it is, why it is,
13	how you predict it, what its consequences are, what
14	its limitations are, what kinds of things create it,
15	and what things don't, you know did okay.
16	MR. LU: But in three minutes
17	VICE CHAIRMAN WALLIS: That's the first
18	step. You've described what you think it is.
19	MR. LU: But I'm trying to actually,
20	I'm trying to do that but I don't think in three
21	minutes I can really explain every single detail where
22	it goes. But there are 20 pages
23	VICE CHAIRMAN WALLIS: But the bottom line
24	is
25	MR I.II: Yes

VICE CHAIRMAN WALLIS: it's got to be
evaluated by the plants.
MR. LU: That's right.
VICE CHAIRMAN WALLIS: That's the bottom
line.
MR. LU: It needs to be evaluated because
it may introduce high head loss.
VICE CHAIRMAN WALLIS: It's the effect of
getting all the particles together so they make an
impervious layer almost an impervious layer.
MR. LU: That's right.
VICE CHAIRMAN WALLIS: It has to be
evaluated by the plants.
MR. CULLISON: Can I interrupt just a
second? Graham, because I hear a couple of different
things here I want to clarify.
First of all, I think that when you
discussed thin bed, you're thinking about it only in
terms of cases where you don't have a thick bed, that
is I think that Dr. Wallis is considering the
possibility of inhomogeneous beds.
And I don't are you considering that
possibility that you might require assuming that
there is a lot of insulation that's on the bed, and
it's a thick bed, are you considering the possibility

1 of requiring consideration of inhomogeneous beds? 2 MR. LU: Okay, first off, if you look at 3 debris generation as it is right now and from the 4 break location through the transport, you have to 5 remember the picture, the first picture we showed of the plant. And it goes through that. The first 20 or 6 7 30 seconds, you generate all the debris and the debris starts to flow around and mix together. 8 9 It's very hard, it's very, very, hard, 10 practically to justify, you are going to have a pure 11 inhomogeneous bed. It's very hard. And most likely 12 what comes to the sump screen is actually well mixed is number one. 13 14 The second, and experimentally it's 15 impossible to generate an inhomogeneous bed. If you run a test facility, you dump the fiber first. 16 17 dump the particulate later. You are going to have that one. 18 19 But in reality, it's just -- I just cannot 20 -- from engineering judgment side, I just cannot see 21 how come --22 VICE CHAIRMAN WALLIS: Let me give you a 23 different constrained judgment. The particles are 24 very mobile. They go through the screen initially. 25 MR. LU: Right.

1	VICE CHAIRMAN WALLIS: And are swept out
2	of the they go through the screen. It goes through
3	the rapture.
4	MR. LU: Right.
5	VICE CHAIRMAN WALLIS: They go all around
6	the thing. By the time they get back to the screen,
7	the fiberglass is there.
8	MR. LU: Right.
9	VICE CHAIRMAN WALLIS: So you filter them
LO	out on the fiberglass. Is that engineering judgment?
L1	MR. LU: Okay, hold on. Let me just give
L2	you to extrapolate a little bit on that phenomenon.
L3	When it comes in, it's not just
L4	particulate itself. It's also with some other fibers.
L5	If you do not have a raw mixture of just pure
L6	particulate, your phenomenon is credible.
L7	But if you still do have a mixture with
L8	other fibers, you mentioned that the fiber may come
L9	later, right? And then after going through the
20	VICE CHAIRMAN WALLIS: I said the
21	particles might come later.
22	MR. LU: Yes, particle may go on later or
23	your fiber will mix with that, so you may have
24	VICE CHAIRMAN WALLIS: So they may come
25	later because this when you start the numps, you

1	know, the fibers go down, then you start the pumps.
2	The fiberglass pulls up to the screen.
3	MR. LU: Right.
4	VICE CHAIRMAN WALLIS: Now the pumps spray
5	water into the containment, which washes down the
6	dust.
7	MR. LU: Right.
8	VICE CHAIRMAN WALLIS: Which is fine.
9	MR. LU: Right.
10	VICE CHAIRMAN WALLIS: And it filters out
11	on the fiberglass.
12	MR. LU: In that case
13	VICE CHAIRMAN WALLIS: I'm just suggesting
14	there are plenty of scenarios where you don't get a
15	homogeneous bed.
16	MR. HAFERA: That disagrees with the way
17	the scenario works. The way the scenario works,
18	again, spray starts early. The series of sprays will
19	automatically start. And the only time they'll start
20	as soon as your reactor your containment pressure
21	gets
22	VICE CHAIRMAN WALLIS: Where do they come
23	from? Where does the water come from?
24	MR. HAFERA: It comes from the refueling
25	water storage tank. It's clean water. It's clean

1	water. It's clean water.
2	VICE CHAIRMAN WALLIS: Okay.
3	MR. HAFERA: That's right.
4	VICE CHAIRMAN WALLIS: Okay, so you
5	haven't started
6	MR. HAFERA: For the first 27 minutes,
7	it's clean water.
8	VICE CHAIRMAN WALLIS: Okay. But it comes
9	later.
10	MR. HAFERA: Right. So then later and
11	as Shanlai mentioned, so later
12	VICE CHAIRMAN WALLIS: Washing down is
13	later
14	MR. HAFERA: you wash down your
15	containers.
16	VICE CHAIRMAN WALLIS: So what comes later
17	by wash down is not the same as what came earlier from
18	the LOCA.
19	MR. HAFERA: That's correct.
20	VICE CHAIRMAN WALLIS: So there's a chance
21	to have a nonuniform bed.
22	MR. LU: But just think about it as
23	deeper. And the particulate may just go through the
24	reactor system.
25	VICE CHAIRMAN WALLIS: But we're arguing
ļ	•

1	qualitatively about whether your fantasy is more
2	realistic than mine because we don't have anything
3	sure to base it on.
4	MR. HAFERA: But it
5	VICE CHAIRMAN WALLIS: I'm not going to
6	argue about it. Well, that's not engineering.
7	MR. LU: Okay, then I guess we'll get to
8	the next point and we still can't handle that. Even
9	though it was an inhomogeneous bed and you have a
LO	layer of particulate deposited on the fiber, the
l1	current correlation can predict the same bad effect as
L2	it has right now.
L3	VICE CHAIRMAN WALLIS: Have you checked
L4	that the correlation predicts the thin I thought
L5	the correlation was fixed up whenever you got a thin
L6	bed effect so that it went through the data points.
L7	MR. LU: Yes, yes.
L8	VICE CHAIRMAN WALLIS: It's not predicting
L9	anything.
20	MR. LU: Exactly. We did not actually
21	once you get a thin bed effect, it's beyond, you know,
22	the application range. You don't need to worry about
23	it.
24	VICE CHAIRMAN WALLIS: Okay. Go ahead.
25	MR. LU: Okay, so in terms of NCR

1 requirement, that's the reason we want to require the licensee to perform the calculation for post thickness 2 3 and consider the thin bed after licensee will remove 4 all the debris. 5 So they still have to consider the latent debris deposited on the screen and the cause of thin 6 7 bed which will give significant head loss. That's the 8 requirement in SER. And so in terms of head loss suction, and 9 we tried to address -- actually responded to all the 10 11 subcommittee comments and these are two major issues 12 we tried to address. And based on our analysis, we believe we can extrapolate the correlation beyond the 13 14 125 degree. 15 And also the thin bed has been defined in Appendix 8. And we're very detailed description --16 17 VICE CHAIRMAN WALLIS: Just one more I see you're finishing up here. 18 question. 19 MR. LU: Sure. 20 CHAIRMAN WALLIS: VICE So you're 21 completely satisfied for all the basis for the 22 correlation, all the mechanical, mechanistic-type 23 theory that went into it, all the equations are based 24 on something sensible, and that the data range is

sufficient for you to have faith in this correlation?

1	MR. LU: Yes.
2	VICE CHAIRMAN WALLIS: Is that a true
3	statement?
4	MR. LU: Yes, at this point, I think
5	and it's reasonably bound the test data we have. And
6	following the correct application procedure and there
7	is always place we can improve. We can run more test.
8	We can do more study.
9	But it's empirically later and then right
10	now if we're talking about 36 pickup truck versus one
11	pickup truck load of debris, and this part of
12	uncertainty is actually we are using a surgeon's
13	knife to cut the notch.
14	VICE CHAIRMAN WALLIS: Be careful about
15	the words you use. I'm just giving you advice here.
16	When you say the correlation
17	conservatively bounds, it's not it doesn't
18	conservatively bound. If you fix up the correlation
19	to change the coefficients so that it goes through the
20	highest point, you know, of some very limited data,
21	that's not really saying that the correlation
22	conservatively bounds.
23	It's saying that you can fix it up to go
24	through the highest point. But you didn't make any

prediction about what was the biggest possibility.

1	This conservatively bounding is based on either some
2	enormous database or some mechanistic icon to how big
3	it can be.
4	MR. LU: Right.
5	VICE CHAIRMAN WALLIS: Just sort of making
6	it go through the highest point of small set of
7	experiments doesn't really conservatively bound
8	anything.
9	MEMBER KRESS: Let me ask you about your
10	extrapolation.
11	MR. LU: Okay.
12	MEMBER KRESS: You, of course, know the
13	viscosity of water as opposed to temperature.
14	MR. LU: Right, sure.
15	MEMBER KRESS: Do you correct the
16	correlation for that viscosity change? Or do you just
17	assume it's
18	MR. LU: The viscosity, of course, is the
19	water property once you have a higher temperature, we
20	are going to yes, we are using that realistic
21	viscosity. It depends on temperature.
22	MEMBER KRESS: Then you multiply the
23	correlation by the ratio
24	MR. LU: Yes
25	MEMBER KRESS: of the viscosity?

1 MR. LU: Yes. So in that regard, actually 2 the total temperature drop -- so that's the reason 3 that we have a strong belief and the technical basis 4 to extrapolate. 5 VICE CHAIRMAN WALLIS: Okay. Thank you 6 very much. 7 MR. UNIKEWICZ: Good morning. 8 VICE CHAIRMAN WALLIS: Good morning. 9 UNIKEWICZ: MR. Му name is Steven 10 Unikewicz, engineer at the Division of Engineering, 11 Mechanical Branch. 12 I'm going to speak very briefly about downstream effects. Tom sort of lead us off going 13 14 through the whole accident scenario. We've gone 15 through a lot of presentations that bring us through bringing water to the face of the sump screen. 16 17 What I'm going to talk about very briefly is what happens downstream to the sump screen. Up to 18 19 this point in time, a lot of the discussion has been 20 focused on what is the fluid passing through the 21 Downstream effects is the evaluation of the screen. 22 CCS system and the containment spray systems 23 downstream of the sump screens. 24 As the fluid passes through, it's going to 25 have a number of different properties. It's going to

1	have an abrasiveness to it. It may have fiber in it.
2	It may have different constituents from latent debris.
3	It will have a certain abrasiveness to it.
4	As it passes through downstream
5	components, downstream components such as pumps,
6	values, heat exchangers, instrument tubing, things of
7	that nature, the effect of that
8	VICE CHAIRMAN WALLIS: Maybe we can skip
9	the whole thing because you simply say licensees have
10	to determine all this stuff.
11	MR. UNIKEWICZ: That's correct.
12	VICE CHAIRMAN WALLIS: Well, in that case,
13	maybe we can move onto the next presentation.
14	MR. UNIKEWICZ: If you so desire.
15	VICE CHAIRMAN WALLIS: Thank you.
16	MR. KOWALL: My name is Mark Kowall. This
17	is the last presentation on the Section 6, Alternate
18	Evaluation Methodology.
19	This section describes an alternate
20	approach which includes elements which are realistic
21	and risk-informed. This was a methodology developed
22	jointly between industry and the staff through a
23	series of public meetings that were held in May and
24	June of this year.
25	Part of the motivation for this approach

1	is the ongoing 10 CRF 50.46 rulemaking effort, which
2	defines a transition break size comparable for the
3	LOCA.
4	A comparable approach in GSI 191 is to
5	define a debris generation break size to distinguish
6	between customary and more realistic design basis
7	analysis.
8	And this debris generation break size is
9	defined as all auxiliary piping attached to the RCS
10	and in the RCS main loop piping a break size
11	equivalent to a double-ended rupture of a 14-inch
12	diameter pipe.
13	VICE CHAIRMAN WALLIS: So there's no
14	debris if the pipe is bigger than that?
15	MR. KOWALL: There is. For pipes bigger
16	than that, we still must demonstrate mitigative
17	capability.
18	VICE CHAIRMAN WALLIS: So there is still
19	debris generation for the bigger pipes?
20	MR. KOWALL: That's right.
21	VICE CHAIRMAN WALLIS: I was just
22	surprised by your definition. I thought the bottom
23	line was that below 14 inches, you have to use all the
24	conservative assumptions which are in
25	MR. KOWALL: That's correct.

1	VICE CHAIRMAN WALLIS: Appendix A.
2	That is you have a bigger pipe, you can back off on
3	some of the conservatisms?
4	MR. KOWALL: The next
5	MEMBER SIEBER: But that's unrealistic.
6	VICE CHAIRMAN WALLIS: But it's not the
7	debris generation which is effected by the break size.
8	It's the LOCA calculations.
9	MEMBER SIEBER: Right, right.
10	VICE CHAIRMAN WALLIS: Right. So I was
11	surprised to debris generation
12	MR. KOWALL: That's just the term we're
13	VICE CHAIRMAN WALLIS: as the qualifier
14	of the LOCA break size.
15	MR. KOWALL: using.
16	VICE CHAIRMAN WALLIS: We know what
17	MR. KOWALL: It's just
18	VICE CHAIRMAN WALLIS: you mean
19	MR. KOWALL: terminology.
20	VICE CHAIRMAN WALLIS: but it just
21	seems odd.
22	MEMBER KRESS: And the next two bullets
23	cover exactly what you're
24	VICE CHAIRMAN WALLIS: Well, the bottom
25	line here is that you haven't changed any of this

1	debris transport creation, clogging, and stuff, none
2	of that is changed by any of this risk-informing.
3	MR. KOWALL: That's correct.
4	VICE CHAIRMAN WALLIS: You still have to
5	assume mitigation. The only thing that might change
6	is perhaps the sump temperature isn't quite the same?
7	We don't know if that's good or bad because if sump
8	temperature is low, there's more viscosity, there's
9	more pressure drop.
10	So we're not quite sure whether that's
11	good or bad. But the only thing you're buying is some
12	of these environmental characteristics you might call
13	it of the LOCA and what is the temperature/pressure
14	history.
15	MR. KOWALL: Right.
16	VICE CHAIRMAN WALLIS: You're not changing
17	anything about how you evaluate the situation.
18	MR. KOWALL: That's right. The
19	CHAIRMAN BONACA: Is there a change in the
20	zone of influence maybe?
21	MR. KOWALL: The zone of influence, it all
22	relies on the baseline methodology as described so the
23	only thing impacted here would be elements of the
24	VICE CHAIRMAN WALLIS: So the effect if
25	probably

1 MR. KOWALL: -- NPSH --2 VICE CHAIRMAN WALLIS: -- very small. MR. KOWALL: -- calculation. 3 4 VICE CHAIRMAN WALLIS: The effect on the 5 conclusion is probably very small. Unless actually risk-inform in the way George may have 6 7 indicated, you might be able to later on if you can make uncertainty analysis of all these phenomena. You 8 haven't really changed the problem by risk-informing 9 it. 10 11 MR. KOWALL: That's right. 12 VICE CHAIRMAN WALLIS: We had some hopes, I think, when we wrote our letter a month or two ago, 13 14 whenever it was, that if you risk-informed all these 15 aspects of the problem, you might learn something which would be useful and might actually have some 16 17 application. But this effort to risk-inform is having 18 19 very, very little effect on anything. MR. JOHNSON: But I don't know that that's 20 21 true actually. We're also, through this risk-informed 22 effort changing -- I tried to emphasize this --23 changing the ability of licensees -- what they can do 24 in terms of mitigation for those breaks beyond that

debris generation break size.

1 And I think that's actually where the 2 potential benefit is. It's in the fixes where I think 3 this provides the opportunity, single failure, safety 4 related, realistic or more reasonable assumptions and 5 realistic calculations. VICE CHAIRMAN WALLIS: t.he NPSH 6 So 7 requirements might be reduced in some way, 8 example? Excuse me. So something would perhaps have some effect on this. But all the stuff we've been 9 talking about today that's in the guidance isn't 10 11 really influenced. In terms of the analysis? 12 MR. JOHNSON: MEMBER APOSTOLAKIS: Wasn't the objective 13 14 of NUREG 1150 to represent the community's views on 15 severe accidents? Okay, at least the U.S. community, 16 the experts on severe accidents. So they had, you 17 know, workshops, and this and that, trying to present what the community knew at the time about the various 18 19 phenomena that could take place after core damage? 20 Are your results what the community of experts in this field knows right now? Or is it just 21 22 Los Alamos's and yours? 23 MR. LATELLIER: If you're referring to the 24 break size, is that what you're referring to?

MEMBER APOSTOLAKIS:

25

The whole thing.

1	Well, I mean there are uncertainties all over the
2	place, aren't there?
3	MR. JOHNSON: Well, again, understanding
4	what we mean by this alternative evaluation and its
5	ability to be risk informed, which is that we are
6	identifying a break size smaller than the double-ended
7	guillotine break of the largest pipe, we're basing
8	that on the expert elicitation and all of that work
9	that went into the technical basis for
LO	MEMBER APOSTOLAKIS: For 50.46
L1	MR. JOHNSON: 50.46.
L2	MEMBER APOSTOLAKIS: I understand that,
L3	yes. But the rest of the study, you did not have plan
L4	to do that?
L5	MR. JOHNSON: Right.
L6	MEMBER APOSTOLAKIS: And the question is
L7	really why not. I mean it's been 25 years.
L8	MR. JOHNSON: Well, the answer to why not
L9	is
20	MEMBER APOSTOLAKIS: Is it that expensive?
21	I mean
22	MR. JOHNSON: the practical answer to
23	why not is you know all of the work, for example, with
24	respect to 50.46, we owe the Commission a proposed
25	rule in December and then we're in the rulemaking

1	process.
2	All of that work which we're not trying to
3	get out in front of is going to take us years. And,
4	again, the Commission has been very clear. We don't
5	have years to deal with this issue.
6	MEMBER APOSTOLAKIS: No, no, no, they are
7	two different objectives, Mike. I mean they are there
8	trying to risk inform the cornerstone of the
9	activities of this Agency for 40 years. You are not
10	trying to do that.
11	All I'm saying is you know we saw a lot of
12	fractions, of things happening this way and that way,
13	uncertainties and phenomenon, and so on, how difficult
14	would it be to try to put some uncertainty
15	distributions in this?
16	Would it be too hard? That's why you're
17	not attempting it? Or is it something I mean look,
18	it's also fine to say we haven't thought of it, we
19	haven't had time to do it.
20	MR. JOHNSON: Well, again, I'm just going
21	to tell you what I told you before. As a practical
22	matter, we didn't have time to do it.
23	MEMBER APOSTOLAKIS: You didn't. Okay,
24	fine. But do you think that would be a good idea?

VICE CHAIRMAN WALLIS:

There's always a

1	follow-on question, right.
2	MR. JOHNSON: On a schedule that would not
3	impact issuance of the SE, it's a fine thing to do.
4	I think actually this gets done in conjunction with
5	the 50.46 rulemaking.
6	MEMBER APOSTOLAKIS: Again, I wouldn't
7	want to tie this to 50.46. That's a much longer term
8	project.
9	MR. JOHNSON: I understand. But we're
10	trying
11	MEMBER APOSTOLAKIS: I mean the stuff that
12	you have done already you can use, of course. I'm not
13	saying don't do that.
14	MR. JOHNSON: Right.
15	VICE CHAIRMAN WALLIS: Okay. Can we move
16	on, George? Or do you want to pursue this risk-
17	informed part any more?
18	MEMBER SHACK: I just want to ask a
19	question. As I read this, there is a difference in
20	the zone of influence in the risk-informed model, that
21	you're using the hemisphere based on the break size?
22	MR. KOWALL: For the Region 1 space,
23	that's right. The guidance proposes the use for
24	breaks that are partial breaks inside of the main loop
25	piping that's right. But I think that's the only

limitation.

MEMBER APOSTOLAKIS: But I wish, in general though now, I wish when the staff says risk-informing something, or uses the term, it doesn't mean just looking for operator actions or alternate means of doing something.

It seems to be risk informed means addressing the uncertainties. And the uncertainties in some problems, like this one, happen to be in the models you are using, the parameters you are using, and so on. Now that would be risk-informing this issue in my mind.

MR. HARRISON: This is Don Harrison from the PRA Branch. And I would truly agree with you. I think the use of the phrase risk informed in this application is probably a misnomer. It's really more of a traditional deterministic resolution of the issue. It's where you've got uncertainties, we put on conservatisms as best as we feel that they're conservative.

The only piece of this that really even deals with the risk is in the solution, the fixes, that whatever is proposed as a solution will have to have a certain reliability, demonstrated reliability.

That's the only piece of this that's

1 really risk informed. The rest of it is more of a 2 traditional approach. Even within the traditional 3 approach, if there was time and money and resources, 4 you could do a best estimate approach and put in the uncertainties in the calculations. 5 Then we'd be arguing over is it, you know, 6 7 92 percent with what kind of distribution it is but since we only have limited data -- so it would be very 8 9 -- I think from a personal standpoint, it would be 10 very --11 CHAIRMAN BONACA: Yes, okay. We need to 12 move on. We have another presentation. We're already 15 minutes late. So we have to move --13 14 MEMBER FORD: But isn't risk informed, 15 Mario, important? I would like --CHAIRMAN BONACA: I understand that. I'm 16 17 only saying that this presentation right now is out of control. I'm saying we need to put some more to what 18 19 we have. 20 VICE CHAIRMAN WALLIS: The thing is we 21 didn't know how long industry was going to take. And 22 we've now just been told -- or I've just heard that 23 industry actually wants to make a fairly long 24 presentation. 25 MEMBER SIEBER: Let's take a break.

1	VICE CHAIRMAN WALLIS: I think it's an
2	important enough topic that we should probably hear
3	them. I think that they have a great stake in the
4	outcome. So we ought to hear what they have to say.
5	If the members will be patient and listen,
6	we'll just keep going.
7	PARTICIPANT: I'll be very patient.
8	VICE CHAIRMAN WALLIS: Did the staff want
9	a moment to just wrap up or do you want to wrap up
10	after industry?
11	MR. JOHNSON: If I can, I'd like to wrap
12	up after industry.
13	VICE CHAIRMAN WALLIS: Thank you.
14	CHAIRMAN BONACA: Let's do one thing then.
15	Let's take a break right now.
16	PARTICIPANT: Yes, that's a good idea.
17	CHAIRMAN BONACA: Take a break until 11:15
18	and then we'll come back again for the remaining part
19	of the presentations.
20	(Whereupon, the foregoing
21	matter went off the record at
22	11:59 a.m. and went back on the
23	record at 11:14 a.m.)
24	CHAIRMAN BONACA: Okay, let's get back
25	into session again.

Just a brief announcement regarding the
agenda. This will go to noontime so we will proceed
with this issue until noontime, adjourn I mean
recess for lunch between twelve and one and at one
o'clock, we will look at ACR-700, okay?
So that's the plan. So ACR-700
presentation is moved now to 1:00 p.m.
MEMBER KRESS: And reduced to an hour.
CHAIRMAN BONACA: Yes, reduced to an hour,
yes, if we can, yes. And then at two o'clock, we'll
take on GSI-185.
Okay, with that, Graham?
VICE CHAIRMAN WALLIS: Thank you, Mr.
Chairman.
Well, this, as I think you're all aware,
Well, this, as I think you're all aware, is an important issue. I think it's important that we
is an important issue. I think it's important that we
is an important issue. I think it's important that we hear industry's side to it. And I'm really looking
is an important issue. I think it's important that we hear industry's side to it. And I'm really looking forward to hearing from John Butler. So please go
is an important issue. I think it's important that we hear industry's side to it. And I'm really looking forward to hearing from John Butler. So please go ahead.
is an important issue. I think it's important that we hear industry's side to it. And I'm really looking forward to hearing from John Butler. So please go ahead.  MR. BUTLER: Thank you. My name is John
is an important issue. I think it's important that we hear industry's side to it. And I'm really looking forward to hearing from John Butler. So please go ahead.  MR. BUTLER: Thank you. My name is John Butler. I'm a Project Manager at NEI.
is an important issue. I think it's important that we hear industry's side to it. And I'm really looking forward to hearing from John Butler. So please go ahead.  MR. BUTLER: Thank you. My name is John Butler. I'm a Project Manager at NEI.  If it's possible, I'd like to take a

1	to do that now?
2	VICE CHAIRMAN WALLIS: Want to do it now
3	or at the end?
4	MR. BUTLER: Now might be instructive.
5	VICE CHAIRMAN WALLIS: Now since
6	everyone is waiting for it, now we might as well have
7	it. I just wanted it's sort of an anticlimax
8	effect here.
9	MR. BUTLER: It's less than an order of
10	magnitude. We don't even worry about it.
11	VICE CHAIRMAN WALLIS: Now this isn't the
12	PRA.
13	(Laughter.)
14	MR. ANDREYCHEK: My name is Tim
15	Andreychek. I work for Westinghouse Electric.
16	And the basis for the numbers that I came
17	up with, the percentage for the thermal hydraulic
18	subcommittee were walk-down data that was performed on
19	a once-through steam generator design.
20	The numbers that were presented today to
21	the full committee were based on a volunteer plant
22	that used a U-tube steam generator.
23	What I would suggest this means is that
24	each plant with different dimensions of a steam
25	generator are likely to have different debris

1 loadings. And I think that's the point you need to 2 make. 3 It's not that one number is any more 4 correct than the other. One number is correct for 5 that particular plant design. That's all I have. 6 Thank you. 7 VICE CHAIRMAN WALLIS: That's helpful. And, of course, if you're going to get a perspective 8 9 on the problem, you need to know the range of these 10 numbers, not just one number. At least we have two 11 data points now. Thank you. 12 MR. BUTLER: Well, actually Tim's point kind of serves as a good lead in to one of my first 13 14 points that I want to make in my slides is that this 15 issue effects all 69 PWR plants. And each plant is 16 unique in some aspect. 17 There is no easy way to group plants together. They can generally be grouped together but 18 19 each is going to have its own specifics, either 20 through the insulation materials that they use, and 21 you can have twin plants at a site that have 22 differences in the insulation materials that they 23 used. 24 Just through years of operation, those 25 differences will come about. Differences in the

latent debris that is found through sampling techniques, differences in the containment coatings that are used, both the types of coatings that are used and the surface areas that they use -surfaces that are coated and percentage that qualified versus unqualified. And certainly in the containment designs and, you know, very much the sump designs that are And it is carried through to the rest of the systems, the pumps that are used are very different. So in effect, I can't stress this enough, there are 69 different solutions to this problem. the trouble we have or the difficulty we have with coming together with evaluation methodology is you have to somehow provide some acknowledgment that there are 69 different solutions. And it does not allow you the luxury of being real explicit in certain areas. In some cases have to recognize that from practical а standpoint, that simplifications are necessary that will effect some plants more than others.

VICE CHAIRMAN WALLIS: Well, John, there may be some rule for NEI to evaluate promising solutions which might apply to a significant number of plants.

1

2

3

4

5

6

7

8

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

And it seems to me that it is very difficult to put the onus on every plant to work out a solution. That it may well be that certain kinds of engineering solutions, which can be shown to be effective, could be worked out collectively.

And NEI might have a role in doing that rather than having everyone be on their own.

MR. BUTLER: Everyone in the end is going to be on their own. The task force that NEI has used to develop the guidance in coordination with the Westinghouse owners' group has had the participation of the major vendor groups who will be providing services to the plants in resolving this problem.

They have their own ideas. We've discussed those ideas in our meetings. There are a pretty good variety of screen designs that are being offered. There are a number of other design changes in terms of insulation change out. And some of these were mentioned in the staff presentation.

But there are also some fairly inventive changes that can be incorporated. You know, I stress this again, the reality is whether or not a particular fix is appropriate for a plant is very specific to the plant situation in terms of what their requirements are, what their time schedule is, just a number of

167 1 factors. 2 So it's up to each plant to decide based upon the information that they have, that's provided 3 4 in the guidance, and provided by the vendors, what is 5 appropriate for them. MEMBER ROSEN: Well, I think what is being 6 7 suggested here is you help the industry with some sort of users group or interchange of information. If one 8 plant comes up with an inventive fix on one aspect of 9 this problem, everybody should know about it. 10 11 MR. BUTLER: Yes. And we'll continue to 12 evaluate what's most appropriate. 13 Our first opportunity to do that will come 14 up at our December workshop. And we have a session 15 planned in which the various vendors will, in effect, be making their case for their inventiveness and their 16 17 solutions. VICE CHAIRMAN WALLIS: John, how about 18 19 defining the problem? I mean invention is one thing 2.0 but it seems that there is no knowledge base about 21 effective, you know, the coatings which are reduced to

So you are suggesting that each plant

the particulate level, there's no basis for evaluating

the effect of that on a screen or whether it makes a

thin bed and all that.

22

23

24

1 conduct an experimental program to develop this? Wouldn't it be much better if industry got together 2 3 and said we need this information collectively because 4 we all have coatings? 5 NEI might have a role in pulling people together to do that. Or EPRI or somebody other than 6 7 just all these plants left out there on their own. The importance of the 6224 8 MR. BUTLER: correlation has certainly been highlighted with the 9 10 staff's draft SER. We were intending to apply that for the range of conditions that we needed to apply it 11 12 for without restricting ourselves to explicitly the testing conditions that were used to support the 13 14 correlation. 15 We felt that that was appropriate. That there were sufficient understanding of the physics of 16 that. If we need to do additional testing in order to 17 apply the 6224 correlation, we will have to do that. 18 19 VICE CHAIRMAN WALLIS: But I don't think 20 it's just applying it. I think the guidance and the 21 SER indicates that for some things like paint chips or 22 paint debris or whatever it is, for latent debris, 23 there really isn't some way you can just pluq 24 something in to the correlation.

Experiments haven't been done to find out

1 any information about it. You can't plug information 2 into something when we've got no database for that 3 stuff. 4 MR. BUTLER: Well, the correlation is --5 VICE CHAIRMAN WALLIS: So --MR. BUTLER: -- applicable for -- if you 6 7 have a good understanding of --8 VICE CHAIRMAN WALLIS: -- but you have a 9 faith that it's applicable to materials for which it 10 has never been tested? MR. BUTLER: We have faith in if you have 11 good understanding of the characteristics of 12 whatever your debris is, the particulate size, the 13 14 surface area, that the correlation is applicable. 15 VICE CHAIRMAN WALLIS: Well, look at what 16 happened in Los Alamos. They thought they had an 17 understanding, did an experiment, and all of a sudden, here's a test which gives you seven times the pressure 18 19 drop which they thought they had -- they would have 20 had, you know? 21 Obviously this requires then some more 22 data to figure out what is going on. And the same 23 thing could happen with any of these kinds of debris. 24 You can't just extrapolate somebody's hypothesis or

correlation to all these areas where there isn't any

1	data.
2	That seems to me inappropriate even if
3	public safety isn't the question here. Even more so
4	when you've got people looking over your shoulder who
5	are concerned with the credibility of all of this.
6	MR. BUTLER: Well, you're asking very good
7	questions perhaps to the wrong person. I'm certainly
8	not an expert on 6224
9	VICE CHAIRMAN WALLIS: Well, would it
10	MR. BUTLER: correlation.
11	VICE CHAIRMAN WALLIS: surprise you if
12	a year from now you and the Agency, just like just
13	guessing the future, found that they had to put a lot
14	of money and I'm talking about billions, into some
15	research to really get a substantial knowledge so that
16	you know what you're doing about this issue?
17	Would it surprise you if that were to
18	happen? Because it wouldn't surprise me at the
19	moment. Now maybe I don't know enough about this but
20	I'm getting the impression it's a very big problem.
21	There are an awful lot of unknowns. And that you need
22	to know what you're doing.
23	Therefore, you ought to be prepared to
24	spend some money and do some work.

BUTLER:

MR.

25

Well, to answer your

1 question, I've gotten past being surprised by this 2 issue. 3 VICE CHAIRMAN WALLIS: Okay. So you 4 wouldn't be surprised by anything? 5 MR. BUTLER: No. VICE CHAIRMAN WALLIS: Well, I think we 6 7 need to do that. We need to -- I think the job of the ACRS, among its other jobs, is to try to sort of 8 9 figure out how to tell it like it is. And so what I'm trying to do in all of this is to get you folks to 10 11 help us to understand it like it is. 12 And that may well -- the conclusion of that may well be that you've got to do some more 13 14 thorough work to understand what's going on. I don't 15 know. But that may be one of the conclusions. Okay. MR. BUTLER: Without trying to go back and 16 describe in detail the industry guidance, we did 17 present to the subcommittee some details on the 18 19 evaluation guidance. 20 I want to stress the point that our 21 intention was to provide a set of methods -- and I've 22 use the words deliberately from the Commission SRM, 23 meeting SRM because it did follow along what our 24 intention was with the quidance, to have a practical

and realistically conservative set of methods that

plants could apply.

The baseline methodology, we still feel strongly that it is a conservative set of methods to give you a conservative result. We may not recognize what best estimate and realistic is when we see it but we can certainly recognize it when it is conservative to the point of almost being ridiculous in some of the values that it gives you.

Our intent with the conservative baseline was to help plants decide how best to resolve the problem. Whether that is to spend their time in the effort refining the analysis to be more -- to remove some of the conservatism in that approach through a CFD analysis or through some other method, or whether there is a most cost-effective approach just to remove some problematic insulation material so that they can meet the requirements with a conservative baseline analysis, or some combination.

So our intent was to use that to guide the problem and allow plants to make the best decision that they could.

VICE CHAIRMAN WALLIS: What do you think about this approach of analysis? Some engineering is done by -- well, we know a lot about things. We use computers. We predict things. We can predict now how

1 airplanes fly and wing design very well because we 2 understand what is going on. 3 There are other areas of engineering where 4 we make things and they work. When people first made 5 the internal combustion engine, it worked. They knew almost nothing about combustion and heat transfer and 6 7 all that. But they made something that worked. 8 Is this an area where really we know so 9 little about what's going on, we've got to start testing things and seeing if they work rather than 10 trying to analyze the problem? What's your feeling 11 12 about that? My feeling for that is I 13 MR. BUTLER: 14 would love to have a better understanding of a 15 realistic scenario and how that effects recirculation. But what we're not dealing in a realistic scenario. 16 We're dealing in design basis space. 17 And you're starting off with a postulated 18 19 break, an instantaneous double-ended quillotine break, 20 which you could argue is either extremely low 21 probability or impossible to occur. And from that, it 22 just continues to pile on some very unrealistic assumptions throughout the scenario. 23 24 It would not be instructive to try to 25 model that to have a better understanding of what that

1 gives you. I think it would tell you it gives you 2 some large amount of debris. And I think we've 3 already covered that. 4 We need to understand that we are in 5 design basis space. We haven't risk informed any 6 aspect of the current regulations in how we apply 7 that. 8 So we need to assure ourselves that we 9 meet the regulatory requirements and our hope is that we can do that without being overly conservative to 10 11 the point where --12 MEMBER APOSTOLAKIS: Graham, let me -- I'm trying to understand your fundamental problem here. 13 14 Are you saying that we don't know enough to be able to 15 say that what we're doing is conservative? Is that 16 your basis thesis here? 17 VICE CHAIRMAN WALLIS: Well, I'm looking forward to the day when the problem is solved. And it 18 19 seems to me that -- well, if you were out there and 20 not in nuclear regulatory space at all, that you are 21 say designing a new plant to do something, you'd do 22 analysis. And you'd have all sorts your 23 uncertainties. 24 And because you have uncertainties in the

analysis, you do a lot of build and test and try it.

1 I mean you never go and build a chemical plant to make something -- or very rarely would you accept maybe 2 3 really crisis mode like the Manhattan Project and have 4 built something without having build pilot plants, 5 without having tested things, without having found out the properties of the things you're going to use. 6 7 You'd have done a whole lot of things in order to make sure that when you actually built this 8 9 plant, it worked. And here we seem to be in this sort of analytical world where everything is analyzed with 10 11 tremendous uncertainty. And that's not a comfortable situation for 12 an engineer to be in. 13 14 MEMBER APOSTOLAKIS: So you are not 15 convinced that what they are doing is conservative? 16 VICE CHAIRMAN WALLIS: No, I'm not saying 17 that at all. I'm saying that to solve the -- I can't think you can analyze the problem away. It seems to 18 19 me there has to be projected solutions. 20 There has to be very careful planning of 21 engineering to make sure these solutions can be 22 assumed to be effective in some way which may well 23 involve big tests because that's the way engineering 24 works when you don't know enough about things to

analyze the problem and make secure predictions.

1 It has to do with uncertainty but at a 2 very fundamental level. You have to build things and 3 design things. And you have to evaluate things. 4 I don't think that -- you know, that's what the 5 industry is eventually going to have to do. And that's where they need help is in 6 7 figuring out with this very uncertain problem with all these aspects to it, how you can come up with any sort 8 of believable fix and make it credible and show that 9 10 it's the right thing to do. 11 CHAIRMAN BONACA: But let me ask you a 12 question. Does the -- I mean one of the concerns you have, if I understand it, is the knowledge base 13 14 supporting this effort is sufficient? And will the 15 effort of developing or completing the knowledge base stop at this stage as -- I mean the plan seems to be 16 17 that industry will go out now and apply this process for a baseline calculation. 18 And I dare say that most of them will find 19 20 that they cannot meet the requirements with the 21 baseline calculations. So they'll go through a 22 refinement process. 23

Now all this will take an extended period of time. It will take months. In fact, I believe you have an objective of -- I mean a year or two before

24

1 you get some results out -- will the industry and the 2 NRC continue to develop the knowledge base to fill 3 those gaps in this period of time? Or we'll just 4 simply say knowledge base is what it is today and 5 that's it? I mean we're not going to go any further. Well, the answer to your 6 MR. BUTLER: 7 question is a qualified yes. Certainly with the screen designs, there are modifications to the designs 8 9 that need to be applied. Specific designs that various vendors are proposing, some have been tested, 10 11 testing the specific designs for various debris 12 Some additional testing may need to be loadings. performed so that the individual resolution option 13 14 designs have testing requirements. 15 Some have been done. Some will need to be There may be a need for additional testing of 16 17 specific debris types that are problematic and are difficult for the plant to remove. So some of that 18 19 will occur. 20 I'm asking because CHAIRMAN BONACA: 21 clearly --22 The reason I'm saying it's MR. BUTLER: 23 qualified is we're on a very tight schedule. 24 plant is going to have to make a decision. Can he

accomplish what testing he needs to accomplish on the

time that's --

VICE CHAIRMAN WALLIS: Maybe I should in answer to George's question try another analogy. I mean if you look at airplanes, I used airplanes before, Boeing, as I understand it, now has a very good base using computers for predicting how an airplane will fly if they design it.

The Wright brothers did not have that.

And they had to do all kinds of things by guesswork and trial and error and so on. They developed a knowledge base. And eventually they didn't fly very far but they did get something off the ground.

I don't know how far you are with this problem. Are you at the Wright brothers' level? Or are you at the Boeing of today level?

And my feeling is you are certainly not at the Boeing of today level. And I'm not quite sure how far you are ahead of the Wright brothers in terms of really coming to grips with this problem and what you need to do with it.

And so I suspect that you cannot analyze it the way you are trying to solve it by just analysis. Something else has to be done. And part of it is knowledge base but part of it is going to be sort of gutsy, down-to-earth engineering of figuring

1 out what to do and showing how and demonstrate it 2 Isn't that the case? works. 3 I mean after they've gone through all this 4 exercise, these 69 plants, you're going to have some 5 meetings with management and say what do we do? MEMBER KRESS: Well, I think the likely 6 7 thing they'll find out, using the methodology, they'll find out they're not -- currently have screens big 8 enough and they'll make them bigger. And they'll do 9 this -- they'll fix it like the BWRs, 10 11 and enough surface that the corrugated area 12 methodology will predict that that surface area is in the positive suction head. 13 14 And then we're going to be stuck with this 15 question, oh, what about thin bed effects? Because it will still be there. And they're going to -- I think 16 I hear that there are designs for which the thin bed 17 effect can be shown not to be there. I think it's 18 19 corrugated screens. 20 Now the question I'm going to have when 21 that time comes is are we sure that the generation 22 zone of influence, using the is 23 conservative still, and can you show me the database 24 that backs up the statement that you have no thin bed

effect?

1	I think that's the way things are going to
2	play out.
3	VICE CHAIRMAN WALLIS: So it's still going
4	to be at the analytical level. They analyze all this
5	stuff and then
6	MEMBER KRESS: Oh, yes, it's strictly
7	going to be analytical.
8	VICE CHAIRMAN WALLIS: what they have
9	to do is
10	MEMBER KRESS: The question is
11	VICE CHAIRMAN WALLIS: what they have
12	to do is
13	MEMBER KRESS: is this analysis
14	conservative?
15	VICE CHAIRMAN WALLIS: What they have to
16	do is satisfy the staff then?
17	CHAIRMAN BONACA: I was trying to
18	understand my question is what is the risk of
19	proceeding now with a guidance that is limited, okay?
20	And it seems the biggest risk is the one of realizing
21	a year from now, a year and a half, that we don't know
22	enough or even worse to go through certain
23	modification and find that we have to modify them
24	further. That's really the biggest risk I see.
25	And I wouldn't mind having that risk if I

1	knew that the knowledge base is going to be expanded
2	over the next year or two to the point where then
3	we'll have also closure on some of these questions.
4	I'm not sure that, however, if we start on
5	this path, we will ever have closure on some of these
6	issues because probably the work will not be done.
7	MEMBER APOSTOLAKIS: Are we discussing now
8	the overall issue? Or are we still in the
9	presentation?
10	(Laughter.)
11	CHAIRMAN BONACA: Well, we are already
12	through half of the remaining time for this
13	presentation.
14	VICE CHAIRMAN WALLIS: Then we should move
15	back to the presentation, George. You're very
16	appropriate. And it is a very appropriate comment.
17	MEMBER APOSTOLAKIS: I would suggest that
18	maybe the speaker should show the slides that send a
19	message or have a point rather than describing the
20	guidance. I mean we know what it is. I mean why you
21	develop the model, okay, yes, sure. I mean the
22	guidance.
23	But is there a place where you have
24	you're making a point.
25	PARTICIPANT: It's the SER that we're

1 discussing today so --2 MR. BUTLER: The point of these slides is 3 to set up the points I'm going to make in the later 4 slides. 5 CHAIRMAN BONACA: I think most members are -- well, anyway, I mean it's your presentation but --6 7 MR. BUTLER: Let me just make one point off of this slide. We've made a number of comments 8 9 about conservative and we can argue how conservative. But we also have a number of simplifications in the 10 11 quidance that we don't want to lose that or at least 12 before make point lose it that those we simplifications are there from a practical standpoint 13 14 of plants applying the guidance. 15 And I'll make a point in a later slide about one of these simplifications that we 16 17 apparently losing. I did want to make the point that this 18 19 quidance, the baseline guidance, the industry 20 guidance, has been applied by a number of -- or the 21 vendor groups that have been participating within NEI 22 on our task force. And I am aware of calculations 23 that are either -- are fairly close to being completed 24 or have been completed for at least six plants.

I can only characterize these results as

1	preliminary because they have been conducted
2	throughout the development of the guidance. And they
3	don't necessarily follow all the guidance explicitly.
4	And they don't address any of the changes resulting
5	from the draft SER.
6	But one thing that is common in the
7	results is that it is showing a fairly significant and
8	consistent increase in the screen area if that's all
9	you do is increase the screen area.
10	VICE CHAIRMAN WALLIS: Can you tell us
11	what you mean by fairly significant?
12	MR. BUTLER: In the range of 1,000 to
13	2,000 square feet.
14	VICE CHAIRMAN WALLIS: And some are now 12
15	square feet?
16	MR. BUTLER: Pardon me?
17	VICE CHAIRMAN WALLIS: Someone, I think,
18	said the smallest one in existence is 12 square feet?
19	MEMBER SIEBER: No, none that small.
20	MR. BUTLER: I think
21	MR. ANDREYCHEK: That was current
22	metric that you have one 12 square feet at the low
23	end.
24	VICE CHAIRMAN WALLIS: And you are saying
25	that they have to be now several thousand square feet?

2 MR. BUTLER: The results a	
	so far have been
3 performed with no other modifications	but to increase
4 the screen area. And the results are	e showing
5 VICE CHAIRMAN WALLIS: I tl	nink that's very
6 helpful information. It gives us some	e idea of the
7 MEMBER APOSTOLAKIS: So t	chis
8 VICE CHAIRMAN WALLIS:	- consequences.
9 MEMBER APOSTOLAKIS:	is impractical?
10 Is that what you're saying? It's im	practical to do
11 this?	
MR. BUTLER: No, no.	
13 MEMBER APOSTOLAKIS: No?	
MR. BUTLER: Again, there	are 69 different
plants. Some plants can accommodate	have designs
that can accommodate fairly large incr	reases in screen
areas. Others are more limited in	the screen area
18 they can accommodate.	
19 MEMBER APOSTOLAKIS: So th	ey will do what?
20 They will go back to	
21 MR. BUTLER: They will	have to make
22 modifications to their	
23 MEMBER APOSTOLAKIS: Some	ewhere else.
MR. BUTLER: debris ge	eneration.
25 VICE CHAIRMAN WALLIS: A:	nd some of them

1	might have to build a different sump or something? Or
2	build something on to the containment to handle the
3	debris?
4	MEMBER SIEBER: No, I think
5	VICE CHAIRMAN WALLIS: There are all
6	MEMBER SIEBER: that would be
7	VICE CHAIRMAN WALLIS: sorts of things
8	you might think of.
9	MR. BUTLER: Again, my first point in the
10	presentation is there are 69 different resolutions to
11	this problem. Each plant
12	VICE CHAIRMAN WALLIS: But if they can't
13	
14	MR. BUTLER: has its own
15	VICE CHAIRMAN WALLIS: fit it if
16	they can't fit it into the existing sump, they're
17	going to have to do some busting of concrete or
18	something.
19	MEMBER SHACK: No change out of insulation
20	would probably be the next step.
21	VICE CHAIRMAN WALLIS: All right,
22	insulation, that's the other thing.
23	CHAIRMAN BONACA: Or even, you know,
24	manage debris throughout the containment with
	manage debits enroughout the containment with

1	the debris so that
2	MEMBER APOSTOLAKIS: So what do you mean
3	by manage, Mario?
4	CHAIRMAN BONACA: By manage I mean is that
5	so you don't have transport of all the debris down
6	MEMBER APOSTOLAKIS: No, I understand the
7	consequences. But what does management of the debris
8	mean? I mean what can they do now to manage that?
9	CHAIRMAN BONACA: I'm talking about
LO	placing within containment probably barriers of some
l1	kind or
L2	MEMBER SIEBER: Insulation.
L3	CHAIRMAN BONACA: screens.
L4	MEMBER APOSTOLAKIS: So they're physical
L5	
L6	CHAIRMAN BONACA: Physical means
L7	MEMBER APOSTOLAKIS: modifications.
L8	CHAIRMAN BONACA: so that you reduce
L9	the amount of debris that will come to the sump by
20	block it in different locations in the containment.
21	MEMBER KRESS: Go from 50 percent to 30
22	percent? You can't get much help that way.
23	VICE CHAIRMAN WALLIS: So only about 40
24	percent of the plants have cal-sil? I understand
25	about 40 percent PWRs have cal-sil insulation in them

1	somewhere?
2	MR. BUTLER: I have not heard that figure.
3	VICE CHAIRMAN WALLIS: That's the number
4	that we found out at one of our meetings, I think. Do
5	these six plants have cal-sil insulation in them?
6	MR. BUTLER: At least one of the did.
7	VICE CHAIRMAN WALLIS: Did they have to
8	face this thin bed business in their analysis?
9	MR. BUTLER: Yes, they all
10	VICE CHAIRMAN WALLIS: They all have thin
11	bed problems?
12	MR. BUTLER: they all calculate thin
13	bed and
14	VICE CHAIRMAN WALLIS: But and then
15	so they know how to do that?
16	MR. BUTLER: Certainly, yes. I mean
17	VICE CHAIRMAN WALLIS: You do?
18	MEMBER KRESS: Again, you have a thousand,
19	several thousand square feet did not talk about thin
20	bed, I'll bet.
21	MEMBER SIEBER: Yes.
22	MR. CULLISON: It solves, again, the
23	industry's perception of thin bed is not a multi-
24	layered thick. It's just the thin bed. And when they
25	go to large areas, they solve not only the thick bed

1	but they also solve I mean the thin bed exists but
2	with a larger area, with their calculations
3	MEMBER SIEBER: So the drop is less?
4	MR. CULLISON: they drop the
5	pressure drop
6	VICE CHAIRMAN WALLIS: So they get less
7	than a millimeter of cal-sil or something? Or what do
8	they get?
9	MR. BUTLER: I'm not an expert so I would
10	preface my remarks with saying that. But one of the
11	consequences of significantly increasing the area is
12	you number one decrease the approach velocity which
13	directly impacts the head loss. And obviously with
14	increasing the area, you're minimizing the impact of
15	the large debris loads because you're spreading it out
16	over a larger area.
17	But the approach velocity is the dominant
18	effect on the thin bed effect, head loss
19	VICE CHAIRMAN WALLIS: Well, we don't know
20	yet. But if you look at the Los Alamos database, if
21	you're talking about the same thing I think you're
22	talking about, is some sort of anomalous increase in
23	pressure drop. And it looks as if the particles are
24	somehow getting closer together.
25	This increases as you increase the

1 velocity in all those tests. So if you get down to a 2 velocity of less than .1 feet a second, based on that 3 database, there might be some hope that you wouldn't 4 have this effect at all. I just don't know. 5 MEMBER SIEBER: Well, even if you don't, you know the lower the velocity, the lower the head 6 7 loss. And so the larger the screen you make, whether 8 you have a thin bed or not, the lower the pressure 9 drop and the higher the NPSH will be. And so even if you get a thin bed that's 10 11 uniformly deposited that does exhibit a pressure drop 12 at those very low flows, those large screens, the NPSH loss is de minimus. 13 14 And so that's really what the advantage 15 It's not trying to avoid making the thin bed is. because of the low velocities. 16 It's the 17 velocities that cause the pressure drop to be very And so there's, to me, that's where the 18 low. 19 advantage of a large screen is. 20 MR. BUTLER: And I don't want to minimize 21 the engineering aspect of this problem. I mean there 22 are actual losses that are introduced by having an 23 extremely large screen that wraps around your 24 containment. And they have to be taken into account.

VICE CHAIRMAN WALLIS:

25

If you really

1	understood the debris transport, you might be able to
2	show that with these very low velocities, everything
3	falls out before it gets to the screen.
4	MEMBER SIEBER: Right.
5	VICE CHAIRMAN WALLIS: Or it falls out
6	enough so that it only covers the bottom of the screen
7	and you don't get a uniform layer which
8	MEMBER SIEBER: That's right.
9	VICE CHAIRMAN WALLIS: is
10	extraordinarily conservative to assume a uniform
11	layer. It's probably going to fall to the bottom of
12	the screen. The top of the screen may be clear.
13	There are all kinds of ways in which
14	things might be good.
15	MEMBER SIEBER: Well
16	VICE CHAIRMAN WALLIS: But the thing I'm
17	concerned about is how do you prove it?
18	MEMBER SIEBER: Well, the key parameter is
19	the velocity. And that's most impacted by the screen
20	size.
21	VICE CHAIRMAN WALLIS: Yes. It's the most
22	obvious simple thing that you can do is reduce the
23	velocity.
24	MEMBER SIEBER: Yes, well that's right.
25	It's a continuity question.

1	MEMBER APOSTOLAKIS: I would suggest we
2	let John complete his presentation. And we're just
3	VICE CHAIRMAN WALLIS: Yes, well I think
4	George
5	MEMBER APOSTOLAKIS: taking away his
6	time.
7	VICE CHAIRMAN WALLIS: had a good
8	point.
9	MEMBER APOSTOLAKIS: I'd like to have him
10	the chance to present what he wants to present.
11	MR. BUTLER: All right. I will continue.
12	First off, we have not had a lot of time to look at
13	the draft safety evaluation.
14	Unfortunately, the staff's review schedule
15	did not offer them or us the luxury of having a lot of
16	interaction during the review process kind of counter
17	to the normal review process where you meet, have
18	RAIs, and discuss things. So we are surprised by some
19	of the actions taken in the safety evaluation.
20	VICE CHAIRMAN WALLIS: That's another
21	I think a very important input for the committee. You
22	haven't had this interaction and yet we're asked to
23	sort of approve something when it appears that you may
24	have some significant questions about it.
25	You are the guys who have or you at

industry --

MR. BUTLER: We just sent in a -- you know, we did take a few days and placed down some of our major comments. And we did provide those to the staff.

We are going to continue to review the SER and one of our major focuses of that review will be to make sure that we have a way to explain to the industry how to apply the combination of the industry guidance document and the staff's SER on how that modifies the evaluation guidance because plants -- the clock starts ticking as soon as the SER is issued. And plants will need to start using this guidance.

So we're hoping between now and the workshop that we have planned in December that we can have a good enough understanding of the SER that we can provide that guidance to utilities on how to apply it.

VICE CHAIRMAN WALLIS: So this factor of 1,000, if the SER goes through on the schedule, and you come up with some very good arguments that it should be a factor of two, is the staff going to change its position after the SER has been issued?

Are you really going to really listen to the industry? And if there is a really good argument

1 that you've made a mistake in assuming a factor of 2 1,000, you'll go back and change it? 3 MR. LATELLIER: If I can speak for the 4 staff, I think the flexibility is offered in the SE to 5 review any information that is beneficial to the defensible reduction of conservatism. And, yes, the 6 7 staff will accept that information whether it's 8 formally implemented as a change to the document 9 remains to be seen. 10 MR. JOHNSON: Michael Johnson speaking. 11 That's true, of course. I was actually responding to 12 talking about an earlier point that John made with my staff so I didn't really hear the question. 13 as Bruce indicates, we will -- we always would 14 15 consider additional information submitted by 16 licensees. 17 VICE CHAIRMAN WALLIS: But it wouldn't be good to have too many of these things that you have to 18 19 adjust. 20 Well, I mean I quess, I MR. JOHNSON: 21 think is the answer to your question -- but remember, 22 keep in mind, we deal with, as John has made a great point, each of these plants is unique. 23 We expect 24 that. And we routinely deal with, even where we have 25 generic guidances used, we routinely deal with a large

number of unique differences where licensees have applied, to some extent, or not applied, to some extent, the guidance.

And so we deal with that as a routine.

VICE CHAIRMAN WALLIS: Yes, John.

MR. BUTLER: All right. Well, I'm trying to speed my way up through this. I made the point about simplifications in the evaluation guidance earlier. The staff's safety evaluation also has a tendency to remove some of those simplifications by requiring plants to provide plant-specific information.

The example Ι provide here is in recognition that for unqualified coatings, which we conservatively assume all fail and all fail in a highly transportable particle size and something that biases it toward aggravating the thin bed effect, we, simplification's sake, three mil for assume а thickness for those coatings, recognizing that there are hundreds of items inside containment that have unqualified coatings, motor, motor centers, junction boxes, all these surfaces have to be accounted for. And a simplification that is assuming a three mil thickness, we felt was an appropriate simplification.

VICE CHAIRMAN WALLIS: All these coatings

1

2

3

4

5

6

7

8

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

_	Come off:
2	MR. BUTLER: Yes.
3	VICE CHAIRMAN WALLIS: Some of those
4	coatings contain materials that you probably wouldn't
5	want in a chemical soup. They're not all the same
6	coatings. Some of the electrical coatings contain
7	materials like chloride chlorine or lead or
8	something or other, whatever it is, which, I
9	understand, you don't particularly don't want to see
LO	in the chemical soup that get in the sump, you're
L1	going to put all those coatings in the sump?
L2	MR. BUTLER: Yes. Unqualified coatings,
L3	they are assumed to fail.
L4	MEMBER SIEBER: I think if you are using
L5	the sump, that you need not worry about the chemical
L6	effects of chlorides on stainless steel because you
L7	aren't going to use the plant after that I don't
L8	think.
L9	MEMBER FORD: I think Graham is talking
20	about the formation of gels.
21	MEMBER SIEBER: Well, that's a different
22	matter.
23	MEMBER FORD: Sure.
24	MR. BUTLER: Continuing, the
25	VICE CHAIRMAN WALLIS: I guess I just want

1	to be sure that when we do these chemical tests, we
2	evaluate chemistry, we put in if it's relevant, make
3	it compatible with this model for the coatings.
4	I didn't know they were going to consider
5	electrical coatings and all kinds of other coatings.
6	I think that
7	MEMBER SIEBER: Yes, insulation.
8	VICE CHAIRMAN WALLIS: complicates the
9	chemical problem.
10	MEMBER SIEBER: Insulation is a factor.
11	VICE CHAIRMAN WALLIS: Okay.
12	MR. BUTLER: Okay.
13	MR. MURPHY: Mark Murphy from Material and
14	Chemical Engineering Branch.
15	In the chemical effects test, there is a
16	generic addition of hydrochloric acid to account for
17	some of the electrical coatings. And then the epoxies
18	have been shown to not degrade. They are tested and
19	they don't break down, you know, in solution.
20	VICE CHAIRMAN WALLIS: Thank you.
21	MR. BUTLER: The last point on this slide
22	I would like to make is section 6, which we titled the
23	Alternate Evaluation in recognition that it's not a
24	risk-informed evaluation. So we're very cognizant of
25	that. And we just call it an alternate evaluation.

1 It's still within the design basis realm 2 just provides a more relaxed but 3 conservative treatment of a less likely spectrum of 4 breaks within the design basis. 5 One aspects that the section 6 allowed would be a more realistic treatment of NPSH, a more 6 7 realistic calculation using nominal input parameters. The SER kind of restricts that use in that 8 9 you'd still need to go through a 9118 evaluation any time you exceed a nominal parameter, which will tend 10 11 to make plants go with their bounding tech spec values 12 to avoid having to constantly go into an operability evaluation. So it really reduced the usability of 13 14 that section 6 analysis. 15 I've made the point that we're still reviewing the SER and that, you know, we're going to 16 start focusing on the application of the guidance so 17 that we can continue on. 18 19 The combined impact of the changes on the 20 result, it really isn't known. That's an uncertainty 21 we're just going to have to deal with at this point if 22 it is finalized in its current form. 23 The calculations that have been performed 24 to date, I imagine as we continue on, some assessment

can be performed using those calculations to get an

1 idea of how significant these changes are. But that 2 hasn't been performed to date. 3 And lastly I'd like to point out the 4 uncertainties that have to be somehow accounted for 5 with the test programs that are ongoing. The chemical effect testing that is -- well, should get underway 6 7 very shortly. The initial results should be available before the end of the year. And the final results are 8 going to be available sometime, hopefully the first 9 10 quarter of 2005. And the second item is the downstream 11 12 effect testing. I'm uncertain about the schedule there. 13 14 Both of these test programs have the 15 impact of effecting the overall resolution process. The issuance of the SER for the quidance will start a 16 clock. Plants will be required to respond within 90 17 days of that issuance. And basically start their 18 19 evaluation. 20 They have until September of next year to 21 complete that evaluation. So anything, 22 uncertainties they have to deal with during that process complicates the final evaluation of the 23 24 resolution options. So we're concerned about that.

And then the schedule for implementing any

1 modifications as necessary is also shown in this 2 timeline. But the main point is the short time period between the issuance of the SER between now and 3 4 September 1st of next year, there are a lot of 5 uncertainties that need to be addressed. John, could I just repeat 6 MEMBER FORD: 7 what I said at the beginning? That if one of the modifications is to remove the cal-sil, if that is one 8 9 of the options being taken, you are aware that by removing silica, you will increase the possibility of 10 11 chloride stress corrosion cracking of the stainless 12 That might be an unexpected consequence of steel? doing this that should be evaluated either in terms of 13 14 test program or within the Reg Guide 15 guidelines. I've made note of your 16 BUTLER: 17 comment. I admit I don't appreciate it. I will take it back to those who can appreciate it. 18 19 VICE CHAIRMAN WALLIS: Okay, John, does 20 that conclude your presentation? 21 MR. BUTLER: That's is. 22 VICE CHAIRMAN WALLIS: We're almost 23 approaching the time when the Chairman said we had to 24 stop. So --CHAIRMAN BONACA: Well, the staff maybe 25

1	has a closing statement?
2	VICE CHAIRMAN WALLIS: Well, yes well,
3	that's it, I was just hoping we could end up with the
4	staff. If you can do it before twelve, Michael?
5	(Laughter.)
6	MR. JOHNSON: That's okay. Yes, actually
7	
8	CHAIRMAN BONACA: We come back at one but
9	if you guys want to go further now, that's fine.
10	VICE CHAIRMAN WALLIS: For those who are
11	impatient to learn more, we can stay here.
12	MR. JOHNSON: My comments are simply
13	conclusionary actually.
14	And has been said a number of times today,
15	and we would stipulate to the fact that there is
16	always more that can be learned, and we are going to
17	learn as we go forward, and we'll deal with what we
18	know.
19	And, for example, we're not opposed to
20	in fact, we'll consider issuing even a supplement to
21	the SE if that becomes appropriate based on something
22	that we learn. That's certainly within the realm of
23	possibility.
24	We recognize that there are areas where
25	there is not a lot of data. And that's, again,

1 something that we're going to continue to learn as we 2 go forward. But having said, and we've said a number 3 4 of times today, we believe that we know enough about this issue such that the staff's conclusion is that 5 based on the GR and the SE that there is reasonable 6 7 assurance of adequate protection for someone exercising the methodology and then making fixes. 8 9 The plants that do that will be in a safer The plants will have an understanding of 10 place. 11 whether they have a problem. That was one of John's 12 That was really the industry's thrust in points. terms of developing the methodology. 13 14 We agree that with the fixes pointed out 15 in the SE, that the staff -- the plants will have an understanding of whether they have a problem. 16 will certainly have a sense of comfort that fixes that 17 are made as a result of this SE, again, will result in 18 19 plants that are safer. We've had lots of interaction. I want to 20 21 go back -- I don't want you to leave with the 22 impression that, again, staff has not had a lot of 23 interaction. 24 We've had from the first draft report that 25 was submitted on this, we've had a full round of REIs.

1 We've gotten written response on those REIs. We've 2 gone back and had additional discussion. 3 There are many, many areas of 4 evaluation where we've had extended dialogue with the 5 industry on the evaluation. We're going to continue to dialoque. 6 7 One of the points that was indicated in a 8 letter from Tony Petrangelo to us last week was, for 9 example, that we have dialogue with vendors to understand what vendors are proposing in terms of the 10 11 fixes. We think that is a good thing. 12 We're going to work -- we're going to set up that dialogue. We've talked to Tony and they're 13 14 going to orchestrate that dialogue with the staff so 15 we understand what folks who are going to be fixing these problems are coming up with and the challenges 16 and so on and so forth. That's a good thing. 17 But I guess my bottom line is we've had 18 19 lot of interaction. 20 I do want to make the point that -- again, 21 I tried to make this point in my opening in terms of 22 what we see as our regulatory responsibility. 23 know, we -- again, we're faced with resolving problems 24 and, you know, sort of looking at justifications is

always the responsibility of the licensee to provide

1 an adequate justification. 2 It's the responsibility of the NRC to 3 decide whether that justification is adequate. 4 whatever fixes they put in place that would correct 5 that problem are adequate. And so that's the approach that we will have. 6 7 I'm very encouraged by the industry talking about additional tests. 8 And we want the industry to do additional testing if they feel it's 9 That would benefit the process. 10 appropriate. 11 would certainly look at whatever comes from that. 12 It's not the responsibility -- we don't feel at this stage that it is the responsibility of 13 14 the NRC to develop some new unthought of test program 15 to address these issues. We very much want the industry to continue 16 to do what is necessary and particularly could be 17 beneficial to address some of these refinements in 18 19 some of these areas where there is policy of data. 20 And so again, I just wanted to say we 21 believe it's time to go forward. We are going to 22 learn a lot going forward. But we believe it's time 23 to go forward with respect to the evaluation. 24 VICE CHAIRMAN WALLIS: I want to raise two

points.

1 You make statements about plant safety. 2 sure the plants are safe. We haven't 3 discussed any of that. We have no evidence. I don't 4 quite know how you make a statement until you see the 5 consequences. You can't make a statement on plant safety 6 7 based on these documents because they haven't been implemented yet. So I don't -- that's just a comment. 8 9 I think that's irrelevant to what we're here for 10 today. The ACRS isn't going to take any position on 11 plant safety because we haven't seen any evidence. 12 But we have taken an issue with some technical issues. And it seems to me that you say you 13 14 are comfortable. Are you comfortable with proceeding 15 without resolving what seem to be quite a few technical issues that we have raised? Are you really 16 comfortable proceeding without resolving technical 17 issues that we have raised? 18 MR. JOHNSON: Well, of course a few of the 19 20 technical issues you've raised are issues where we 21 have ongoing work. For example, chemicals. And 22 that's built into the resolution process. 23 We talked about downstream effects and 24 John -- and we have also indicated that there is some

ongoing work on downstream effects.

25

And that's

1 actually a part of the evaluation going forward. 2 In general, we have made changes response to the comments we've gotten. 3 And yes, I 4 think the answer is that the staff is comfortable 5 going forward. Not to say that this document is so perfect. We're still incorporating minor changes to 6 7 the document. 8 VICE CHAIRMAN WALLIS: I'm so surprised, Michael, because I come from a different environment 9 maybe where if I review of a technical paper for a 10 11 journal or if I review a student thesis, and if has 12 these sort of fundamental technical questions about it, it doesn't get accepted. 13 14 Maybe this is a different environment? Or 15 maybe you know something more? I don't want to continue the conversation. 16 17 Just personally I'm a little puzzled by your comfort. But it maybe because of the background I come from. 18 19 CHAIRMAN **BONACA:** Yes, Ι quess discomfort a little bit is due to the fact that I 20 21 really was left with the impression that we do not 22 have a full appreciation of the dimension of the 23 problem. 24 I mean we came up with dimensions of debris of different quantities, et cetera. So -- and 25

then that leaves me with uncertainty about the adequacy of proposed fixes.

So the sense I'm getting is that you do have an appreciation of the problem from what you're

address the problem. If you do not have a full

7 appreciation of what the problem is, I mean how can

you make a judgment on the adequacy of the fixes, you

saying even if it is the burden of the licensees to

know?

MR. JOHNSON: Well -- and I appreciate Tim's comments sort of explaining the differences. You know we were all struck by the numbers that Tim used at the end of the subcommittee meeting. And so we wanted to go back and look at where we thought a fiber plant, for example, would come out using the same evaluation.

And it is plant specific. And I think that helps. I don't think you heard from anyone that we need to add additional conservatism on the various aspects of this evaluation. What you heard, in fact, from the industry is that in some cases, they believe that we're overly conservative.

And, of course, the staff's response to that is we may be overly conservative. But if that is the case, it's because there are these unknowns that

1	somehow have to be accounted for.
2	CHAIRMAN BONACA: I don't worry about the
3	baseline calculation. At some point, everybody will
4	have to come in to the refinements. And that's really
5	what I'm wondering how they're going to apply them
6	based on what I've heard today. I realize I'm not a
7	member of the subcommittee but it was left to some
8	puzzlement in my mind.
9	MEMBER KRESS: Well, let me ask a question
10	about the head loss correlation. This is to you,
11	Mike.
12	You've treated one of the parameters, the
13	specific surface area, to beta points on various
14	debris mixtures. And you come up with the different
15	values for that depending on which test it was and the
16	mixture.
17	Will you require the use of the value for
18	that that gives the most conservative result? The
19	biggest head loss?
20	MR. LU: Could you repeat your question
21	again? We are trying to discuss what exactly you mean
22	in terms of the specific area there.
23	MEMBER KRESS: The head loss correlation
24	has parameters in it that were adjusted to fit the
25	data. And depending on which test you adjust it to,

1 you had different values. For example, for the 2 specific surface area. 3 Now my question is there is a range of 4 these or a choice to be made about which specific 5 surface area for which debris type you will use. my question was will you require that they use the 6 7 value that gives the most conservative result, that is 8 the biggest head loss? 9 MR. HARRISON: Looking at the calcium silicate test in particular, the specific surface 10 11 areas we came up with were identified with the worst 12 conditions that we found. And the recommendations had an addition ten percent factored in. 13 14 Ten percent in the specific surface area 15 could be as much as 21 percent in the head loss because it's the number squared in the correlation. 16 17 MEMBER KRESS: So actually you're making them use the most conservative quidance for that. 18 19 MR. HARRISON: And I believe we're also 20 recommending some enhancement on the actual number 21 determined from the tests, add a safety factor to 22 that. 23 Okay, thank you. MEMBER KRESS: VICE CHAIRMAN WALLIS: Mr. Chairman, it's 24 25 It's up to you to decide what to do next. yours.

1 CHAIRMAN BONACA: Okay. Any other 2 questions or points the members want to make? Please. MR. CULLISON: I would like to make a 3 4 point and that is that I think that there is a safety 5 problem here today. And I think that the Advisory Committee has to be careful that we not allow the 6 7 progress to move forward rapidly. 8 taking too long. think 9 recognize there is a real safety problem today that effects us within the design basis envelope. 10 11 On the other side, I think it's also clear 12 that there are various aspects of this where the staff believes there is conservatism with very little 13 justification belief 14 for that that there is 15 conservatism. And there is a need for clearly more work 16 beyond what exists as the basis that the staff would 17 use today for its evaluation. 18 19 So, again, let me point out that there are 20 two sides to this. But I think we have to be very 21 careful that we allow the industry to move forward or 22 we force the industry to move forward aggressively to 23 solve a problem that does exist today. 24 We often deal with hypothetical problems 25 that -- this is a real problem.

1	VICE CHAIRMAN WALLIS: Yes.
2	CHAIRMAN BONACA: That's why I was asking
3	those questions regarding is there going to be
4	additional work to be done to close some of these
5	issues.
6	MEMBER KRESS: Like confirmatory research.
7	CHAIRMAN BONACA: Yes. Because if that is
8	the case, the downstream risk is the one that the
9	licensees may have to do additional modifications to
10	their sumps. But still the trend is going to be in
11	the positive direction.
12	MEMBER APOSTOLAKIS: But again I'm not an
13	expert in this area but I'm puzzled by a couple of
14	issues. First of all, we've heard the time pressures.
15	And I agree with Rich. After 25 years, all of a
16	sudden there is time pressure?
17	Second, some of the proposed actions to
18	take care of the problem, which is something that
19	Graham keeps coming back to, I mean what are you going
20	to do at the end? Not just analyze the thing. Are
21	they very expensive to do? Are they all of them
22	are?
23	MEMBER SIEBER: Yes.
24	MEMBER APOSTOLAKIS: All of them are? I
25	understand the issue of increasing the surface area

1	but all of them are expensive? I mean the barriers
2	that Mario mentioned to limit the
3	MEMBER KRESS: Well, I mean that's
4	MEMBER SIEBER: It's all relative.
5	MEMBER APOSTOLAKIS: What?
6	MEMBER SIEBER: It's all relative.
7	MEMBER APOSTOLAKIS: Relative to how much
8	pain you're going to get by not
9	MEMBER SIEBER: You run the plant and make
10	the mods or don't run
11	MEMBER APOSTOLAKIS: Wait, wait, wait,
12	there are various kinds of pain.
13	MEMBER SIEBER: Money is
14	MEMBER APOSTOLAKIS: One is getting a
15	negative ACRS letter on this safety evaluation and
16	VICE CHAIRMAN WALLIS: George, you are
17	very right. I think we need an if this were a
18	student design project, I'd say you need an economic
19	analysis. I want to know what is the risk. I want to
20	know if we make a bad decision based on this SER, the
21	industry may have to spend 200 million dollars. How
22	much is it worth getting better information
23	MEMBER APOSTOLAKIS: That's exactly my
24	point.
25	VICE CHAIRMAN WALLIS: and working on

1	your research, which may coat me ten million dollars
2	
3	MEMBER APOSTOLAKIS: Yes, exactly.
4	VICE CHAIRMAN WALLIS: in order to save
5	the risk of making a 200 million dollar mistake.
6	That's the kind of thing I'd like
7	MEMBER APOSTOLAKIS: And that's the way
8	VICE CHAIRMAN WALLIS: because that's
9	the way I'd think if I were a business man.
10	MEMBER APOSTOLAKIS: and that's exactly
11	where I was going to. I mean
12	MR. HAFERA: Excuse me. I think on my
13	third slide, my last line, I projected some practical
14	solutions and some of those are fairly are not
15	necessarily it doesn't take a lot of engineering to
16	go get a bunch of insulators and double jacket your
17	insulation.
18	MEMBER APOSTOLAKIS: That's exactly
19	MR. HAFERA: And remove all your fiber
20	from the source term. There's a nice, inexpensive fix
21	that every plant could do.
22	MEMBER APOSTOLAKIS: So why aren't they
23	doing it then?
24	MR. HAFERA: Well, it's up to them to do
25	it.

1	MEMBER APOSTOLAKIS: Well, I understand
2	that.
3	MR. HAFERA: We can suggest it.
4	MEMBER APOSTOLAKIS: But that's my problem
5	that
6	MR. HAFERA: And, again
7	MEMBER APOSTOLAKIS: I see here again
8	a question that is open. There are strong
9	disagreements. Do more tests. Do more research. And
10	I'm wondering, you know, are there any solutions that,
11	you know, coming back to the internal combustion
12	engine. They didn't quite understand what was going
13	on but they built it. Maybe there are some solutions
14	here
15	CHAIRMAN BONACA: The only problem in that
16	example is that we will never know if the sump works
17	until you have a LOCA and hopefully we'll never have
18	it.
19	MEMBER SHACK: You know you've made it
20	better. Have you made it good enough?
21	MEMBER SIEBER: Yes because you have to
22	have the analytical methods and the data to know that.
23	CHAIRMAN BONACA: That's right. I mean we
24	are never going to take

1 actual things they can do that would be convincing 2 that result in adequate protection? 3 CHAIRMAN BONACA: Adequate protection? 4 MEMBER SIEBER: Until --MEMBER APOSTOLAKIS: Without studying and 5 expanding the methodology. 6 7 MEMBER SIEBER: -- until we have the database, which does not require extrapolation, and 8 9 the analytical methods that make physical sense, you 10 can't show whether you are good enough or not. though you can physically make improvements to the 11 12 plant. And so I think that you need to work on 13 14 both ends of it. I think there are more pieces of 15 data that need to be developed. I think there are improvements to the models that need to occur. 16 17 On the other hand, I think that licensees could be thinking in terms of not running tests to 18 19 avoid the requirement to extrapolate but to come up 20 with designs that will pull the operating parameters 21 into the realm of test data they already have, 22 reducing flow velocities, increasing screen area, eliminating debris to the extent that you can. 23 24 VICE CHAIRMAN WALLIS: Absolutely. MEMBER SIEBER: And so those are the kinds 25

of approaches that I expect. But moving forward the
way the SER now says and the guidance now says I think
will lead to a quagmire.
CHAIRMAN BONACA: Well, I think we need to
take a break now.
MEMBER APOSTOLAKIS: For what? Ten
minutes or lunch? Lunch?
CHAIRMAN BONACA: Yes.
MEMBER APOSTOLAKIS: What's going to
happen to the schedule now? Can we
CHAIRMAN BONACA: Like I said before,
we're going to take a recess now until one.
At one sharp, we're going to get together
and review ACR-700. And hopefully we can do it in an
hour. You know, that's the time we're allotted now.
And then we'll just resume the schedule as
we had it.
But I will start the meeting at 1:00 p.m.
sharp. So with that we can recess.
(Whereupon, the foregoing matter went off
the record at 12:16 p.m. to be reconvened in the
afternoon.)
CHAIRMAN BONACA: Okay. We are
CHAIRMAN BONACA: Okay. We are continuing the meeting and we have a quarrel. So we

1	Agenda, that's Pre-Application assessment report for
2	the advanced of 100 design. Dr. Kress?
3	MEMBER KRESS: Thank you. We, the staff,
4	since about 2002 or so has been working on the pre-
5	application review for ACR-700. And they've been
6	looking at what's been called focused issues.
7	And they have written this is a severe
8	I mean an SAR instead of it's a safety
9	assessment report. They've issued this. And you've
LO	gotten the copy of it.
L1	And hopefully most of you have read it.
L2	And that's what we're going to hear about today, the
L3	results that is. And I guess are you going to lead
L4	off Laura?
L5	MS. DUO: Yes, I'm just going to take a
L6	minute. Good afternoon, I'm Laura Duo. I'm the
L7	section chief for the new reactors group. Before we
L8	start, quickly, I just wanted to introduce Bill
L9	Beckner is the new program Director for our program.
20	Many of you remember Jim Lions going
21	through this. This is Bill's first opportunity to
22	come before you.
23	MR. BECKNER: I think you probably
24	remember me from other jobs.
25	MS. DUO: Okay, I know that we are

compressed on time. So, I'm going to go just through 1 this quickly and then turn this over to Belkys again. 2 3 Pre-application is in accordance with the 4 Commission's policy statement on advanced reactors. It 5 encourages the Staff to engage early on complex 6 technical issues and start a good dialogue with 7 applicants well before а design certification application comes in. 8 The goals of the activity we consider that 9 we're presenting today is sort of our completion of 10 11 phase two. Again, completion in the concept of pre-12 application is the identification of a path forward in design certification. 13 14 I don't think you're going to be hearing 15 any firm regulatory conclusions today, nor does the report have any firm regulatory conclusions. So, with 16 that, I'm going to turn that back over the Belkys. 17 MEMBER KRESS: But, before you do, I would 18 like to -- in the spirit of identifying the way to 19 20 move forward, I would like the committee to look upon 21 this meeting as a way to identify the things we need 22 to review and the issues we might be most interested 23 in when we get to our part of the review, certification of ACR Weather 700. 24

Thank you, with that now you can turn it

over.

MS. SOSA: Thank you, good afternoon. I am Belkys Sosa. I'm the Department Manager for the ACR-700 pre-application review. And, as Laura said, the purpose of today's meeting is to brief the Committee on the status of the pre-application review, to provide information to the Committee on the major issues identified in the pre-application safety assessment report, the PASAR, as we called it for the ACR-700 design, and to also request that the ACRS provide a letter on the Staff's assessment on the design and the feasibility of completing the design certification review.

Our Agenda is being modified somewhat due to the time limits. I'm going to try to go very quickly. What I have prepared today is an overview, very general type of presentation on the different focus topics.

We are planning a presentation by Don Carlson. And we also would like you to hear from the Applicant at AECL on the same topic. They have prepared a letter of presentation on what they intend to engage us on in the transition phase.

The approach for the pre-application review, again, was to identify some terms. We are not

1 trying to resolve the issues, we were trying to 2 facilitate the design certification review. 3 Phase one was the familiarization phase. 4 That lasted approximately a year. We also tried to 5 develop an understanding of the differences between the ACR-700 and other CANDU plants, to identify 6 7 existing regulations that may not be met by this design and to identify new regulations that will be 8 required in order to provide and ensure adequate --9 VICE-CHAIRMAN WALLIS: 10 This bullet of 11 differences, it seems to me you need to be clear about 12 what appear to be differences, but may be superficial because it looks differences, and what are real 13 14 differences about approaches to safety or defense in 15 depth, or the principles. And so, somehow separate those out for us 16 so we don't get lost in the details and we can see 17 these are the main key differences that affect 18 19 something at a higher level. Maybe that would help us 20 too. 21 MS. SOSA: That's a good point. The ACR-22 700 is light water cooled. It's not heavy water or --23 so there are some differences that we need to point 24 out. And we also have been engaged with the 25

Canadian Nuclear Safety Commission as another resource in the pre-application review, including several technical interactions with them.

They are -- designing -- now, the preapplication review scope was selected by the
Applicant. And there's 13 different areas. What you
see underlined are, for instance, the boundary design,
the computer codes and validation adequacy, the power
fueling confirmation of negative void reactivity and
the fuel design, are issues that AECL determined to be
key focuses.

Again, that was done in response to some concerns from NRC resource limitations. They said, please focus on this first. The item that you see in red is design basis access and acceptance criteria.

It was determined by the Staff to be the NRC priority. And the items that you see in blue, focus topics five, ten, and twelve, essentially do not have distinct sections in the report.

What we did is we wrote that information with the other focus topics. So, you won't find a separate chapter on that. The report for every focus topic contains a review scope section where discussion on what was reviewed and the guidance that it was reviewed again to the extent that it exits.

There's a section on regulatory issues that were identified for each focus topic. Again, rules, rulemaking are exemptions that will need to be resolved, are listed on there.

Potential policy issues, again, there's a section that discusses items that could potentially require upper management or Commission dinosaur resolution.

At this point we feel it is pre-mature to call any kind of policy issue because we haven't seen the application yet. Technical issues, again, it discusses significant technical items identified that will require additional data tests or analysis in order for a resolution to be issued.

And the conclusions section is nothing more than identifying what the feasibility of successfully completing the design. The Staff feels at this point that nothing that we've reviewed would preclude certification of -- not certification -- but moving forward with design certification.

Here are the major milestones in the preapplication. Phase one complete in July of 2003.

Phase two is currently ongoing and scheduled to
complete at the end of this month with issuance of the
report.

1 The draft report was provided to Committee for review September 16<sup>th</sup>. Essentially, the 2 3 PASAR will be issued at the end of this month. 4 November we will start with what we call the 5 transition phase. And that will go through until we actually 6 7 receive the application. 8 MEMBER KRESS: Do we have a target date 9 for completing the whole certification process yet? Or 10 is that too soon? 11 MS. SOSA: I think that is a little soon. 12 Once we receive the application we will develop our estimate on the schedule. Now, again, this is a very 13 14 general overview for each of the focus topics. 15 For class-one pressure boundary design we have a couple of regulatory issues involving 50-55A, 16 Essentially, for areas where ASME 17 the use of ASME. code requirements are not applicable or need to be 18 19 supplemented, the Staff will evaluate 20 acceptability of Canadian codes and standards. 21 Again, for the ACR-700 they don't have a 22 reactor vessel, they use pressure tubes. So, there's a regulatory issue there. But, the Staff feels that, 23 24 in accordance with 52-40A, the technical requirements

specified in 50-61, the pressurized thermal shock, the

1	fracture toughness and the materials surveillance
2	requirements are not technically relevant.
3	MEMBER APOSTOLAKIS: Excuse me, come back
4	to the first bullet. Does Canada follow the ASME
5	standards?
6	MS. SOSA: In some areas of the design
7	because of the unique aspects, for instance, the
8	material, the use in the pressure tubes, that's not in
9	by ASME. So, a lot of it is
10	MEMBER APOSTOLAKIS: But let's say that
11	the issue is is it possible that Canada will apply
12	its own standard? Or is that covered by what you say
13	there?
14	You say for those areas where the ASME
15	code requirements are not applicable.
16	MS. SOSA: Correct.
17	MEMBER APOSTOLAKIS: You look at the
18	Canadian standards. What about the areas where the
19	ASME code applies but they have their own standard?
20	MS. SOSA: For those areas we will use our
21	standards. So, only for areas where we don't where
22	it's not covered in ASME, then we use
23	MEMBER APOSTOLAKIS: I'm sure you'll teach
24	them to have their own standards. And they have
25	agreed to this

1 MEMBER KRESS: Evaluate the acceptability 2 the Canadian standards. you do When 3 evaluation of the Canadian standards, normally what 4 you do is compare those to ASME standards. 5 Are you going to basically be developing what you think our standard ought to be and see if 6 7 this meets it? How are you -- what is your acceptance 8 criteria. 9 MEMBER APOSTOLAKIS: Yes. 10 MEMBER KRESS: That's yet be determined, I guess. 11 12 I'd like to refer to MS. SOSA: Ted explanation on 13 to give you an 14 Actually, why don't I have Victor? 15 MR. SNELL: Victor Snell with AECL. Just to answer the question briefly, and sorry for --16 Belkys time -- for areas in Canada where ASME would 17 apply, we use it. So, it's just as simple as that. 18 19 MEMBER APOSTOLAKIS: Okay. 20 MEMBER KRESS: But it doesn't help the 21 issue about evaluating of how do you go the 22 acceptability of a standard. 23 MS. SOSA: Of the Canadian Standard? 24 MEMBER POWERS: Yes. For instance, if 25 you're working with the zirconium alloy, so you look

1 at a Canadian standard for that alloy. Have you 2 given thought at all to what it requires to review and 3 assess that standard? 4 MS. SOSA: I think the approach is going try to evaluate the standards to 5 6 applicable requirement, to the same level of 7 requirements that we have. But we will be using Canadian standards 8 for that. 9 10 MEMBER POWERS: Do you have a standard -is there a requirement in particular on deuterium 11 12 take-up by the alloy? Yes, this is John Fair. 13 MR. FAIR: to answer your specific one 14 going the 15 But, those design aspects that are not materials. covered by the code, specifically we tried to review 16 and see that they meet the intent of the code, which 17 is the margins of safety, etcetera. 18 19 For the materials aspect, they're going to have to look at details of materials, testing and 20 21 stuff like that, and the type of detailed review you 22 would do when accepting the materials that accepting the ASME code. 23 24 But we do not have specific criteria for 25 doing this evaluation.

MEMBER POWERS: I guess this sounds like it can be either an easy job or an impossible job. I mean, if I go in and look and say, okay, here's the standard, and here's a bunch of data, and sure enough they bound it up with the standard, it's not too difficult to do.

If, on the other hand, they go in and say, well here's the data to use, but here's the database that really exists and here's all the testing methods that hey did, and how good and reliable those testing methods are, and the bias that's inherent in the various testing methods, and the bias that was applied because the samples were not really pressure tubes but little plantchets that people tested and things like that. This could well be a lifetime occupation.

MR. FAIR: Well, we think that some of the areas are going to be difficult, but not impossible. I think there's a lot of test data out there on some of the areas that we don't have covered by the ASME code that ADCL has referenced.

And I believe that we're also going to be looking at doing some confirmatory stuff with our research. So, it's not an easy job and we agree with you, it's going to take a lot of effort to review some of these areas.

1 MEMBER POWERS: The problem see 2 inherently in it is there are data that are not cited either in the standards or by AECL that also exist on 3 4 these materials. And finding them is a chore. 5 MR. FAIR: Well, you may be correct on I mean, I can't speak to things I don't know 6 7 exist. Other than the fact that, when we get into the review, we'll probably do document searches and try to 8 get as much of the information as we could find out 9 10 there. 11 MEMBER KRESS: Is the process that 12 Canadians went through to develop their standards similar to the process we go through to develop ASME 13 14 standards? 15 I'll leave that to AECL to MR. FAIR: answer, but I believe so. 16 17 MR. SNELL: Victor Snell again. I can try and give a general answer, because I'm not a standards 18 19 But I think the general answer is yes. expert. 20 By in large, where ASME applies, we use 21 So, the Canadian standards have been developed 22 over a large number of years with operating 23 research experience, and basically come from initially 24 at the labs, and confirmed by operating

experience, and get formalized into standards by a

1	group consisting of the Canadian ministry playing
2	a sort of puddles over a park controlling role.
3	So, by the time the Standard comes out,
4	what it represents is an industry consensus that has
5	the input, if not the formal agreement of the
6	regulator, incorporates operating experience and
7	research experience, and stands as subject to revision
8	as things change.
9	That's basically the process that's been
LO	followed.
L1	MEMBER KRESS: Sounds very similar to the
L2	process we did.
L3	MEMBER POWERS: A skeptical person might,
L4	not that I am one, might say the old boys club gets
L5	together and sets the standard in Canada, just like
L6	the old boys club sets the standards in the United
L7	States.
L8	They cannot be considered consensus of the
L9	entire
20	MEMBER ROSEN: In the United States there
21	are safeguards that are implied by ANSE to attempt to
22	keep the old boy network under control.
23	MEMBER POWERS: Another old boy network
24	oversees the first old boy network.
25	MEMBER ROSEN: Well, there are certain
	•

1	criteria for who can be on the standards committee and
2	the representation and that sort of thing.
3	MEMBER APOSTOLAKIS: I thought Professor
4	Wallis this morning raised concerns about one of the
5	ANSE standards.
6	MEMBER ROSEN: Well, that's always
7	possible.
8	MEMBER APOSTOLAKIS: Didn't you say that
9	you looked at the models and
LO	MEMBER KRESS: I think we're going to need
L1	to move on on this issue. We've discussed the
L2	standards enough.
L3	MS. SOSA: Thank you. The PASAR also
L4	discusses various issues on degradation mechanisms
L5	that will require additional information and further
L6	review for resolution.
L7	Design basis access and acceptance
L8	criteria, focus topic number two again, this was
L9	the NRC priority during the pre-application period.
20	AECL proposed risk informed reactor accident and
21	clarification scheme, essentially introducing the
22	limit the core accidents as a new category.
23	The Staff recommends to adapt a
24	probabilistic event selection for ACR-700, this is a
2.5	line within the new risk inform initiatives. Severe

channel flow blockage and the stagnation
MEMBER APOSTOLAKIS: Wait, the second
bullet there says the Staff recommends a probabilistic
you're going to select design basis accidents using
MS. SOSA: No, we are going to look at the
limited core accidents in between category that AECL
is proposing, and make a determination based on the
probability and frequency, whether they belong in DBA
or severe
MEMBER APOSTOLAKIS: Yes, so you're using
probabilities to define the DBAs aren't you?
MEMBER POWERS: No, categorizing the
hypothesized accident into one of two categories, DBA
or severe accident. The accidents already exist.
MEMBER APOSTOLAKIS: The analysis, you
mean.
MEMBER POWERS: The scenario already
exists.
MEMBER APOSTOLAKIS: Yes.
MEMBER POWERS: The question is, is the
design basis accident that's subject to conservative
deterministic evaluation.
MEMBER APOSTOLAKIS: But it's an
interesting thing, though. I mean, you're saying that

1	as if it's the easiest thing in the world. I mean,
2	tomorrow we have a whole presentation on licensing
3	future reactors that will be risk
4	MEMBER POWERS: We know that the academic
5	community can complicate any subject.
6	MEMBER APOSTOLAKIS: I think there are
7	some skeptical members of this committee that do that
8	very well. There seems to be a disconnect. On the
9	one hand we have a major research project trying to do
10	that for future reactors.
11	And here we're saying, no, we're going to
12	adopt a probabilistic approach and do it. I'd like to
13	see that. I think we were supposed to have seen it
14	already.
15	MEMBER KRESS: They will also have a PRA.
16	MEMBER APOSTOLAKIS: Of course.
17	MEMBER KRESS: The PRA will look at the
18	whole range of accidents, like PRAs do.
19	MEMBER APOSTOLAKIS: I understand that.
20	But, I thought that's an issue that our staff is
21	facing is that DBA isn't PRA. What do we do about it?
22	MEMBER KRESS: What DBAs are supposed to
23	do is render the design into an acceptable safety.
24	What the PRA does is validate that, tell you whether
25	or not you have a risk.

1	MEMBER APOSTOLAKIS: I know.
2	MEMBER KRESS: So, I think the process
3	they're talking about may be workable. They may have
4	to they have to decide on what probabilistic value
5	they'll use for the break.
6	MEMBER APOSTOLAKIS: Yes.
7	MEMBER KRESS: And then that may be an
8	issue, I don't know. They may choose one of them, the
9	PRA and tell them, maybe we should have used a
10	different one.
11	They may have to adjust that. I don't
12	know what they plan on doing. I'm just throwing out
13	words.
14	MEMBER APOSTOLAKIS: Well, as I say,
15	tomorrow we will cover a whole presentation on the
16	issue.
17	MEMBER KRESS: Yes.
18	MEMBER APOSTOLAKIS: Maybe we can tell
19	them it's trivial, go, find out from these guys and do
20	it.
21	MEMBER KRESS: Say again?
22	MR. BECKNER: I don't know that Belkys
23	said it was going to be easy. I think she said that
24	was we intend to try. But I think we would concur
25	that it's not an easy task.

1 MEMBER DENNING: Could you give us some 2 idea as to what the threshold might be between what's 3 a design basis accident and what's a non-design basis 4 accident? 5 MS. SOSA: I'd like to defer to Jerry He was the chair of a working group that we 6 7 established specifically to look at this. MR. WILSON: Jerry Wilson, first of all, 8 I'd like to remind the Committee that the Staff has 9 been before the Committee several times on these non-10 11 NRWR policy issues, one of the issues of which was 12 selection of accidents for finite reactors. And this Committee approved that proposal. 13 14 And the Commission approved that proposal. And so, 15 the Staff is proposing to do is adopt that approach for this particular design. 16 17 And the specific answer to your question, I think the range that we're looking at for design 18 19 basis accidents would take us down into a frequency of 20 ten to the minus five. 21 MEMBER KRESS: I recall that this was a 22 process that Exxon proposed. 23 MR. WILSON: Something like that, similar. 24 But, we haven't worked out the details, but this a 25 proposal for going forward at this point.

1 MEMBER KRESS: And the selection of ten to 2 the minus five is based on what? Well, a range that was 3 MR. WILSON: 4 discussed in those policy papers that have been sent 5 to the Committee on the frequency it feels appropriate for design basis accident. 6 7 As an alternative to MS. SOSA: Okay. meeting the requirements of 50-34, the Staff may 8 9 propose a mechanistic fission product source term for commission consideration. 10 11 Computer codes and validation adequacy 12 were focused up in number three. This involved the neutronics tools, as well as the thermal hydraulics 13 14 codes. 15 The current physics codes that AECL brought in, the WIMS codes, DRAGON, RFSP, staff 16 17 determined will meet modifications and revalidation for ACR-700 conditions. 18 Experimental database on header and fitter 19 20 inventory on fuel distribution, horizontal fuel bundle 21 thermal hydraulics and RD-14M integral test is 22 required for a successful completion of design 23 certification. 24 Now, modifications to test facilities, 25 such as the RD-14M and CWIT, and the LASH facility,

may be required to correctly scale the ACR-700 design.
MEMBER KRESS: Now, I'm sitting here with
perhaps a mis-apprehension about these facts. Do
these requirements, the current physics codes, and
these modifications, for example, are those things
that you expect the Applicant to do?
MS. SOSA: Yes, they are currently working
on that.
MEMBER KRESS: Now, on the scaling
question, are you going to require that the AECL do a
scaling analysis?
MS. SOSA: The staff is currently doing a
scaling analysis.
VICE-CHAIRMAN WALLIS: Did you say
something about thermal hydraulic codes that I missed,
or are you just talking about physics codes?
MS. SOSA: The thermal hydraulic codes
were also reviewed, the ATHENA code was. Several runs
were performed. And, the outcome is what you see
here. Essentially it was determined that the database
would still need to be worked on to make sure that it
represents ACR-700 conditions, and that the test
facilities will have to be verified to make sure that
they are scaled correctly.
VICE-CHAIRMAN WALLIS: You have the ATHENA

1	code?
2	MS. SOSA: Yes.
3	VICE-CHAIRMAN WALLIS: We can use your
4	MS. SOSA: Yes, we have. And the Staff is
5	working on their own independent tool.
6	VICE-CHAIRMAN WALLIS: How do you verify
7	or decide to accept a code?
8	MS. SOSA: How do we verify?
9	VICE-CHAIRMAN WALLIS: How do you decide
10	that a code is acceptable?
11	MS. SOSA: Well, I'd like to defer to the
12	lead on the thermal hydraulics review, Walt Johnson.
13	MR. JOHNSON: Yes, we're going to apply
14	the Walt Johnson, reactor assistance branch. We're
15	going to apply the draft reg guide, 1120, which
16	VICE-CHAIRMAN WALLIS: Is this the one
17	that has never come out yet?
18	MR. JOHNSON: The reactor
19	VICE-CHAIRMAN WALLIS: We have been
20	working to get it out for eight years or something, is
21	that the one?
22	MR. JOHNSON: This is the one.
23	VICE-CHAIRMAN WALLIS: Maybe if you used
24	it, then that would be sort of day factor whatever
25	they say issuance.

1 MR. JOHNSON: I suppose it would. Ιt 2 seems like a good way to go as -- be done and requires 3 that the code be validated against the important areas 4 in the PIRT. 5 And we're going to follow the approach because it seems like the appropriate way to go. 6 7 VICE-CHAIRMAN WALLIS: That would be very 8 good. I think we'd be happy to see this document 9 used. 10 MS. SOSA: Thank you. Severe accidents 11 definition, adequacy of supporting research and 12 developing, focus topic number four. The NRC PIRT process identified a number of key technical issues 13 14 that must be addressed for successful completion of 15 design certification. The PIRT process also identified potential 16 17 deficiencies in the experimental database used to validate the analysis codes. And the Staff will use 18 19 MELCOR, will model on MELCOR to model the unique 20 characteristics of the ACR-700 configuration for 21 independent validation. 22 And, the Staff is not planning to conduct 23 additional experimental work. We anticipate that the 24 AECL experiments are going to be sufficient

validate the analysis.

1	MEMBER KRESS: Now, the Canadians use a
2	version of the map code for this?
3	MS. SOSA: Yes.
4	MEMBER KRESS: Have you reviewed that?
5	MS. SOSA: Yes. I'd like to defer that
6	question to Sid Basu. And he can elaborate a little
7	bit on what the plan is.
8	MR. BASU: Okay. This is Sid Basu from
9	research. I guess I missed Tom's question.
LO	MEMBER KRESS: I wondered to what extent
L1	you plan on reviewing the map code that the Canadians
L2	use for their severe accidents?
L3	MR. BASU: We are going to be looking the
L4	mapped ACR version that they are either developing
L5	currently or probably just about completed the
L6	development.
L7	And we're going to look into the code to
L8	see whether all the phenomena are adequately modeled
L9	there. That's currently the extent of our review
20	process.
21	MEMBER KRESS: With respect to no
22	experiments needing, are there any experiments being
23	done to look at LCI steam explosions in heavy water?
24	MR. BASU: Yes, they have planned which
25	is mostly interaction experiments. They have about

1	half a dozen experiments planned. They were going to
2	run the commissioning test with a smaller amount of
3	melt mass just to see, you know, how the system
4	facility works.
5	And I believe the test was planned some
6	time in August. I don't believe it has been run yet.
7	MEMBER KRESS: Do these tests include
8	substantial amounts of the caladium two and pressure
9	two metal components?
10	MR. BASU: Yes.
11	MEMBER KRESS: I think
12	MS. SOSA: Canadian design codes and
13	standards, focus topic six. The Staff believes that
14	SECY-47 has direct applicability to the use of
15	Canadian codes and standards for the ACR-700.
16	In response to that, the Commission
17	directed the Staff to review the international codes
18	and standards only as part of applications or pre-
19	application reviews.
20	So we believe that the ACR is covered by
21	that. Now, we expect, as you mentioned earlier, that
22	the review of Canadian codes and standards will have
23	a significant impact on the time and technical
24	resources of the Staff certification review.
25	So we are preparing for that. The next

1 focus topic is distributed control systems and safety 2 critical software. The Staff raise a question in their review on how the design complies with NRC's 3 4 position on defense in depth. 5 Since it appears at the trips head points for both the shut-down systems are the same, the Staff 6 7 question whether shut-down system one and two are 8 developed to meet the same systems functional and 9 software requirements. 10 AECL's presentation the last time we came 11 to the ACRS in January of 2004, indicated that 12 reliability safety critical of software is through particular quantitative 13 demonstrated 14 reliability goals. 15 This may raise an issue, since current NRC not provide the use 16 position does οf 17 reliability goals. MEMBER KRESS: But, is it precluding them? 18 19 Is the NRC position precluding the use of goals? 20 MS. SOSA: I'd like to defer that question to Mike Chramel, he can elaborate. 21 22 MR. CHRAMEL: I'm not sure. We say that 23 we don't allow quantitative reliability to be the only 24 means of verifying the quality of the reliability of

the system.

1	It could be used as an added incentive.
2	But it should be both qualitative and quantitative.
3	MEMBER APOSTOLAKIS: Well, in order to do
4	a quantitative analysis, you have to do the
5	qualitative first. So, it shouldn't be that hard to
6	satisfy that requirement.
7	I remember there were some funny words in
8	the regulations about the reliability goals related to
9	software. It didn't quite come to the point where
10	they said don't use them.
11	But, it clearly sent the message that you
12	guys were very cool toward the idea. Well, that was
13	a long time ago.
14	MR. ARNDT: That was seven years ago.
15	MEMBER APOSTOLAKIS: Seven years ago.
12	
16	Steve, do you want to say something?
16	Steve, do you want to say something?  MR. ARNDT: Steve Arndt. The other issue,
16 17	
16 17 18	MR. ARNDT: Steve Arndt. The other issue,
16 17 18	MR. ARNDT: Steve Arndt. The other issue, of course, was the particular methodology they use is
16 17 18 19	MR. ARNDT: Steve Arndt. The other issue, of course, was the particular methodology they use is not something we've specifically looked at, although
	MR. ARNDT: Steve Arndt. The other issue, of course, was the particular methodology they use is not something we've specifically looked at, although we're in the process of looking at similar things.
16 17 18 19 20 21	MR. ARNDT: Steve Arndt. The other issue, of course, was the particular methodology they use is not something we've specifically looked at, although we're in the process of looking at similar things.  MEMBER SHACK: But, do the two systems
16 17 18 19 20 21	MR. ARNDT: Steve Arndt. The other issue, of course, was the particular methodology they use is not something we've specifically looked at, although we're in the process of looking at similar things.  MEMBER SHACK: But, do the two systems meet the diversity goal? Are they using the digital

1 But, the thing we are looking for is the requirements 2 are the same or not. 3 MS. SOSA: On power fueling is focus topic 4 number eight. The Staff's approach was to compare the 5 design of the ACR-700 on power fueling systems to the design related regulations in part 50 and part 52. 6 7 The Staff determined that existing 8 regulations are adequate to support design 9 certification on power fueling for the ACR-700. Now, 10 the on power fueling process could be a relatively 11 high probability initiator for limited core damage 12 That's something that's -accidents. MEMBER ROSEN: Now, in reading the PSAR, 13 14 what I learned was that, for on power fueling, the 15 components that 10CFR would require in terms of isolation were the -- not be available in the current 16 design of the ACR-700. 17 Am I correct in that some additional 18 19 design work may be necessary to bring it into full 20 compliance, mainly in the area of double isolation and 21 those kinds of --22 MS. SOSA: I'd like to refer that question 23 to Steve Jones or John Fair as well. 24 MR. FAIR: Hi, John Fair. We've reviewed 25 it, the pressure boundary in accordance with 50-55A

1 designation in the regulations. And some of the lines 2 that were coming off of the refueling machine didn't have double isolation valves. 3 4 And I believe AECL was considering whether 5 they were going to change some of those designations to conform with U.S. regulations are not. 6 7 MEMBER ROSEN: Well, isn't it time to stop 8 considering and kind of fix on a design weakened 9 review? I'll leave that to AECL. 10 MR. FAIR: MS. DUO: This is Laura Duo again. 11 12 Again, pre-application was looking at some of the larger issues in having -- forward. Once we had the 13 14 design certification application, that's where we 15 start to get into those issues more deeply. 16 But, until we have that application 17 submitted, we have to review what we have before us. MEMBER ROSEN: Well, I think you can say 18 19 that isolation isn't important. But, if it's clearly 20 not in conformance with some of the requirements of 21 part 50, I mean, that's a show stopper, isn't it? 22 MR. ARCHINOFF: Can I just interject for second. It's Glen Archinoff, AECL. As far as I know, 23 that one has been taken care. That change has been 24 25 made in the design, that particular one.

1	MEMBER ROSEN: Well, there are few others.
2	In reading I don't have a mental picture of it
3	right now. But, I'm reading when I read that I was
4	concerned there were a number of things.
5	None of them looked like terrifically big
6	hitters. But, if they weren't fixed, they simply
7	wouldn't comply. So, I think we'll have to focus on
8	that in the future.
9	MEMBER KRESS: Well, they'll either have
10	to comply or get an exemption.
11	MEMBER ROSEN: Right. They can always get
12	an exemption.
13	MEMBER KRESS: I know it's unheard of.
14	MEMBER ROSEN: Well, I mean, exemptions
15	have to have due cause and all that shown.
16	MEMBER SIEBER: On the last bullet you
17	have on this slide, what's the scenario of the core
18	damage actions to
19	MS. SOSA: Okay, I'd like to defer to
20	Steve Jones for that one.
21	MR. JONES: Steve Jones, NRR. The both
22	operational experience and AECL's preliminary
23	probabilistic safety analysis indicated a couple type
24	of events may result in failure of the end fitting,
25	either due to failure of the refueling machine to

1 properly re-seal the fuel channel, or due to impact of 2 the fueling machine with the end fitting. 3 In that case, events such as fuel ejection 4 from the fuel channel are possible. 5 MEMBER SIEBER: Okay. MS. SOSA: Okay. Thank you. Confirmation 6 7 of negative void reactivity, focus topic number nine. 8 And, again, Don is here to provide you more detail. 9 We heard you and got some feedback last time we were here in January, where you referred to 10 11 this issue as probably the number one issue to look at 12 during the pre-application review. So, based on that feedback, we prepared a 13 14 more detailed presentation for you. Now, the Staff 15 feels that, again, the design that they reviewed during pre-application is a preliminary design. 16 17 So that's important to recognize. If the AECL comes in with a design that's still -- has not 18 19 eliminated the potential for substantially positive 20 reactivity during the initial checkable reading, they feel that they would raise a similar issue as that in 21 22 SECY-92. 23 MEMBER KRESS: Could you elucidate us on 24 what checkable --25 MS. SOSA: Yes, I think that Don has

1 prepared a detailed presentation on that. So, I will 2 defer him. So, again, the challenge here will be what level of confidence are needed for establishing 3 4 compliance with GCD11. 5 Here is focus topic number 11. The issues, again, after review is the treatment of 6 7 limited core damage accidents. And risk objectives should be expanded to address both the limited core 8 9 damage accidents and the severe core damage accidents. And the definition is there. 10 Limited 11 core damage accidents are accidents that involve just 12 a single channel, by design, do not propagate to the entire core. 13 14 And, severe core damage involve the entire 15 core. 16 MEMBER SIEBER: What are the consequences, 17 however, of limited core damage accident? limited to inside containment and contamination? 18 Or 19 is there a potential for external consequence? 20 MS. SOSA: That's a good question. 21 think I'm going to defer to Marty Stusky. 22 the room. 23 This is Marty Stusky from MR. STUSKY: 24 NRR. The Applicant stated that the consequences of 25 limited core damage accidents are confined inside the

1	containment building itself, which would be small
2	because it's only one 296 <sup>th</sup> of the core inventory or
3	so, single channel. It's something we'll look at.
4	MEMBER SIEBER: Okay. Thank you.
5	MEMBER POWERS: What are consequences
6	outside the containment then are all relative or
7	dependent on what the leak rate from the containment
8	would be.
9	MR. STUSKY: That is correct.
10	MS. SOSA: Okay. The last focus topic is
11	the fuel design. The design certification process for
12	the ACR-700 fuel will deviate from past practices.
13	The reason is that AECL does not have a
14	referenced CNSC approved ACR-700 fuel design or fuel
15	performance methodology. The fuel design criteria
16	deviates from SRP 4.2.
17	And the ACR-700 design and operating
18	conditions deviate from operational as well.
19	MEMBER POWERS: That's the whole set of
20	things, right?
21	MS. SOSA: Yes, it's very different.
22	Their fuel design is very different.
23	MEMBER KRESS: I understand the CANFLEX
24	shown has a much thinner clad around it.
25	MS. SOSA: I'd like to defer the question

1	to Paul Clifford.
2	MEMBER KRESS: The question is what are
3	the implications of that with respect to, say,
4	appendix K type acceptance criteria.
5	MR. CLIFFORD: Yes, Paul Clifford, NRR.
6	Yes, the cladding for the CANFLEX is about 30 percent
7	thinner than typical LWR cladding. The cladding is
8	thinner, it is designed to collapse instantly during
9	initially due to system pressure right onto the fuel
10	channel.
11	MEMBER KRESS: Minus the heat transfer?
12	MR. CLIFFORD: Correct. They have a very
13	high heat rate. And that's required to transfer the
14	heat.
15	MEMBER KRESS: What are the implications
16	of that with respect to the 17 percent clad oxidation
17	criteria?
18	MR. CLIFFORD: The clad is our force, so
19	we're familiar with the behavior. As far as clad
20	rupture or burst during a LOCA, we don't expect it to
21	do any worse than what we've seen in a current white
22	water reactors.
23	We expect the 2,200 and the 17 percent to
24	be applicable.
25	MEMBER KRESS: Oh, that's my question.

1	I'll have to think about that one.
2	MS. SOSA: Now, AECL's limiting reactor
3	experience database for higher burnout slightly
4	enriched uranium fuel bundle designs may a reliance
5	of ongoing irradiation programs, which are not going
6	to be completed until 2009 timeframe.
7	MEMBER KRESS: You talked about higher
8	burn-up SEU fuel there. My impression was that the
9	burnouts were on the order of 25 megawatt days per
10	ton. Now, I wouldn't call that high burnout.
11	MR. CLIFFORD: Well, I think it referred
12	to higher the current
13	MEMBER KRESS: Oh, higher than the
14	current.
15	MR. CLIFFORD: Right, the current is about
16	2,000. And the AECL would be looking somewhere
17	between 25 and 30,000.
18	MEMBER KRESS: I see, much higher than the
19	current database on that fuel.
20	MR. CLIFFORD: Right, well within our
21	experience database for the reactors.
22	MEMBER KRESS: Okay, I understand that.
23	MEMBER SIEBER: And that's due to the
24	slight enrichment?
25	MS. SOSA: Yes.

1	MR. CLIFFORD: Right.
2	MS. SOSA: So, in conclusion, the Staff
3	has prepared carefully for reviewing the ACR-700
4	design certification application. Based on the
5	information provided by AECL during the pre-
6	application review, the Staff identified a number of
7	issues that will require more detail for resolution.
8	But, we did not identify any issues that
9	would preclude certification of the ACR-700 design.
10	MEMBER APOSTOLAKIS: What are the top are
11	the top two issues, the most important ones? You have
12	identified a number of issues.
13	MS. SOSA: I think what the presentation
14	has kind of touched on today is probably gives you a
15	good idea of where we are.
16	MEMBER APOSTOLAKIS: But there are
17	several.
18	MS. SOSA: Is one issue.
19	MEMBER APOSTOLAKIS: The what?
20	MS. SOSA: The coolant reactivity is one
21	issue that will have to receive a lot of attention
22	during the certification. Everything else we have
23	discussed today.
24	The fuel design is another significant
25	area.

	231
1	MEMBER POWERS: And she failed to mention
2	the most important one, which is the aqueous chemistry
3	of iodine in the containment building.
4	MS. SOSA: I'm saving that one.
5	MEMBER POWERS: She has an entire
6	presentation on that one.
7	MEMBER KRESS: If there's one thing the
8	Canadians know about it's that.
9	MEMBER POWERS: They probably got it
10	wrong, so we need to review it carefully.
11	MS. SOSA: The Staff is currently
12	preparing a SECY paper to inform the Commission on the
13	issues identified during the pre-application review in
14	preparation for design certification.
15	MEMBER KRESS: Thank you very much.
16	MEMBER POWERS: If I could, I'd like to
17	ask a question.
18	MEMBER KRESS: Yes, sir.
19	MEMBER POWERS: It's a question of you.
20	MEMBER KRESS: Oh, well in that case, no.
21	MEMBER POWERS: As you are acutely aware,
22	I am aging, and so my memory suffers.
23	MEMBER KRESS: I hadn't noticed.
24	MEMBER POWERS: Do we have within the
25	regulations for advanced reactors considerations of

1	issues of non-proliferation and other national
2	policies regarding nuclear materials?
3	MEMBER KRESS: I don't think so. I don't
4	think those are in the regulation. Now, somebody may
5	correct me.
6	MEMBER APOSTOLAKIS: They are not.
7	MEMBER KRESS: I don't recall ever seeing
8	any questions about proliferation in the regulations.
9	MEMBER POWERS: Does the Committee have
10	obligations in regard to the issues of nuclear
11	materials for proliferation?
12	MEMBER KRESS: I would think our Committee
13	ought to think about everything having to do with
14	issues of public health and safety.
15	MEMBER POWERS: That's a safeguards issue.
16	MEMBER APOSTOLAKIS: I don't think so. I
17	think that's an issue of national policy
18	MEMBER KRESS: That's a policy issue.
19	MEMBER APOSTOLAKIS: It's not us.
20	MEMBER KRESS: I don't think it's
21	something we have to if I'm going to review
22	something like the CANDU, I'd normally ask that
23	question in terms of my certification review.
24	We might ask why not put them underground,
25	because they are less susceptible to terrorist

	253
1	attacks.
2	MEMBER APOSTOLAKIS: Is that stuff part of
3	10CFR?
4	MEMBER KRESS: No.
5	MEMBER APOSTOLAKIS: No, it's not. So
6	it's none of our business.
7	MEMBER KRESS: I think we stick to 10CFR.
8	MEMBER APOSTOLAKIS: And it's not the
9	Agency's business either.
10	MEMBER KRESS: That's probably right.
11	MEMBER SIEBER: No, I think proliferation
12	is explicitly part of the Atomic Energy Act, George.
13	So, it very much is part of our business.
14	MEMBER APOSTOLAKIS: It's Commission, but
15	it's not
16	MEMBER SIEBER: If you look legislation,
17	you are definitely covered by the Atomic Energy Act.
18	MEMBER POWERS: That's where the limits on
19	fuel enrichment come from.
20	MEMBER APOSTOLAKIS: I didn't hear that.
21	MEMBER POWERS: That's where the limits on
22	fuel enrichment come from.
23	CHAIRPERSON GEOFFREY: Just a second. I
24	hate to break in, but we were supposed to gain back
25	half an hour. And, it took 45 minutes to deliver a 20

1	minute presentation.
2	Now, there is going to be how many other
3	presentations.
4	MEMBER KRESS: We're going to hear from
5	the Canadians.
6	CHAIRPERSON GEOFFREY: We have 30 minutes
7	left. I'm sorry. Somebody has to manage the time.
8	And we'll certainly go over the hour at this point.
9	But, I need to watch the time.
10	MEMBER KRESS: I think this is certainly
11	legitimate questions.
12	CHAIRPERSON GEOFFREY: I understand. I'm
13	not arguing. I'm only saying that
14	MEMBER KRESS: I think it might be better
15	to ask the Staff if they're going to consider those
16	things in their certification review. And I think the
17	answers going to be, leave those to the safeguards
18	people.
19	CHAIRPERSON GEOFFREY: Yes.
20	MEMBER KRESS: But, anyway, we'll give you
21	the floor now.
22	MR. CARLSON: I'm Don Carlson. I'm in the
23	Office of Research. And I'm going to be talking about
24	pre-application focus topic nine, confirmation of
25	negative void reactivity.

1 That's chapter eight in the PASAR. 2 let's jump right into the highlights from my pre-3 application review. As you've heard before, we've 4 conducted PIRT processes for ACR-700. 5 There's actually three coordinated PIRT sub-panels, one on nuclear analysis, which is what 6 7 I'll be talking about. And we mentioned already 8 thermal hydraulics in severe accidents. 9 A major insight that emerged from the 10 nuclear analysis PIRT was the importance of 11 checkerboard voiding of alternate channels in ACR-700 12 large LOCAS. And so, there was already a question asked 13 14 about that. As you recall, the CANDU reactors and 15 ACR-700 in particular are horizontal pressure tube 16 reactors. 17 ACR has one inlet header at one end, and another inlet header at the other end, and, likewise, 18 19 outlet headers. And so, the flow of coolant and the 20 flow of fuel during on-line fueling is in opposite directions in alternating channels. 21 22 When you have a large break LOCA, let's 23 say it's an inlet header, then the channels that are 24 connected to that inlet header, void very quickly, say

in a about a second, more or less, depending on the

size of the break.

And, that's every other channel in the core. And the other channels remain cooled for several seconds. The insight from the PIRT panel was you go from half voiding to full voiding.

But, what really counts in LOCA analysis is the half voiding, because, by the time you get to full core voiding, hopefully you will have -- the reactor, after which time of course inherent reactivity effects like void reactivity are of no consequence whatsoever.

So, as soon as we identified this, we actually had a PIRT meeting right after the last time we briefed the Committee on ACR-700 in January, in which this came up.

And, out of that meeting, we did a number of calculations of checkerboard void reactivity. Now, the AECL design analysis that was presented to us for the pre-application review reported a full core void reactivity, that is all the coolant in all of the channel is voided, not checkerboard, of minus seven milli-K.

And this is based, it seems, on a tradition in Canada of analyzing traditional CANDUs that way. And it's probably appropriate to do that.

1 But, as I'll explain in a moment, the physics of 2 checkerboard reactivity substantially different in this design. 3 4 And, it turns out the checkerboard void 5 reactivity gives you positive effects. So, the results of our calculations were reasonably consistent 6 7 with AECL's. Analyzing similar cases, similar models of 8 full core reactivity, roughly in agreement with them 9 on the slightly negative full core void reactivity, in 10 our calculations discovered that the checkerboard 11 12 reactivity was positive. And we did these calculations doing 13 14 different models, different methods, different 15 analysts, and got consistent results. So we're confident that we're correct in this assessment that 16 17 -- positive that there is a positive checkerboard void 18 reactivity. 19 Now, I should interject too that there is 20 no such thing as pure checkerboard voiding. You get void fractions of maybe 90, 95-99 percent in the 21 22 voided channels. 23 And the cool channels will have void 24 fractions of a few percent. But, again, the insight

from the PIRT was, rather than focus on full core void

1	reactivity, let's find let's focus on another
2	figure of merit that's relatively simple to define in
3	calculating. That's the checkerboard void reactivity.
4	VICE-CHAIRMAN WALLIS: What's the pattern
5	of this checkerboard? Is it just a like a
6	checkerboard?
7	MR. CARLSON: It's exactly like a
8	checkerboard.
9	VICE-CHAIRMAN WALLIS: Alternate channels
10	run across the whole matrix?
11	MR. CARLSON: The whole face of the
12	reactor core you have alternate channels with coolant
13	coming at you and going back in the opposite
14	direction.
15	VICE-CHAIRMAN WALLIS: It seems to me that
16	can happen, there must be a lot of other modes besides
17	perfect checkerboard.
18	MR. CARLSON: Just about all it happens
19	over a large range of large break sizes and locations.
20	The term checkerboard voiding is a reasonably good
21	description of those patterns.
22	CHAIRPERSON GEOFFREY: The patterns come
23	about because of the way the headers are set up?
24	MR. CARLSON: Yes.
25	MEMBER KRESS: It's a little bit of

1	surprise to me that that gives you positive, whereas
2	the whole core gives voiding gives negative.
3	MR. CARLSON: Yes, it came as a discovery.
4	Nobody really foresaw this.
5	MEMBER KRESS: Do you want to explain that
6	to us?
7	MR. CARLSON: Yes.
8	MEMBER SHACK: Why wouldn't you be
9	concerned about that in a conventional CANDU? It's
10	got the same thing, right?
11	MR. CARLSON: Well, I could let AECL
12	explain it. But I think it's fairly simple. In a
13	conventional CANDU void reactivity effects are more
14	linear.
15	So, if it is say 20 milli-K or 18 milli-K
16	positive in a conventional for full core voiding than
17	half core voiding, regardless of whether it is
18	checkerboard or other pattern it's roughly half.
19	MEMBER KRESS: That's what I was going to
20	guess. But there are reasons why it's not in this
21	one.
22	MR. CARLSON: In this case it's not
23	linear.
24	MEMBER KRESS: Obviously.
25	MR. CARLSON: That was the major insight.

1	Before I try to explain a little bit about the physics
2	and other technical insights, I want to make a few key
3	points.
4	First of all, as Belkys mentioned, this is
5	a preliminary design. It evolved somewhat during the
6	pre-application review and may evolve further. We'll
7	see what AECL submits for design certification.
8	Another point worth mentioning and this
9	is one area that distinguishes ACR from conventional
10	CANDUs conventional CANDUs have a fuel temperature
11	coefficient that is very small, essentially zero.
12	This design has a more negative Doppler
13	fuel temperature coefficient. It's maybe a half to
14	two thirds as strong as what we're used to in PWRs and
15	BWRs.
16	But it's clearly negative. And so, the
17	effects of fuel temperature, fuel heat-up, may tend to
18	limit the power surge just by positive checkerboard
19	voiding.
20	MEMBER KRESS: And the material design
21	criteria, this is 11, is it?
22	MR. CARLSON: Yes.
23	MEMBER KRESS: It doesn't necessarily
24	preclude a positive void coefficient?
25	MR. CARLSON: No, it does not. I mean,

1	coolant density effects figure into the assessment in
2	relation to GDC11. But, one could approve a design
3	with positive power coefficients based on GDC11 not
4	positive power coefficient, power void reactivity.
5	GDC implies some power coefficient, and is
6	considered to be met in light water reactors with the
7	existence of negative Doppler and negative power
8	coefficient.
9	And you might have that in a CANDU even
10	though there is positive void reactivity.
11	MEMBER SIEBER: On the other hand, the
12	Doppler is weaker than a standard light water reactor.
13	MR. CARLSON: Somewhat weaker.
14	MEMBER SIEBER: And so, an accident
15	limited by Doppler in standard light water reactor
16	Doppler may go a few milliseconds to a pulse power of
17	1,000 percent.
18	Maybe you would get more than that in this
19	case.
20	MR. CARLSON: We are evolving a capability
21	to do the transient analysis. Everything that I'm
22	going to be presenting now, and everything we've done
23	to date really is static calculations of K effective
24	voided versus K effective cooled.
25	PARTICIPANT: That's what I was going to

1 This checkerboard -you impose ask you. 2 checkerboard, and then you see what happens? you let it evolve in a transient? 3 4 MR. CARLSON: So far the question confirm 5 negative void reactivity. That was the preapplication --6 7 PARTICIPANT: The next thing is, how does this checkerboard evolve, what does it do? 8 The 9 question is, how does it evolve, and what does it do? MR. CARLSON: The question is, how does it 10 evolve, and how does the overall transient play out 11 12 when you consider the effects of void reactivity and Doppler reactivity. 13 14 And so we're evolving the capability to do 15 that, so is AECL. I wouldn't describe ours or theirs for what I've sent to date as yet to the level of best 16 17 estimate. PARTICIPANT: Do you let the checkerboard 18 19 evolve naturally as a sort of instability from a steadier situation, a more uniform situation? Or do 20 21 you impose a checkerboard on someone? 22 MR. CARLSON: Well, it's -- the thermal 23 hydraulicists hypothesize a break in size 24 location, and calculate the break flows. And it's a thermal hydraulic calculation. 25

1	PARTICIPANT: How does it checkerboard?
2	MR. CARLSON: The header breaks.
3	PARTICIPANT: And then it must be a
4	checkerboard, no matter what, because the way the flow
5	has to go.
6	MR. CARLSON: Or something above the
7	header.
8	MEMBER RANSON: Is the coolant borated in
9	this reactor?
10	MR. CARLSON: No, it is light water
11	coolant. If you like, I have some back-up slides if
12	you want to spend a minute reviewing what this design
13	is in relation to conventional CANDUS.
14	MEMBER KRESS: I think we're okay.
15	MEMBER RANSON: Is there boric acid in it?
16	MR. CARLSON: Not in the coolant under
17	some operating conditions they have very small amounts
18	of boron or gallium in the moderator, not the coolant.
19	MEMBER KRESS: Okay, moving on.
20	MR. CARLSON: And that does have a
21	positive effect on void reactivity. So, some of the
22	technical insights. First of all, I think I mentioned
23	this when we were talking to you in January, the void
24	reactivity is a combination of large positive and
25	large negative contributors.

1 MEMBER KRESS: Yes, when I see that it 2 always scares me. Do you plan on doing an appropriate uncertainty analysis when you --3 4 MR. CARLSON: Exactly. 5 MEMBER KRESS: Okay. MR. CARLSON: I can talk about that as we 6 7 It is, because of that actually, non-linear 8 with partial voiding. It can be positive during 9 checkerboard voiding, even though it is negative for 10 full voiding. And it is sensitive to void distribution 11 12 not only between channels, like checkerboard void reactivity, but within channels. You get different 13 14 void reactivity, substantially different between 15 stratified versus uniform density reduction within a 16 channel. 17 And, again, it is sensitive to core 18 design, operating parameters. For example, whether 19 there is boron in the moderator. Burn-up effects, it 20 is sensitive to some uncertainties, perhaps, in the 21 fuel burn-up isotopics. 22 So, another important point to make is the confirmatory measurements of coolant void reactivity 23 24 have never been done in operating CANDUs because it's

inherently difficult and may not be done for ACR-700,

1 although we are considering novel ways of doing it, 2 say in an initial core. 3 But, AECL has not identified any plans to 4 measure it in an ACR-700 operating core. But you will do some 5 MEMBER KRESS: critical experiments? 6 7 MR. CARLSON: Well, hence the importance 8 code validation based on benchmarks against 9 critical experiments in zero power critical facilities. 10 MEMBER KRESS: And you can rely on your 11 12 calculation tools. But those experiments have 13 MR. CARLSON: 14 be representative. And there -- AECL has 15 identified some existing data from Italy, from Japan, from the UK. 16 17 And they are in the middle, or early stages of a rather extensive program using their ZED2 18 19 experiment facility at Chalk critical 20 specifically aimed at validating void reactivity and 21 other effects for ACR-700. 22 MEMBER POWERS: When you say that the 23 measurement is inherently difficult, are you implying 24 that, if I did the test, I would get data that were 25 sufficiently scattered that I might not be able to use

1	it for confirmation?
2	Or are you saying it's just
3	extraordinarily difficult to get
4	MR. CARLSON: It's a feasibility issue.
5	Here we're talking about voiding of an entire channel.
6	Actually, half the channel is in the court.
7	And there's a small number to measure
8	there, right? The small void reactivity. Well,
9	imagine voiding a channel voiding channels in
10	existing power reactors.
11	It has never been done. Now, we have
12	thoughts about how it could be done. But, you know,
13	it's not cheap, it's not easy, and it's not
14	MEMBER SIEBER: It would be easier in a
15	CANDU than it would be in any other.
16	MEMBER POWERS: I guess what I'm asking
17	is, suppose that I found a way to do it, would the
18	data be sufficiently precise that I could arrive at a
19	confirmation of my model?
20	Or would they be sufficiently scattered or
21	replica tests that I might come up with, well, maybe
22	it's okay?
23	MR. CARLSON: I think you're saying it's
24	hard to get a clean experiment. And I think that's a
25	valid observation. So, not have a clean experiment,

1	you know, not having a clean measurement, because not
2	an experimental facility, you could get scatter.
3	So, the bottom line is, we're looking at
4	relying on critical experiments in CIE to validate
5	this.
6	MEMBER POWERS: If it's just difficult,
7	then that's one thing. But, if it's difficult and I'm
8	not guaranteed to get my answer, then it's not worth
9	pursuing.
LO	MR. CARLSON: We could discuss this at
L1	length.
L2	MEMBER KRESS: I'm certainly leaning
L3	towards the end of that spectrum that says you're not
L4	going to get good data.
L5	MR. CARLSON: Yes, that's why a huge
L6	heroic effort. You come back a little bit like you
L7	kissed your sister, you know, it didn't leave you with
L8	a great deal of thrill.
L9	MEMBER KRESS: I wouldn't know, I've never
20	tried that.
21	MEMBER POWERS: I wouldn't know, I don't
22	have a sister.
23	MR. CARLSON: It's an important
24	observation. It's a significant observation. It's
25	never been done for any operating CANDU to date. And
	·

1	they have reactivity issues in operating CANDUs.
2	It's positive strongly positive in
3	operating CANDUs. So, the checkerboard void analysis
4	requires, in our case, some changes to our methods and
5	models.
6	And we're starting to implement those.
7	And specific testing is part of the ZED2 test program.
8	The specific experiments have to be done to address
9	checkerboard void reactivity.
10	And the way they do validation
11	traditionally needs to be modified because of the
12	checkerboard void reactivity issues.
13	MEMBER POWERS: Have you looked at the
14	consequences yet of the reactivity excursion during
15	your checkerboard?
16	MR. CARLSON: I mentioned earlier that
17	we're evolving a capability to do that based on parts
18	coupled with trace. We're getting there. And we
19	should be have some good progress on that in the
20	next year or so.
21	MEMBER POWERS: I mean, can one do just
22	like a back on the envelope give me some feel for
23	like the amount of energy I put in?
24	MR. CARLSON: We've seen preliminary
25	calculations from AECL on that. But I wouldn't regard

1 them at a level that I would draw really good insight 2 from that. 3 So, we're evolving so we have models that 4 are of adequate quality that we can develop real 5 insight. I mean, if I put in two 6 MEMBER POWERS: 7 calories per gram, I'm not going to get too excited. If I put in 200 calories per gram then maybe my pulse 8 rate -- it's a little better than kissing your sister 9 in that case. That's a hot time in the old town 10 11 tonight. 12 Well, the problem is it is MR. CARLSON: very sensitive to the magnitude of the coolant void 13 14 reactivity. 15 MEMBER KRESS: But you could use that as a parameter. And I think you could handle the Doppler 16 coefficient at a relatively simple way. You could 17 probably d your calculation. 18 19 MR. CARLSON: It's very hard to a priori 20 develop a point kinetics model that mean anything. You have to do a spatial kinetics. 21 22 MEMBER POWERS: I'm afraid it's like all 23 I can get you a number, but it's the these things. 24 tails of the distribution that count here. And they 25 go up to the point that something unkind happens.

1 MEMBER KRESS: Right. 2 They're very slim reads. MR. CARLSON: 3 Okay, let's talk a little bit more about physical 4 impact --5 MEMBER KRESS: This is why you get the checkerboard positive void coefficients? 6 7 Not exactly. MR. CARLSON: These are calculations done for full core void reactivity, very 8 9 simple ones. But we're trying to understand where AECL, our CANDU are going, from where they've been. 10 11 And where they've been in conventional 12 natural uranium, NU, natural uranium CANDUs to ACR-And so we did some simple calculations of the 13 14 neutron spectral shift that happens upon voiding the 15 coolant, 100 percent, not checkerboard. in a conventional CANDU, 16 17 spectral shift fairly subtle. And I won't discuss it at length, although it does make for a interesting 18 discussion. 19 The main point here is, for ACR-700, that 20 21 coolant is very much a moderator also. So voiding it 22 really changes the increases, spectrum 23 dramatically, and you get a great increase in the fast 24 end epithermal region and a decrease in the thermal --

25

it's a slight softening.

1 And that's hard to talk about. It's 2 easier to talk about if you do your calculations and 3 then edit out what the four factor formula spectral 4 contributors are to all this. 5 And we did it again for conventional CANDU and for the reference pre-application design, actually 6 7 for a very simple case of a lattice of fresh fuel. So this doesn't correspond exactly to 8 irradiated fuel. But the trends, overall observations 9 are valid here. In a conventional CANDU -- you see in 10 11 the first two columns, we got something from the 1995 12 paper presented by Whitlock & Company from the AECL showing that -- what the spectrum components were of 13 14 void reactivity in a conventional CANDU. 15 We did calculations with HELIOS 1.8 at Purdue University and got very similar results. 16 17 observation is that the positive void reactivity in a conventional CANDU is the summation of moderate 18 19 positive contributors, the largest one being increase 20 in residence escape probability with voiding. 21 Now, with ACR-700, for full voiding we see 22 in the third column there that -- of large positives and large negatives. And, interestingly, what was 23

conventional CANDUs is now the strongest negative

formerly the strongest positive contributor

24

1 contributor, 72.4 milli-K negative. 2 Fast fission factors, high thermal 3 utilization factors, high reproduction factors, small. 4 And it all adds up to give you a few milli-K negative. 5 We then analyzed the case of 50 percent uniform voiding. We just did uniform density 6 7 reduction in the coolant channels. And you see that 8 the contributors are somewhat linear, 9 perfectly. And so, they all go down by half or a 10 11 little more. And it sums up to actually a void 12 reactivity that is more negative than full core voiding. 13 14 And then, for checkerboard voiding, the 15 minor -- again, it deviates from linearity, but each of the contributors, but in a different way. And now 16 17 it is positive, 3.5 plus. And the biggest change has been in the 18 19 residence escape probability. There are six point one 20 milli-K right there, which counts for the difference 21 by itself. 22 But there are other factors that balance 23 of it This has, course, uncertainty out. 24 implications. Uncertainty and contributors add up to 25 big uncertainties in the small sum.

1 MEMBER KRESS: That's what worries you 2 about that sort thing. 3 MR. CARLSON: And it gives you sensitivity 4 -- just now that it's very sensitive -- to operating 5 conditions to voiding patterns, etcetera. MEMBER KRESS: But this, even if you do an 6 7 uncertainty analysis to ensure that the range of the coefficient -- reactivity coefficient -- is not too 8 big, for example, but still submitted a positive on 9 one end, that doesn't preclude the acceptance of that, 10 11 does it? 12 MR. CARLSON: Yes, I mean, we will analyze what it all means. 13 I guess the question is, 14 MEMBER KRESS: 15 how positive does it have to be before you really --16 I guess it depends on the other power coefficients. 17 MR. CARLSON: Yes. Ι mean, to put 18 whatever the source of the reactivity is in 19 perspective, whether it is voiding or Doppler, one 20 dollar, you know, the effective delayed neutron 21 fraction, is about five milli-K in an equilibrium 22 core. 23 So, these numbers are large in relation to 24 a dollar. The reactor period is a strong function of 25 how far over you are -- key effective -- in the prompt

neutron lifetime.

So, in this reactor, the prompt neutron lifetime is ten times longer than what we're used to in conventional -- in light water reactors. But it is three times shorter than what you have in conventional CANDUS.

Again, you'd be able to balance it out when you have the parts coupled with trace and do some parametrics. So, that table was just for the simplified case of a lattice of fresh fuel bundles in both cases.

Then we proceeded to do some calculations taking into account burn-up for both uniform and mixed burn-up lattices. Because you have refueling from both ends, in the middle of the core you will have roughly similar burn-ups in neighboring channels.

At either end you will have very different burn-ups in neighboring channels. So we did cases with kind of a mid-core burn-up of 12.3 gigawatts per ton and then a checkerboard or a mixed burn-up of 1.6 and 24.4, which would be very much near the ends of the reactor.

These are simple two dimensional infinite array cases, but they provide good physical insight.

It carries over quite nicely into three dimensions in

1 some cases.

So, for the uniform burn-up, we get -- it doesn't -- we did the two voiding patterns, checkerboard one voiding pattern is we voided the lighter shaded channels.

And the checkerboard two voiding pattern in the second column there is where we voided the darker shades ones. So, of course, it doesn't matter in the case of uniform burn-up.

It's plus 4.7 milli-K for uniform burn-up.

And full voiding is minus 3.4. For mixed burn-up it makes a great deal of difference whether you are at one end of the reactor versus the other.

Where you're voiding the higher burned fuel, then it is plus 65. milli-K. What this means then is, if you have positive void reactivity and a LOCA, the power-surge that happens will also have a significant axial tilt.

This 6.5 end of the reactor will be more reactive than the other. But the whole reactor probably will go up and might tend to be turned abound by Doppler.

So, the main conclusions on this focus topic was that the reviewed preliminary nuclear design of ACR-700 does not have negative void reactivity in

1	large LOCAS.
2	As we mentioned, the design changes could
3	be made to reduce LOCA void reactivity. Those design
4	changes would involve increasing dysprosium and
5	enrichment in the fuel design.
6	MEMBER KRESS: Some things that probably
7	don't want to do?
8	MR. CARLSON: Well, Alaska AECL. And,
9	again, very important, CDR bias and uncertainties are
LO	potentially large in relation to nominal values. And,
L1	AECL's ongoing experimental work, particularly at ZED-
L2	2, but also their fuel irradiations, and isotopic
L3	assays that will come out that will be important
L4	benchmarks for quantifying and uncertainty.
L5	MEMBER ROSEN: What can you say about the
L6	effect the large LOCAS and negative void reactivity as
L7	a function of power? In other words, compare two
L8	cases, a full power case and a zero power case.
L9	MR. CARLSON: Well, are we talking
20	strictly about void reactivity? Void reactivity seems
21	to be a fairly weak function of fuel temperature.
22	And, low power to a neutronics person
23	means lower fuel temperature.
24	MEMBER DENNING: But, in the tangent
25	makes a lot of difference where the power levy

1	MR. CARLSON: Oh, I see what you're
2	saying, yes. And, yes, that's one of those things
3	we'll have to analyze with a transient analysis
4	capability, like we're developing with Park's.
5	You can't really do it with static
6	calculations and draw meaningful conclusions.
7	MEMBER ROSEN: Well, my experience with
8	positive coefficients, in the case I know of, moderate
9	temperature coefficients, reactors PWRs these days
10	are often designed with positive moderator temperature
11	coefficients.
12	But they only are so for part of the
13	cycle, usually up to mid-cycle, and usually only at
14	very low power. So, I was wondering if there's any
15	sensitivity like that here, certainly not there's
16	no boron in these reactors, so it's not the same.
17	MR. CARLSON: Well, only the moderator
18	under some conditions.
19	MEMBER ROSEN: Yes, under some conditions.
20	But there's no sensitivity in power
21	MR. CARLSON: Well, it's not no
22	sensitivity, but it's not a strong sensitivity.
23	MEMBER ROSEN: Okay.
24	MEMBER DENNING: A comment on the
25	uncertainties, and that is that, you know, I think

1 even today you could have done a fairly simplistic 2 uncertainty analysis. Obviously 3 it depends upon state 4 knowledge to what you do. And I think it would be 5 interesting to see that. And, obviously, as time goes on people would be able to do that better. 6 7 But I think, as good practice, we ought to really try to look at the uncertainties on these 8 9 numbers, because we could be -- I mean, all of those cases might be positive. 10 Or all of those cases may be negative, as 11 my quess based upon the realistic assessment of 12 uncertainties. 13 MR. CARLSON: I think you're leading into 14 15 We actually do have -- the path my next slide. forward is we're going to continue trying to develop 16 our analysis capability and, of course, in parallel 17 review analyses of these transients by AECL. 18 But, our capability involves modifying the 19 20 Park's code and coupling it with a suitable trace 21 model of ACR-700 and MELCOR where needed for 22 simulating operations and accidents, including the 23 combined effects of void and Doppler reactivity, and 24 including parametric sensitivities on uncertainties or

biases in void reactivity and other effects.

1 But the second bullet here is interactions 2 with AECL to assess the applicability and adequacy of the existing and planned sets of experiments for 3 4 validating code predictions of void reactivity and 5 other effects, and to provide timely identification in gaps in what they're trying to do with those two 6 7 experiments in their fuel irradiations. And we'll be doing that using state-of-8 9 the-art methods that the research has developed over the past eight years or so in the code modules called 10 11 Scale Tsunami. 12 They are sensitivity uncertainty analysis methods based on generalized perturbation theory to 13 14 join solutions to the transport equation. And that 15 type of approach, I think, is a sophisticated and very useful way of doing what you're talking about. 16 17 MEMBER KRESS: I think we need to move on. Thank you very much. Now I think we're going to hear 18 19 from the AECL. 20 MR. ARCHINOFF: Good afternoon. My name is Glenn Archinoff. I'm the ACR Licensing Manager 21 22 with AECL Technologies. I'd like to thank the 23 Committee for giving us the opportunity to say a few 24 words here today. Before I begin, just let me introduce the 25

1 other folks that are here as well. John Paulson is 2 the President of AECL Technologies right there. 3 Victor Snell is the Director of Safety and Licensing. 4 Peter Boczar is the Director of Reactor 5 Core Technology. And Ben Rouben is the ACR Physics Robert Yan, ACR Licensing, and Kyle Reed 6 7 from Bechtel is here with us as well. 8 I'm going to start with a very brief 9 presentation discussing the pre-application phase, just a very brief overview. Belkys has pretty much 10 11 covered what I was going to say. 12 So I'm going to be very brief. And then we'll get to Peter, who's going to talk about the work 13 14 that we're doing to improve our reactor physics 15 methods. And then we'll continue the discussion on 16 coolant void reactivity. The objective that AECL 17 Technologies had for the pre-application phase was 18 essentially to determine if the design of the ACR-700 19 20 could be certified within the U.S. Regulatory 21 framework in a reasonably timely manner. 22 particular There were two areas 23 We know that some parts of the regulatory emphasis. 24 framework aren't really a good fit with the underlying

CANDU design.

1 So we need to see how that was going to 2 work out. Another aspect was that NRC Staff -- or not 3 NRC Staff are familiar with the underlying 4 technology. 5 And we knew it was going to take time for Staff to come up to speed. And Belkys covered the 6 7 activities in the two phases of the pre-application 8 phase. She mentioned the focus topics. 9 won't go over those. But, just to get to where we are 10 11 now, as we come to the end of phase two of the pre-12 application. We believe that the main objective of pre-13 14 application, in fact, has been met. Our view is that 15 the certification of the ACR-700 design within the regulatory framework is feasible. 16 17 Belkys talked already about CANDU specific aspects, where the regulations just don't fit or don't 18 19 And we would apply Canadian requirements. And we believe we will be able to show 20 21 that they meet the intent of U.S. regulations. There was a tremendous amount of interaction with NRC Staff 22 23 during pre-application phase. 24 Something like 34 formal deliverables over 25 300 additional documents were submitted. 23 in-depth

1 technical meetings were held, a lot of interaction. 2 And we believe Staff are now 3 familiar with the technology. And so, that would 4 facilitate a timely design certification process. 5 Now, of course, there are still issues to address. And Belkys has discussed some, and Don 6 7 discussed some as well. And so, that will be the focus of our next phase, which we call the transition 8 phase, which will be from now until the time we 9 actually submit the application. 10 11 Our objective for that phase is to make 12 high confidence that have that the sure we certification application we submit will be acceptable 13 14 to NRC. 15 And, for this phase, we've identified a smaller set of focus topics. Right at the top of the 16 17 list there, reactor physics codes and coolant void reactivity, but a number of other ones as well. 18 19 And, once we have received the pre-20 application safety assessment report, there may be 21 other focus topics, depending on what's in it, and 22 depending on our further discussions with NRC Staff. 23 So, that's a really quick summary of what 24 we feel was achieved in the pre-application phase to 25 date, and where we intend to go from here. If there

1	are any questions on that, I'd be happy to take them.
2	But, otherwise, we could move on to the
3	other presentations.
4	MEMBER RANSOM: What is the status of the
5	certification in Canada?
6	MR. ARCHINOFF: There isn't an analogous
7	formal certification process in Canada. What's
8	happening in Canada is what we call a license ability
9	review, where the CNSC is reviewing pretty much the
10	same material that we've given to NRC for the purpose
11	of making the determination of whether they think the
12	design will be licensable.
13	That will culminate essentially in a
14	letter, identifying if there are any major concerns or
15	impediments to licensing. So, it's analogous to pre-
16	application, but it's not as formal.
17	MEMBER RANSOM: What do you mean by
18	licensable? Licensable in Canada?
19	MR. ARCHINOFF: Canada, yes.
20	MEMBER KRESS: This question may be out of
21	line, but do you intend to build one of these in the
22	U.S. at a U.S. site? Or are there other reasons for
23	there are other reasons for certification I know.
24	MR. ARCHINOFF: Yes, our hope is that one
25	of these will be built maybe more than one, maybe

1 a whole bunch will be built in the U.S. 2 MEMBER POWERS: I'm pretty sure they're counting on 25 in Tennessee. 3 4 MEMBER KRESS: UVA will buy anything. 5 MR. ARCHINOFF: I'm going to turn it over to Peter Boczar now. 6 7 MR. BOCZAR: Thank you. Good afternoon ladies and gentlemen. It's a pleasure to be here. I 8 9 have responsibility for physics and fuel in AECL. 10 Given that these are two of the focus topics, I have 11 an interesting life. 12 I'm going to talk about physics in this one. Just a very, very short overview presentation to 13 14 give you an idea of where we are and where we are 15 going with respect to the physics tools that we're 16 using. After me, Ben Rouben will describe some 17 details of the actual LOCA analysis in response to 18 19 some of the earlier questions that you had. 20 of our current tool set, it's based on three stages to the calculation, a lattice calculation using WIMS 2D 21 22 transfer code, a multi-group transport calculation, condense the two energy groups averaged over the cell. 23 24 There are some devices in the core that 25 are vertical in the reactor, they are perpendicular to

1	the fuel channel, so they're not normally represented
2	in the lattice calculation, in the 2D calculation.
3	So we use a 3D transport calculation to
4	represent those effects. And then those shell average
5	cross sections are used in the reactor calculations
6	RFSP two group diffusion theory.
7	This code does a number of different kinds
8	of calculations, time average calculation, refueling
9	simulations, the day-to-day fuel management
LO	calculations, xenon transients, kinetics calculations.
L1	And our kinetics calculations include
L2	thermal hydraulic feedback in accident analysis such
L3	as LOCA. An important part of the tool set is MCNP.
L4	There are obvious limitations to the reference tool
L5	set.
L6	We will use MCNP to benchmark the
L7	reference calculations, determine the uncertainties,
L8	the applicability of the analysis approach.
L9	MEMBER KRESS: Would that be equivalent to
20	the park's code?
21	MR. BOCZAR: No, MCNP is a sorry, MCNP
22	is a fundamental, theoretically rigorous code. There
23	are no approximations in MCNP. It's a Monte Carlo
24	simulation.
25	So it's only limited by the detail in your

1	modeling and the nuclear data. So it's used as a
2	numeric benchmark.
3	VICE-CHAIRMAN WALLIS: Well, there's an
4	approximation in treating nuclearized of their
5	spheres or something. I mean, at some level there's
6	approximation.
7	It's not exact model of anything. The
8	level of approximation is normally acceptable.
9	MR. BOCZAR: Yes. It is as accurate a
10	calculation as one can achieve.
11	MEMBER DENNING: But, of course, there's
12	this statistical uncertainty associated with the Monte
13	Carlo element of it.
14	MR. BOCZAR: Yes, of course, there's a
15	statistical uncertainty which one can address by
16	MEMBER DENNING: If you wanted to know.
17	MR. BOCZAR: It's used by Los Alamos for
18	the things they do there.
19	MEMBER RANSOM: Has there been any
20	comparison between like RFSP and the Park's code that
21	you've heard about?
22	MR. BOCZAR: TO date we haven't undertaken
23	comparisons of our toolset with Park's. We've done
24	comparisons with namely with MCNP, because any
25	other codes that has approximations compared to MCNP.

1 Now, as we go forward, as you'll see, we engaging independent assessments of 2 will be 3 adequacy of the analysis. So, of course, we're keenly 4 interested in the accuracy of the code, the 5 suitability of our modeling. 6 And assessment of the tools has been an 7 important part right from the onset. The key ACR physics phenomena that we have here compared to the 8 current CANDU, there's a tighter neutronic coupling 9 between adjacent lattice cells, because the lattice 10 11 pitch or the separation between adjacent channels has been reduced from 28 centimeters to 21 centimeters. 12 There can be greater heterogeneity between 13 14 adjacent cells. And that's not necessarily the case 15 for normal operating conditions. But there are scenarios such as checkerboard voiding where there is 16 17 greater heterogeneity between adjacent channels. And that has to be accounted for. Leakage 18 19 tends to be greater as well. Our assessment to date 20 is that the toolset is adequate for most applications. 21 So, for normal refueling, for the normal 22 design calculations, the toolset is adequate. 23 are enhancements that are desired for certain 24 heterogeneous configurations.

is

alluded

to

in

And

this

25

Don's

1 presentation as well. So, speaking to those 2 enhancements then, I mentioned the three parts of the calculation. 3 4 The first part, the fundamental part, is 5 the lattice calculation. Normally we model a single lattice cell in isolation. So, this might be what one 6 7 normally models in isolation of -- the assumption is an infinite lattice of that cell and the effects of 8 the adjacent cells is normally accounted for by some 9 sort of leakage correction. 10 MEMBER POWERS: Just use a mere boundary 11 condition or something like that? 12 MR. BOCZAR: Something like that, yes. So 13 14 we've just released a beta version of WIMS, which has 15 considerable enhancements, considerable theoretical improvements over the version of the code that we've 16 17 been using till now. It has an improved residence treatment, a 18 19 more detailed geometrical representation. 20 example, we can represent explicitly a bundle that, 21 for some obscure reason, sits at the bottom of the 22 fuel channel, rather than concentrically suspended in the middle of the fuel channel. 23 24 We are putting in place what we call this 25 multi-cell capability where, instead of just modeling

1 one cell in isolation, we can model -- in this case I 2 shown a two-by-two checkerboard where 3 properties of one cell might be different from the 4 others. 5 So, this cell is cooled, for example, and the adjacent neighboring cells, if we reflect this, 6 7 are voided. So, in doing this, one can explicitly model the effect of the environment on the properties 8 of the cell of interest. 9 VICE-CHAIRMAN WALLIS: That's easier than 10 11 the problem where it's partially voided and you don't 12 know where the water is. We can also model -- the MR. BOCZAR: 13 14 assumption here is that we do know where the water is. 15 when we do a couple RFSP ATHENA transient calculation, we get feedback from ATHENA as to the 16 17 voiding. VICE-CHAIRMAN WALLIS: And mostly a sort 18 of annular flow where liquid films on the walls. 19 20 that what you have most of the time? 21 MR. BOCZAR: It's -- the blow down happens 22 very quickly, within about a second for the voided 23 channel. And the void distribution, we believe, is 24 fairly uniform because of the high turbulence. 25 Okay, so we believe this capability by

itself will be sufficient to address most of the 1 2 issues that we have encountered. In terms of the 3 whole reactor code, the RFSP calculation, we've 4 developed an improved treatment of burn-up, which we 5 call micro-depletion. So this modeling takes into account the 6 7 local history of the fuel at that point in time. And, the local conditions on the history, so the coolant 8 9 density, the fuel temperature. 10 And we're also adding specific 11 enhancements to address heterogeneity between adjacent 12 cells, so, to be able to use this information from the last calculation and the full core calculation. 13 14 And it's this enhanced toolset that will 15 be used for the DCD, for the analysis that supports And we'll be validating this toolset, of 16 17 course. MEMBER ROSEN: Hold on for a minute. 18 19 occurs to me that, if you're thinking about fuel 20 depletion and using the exact state of a CANFLEX 21 module in a calculation, this is different than a 22 light water reactor in this country because these 23 CANFLEX modules move along the channel during the 24 course of their --

Yes.

MR. BOCZAR:

1	MEMBER ROSEN: in reactor times. So,
2	it's not like a fuel assembly in a PWR, for example,
3	where you put it and it stays put.
4	MR. BOCZAR: Yes.
5	MEMBER ROSEN: This one changes not only
6	because of the burn-up and flow changes, perhaps
7	MR. BOCZAR: Yes.
8	MEMBER ROSEN: but because it moves.
9	MR. BOCZAR: Right.
10	MEMBER ROSEN: And so, you have to keep
11	track of all of that.
12	MR. BOCZAR: Exactly. So that's what RFSP
13	does.
14	MEMBER ROSEN: I see.
15	MR. BOCZAR: It simulates the actual
16	movement of fuel in the channel as a result of the
17	main thing is refueling. And, of course, it models
18	the effect of depletion and isotopic changes.
19	And it reflects the actual local
20	environment and the history.
21	MEMBER ROSEN: So, when you start a
22	transient in a given instant, where all these channels
23	what was it, a dozen assemblies per channel?
24	MR. BOCZAR: Yes. There are twelve
25	bundles per channel.

1 MEMBER ROSEN: Which all have moved and, 2 you know, so you've got this huge array of 3 channels, or whatever it is, with 12 assemblies per 4 channel, all of which have moved and have a history. 5 MR. BOCZAR: Yes. And, typically, if you look at eight channels, suppose this is a channel and 6 7 you start refueling at this end, and the ACR-700 is a two bundle shift. 8 So you add two bundles at one of the 9 So, at one end of the channel the fuel I 10 channel. 11 relatively fresh, it's relatively new. And, as that 12 fuel gets moved down the channel with a result of subsequent refueling, you know, it burns up. 13 14 So, the fuel at the other end of the 15 is depleted. channel So, the fuel management simulation, RFSP, accounts for that. So, our analysis 16 17 approach, we use WIMS 3.0. We'll be incorporating enhancements to 18 19 RFSP to reflect the environment. We'll supplementing 20 that specific analysis with MCNP analysis to get a better handle of the calculation uncertainties. 21 22 And, of course, I mean, you can look at 23 the calculational uncertainties. But there's only one 24 way to find out what reality is. And that's to

measure it.

1 So, the foundation of our qualification is 2 based on measurements, experiments, cold, clean, critical experiments as Don mentioned in his ZED-2 3 4 facility at Chalk River. 5 And this is а very, very flexible facility. We'll be measuring everything that moves. 6 7 So we'll be measuring the effects of checkerboard 8 voiding. We'll be measuring the effects of partial 9 voiding. We'll be measuring the effects of different 10 11 burn-up distributions, using fuel and using simulated 12 burned-up fuel. We'll measuring 13 be temperature 14 coefficients, all the reactivity coefficients. 15 with that, the whole intent there is that, for each of the -- parameters, we'll establish a bias and an 16 17 uncertainty. Then that bias and uncertainty will be 18 reflected in the safety an licensing analysis. 19 mentioned other critical facilities. We'll be getting 20 some information from NRU irradiations. 21 22 So, for example, information on depletion 23 We have dysprosium as a neutron of the fuel. 24 absorber, which is unique, in our reactor. We'll be

getting validation data for that depletion from NRU

1	irradiations.
2	MCNP for filling in the gaps, for scaling,
3	for extrapolation, from ZED-2 conditions to reactor
4	power conditions. And I mentioned previously that we
5	will be engaging independent assessments to confirm
6	the adequacy of both the modeling and the adequacy of
7	our qualification.
8	We believe that the series of experiments
9	we have planned at ZED-2 are fully adequate and
10	sufficient to validate the toolset. But we'll get
11	independent confirmation of that. And these are the
12	conclusions.
13	VICE-CHAIRMAN WALLIS: When you say it's
14	not adequate, do you have some criteria about how
15	accurate it needs to be?
16	MEMBER APOSTOLAKIS: Come on.
17	MR. BOCZAR: That's really, in my view an
18	iteration
19	MEMBER APOSTOLAKIS: This is the physics.
20	It's not thermal hydraulics. This is science.
21	VICE-CHAIRMAN WALLIS: I don't care if
22	it's the size of fork for lifting manure, it's still
23	got to be adequate on some basis.
24	MR. BOCZAR: The final basis is the safety
25	analysis. We have to show that, with the

1 uncertainties and the biases that we have the margins 2 that we believe we have. 3 So, it's hard to establish what 4 acceptance criteria is a priori and in isolation of 5 the subsequent use of that information in a safety analysis. 6 7 MEMBER DENNING: Isn't reactivity coefficients your ability to predict reactivity 8 coefficients that's critical to us from a safety 9 viewpoint, as opposed to fuel depletion or things like 10 11 that, which we don't care about? 12 MEMBER APOSTOLAKIS: Then we'll use multigroup theory. 13 14 MR. BOCZAR: We use --15 MEMBER DENNING: No, but isn't that the criteria? 16 Your ability to accurately give 17 credibility in the reactivity coefficients that you calculate theoretically. 18 The reactivity coefficients 19 MR. BOCZAR: 20 are certainly important. But, the process we follow 21 I think is very similar to the U.S., where, for each 22 of the important accidents, we define the phenomena. 23 And, for each of those phenomena, the 24 important contributors to those phenomena from each of 25 the disciplines. So, in physics, the reactivity

coefficients are obviously a very important parameter.
But, the ability to measure power is
another important parameter, so that you control the
compliance with bundle power and channel power limits.
So, reactivity coefficient are important,
but there are other things too. Your ability to
calculate the depletion of dysprosium will impact on
the accuracy of your void reactivity calculations.
MEMBER APOSTOLAKIS: No, but I think the
point of the comment was that we are reviewing safety
here. So, the purpose of your presentation, as far as
we are concerned, is the reactivity coefficients.
MR. BOCZAR: Well, those parameters that
impact safety
MEMBER APOSTOLAKIS: I mean other things
are for different things.
VICE-CHAIRMAN WALLIS: And the question
that would be what's the risk of being wrong in
those coefficients? I mean, what's the uncertainty?
Is it a very low probability that you'll exceed some
criteria and, whatever?
MEMBER APOSTOLAKIS: I think so. That's
when the parameters come into the picture, so much
more uncertain.
MR. BOCZAR: We establish the

1	MEMBER APOSTOLAKIS: The least of your
2	worries should be the calculation of the reactivity
3	coefficient.
4	VICE-CHAIRMAN WALLIS: Well, probably this
5	is a much more certain area than many other areas we
6	get into.
7	MEMBER KRESS: When it comes to reactivity
8	insertion accidents, can they revert back to the old
9	criteria or acceptability, because this is almost
10	fresh fuel and it has 25K burn-up, mostly.
11	MEMBER POWERS: In the end, the old
12	criteria really is a pellet clad interaction
13	criterion. And their clad collapses down
14	MEMBER KRESS: It's already collapsed on
15	to the
16	MEMBER POWERS: onto the fuel. So I
17	can't imagine the mechanics are anywhere near alike.
18	MEMBER KRESS: Do we need to do reactivity
19	insertion tests for this kind of fuel?
20	MEMBER POWERS: Well that's I mean, the
21	issue is one of magnitude here. And, before I started
22	asserting a need to look at pellet clad interactions
23	in this configuration and it is a little softer
24	fuel on top of that.
25	You need to get this magnitude issue down.

1 It's less bothersome here because you're talking about 2 a voided channel. And so, what are you going to 3 disperse your fuel onto, a cooled zirconium clad? I 4 mean, it's not quite the same issue. 5 MEMBER KRESS: It's not the same issue. It's a different issue 6 MEMBER POWERS: 7 So, I think you really -- that is why I was anxious to know whether we are working with a two 8 calorie problem or a 200 calorie problem, because my 9 reaction to them are completely different. 10 We did look at source term consequences of 11 12 having a reactivity insertion felt like you're just not in the same league with a little diffusion 13 14 release. 15 MR. BOCZAR: I think that's a perfect 16 segway into the next presentation. Ben Rouben is the manager of the -- one of the two physics branches at 17 AECL. 18 19 Is the manager of the Physics branch at 20 Sheridan Park, and he's also the ACR Physics Manager. 21 MR. ROUBEN: Good afternoon. I have a 22 short presentation to pursue the question of void 23 reactivity. Now, for the ACR-700, the choice of the 24 void reactivity was made to provide a good balance of

nuclear safety or nuclear protection between one kind

of accident, the LOCAS, and another category of accidents, the fast cool down accidents.

And so, one requirement which stands from that objective of balance was to ensure that the power transient in any design basis accident would be mild before the tripping of the reactor, before all accidents.

Just to repeat what was said before, in the ACR-700 the design of the coolant system is two passes in a figure of eight so that, in adjacent channels, the coolant is flowing in opposite directions.

And, if we have large loss of coolant, which would void a lot of channels, nonetheless, one pass will generally void faster than the other. And that is what is called checkerboard void reactivity, because the density in all the channels going in one Director is different from the density of the coolant in the other channels.

This checkerboard void reactivity gives rise to non-linear effects, as Don Carlson mentioned. And so, the reactivity that you would get from 50 percent voiding by voiding one pass is certainly not the same as you would get by voiding 50 percent of all channels.

1 And Don demonstrated that. The point that 2 I would like to make, though, is the extreme case when one talks about checkerboard voiding, one often thinks 3 4 of complete voiding in one pass and complete full 5 coolant density in the other. That's not really a physical occurrence, 6 7 because you cannot lose all the coolant in one pass instantaneously. Now, our LOCA analysis is done by 8 9 calculating coolant densities with thermal hydraulics code. 10 And we do that with ATHENA. And then we 11 12 input those coolant densities into a kinetics code. The kinetics code is RFSB ISD, as Peter mentioned. It 13 14 has a kinetics capability. 15 And, generally speaking, the coolant densities -- the coolant density transients are a 16 17 function of the pass, of the channel, and even actually within the channel. 18 All that information is passed on from 19 20 ATHENA to RFSB. I'm showing in the next two slides a 21 particular case. I'm showing the system reactivity 22 and the resulting core power transient from a large 23 break, a reactor outlet header break, a 100 percent 24 break, which should give a large value of void

reactivity because the coolant is lost very quickly in

1	the 100 percent break.
2	So, in the next slides, what happened?
3	There should be there they are. This slide shows
4	the reactivity as a function of time for the first
5	three seconds for this 100 percent outlet header
6	break.
7	The reactivities here were not calculated
8	with RFSB. But they were calculated with MCNP using
9	a full court model of the reactor and using the
10	densities as provided by ATHENA to this full core
11	model.
12	Okay, so this is the best calculation of
13	the reactivity versus time using the actual densities
14	from ATHENA.
15	MEMBER KRESS: Those look like the height
16	that I used.
17	MR. ROUBEN: Oh yes.
18	MEMBER KRESS: Are they calculated here?
19	MR. ROUBEN: Well, the difference is
20	MEMBER KRESS: Oh, this is the whole
21	reactivity. I see.
22	MR. ROUBEN: This is the entire area.
23	MEMBER KRESS: I'm sorry. It's not just
24	the void, it's the whole reactivity.
25	MR. ROUBEN: No. And it starts out

1 negative because the first phenomenon is voiding and 2 also leakage of neutrons. And that starts out with a 3 negative reactivity for a few tenths of a second. 4 Then the checkerboard voiding phenomenon 5 comes in as the difference in density between the And so, the reactivity does go 6 passes takes over. 7 positive around one second and reaches about 1.4 milli-K. 8 Now, this whole calculation was done 9 10 without the shut-down system action. So, there was an 11 assumption in the calculation that the shut-down 12 system didn't act. In actuality, the shut-down system would 13 14 be tripped around .7 seconds. The trip time would be 15 about .4 seconds or so. And so, just the delays in the circuits, in the electronics, would actuate the 16 shut-down system at .7 seconds, and the shut-off rods 17 would enter the core around one and a half seconds. 18 19 But, again, this whole calculation is just 20 for the assumption of the voiding without shut-down 21 systems. 22 MEMBER POWERS: Just to make sure I know 23 what I'm looking at here, the blue squares represent 24 some average over time of the voiding that's predicted

by ATHENA?

MR. ROUBEN: No, it's not average, it's
instantaneous values.
MEMBER POWERS: Okay. So, but I guess
what bothers me is, if they are instantaneous values,
I would have assumed that I would have seen large
fluctuations in the curve, rather than a very smooth
curve. Am I just looking at connected points?
MR. ROUBEN: These are just connected
points, yes.
MEMBER POWERS: So, in between the dots
there were no calculations done. That's just a curve
for the eye there. Is that correct?.
MR. ROUBEN: Yes. ATHENA does the
calculation for the entire time. But we picked
certain
MEMBER POWERS: Points and then you did
your MCNP calculations for
MR. ROUBEN: That is correct.
MEMBER POWERS: If we if you had done
things more densely, would we have seen a lot of
variation between the points, or is it relatively
smooth in there?
MR. ROUBEN: I would think it's relatively
smooth.
MEMBER DENNING: Is the height of the box

1	one sigma? It looks like the height of the boxes are
2	different. Is that one sigma in the MCNP?
3	MR. ROUBEN: No, this is just the
4	MEMBER DENNING: That's just the box. You
5	don't have the how big is the MCNP.
6	MR. ROUBEN: It would be about .2, .3
7	milli-K or so. So, not far from the height of the
8	box, but I would say it's about .2 or .3. You can
9	reduce that, of course, by increasing the number of
10	histories.
11	These histories were done with about 30
12	million histories in these calculations. These
13	results are preliminary in the sense that the ATHENA
14	transient here was calculated assuming constant power.
15	Now, we took this reactivity curve and we
16	put it into a point kinetics calculation. So, the
17	power decreases for the better part of a second. And
18	then it does go above one as the checkerboard voiding
19	reactivity becomes positive.
20	But, the transient is self-limiting. And,
21	after a few seconds, will come down.
22	VICE-CHAIRMAN WALLIS: One would be very
23	careful about this plot because a novice examiner
24	might get the impression that the shut-down system
25	caused the transient

1	MR. ROUBEN: The calculation was done
2	without shut-down system. So, the power transient was
3	self-limiting. And, again, if the shut-off valves
4	were actuated at .7, they would come in around here at
5	1.5 seconds.
6	And they would cut off this peak even
7	more.
8	VICE-CHAIRMAN WALLIS: Well, I think it is
9	probably true. But it would be nice if you could see
10	it going on for a bit longer so we know it doesn't
11	come up again.
12	MR. ROUBEN: Definitely I don't have
13	these numbers here, but when we do the full analysis,
14	we go beyond three seconds.
15	VICE-CHAIRMAN WALLIS: You'll go beyond
16	three seconds, a bit more beyond the peak to make sure
17	it's not coming up again.
18	MR. ROUBEN: The thermal hydraulics
19	calculation goes a long way. The physics LOCA
20	calculation goes to a few seconds.
21	VICE-CHAIRMAN WALLIS: And then you're
22	happy?
23	MR. ROUBEN: Yes.
24	MEMBER DENNING: But there are a couple of
25	full power seconds potentially in there. What's the
	•

1	enthalpy of the fuel? Did you look and see what the
2	enthalpy is in the fuel at this point?
3	MR. ROUBEN: I don't have the numbers with
4	me. This would, of course, be reduced a lot with the
5	shut-down system. So, it would be even less than a
6	couple of full power
7	MEMBER KRESS: The core is still voiding
8	there? I mean, there is significant flow in the core
9	to cool to take heat out of the bins in that
LO	period?
L1	What is the thermal power? Is it about
L2	three times the 700?
L3	MR ROUBEN: Of the ACR?
L4	MEMBER KRESS: Yes.
L5	MR. ROUBEN: It's around 1,950 or
L6	something.
L7	MEMBER KRESS: So multiply that by two
L8	seconds and I don't know what the MCNP is, but you
L9	can get some idea.
20	VICE-CHAIRMAN WALLIS: But we don't know
21	when it comes down. It' still up at 1.2. At the end
22	of the graph it may go on for ten seconds. We don't
23	know the integral on that.
24	MEMBER KRESS: Right, I think if you
25	continued that it would repeat itself, if you

1	continue, wouldn't it?
2	MR. ROUBEN: Well, it would certainly be
3	arrested very quickly
4	MEMBER KRESS: Yes, if you put the rod.
5	That's what I was counting on, the rods going in.
6	MEMBER FORD: If I could interject, for a
7	licensing calculation, we would certainly credit the
8	shut-down system action.
9	MEMBER KRESS: Certainly.
10	MEMBER FORD: This is to help understand
11	what's going on. This is to help understand the
12	phenomena.
13	MEMBER KRESS: Right.
14	MR. ROUBEN: The safety analysis would
15	credit the shut-down system.
16	MEMBER KRESS: Sure.
17	MR. ROUBEN: In terms of conclusions, I
18	just wanted to say that MCNP, being the best
19	calculation we can find, has given us a good handle on
20	the physics of checkerboard voiding.
21	And, as far as our other tools, as Peter
22	mentioned, we are working to further develop the
23	capabilities, especially for checkerboard voiding,
24	generally for heterogeneous, but the most important
25	one being checkerboard voiding.

1 So, we are developing methods to cater to 2 the heterogeneous in RFSP, for instance. 3 effect of the checkerboard voiding, as we saw here, is 4 a mild power transient, which is self limiting and 5 turns over, even without a shut-down system. 6 MEMBER KRESS: Thank you. Well, the 7 Staff, I think, is expecting a letter from us. And I think the nature of the letter will be some sort of 8 9 comment on your -- the job you did with the SAR. Perhaps I would like to, in the letter, 10 11 identify what I would at this time call focus topics 12 for ACRS review. Maybe that would help. I quess we can turn it back to you, Chairman. 13 14 CHAIRPERSON GEOFFREY: Okay. Thank you 15 very much for the presentation. The next presentation we have is on the GSI-185. Before we get to that, we 16 17 have clearly schedule problem. We are running over two hours late. 18 19 we need to get to the letter before close of day, because, otherwise it will not have information on 20 21 what to put in the letter. 22 And it he only has tomorrow available with 23 He's not going to be here on Saturday. So, the problem we are having is that I need to stop the 24

presentations at six p.m.

1 We need at least one hour to work on, 2 which means the next two presentations have to be 3 within time. I have to depend on you to control time 4 within one and a half hour. 5 You have it on the agenda, but please make an effort. We need to really be able to get to the 6 7 letter by six p.m. That also means that that puts 8 into question a break. 9 Do you want a break? But then you'll have 10 to eat some other break for your presentation. 11 have to be tough. All right. So let's take a break 12 until ten after three, and then start with the next item on the agenda. So, please be here at ten after 13 14 three. 15 (Whereupon, the above-entitled matter went off the record at 2:56 p.m. and went back on the 16 17 record at 3:10 p.m.) CHAIRMAN BONACA: Back in session. The 18 19 next item on the agenda that we're going to cover is 20 GSI-185, and Vic is going to lead us through that. 21 MEMBER RANSOM: The concern about the 22 warm dilution dates back quite a ways to issue of 23 like 1995, and --24 MEMBER SHACK: Strictly newcomer. 25 MEMBER RANSOM: Right. The current

general safety issue 185 was established in roughly 1999 as a request from NRR, and then RAS performed a prioritization study, support of establishing general safety issue 185, which is titled "Control of Recriticality Following Small Break LOCAS in PWRs", and both the prioritization study and everything that had been done before assumed no mixing between deborated water and the steam generator, and the borated water in the reactor vessel. And this led to some concern about the power that might be deposited in the fuel and possibility of fuel damage.

Subsequent to that, RAS has conducted research to improve the mixing ability, and also the neutronic capability calculating the core power. These were the two elements that were key potentially resolving this issue. And the staff and our contractors met with our Thermohydraulic Subcommittee in 2002 twice, and also twice this year to review the details of the research and the results of system simulation, mixing core neutronics and the probability considerations for the occurrence of these events, and as a result of these meetings and the documented research contained in a draft NUREG report, it was the consensus of the committee that this should be brought to full ACRS, and that's where we are

1

2

3

4

5

6

7

8

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

today. So with that, I'll turn it over to Jack.

MR. ROSENTHAL: I'm Jack Rosenthal. I'm the Branch Chief of the Safety Margins and Systems Analysis Branch in the Office of Research. So we're talking about GSI-185, which is a boron dilution scenario, and it's a pressurized water reactor issue in which one postulates that one's had a small break LOCA. There has been some time when you're in a reflux cooling mode. You're essentially discerning boron, boron in the primary system and it was in this case of loop seal.

You have to form a diluted slug. Mr. di Marzo will be talking more about slug formation in a few minutes. You have to somehow transport that diluted slug into the primary system, and you can do that either by the start of natural recirculation, or by the operator's turning on reactor cooling pump. And then we asked ourselves the question, if you form a slug and you transport the slug, will there be a recriticality, and will that recriticality form teal damage.

I want to draw the distinction; there's a fair amount of work going on in Europe on the issue.

And there's a fair amount of work that we did on the issue. It was focused on the thermohydraulics of the

issue, and only recently -- actually, I think I have to give credit maybe most to Professor di Marzo for saying wait a minute, it's not simply a thermohydraulic issue. The real issue is I'm going to bust up fuel, if you have the event. So we really do five components; the probabalistic risk assessment, there's systems analysis - things like just by looking at the size of piping, size of the loop seals, mixing transport analysis, a really very simplistic RELAP model - just enough to drive the PARCS code.

Research made an investment in building a 3D space time kinetics capability, and this is an application where the ability to do that sort of analysis is paying off. It's more realistic than And last is a fair amount of fuel point kinetics. work that we've also done, so we see for this somewhat simplistic problem, it really is a very multidisciplinary problem, where we're taking advantage of work that was done in prior years in Maryland, and in Germany, PKL, the development of PARCS at Perdue as 3D kinetics model, in this case coupled to relap, but we also couple it to TRACE, the same code. Some code work that we did at Kurchatov that gives us confidence that we know how to do stuff. And then all the work that we did on reactivity insertion events gives us a

1

2

3

4

5

6

7

8

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

1 contemporaneous idea of what the fuel failures might 2 be, so it's quite an integral program. Subcommittee, 3 With the Ι did 4 introduction, then David did a lot of the -- Dave 5 Besette, the Systems work, and we decided just in the interest of time that I would speak quickly, and then 6 7 we'd go on. So what's the probability? 8 If you have a large break LOCA, you 9 depressurize, the event is over, so you need a small And, in fact, you need a small LOCA, 10 break LOCA. 11 which you can get by a pipe break or opening a valve 12 and leaving the valve open. And the small break LOCA alone isn't going to cause this event. You have to 13 14 fail ECCS; either you have a hardware failure or the 15 operators turn it off, in order to get in a condition in which you're distilling water. And so what I want 16 to leave you with the idea is that this is a subset of 17 all small LOCAs, and not equal to LOCA for --18 19 MEMBER POWERS: Well, it's a trivial 20 subset because everything you set up there is exactly 21 TMI. 22 MR. ROSENTHAL: It is TMI. 23 CHAIRMAN BONACA: But the PORV, that 24 includes the assumption that the operator doesn't 25 realize that he has a stuck-open PORV.

1 MR. ROSENTHAL: Later on I'm going to show 2 you a slide with 10 to the minus 7 on it, and --3 CHAIRMAN BONACA: I'm trying to understand 4 this 2 to the minus 3. 5 MR. ROSENTHAL: And Dana is right, that I'm describing Three Mile Island. And, in fact, we 6 7 discussed that at the subcommittee with Dr. Wallis, that in fact this sounds like TMI, so it's hard to 8 9 deny that it could never happen. Well, TMI the number 10 CHAIRMAN BONACA: 11 wasn't 10 to the minus 3, it was 1 in 50, I mean. MR. ROSENTHAL: Just the probability of a 12 stuck-open valve. 13 14 CHAIRMAN BONACA: Yes. All right. 15 MR. ROSENTHAL: Okay. Now I'm starting to 16 repeat myself. In order to get into this scenario, 17 and I'm describing TMI, you'd have to have a condition with a small break LOCA. You interrupt high pressure 18 19 injection. You then terminate the small break LOCA somehow, and HPSI is off for a period of time. 20 We know from the difficulty of conducting 21 22 the experiments at PKL and at Maryland that, in fact, 23 it's somewhat difficult to form a slug, and it would 24 take at least an hour to form a slug, which is time

action to take place.

25

the

And, in fact,

1	experimenters have difficulty running an experiments
2	that formed this nice slug and held it where they
3	wanted it until they wanted to move it. Well, when
4	you look at this, you say the best prospect of this
5	happening is a stuck-open PORV with a terminated and
6	restarted HPSI.
7	MEMBER POWERS: It seems to me that this
8	is not very difficult to do at all, in the simple
9	sense that that's exactly what happened.
10	MR. ROSENTHAL: They went into reflux
11	cooling for some period of time.
12	MEMBER POWERS: A long period of time.
13	MR. ROSENTHAL: Well, this is what drives
14	it. You're going to hear a deterministic argument in
15	a couple of minutes, but I'm just setting the stage
16	for where we perceive it in terms of probability.
17	MEMBER POWERS: Yes, but I'm having
18	troubles with the probabalistic statement. I'm
19	looking at it this way - if it's happened once, then
20	surely the probability must be extraordinarily high
21	that it will happen relative to things like 10 to the
22	minus 4, and 10 to the minus 5. It's relatively
23	since it has happened once in 2000 reactor years of
24	operation, I mean being a Baysian here.
25	MR. ROSENTHAL: No. vou're being a

1 Classicist, and it would be 1 in 4,000 or so at this 2 point, which gives you like 2 times 10 to the minus 4 3 or something. I mean a Classicist would argue --4 MEMBER POWERS: Classicist would, but I 5 would simply use the event as a Baysian update, in which case my probability is a lot higher than 2 times 6 7 10 to the minus 4. Well, they did make 8 CHAIRMAN BONACA: 9 significant changes in that type of plant to the change the very number, because they had no trips or 10 11 secondary size parameters, and that's why they were 12 opening the PORV and sticking it open once every 50 That was the history before TMI for the B&W 13 14 plants. Now what they did, they implemented feedwater 15 trips, so if you loose feedwater you will have a scram before you have a transient at the primary site, so 16 17 therefore, they stayed away from the PORV. Now that's why I was asking the question before. I mean, they 18 19 made changes that resulted in that number you're 20 showing us --21 MR. ROSENTHAL: The minus 3 number is a 22 hardware valve number. That's of an initiating event. 23 TMI is a full sequence. I just want to set the stage 24 here, so you're concerned about the event.

For Westinghouse and combustion plants,

1 the loop seals are just plain smaller. The volume of 2 the piping involved is smaller, so that if 3 postulate the maximum slug size and you inject that 4 into the core, you don't go recritical. So it's just 5 plain not a Westinghouse or a combustion issue. Now I will give the subcommittee credit 6 7 because we were so focused on B&W that we hadn't looked at Westinghouse, and CE, and under 8 9 prodding from them we went back and did look, and did some analysis. And then finally at the end, looked up 10 11 the size of the piping, which is probably the most 12 persuasive thing, that the volume is just not there, so it's a B&W problem, B&W lower loop problem. 13 14 VICE-CHAIRMAN WALLIS: Is it also a 15 problem with the lower loop --MR. ROSENTHAL: Lower loop, because we 16 17 said the raised loop will have a smaller volume again. But I do want to leave the very strong -- it's a B&W 18 19 issue, not a CE and Westinghouse. Not to pick on 20 them, it's just that's how the piping looks. 21 MEMBER ROSEN: Even a subset of B&W. 22 MR. ROSENTHAL: Yes, sir. Okay. So now 23 let's look at B&W for just a minute. 24 MEMBER ROSEN: How many of the B&W plants 25 are lower loop, of the six?

1 MR. ROSENTHAL: Five out of the six. 2 MEMBER ROSEN: Five out of the six? 3 MR. ROSENTHAL: I think Davis-Besse is the 4 only raised loop. 5 MEMBER ROSEN: Oh, good. Okay. MR. ROSENTHAL: Okay. So now you have to 6 7 transport the slug and there's two ways; natural circulation, which is a slower event, and one 8 9 is by the operators turning the pumps on. So for the case that we're most concerned with, there's explicit 10 11 procedures in their EOPs not to turn on those pumps 12 until they have acceptable conditions. Having said all that, that it's a 13 Okay. 14 B&W lower loop problem, where we think we're robust 15 that it is not a combustion or Westinghouse problem -16 let me just go on. And one can argue that this is 17 argumentative. You take a small break LOCA as about 2 18 times 10 to the minus 3, if it's the valve. 19 It's got 20 to be early in the fuel cycle, about the first 20 21 percent of the fuel cycle, which also was TMI, in all 22 It was early in their fuel cycle, because fairness. 23 that's when the boron is holding down more reactivity. 24 For slug formation, in order to get in this condition,

you need equipment failure - one or more pieces of

1	hardware fail, typical train is 10 to the minus 2, so
2	it's some number of that order of magnitude.
3	VICE-CHAIRMAN WALLIS: It's either
4	equipment or it's inappropriate operator action.
5	MR. ROSENTHAL: Well, my P4 is the restart
6	of the reactor coolant pump
7	VICE-CHAIRMAN WALLIS: By shutting off the
8	HPI or whatever it is that you need to do.
9	MR. ROSENTHAL: Yes. Yes, sir.
10	VICE-CHAIRMAN WALLIS: That's also in
11	there.
12	MR. ROSENTHAL: Yes. Okay. And then you
13	have to restart the pump, and for that we looked at
14	the human we got the human factor experts.
15	MEMBER POWERS: You're going to create
16	these things as independent, and it's just no way that
17	they're independent.
18	MR. ROSENTHAL: Go on.
19	MEMBER POWERS: Well, I mean, that's what
20	you do. Right? And why do you think that P3, P4 are
21	independent?
22	VICE-CHAIRMAN WALLIS: The guy who's going
23	to shut off the HPI is probably under some
24	misapprehension about what's happening. He might
25	equally well start the pump under the same

misapprehension. That's what happened at TMI; because they misunderstood what was going on, they did things that had a common cause.

MEMBER RANSOM: I think the procedures right now are for the operator to call for not to restart the pump and kill natural circulation that's existed for a given length of time, and so it would have to be in violation of that procedure.

MR. ROSENTHAL: So this would be an estimate that we would use to get a sense of the likelihood of this boron dilution event in which the operators turn back on the pumps. One can argue what is the magnitude on the number, and I just wanted to give you a feel for this, because in a little while we're going to talk mechanistically about what would happen. And I think that what we're saying is that we believe that mechanistically, the consequences of such an event would be low in terms of the extent of fuel damage, and as a basis for dismissing the issue. that if you combine that with our perception of the probability of the event, it further dismissing the issue.

MEMBER ROSEN: Do you think if one were to say that it's a common mode failure of operators' cognitive processes, so that P3-P4 is not 10 to the

1

2

3

4

5

6

7

8

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

minus 4, it's 10 to the minus 3. Would that change your answer?

MR. ROSENTHAL: No.

MR. BESETTE: The human factors people actually gave two numbers for P4. One is like a standard error rate, the other one is what you might call a highly stressed error rate. And the one that is shown is the highly stressed error rate. The standard error rate is lower. I guess another factor to consider is that by this time, the emergency response center at the plant would have been actuated and there would be a lot of people --

MR. ROSENTHAL: Let me make another point, and that is that you're used to seeing core damage frequencies of 10 to the minus 4, 10 to the minus 5. Sometimes people will get up here and argue seriously about 10 to the minus 6 for core damage frequency. This number here is an estimate of an event in which you put an unborated water slug back into the core, and that's not core damage. And, in fact, it's a scenario in which to get in this scenario I've interrupted HPSI, and then I've recovered high pressure injection. So if I cause fuel damage, which I will show mechanistically we think is of low likelihood, it's into a situation in which I have

1 operable ECCS, so we're far from a core damaging 2 scenario. MEMBER POWERS: It seems to me that if I 3 4 were going to try to redo this calculation, I would 5 take P4 as one. MEMBER ROSEN: 6 One. 7 MEMBER POWERS: If I've interrupted high 8 pressure injection, at some point, for whatever reason 9 I did that, at some point I'm going to turn on the Guaranteed, 10 coolant pump. just guaranteed that I'm going to do it. 11 12 VICE-CHAIRMAN WALLIS: The only evidence we have for how operators behave under really high 13 14 stress would seem to be TMI. That would be another 15 incidence --16 MR. ROSENTHAL: We also have the Crystal 17 River event, which was a very telling -- I'm sorry, Dr. Rosen. 18 No, no. 19 MEMBER ROSEN: We have TMI for 20 sure, but we don't have this circumstance anymore 21 without having had TMI, and having had the corrective 22 and having had the training and actions, 23 procedural changes, so we're in a different world. 24 You can't use a pre-TMI number any more. 25 MR. BESETTE: At the time of TMI, there

1 were no procedures one way or the other in terms of 2 tripping reactor coolant pumps, or stopping reactor coolant pumps. If you had a LOCA, you didn't have to 3 4 trip reactor coolant pumps. Now you're directed to 5 trip them, and so there were no procedures one way or the other at the time of TMI. 6 7 CHAIRMAN BONACA: But in order to have a 8 slug formation, you've got to have the operator 9 terminating HPSI. Right? 10 MR. di MARZO: You have to have several 11 concurrent things. You have to have the primary 12 higher than the secondary in terms of energy. INother words, secondary has to be a sink. You have to 13 14 have HPSI interrupted, you have to have break 15 isolated, and you've got to maintain this kind of situation for a relatively long time with an eventary 16 17 range which is very tight. 18 MEMBER ROSEN: And then you have to restart --19 MR. di MARZO: 20 And then you have to 21 restart HPI, so the inventory in which you've got to 22 be has to be such that you don't cool the core, and you do not go into resumption of natural circulation. 23 24 CHAIRMAN BONACA: I was just dealing with 25 the probability issue. What I'm trying is that right

1 now with the formation of the two margin and adequate 2 core cooling, et cetera, the probability that he will cut off HPSI is extremely low, I think. But what is 3 4 that small number there? I don't see that. 5 small break LOCA. Slug formation. 6 MEMBER ROSEN: 7 MR. ROSENTHAL: WE've lumped all the 8 hardware and human into some estimate of 9 formation. As I say, this is to give you a perception 10 that we're working on a infrequent event. 11 CHAIRMAN BONACA: I understand, but the 12 point is that yes, I have more credit than that to the slug formation. I would go to 1 in 10 to the minus 3 13 14 almost, because you would have to have this intent and 15 no recognition of circ cool margin, et cetera. guys are trained so heavily on this issue, I mean it's 16 17 just not going to happen. But the other points, however, that I think about is that RCP. Yes, I mean 18 19 there are steps and procedures to do that. 20 going to be closer to one, I think. 21 MR. ROSENTHAL: To one? 22 CHAIRMAN BONACA: Well --23 MR. ROSENTHAL: If failure to follow the 24 procedures over an hour into an event? 25 CHAIRMAN BONACA: No. No.

1 MR. ROSENTHAL: It's at least 10 to the 2 minus 2. This was the standard methodology that -human factor methodology. 3 4 CHAIRMAN BONACA: Okay. 5 MEMBER ROSEN: We're assuming here that this is not a cognitive failure of the whole crew. If 6 7 you have cognitive failure of the whole crew, as you had at TMI, then you're going to get higher numbers, 8 but if you -- it's very much harder to do that in post 9 10 event environment than in a pre-event environment. 11 Yes, CHAIRMAN BONACA: also a very 12 different situation in the control room. You have three people there with the --13 14 MEMBER ROSEN: Four o'clock in the 15 morning. 16 MEMBER RANSOM: Correct me if I'm wrong, 17 but I didn't think this improbability argument was really key to resolving the safety issue. 18 19 MR. ROSENTHAL: Correct. 20 MEMBER RANSOM: It's only frosting on the 21 cake. 22 MEMBER ROSEN: Frosting on the cake tells 23 us it's about 10 to the minus 6. You can argue it could be as low as 10 to the minus 7, might be 10 to 24 25 the minus 5.

1 CHAIRMAN BONACA: All right. see 2 somewhere --So now from --3 MR. ROSENTHAL: Okay. 4 MEMBER ROSEN: We don't care whether it's 5 any of the numbers. 6 VICE-CHAIRMAN WALLIS: You're going to 7 tell us it can't happen, not the consequences of not 8 happening. 9 Okay. Now let's talk MR. ROSENTHAL: 10 about the consequences. Now we've said that for CE 11 and Westinghouse, just based on the slug size that you 12 can form, you're not going to recritical. B&W lower loop you could have 40 cubic meters of unborated water 13 14 that you could put into the core. And if you do that, 15 there's two cases two consider; one is natural circulation, and the other is the restart of the 16 17 reactor coolant pump. So now we use the PARCS code, and we can 18 19 calculate the reactor kinetics, and we can calculate 20 the enthalpy deposition in the fuel. And what you 21 find for the natural circ case, things happen slow 22 enough, the normal feedback mechanisms in the core are 23 fast enough that, in fact, we don't think that you'll 24 fail fuel. 25 For the restart case, which is faster,

1 where you've got a pump that's stuffing unborated 2 water into the priming system, there is a potential for fuel failure. And that would be limited to some 3 4 peak region of the core, and that would be in a 5 scenario in which you have high pressure injection available by definition of the scenario. 6 7 So we think of the consequences of the 8 event are modest, and one can argue over the frequency 9 of the event, but we also believe that that is modest, and that with the explicit procedures already in the 10 11 B&W EOPs, enough has been done that we do not have to 12 require more be done. So I'm now repeating myself. 13 14 problems with CE and Westinghouse. B&W is a plant 15 that's vulnerable. B&W is the one that's addressed the issue already with explicit procedures which 16 suppresses the probability of the event. And based on 17 that, we concluded that no further regulatory action 18 19 was necessary. MEMBER DENNING: 20 I have a couple of 21 questions. One of them is where is the Boron that got 22 left behind when the water evaporated and then 23 Is it supposedly stuck up in the -recondensed? 24 where is it?

MR. ROSENTHAL: It's in the reactor vessel

1	in the core.
2	MEMBER DENNING: It's in the core, so you
3	have an unusually high amount of Boron in the core.
4	MR. ROSENTHAL: Yes, but we're not going
5	to you have a LOCA. Dave Diamond is going to
6	present the criticality in a few minutes.
7	MEMBER DENNING: Okay.
8	MR. ROSENTHAL: But you've had a loss of
9	cooling event, and you've had an ECCS injection, so
10	you're starting with like 2,000 ppm that you've been
11	putting into the core from the injection of the ECCS.
12	The little bit from the distilling, the little bit
13	extra Boron
14	MEMBER DENNING: But that's the difference
15	between that little bit of difference is the
16	difference between why you've got a problem. I mean,
17	that's why you have dilution, is because you left some
18	Boron behind someplace.
19	MR. ROSENTHAL: And you're postulating
20	that you're putting an unborated water slug, not 2,000
21	ppm but close to zero ppm.
22	MEMBER DENNING: I know, but you increase
23	the concentration some place in the system of Boron to
24	come up with that slug of water that's unborated. Am

I wrong? So it's a matter of the distribution of

1	where it's in the system.
2	MR. ROSENTHAL: Oh, yes. Yes.
3	CHAIRMAN BONACA: Yes, because you make
4	the assumption that when it comes in, it doesn't mix.
5	MEMBER DENNING: Well, then that's not
6	CHAIRMAN BONACA: It comes to the core.
7	MEMBER DENNING: Does it not mix in the
8	downcomer or what are your
9	MR. ROSENTHAL: Okay. Now Professor di
10	Marzo is going to talk. This is an introduction.
11	MEMBER DENNING: Okay.
12	MR. ROSENTHAL: In due course, we'll talk
13	about where you would form a slug, how big the slug
14	could be, how you could transport the slug from the
15	pump, through the pipe, downcomer, lower plenum, and
16	back up
17	MEMBER ROSEN: And what happens to the
18	Boron that got came out of the slug, and whether
19	that matters; where it went, and whether that matters.
20	MEMBER DENNING: Jack, one other question
21	that's important; and that is, reactor coolant pump -
22	this current requirement that they not restart the
23	reactor coolant pump until some particular time, is
24	that implemented specifically to avoid this problem,
25	or is there for another reason?

1 MR. ROSENTHAL: It's in the B&W -- I'm 2 sorry, it's the bases, it's the EOP bases document 3 that told that this is the reason that they shouldn't 4 do it. 5 MEMBER DENNING: And this is the reason they shouldn't do it. 6 7 MR. ROSENTHAL: I don't want to use the 8 word --9 MEMBER DENNING: The thing that I'm 10 worried about is, are there situations where we wish 11 they really had started that reactor coolant pump, 12 that they did not have a prohibition against it? this is an unreal problem, if mixing and stuff like 13 14 that really mean this isn't the real problem, and 15 we've imposed a requirement that they not start the pump because of a non-real problem, then I want to 16 17 know, you know -- you're telling me that from your analyses, it's not too bad. I want to find out is it 18 19 really important, and if this is a fake problem that 20 we've just set up by the boundary conditions, I'd like 21 to know have we really done the wrong thing from a 22 safety viewpoint by prohibiting the restart of that 23 coolant. 24 MR. ROSENTHAL: Ι you quess

postulate. You have those 40 cubic meters of water in

	ullet
1	your seal, and if you did have a core recovery, it
2	would be really useful to get that over to the core,
3	if you had no other way of getting water there. It
4	would just buy you some time. Ultimately, you need to
5	get some ECC injection back.
6	MR. BESETTE: It's interesting these
7	restrictions have been in place since 1996, though.
8	Framatome put them in place at that time, and I
9	believe based on possibility of Boron dilution
10	MEMBER RANSOM: The only reason the
11	procedure is there is because of Boron dilution.
12	VICE-CHAIRMAN WALLIS: The Chairman wants
13	to finish by 4:30.
14	MR. ROSENTHAL: No problem.
15	MR. DIAMOND: I'm David Diamond from
16	Brookhaven National Lab, and I will be very brief.
17	I'd like to give you an idea of the analysis that we
18	did at Brookhaven that Jack alluded to.
19	We wanted to understand the consequences
20	of the event given a particular slug, and what we mean
21	by the consequences are calculations of the fuel
22	enthalpy throughout the core as a function of time.
23	
	The fuel enthalpy that we're talking about is averaged

but we look at it as a function of position within the  $\,$ 

reactor. And as I say, it's a function of time during the boron dilution event. And, of course, we look at fuel enthalpy because that is generally used as a failure criterion for reactivity initiated accidents.

We, of course, did best estimate studies and, of course, parametric studies to determine the effect of different assumptions, such as flow rate, Boron concentration and reactor types. And I'll, of course, only touch on one or two calculations here today.

As Jack mentioned, we use a methodology developed by RES, and it couples in this particular case Relap 5 with PARCS. PARCS, of course, providing the neutron kinetics, and I have some attributes of the PARCS code listed here, which I won't go into. I have more on these slides than I will touch on, but the information is there for your perusal at a later time.

This slide shows something important in developing a PARCS model, and that is the fact that the assemblies are represented as homogenized regions, so that a true assembly which is heterogenous, one does a calculation over the full spectrum of neutron energy, and over this assembly, then averages the cross-section information,

1

2

3

4

5

6

7

8

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

1	averages it spatially in order to get a uniform
2	representation of the assembly, and averages it in
3	terms of energy in order to reduce things down to two
4	neutron energy groups. And that is the way in which
5	the core calculations are done. There is a way of
6	backing out information on the pin-by-pin power, but
7	I'm not going to get into that in this.
8	MEMBER RANSOM: It might be important to
9	touch on the validation for this model, how much faith
10	can you have in this.
11	MR. DIAMOND: All right. The PARCS code
12	has been validated by comparisons with many different
13	benchmarks, both experimental and numerical. For this
14	particular calculation, of course, one doesn't have
15	direct validation. However, we did do some code-to-
16	code comparisons against a Russian code using a
17	totally different methodology, just to give us a
18	certain level of confidence in the ability of the
19	methodology used in PARCS to be able to calculate the
20	core under these conditions. And these conditions are
21	extreme relative to
22	MEMBER RANSOM: It's my understanding that
23	those were reactivity transients that you compared it
24	against. Is that right?

MR. DIAMOND: They were specifically for

1 Boron dilution. 2 MEMBER RANSOM: Okay. 3 MR. DIAMOND: The calculations that we did 4 modeled a B&W design. It's 177 assemblies in the 5 It happened to be TMI-1, and it's modeled at the beginning of cycle because as mentioned, that's 6 7 when a Boron dilution has consequence. Indeed, we did 8 some analysis to show that the consequences are of concern only in the first maybe 10 or 20 percent of 9 the cycle. It depends on the type of fuel cycle one 10 11 has. 12 MEMBER POWERS: If I have a core that's 60 percent fresh fuel, 40 percent old fuel, I don't need 13 14 to worry, uniformly distributed. 15 MR. DIAMOND: No. This has nothing to do with the fuel in the core. It has to do with the 16 17 cycle which starts out with a high concentration of and then eventually goes down to 18 concentrations that are so low that a dilution doesn't 19 20 really add much. And it turns out that that point is 21 reached fairly early in the cycle. 22 MEMBER ROSEN: Do you know how high the 23 Boron concentration is at the beginning of life? 24 it --Typically, 25 MR. DIAMOND: Boron

1 concentration is about 1,500 ppm, and that's generally 2 true --3 MEMBER POWERS: That's hot full power? 4 MR. DIAMOND: Hot full power, yes. 5 that's generally true even as one goes to longer fuel cycles. 6 7 MEMBER POWERS: The previous speaker put up things that said gee, all I did was pop this fuel 8 9 with perhaps as much as 185 calories per gram, full of numbers for different assumptions, and I was supposed 10 11 to walk away with a lot of comfort; that 25 calories 12 per gram, I'll walk away with a little bit of comfort. When you cross on how many calories per gram I'm 13 14 starting to get real nervous. 15 MR. DIAMOND: Okay. Let me go through the calculations and qualify those numbers a little bit, 16 17 put them a little bit in context, and then we can get back to your question, perhaps. 18 19 Anyway, the starting point calculations that we did is late in the scenario; that 20 21 is, it's after the dilution has taken place in the 22 cold leq. At this point, all the control banks are 23 inserted, the control and shutdown banks. The fuel 24 has cooled a little bit and is down to 500 -- excuse

me, the moderator has also cooled by virtue of the

injection of the ECCS, and it's at 500k for this calculation. And at a Boron concentration of 2,500 ppm, which corresponds to the ECCS concentration. So at this point in time, the reactor is about 15 dollars shut down. And then the transient boundary conditions that we imposed in order to do the calculation is a Boron concentration as a function of time at the lower plenum. And how we get that, Marino di Marzo will explain after I'm finished here. And then we looked at flow rates based either on assuming natural circulation or the restart of a pump in the diluted loop.

This is the layout, and I just want to show you that the numbers represent control banks, and so we have a checkerboard pattern of assemblies with control rods, and checkerboard with those without control rods.

The reason that one-eighth of the core is highlighted here is that we did have one-eighth symmetry, and although we calculated in PARCS, we calculate the result for every assembly in the thermohydraulic calculation that this is coupled to; namely, RELAP5.

We only considered thermohydraulic channels representing each of the assemblies in a one-

1 eighth core. And they're listed here for 2 purposes; one -- well, first of all, note the yellow 3 assemblies, those in which one has control rods 4 initially. And the number at the bottom of the 5 assembly is the burn-up in this particular core. The assemblies here, these two assemblies 6 7 that are shaded have low burn-up. They're fresh fuel in this particular core. This is at beginning of 8 9 cycle, and it's in these two assemblies where the peak 10 fuel enthalpy occurs. And also I might say at this 11 point, it also occurs at the bottom of the core. And 12 I think that's what Jack was referring to by saying that this is not a core-wide -- that one doesn't get 13 14 to high enthalpy throughout the core. One gets it in 15 these two assemblies, and at the bottom of the core. 16 MEMBER ROSEN: And those are megawatt days 17 per ton numbers? Gigawatt days per ton. 18 MR. DIAMOND: MEMBER ROSEN: 19 I mean, gigawatt days per 20 ton. 21 MR. DIAMOND: Yes, that's correct. 22 MEMBER SIEBER: So that's 16 assemblies 23 for the whole core, two per one-eighth segment. 24 MR. DIAMOND: That's correct. 25 MEMBER SIEBER: Okay.

1	MR. DIAMOND: Okay. So here is your lower
2	loop plant, and what we do is in the RELAP5
3	calculation to model each of the fuel assemblies in
4	that one-eighth core as a thermohydraulic channel.
5	These are, of course, one dimensional models, and they
6	are coupled at the top and bottom. And we have an
7	explicit representation of the inlet plenum and the
8	outlet plenum.
9	MEMBER RANSOM: As I understand it, there
10	are 29 channels. Is that right?
11	MR. DIAMOND: Well, actually a $30^{ ext{th}}$ for
12	bypass flow. Yes. And this shows you a result when
13	the flow goes to 25 percent of nominal value. And the
14	blue curve here is Boron concentration, the ordinate
15	is on the right side here. That's ppm, and you can
16	see that it starts off at 2,500 and goes down in about
17	just a few seconds to about 450 roughly ppm, and then
18	comes back up to 2,500. And the resulting reactivity
19	versus time is shown here in red. And that starts
20	off, as I said, at 15 dollars subcritical
21	MEMBER ROSEN: I'm sorry, Dave, to be so
22	stupid, but I don't know what this 10 second or 20
23	second transient is. What happens during that 20
24	seconds?
25	CHAIRMAN BONACA: The Boron goes

1	MEMBER ROSEN: I know, but what in the
2	plant
3	MR. DIAMOND: Yes. This is starting from
4	one pump starting at time zero.
5	MEMBER ROSEN: Okay. And this is in the
б	core, which starts at 2,500, and it's being flushed,
7	basically.
8	MR. DIAMOND: That's correct.
9	MEMBER ROSEN: Okay.
10	MR. DIAMOND: We impose this Boron
11	concentration versus time at the inlet plenum, the
12	lower plenum.
13	MEMBER ROSEN: Okay.
14	MR. DIAMOND: And then calculate the
15	consequences in the core in terms of power.
16	MEMBER ROSEN: This is essentially the
17	startup of 1 RCP. Is that what this
18	MR. DIAMOND: That's correct.
19	CHAIRMAN BONACA: That's an average core,
20	the whole core?
21	MR. DIAMOND: I'm sorry?
22	CHAIRMAN BONACA: I mean, you have a
23	finite amount of water coming in from the slug.
24	MR. DIAMOND: Yes, that's correct.
25	CHAIRMAN BONACA: Okay. And where is it

1	placed?
2	MR. DIAMOND: And it's placed in the lower
3	plenum, and then flows up through the core. This is
4	a B&W case which is 40 cubic meters.
5	CHAIRMAN BONACA: Assuming the whole core
6	to be affected by this.
7	MR. DIAMOND: Yes.
8	MEMBER ROSEN: Now these are huge pumps,
9	great big motors. From the time you actually press
10	the button until the time it gets to full speed, is
11	that taken into account?
12	MR. DIAMOND: In this particular
13	calculation, yes. This takes about 10 seconds.
14	MR. di MARZO: Yes, but the problem is
15	there is water before the deborate, so the pump gets
16	to full speed before the deborate arrives. In other
17	words, you have to start flushing the downcomer and
18	whatever you had in the cold leg downstream the pump
19	first, and then you get that. So essentially, it's
20	full speed almost.
21	MEMBER ROSEN: The pump starts up and it
22	pushes a lot of borated water in first, and then
23	incomes the non-borate.
24	MR. di MARZO: Right.
25	MEMBER ROSEN: And that whole the non-

1 borated water gets to the core is time zero here. 2 MEMBER POWERS: That's zero. That's correct. 3 MR. DIAMOND: 4 MEMBER ROSEN: Not the pump start time. 5 MR. DIAMOND: That's correct. 6 MEMBER ROSEN: Okay. 7 That's correct. And the MR. DIAMOND: result on power is shown in the red curve here, and 8 9 the scale here is, 100 percent, of course, is nominal 10 power. And one gets to a prompt critical situation, 11 and that's the reason that the power rises so rapidly. And, of course, that 12 You have a very sharp burst. burst is turned over rapidly, as well, because this is 13 14 a characteristic of light water reactors, the doppler 15 feedback is extremely powerful and very fast. Having said that though, you could also 16 notice that it did get up to 2,700 percent before 17 being turned off. Now it then goes through a series 18 19 of, like you could almost call them oscillations, as a result of the conflict between the dilution that's 20 21 taking place and all of the negative feedback that 22 takes place as a result of the increase in fuel temperature, and then the decrease in density as you 23 24 get voiding sporadically in the core. And what I said earlier, what we're most 25

interested in, though, is to take a look -- this power here is a global power, and we're really interested in something that's happening locally; namely, how is the individual fuel rod behaving. And we judge that according to what the fuel enthalpy is, and in the blue curve here we're looking at the fuel enthalpy in the rod that has the maximum value. And what we see initially is a rise in fuel enthalpy from about 17 calories per gram to an increase of about 30 calories per gram, to about 47 calories per gram. And that's this initial jump here. It's almost hard to see because we're talking about a jump in less than one This initial pulse here is a very narrow pulse relative to this time scale here. So that initial fuel enthalpy increase by which a lot of people judge fuel behavior is only on the order of 30 calories per gram.

However, in this particular case, because there is so much diluted water that's coming into the core, we see that - and it's coming in so fast, at 12 seconds we're up to about a maximum fuel pellet enthalpy of about 190 calories per gram, or an increase of about 170 calories per gram.

MEMBER POWERS: And what turns it over there is the re-boration.

1

2

3

4

5

6

7

8

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

1	MR. DIAMOND: Yes.
2	MEMBER POWERS: As the pump continues to
3	run, it starts putting back in borated water.
4	MR. DIAMOND: That's correct. The slug is
5	a finite volume, and
6	VICE-CHAIRMAN WALLIS: In other words, the
7	pump is now turned off.
8	MEMBER POWERS: Oh, my gosh, I made a
9	mistake on that one. I turned it on for 12 seconds
10	and trip it.
11	CHAIRMAN BONACA: How do you get the pin
12	value?
13	MR. DIAMOND: I'm sorry?
14	CHAIRMAN BONACA: How do you get the pin
15	value? I mean, you do have a calculation here and a
16	cross-match.
17	MR. DIAMOND: Yes. Right.
18	CHAIRMAN BONACA: And then you go to fine-
19	mesh. How do you I mean, you superimpose
20	MR. DIAMOND: You can impose a peaking
21	factor on the assembly calculation.
22	CHAIRMAN BONACA: That's what you did.
23	MR. DIAMOND: In this particular case, no.
24	This is not
25	CHAIRMAN BONACA: Is this an average?
Į	

1	MR. DIAMOND: This is averaged over
2	assembly, and so it would be in the neighborhood of
3	maybe an additional 20 percent peaking factor to
4	account for what it might be at a pin.
5	VICE-CHAIRMAN WALLIS: Let's look at that.
6	If they did bump the pump as they did at TMI, I guess,
7	5 seconds, and they turned it off and left the diluted
8	borated water in the core, you wouldn't get Boron in
9	the core now. It would take its course, presumably,
10	in some way.
11	MR. DIAMOND: It wouldn't be going through
12	as rapidly, that's true.
13	VICE-CHAIRMAN WALLIS: Now circulate as
14	natural circulation or something?
15	MR. DIAMOND: Yes. Well, I mean, there
16	was some momentum built into the flow, so
17	MR. ROSENTHAL: Let's be very careful in
18	describing the scenario. We're an hour into the
19	event, and we've distilled enough water that we formed
20	this maximum 40 cubic meter slug of water in the loop
21	seals.
22	MEMBER POWERS: Deborated.
23	MR. ROSENTHAL: Deborated water, and now
24	you've turned it on, and Dave is trying to show what
25	might happen. And now your and there's only 40

1	cubic meters max to play with, so now you're
2	postulating exactly what? You trip the pump
3	VICE-CHAIRMAN WALLIS: You squirt it in
4	and then you stop.
5	MR. ROSENTHAL: And you stop
6	MEMBER POWERS: No, he starts it at the
7	wrong moment, and then it trips 10 seconds later,
8	which is possible, because he doesn't have all the
9	auxiliaries set up. He's made a mistake.
10	MEMBER SIEBER: But that's not what was
11	analyzed.
12	MR. ROSENTHAL: That's good. That's good,
13	because Dave is showing you the pump case, the natural
14	circ case is a more benign case.
15	VICE-CHAIRMAN WALLIS: No, I'm saying - he
16	said it turned around because you started to bring in
17	borated water. I'm saying will that happen if you
18	turn off the pump, or if the pump trips? Does it turn
19	around if the pump trips?
20	MEMBER SIEBER: Well, the peak won't be as
21	hot in the natural circulation case.
22	MR. BESETTE: Once a pump is going,
23	there's a coast down that lasts for about another 30
24	seconds or so. The flywheel will keep
25	VICE-CHAIRMAN WALLIS: And that's enough

1	to keep the fluid out.
2	MR. BESETTE: And plus, you've got a
3	pretty strong natural circulation when you have 100
4	percent power, too.
5	CHAIRMAN BONACA: I'm sorry, just to
6	understand. Those 40 cubic meters, what is it, a
7	volume of the vessel?
8	MR. BESETTE: The 40 cubic meters is about
9	the volume of the core region has about 36 cubic
10	meters or 40 cubic meters.
11	CHAIRMAN BONACA: You're talking about the
12	whole amount of the core region. Okay. That's fine.
13	MEMBER ROSEN: What saves you is the
14	flywheel.
15	MR. ROSENTHAL: Yes. The volume that
16	we're talking about is below the inlet of the cold leg
17	- I'm sorry
18	MEMBER POWERS: Right there, that one.
19	MR. ROSENTHAL: So it's this volume in the
20	steam generator and in the cold leg below this level.
21	VICE-CHAIRMAN WALLIS: I don't know why
22	the flywheel saves you, because you could turn the
23	pump on for two seconds, and then the flywheel will
24	put the rest of the slug in.
25	MR. di MARZO: Then you don't get the max

	347
1	speed.
2	VICE-CHAIRMAN WALLIS: If you wanted to be
3	extraordinarily pessimistic you could say absolutely
4	the worst possible thing happens.
5	MEMBER SIEBER: And I don't think that is,
6	because a transient is much slower. When the
7	transient is slower, you don't get to the peak power.
8	And it's self-limiting.
9	VICE-CHAIRMAN WALLIS: We don't have the
10	spectrum of transients.
11	CHAIRMAN BONACA: I want to think about
12	the slug going through from the narrow pipe down the
13	downcomer. We're assuming that it fills the
14	downcomer, and then it comes up. I can imagine, for
15	example, a slug going in locally in the region of the
16	core, so have a more drastic effect, because it could
17	last a longer time.
18	MR. DIAMOND: Well, I think Professor di
19	Marzo discusses the slugs.
20	MEMBER RANSOM: Well, isn't there an
21	issue, too, that if you have like 40 cubic meters of
22	the deborated water, and you turn on the pump, the
23	pump is going to cavitate at some point because there

isn't any fluid behind that slug. It's going to pump

down until it starts to cavitate, and I would think

24

348 1 operational procedures would call for shutting it 2 down. 3 MR. di MARZO: That would depend when you 4 do it, because you would do it at some level of -- you 5 may have some level of refueling. You do it or you may have just the slug itself. 6 7 MEMBER RANSOM: You mean you're assuming that you would have the slug sitting there, but then 8 refilled with borated water above that? 9 MR. di MARZO: 10 The slug can be at any 11 position up and down the steam generator if you're 12 starting refueling, for example, and then at that point start the pump. Or you can postulate that you 13 14 start the pump exactly at the final time when the slug 15 has just finished forming. That introduces another 16 probability there. You have to factor that in, I 17 suppose. MR. DIAMOND: All right. And perhaps the 18 consequences will become also a little bit clearer if 19 20 I show one case where the flow rate is only at 3

MR. DIAMOND: All right. And perhaps the consequences will become also a little bit clearer if I show one case where the flow rate is only at 3 percent, representing natural circulation. And in this case, again the Boron concentration starts at 2,500, and it takes much longer for the slug to go through the core. And this acts in your favor in terms of making the event more benign.

21

22

23

24

Again, the red is the reactivity versus time, which is just the conflict between the Boron dilution and the feedback. And the result, though, is different for the pump-on case. The red is now the power. Again, in terms of having a prompt critical pulse initially, that's the same except that this one only goes up to about four or five hundred percent, and then it goes through a series of oscillations over a longer period of time because this is a slower event. But also, if you look at the peak fuel enthalpy as a function of time --

VICE-CHAIRMAN WALLIS: At the end of that process when the slug is now in the core. The core's coolant is unborated water. Is it the voiding which is filling the reactivity rather than the Boron?

MR. DIAMOND: It's a combination - yes - the voiding and fuel temperature. And also the fact that yes, we think in terms of a monolithic slug going through, but it's actually a very spatially dependent process. So this initial rise of the fuel enthalpy is only about 25 calories per gram here, and then the peak value of the fuel enthalpy, which again is in those fresh fuel assemblies at the bottom of the core, it's only about 90 calories per gram in this particular case.

1 One other case, this is the no-never-mind 2 This is the simulation for a Westinghouse cold 3 leg design, where the Boron concentration versus time 4 is a much shorter dilution. This comes right back up 5 in about 2 seconds, because we're talking about an order of magnitude difference in the volume, going 6 7 from about 40 cubic feet to about less than 4 cubic 8 feet. 9 MEMBER POWERS: Could we go back to your 10 previous slide? 11 MR. DIAMOND: Sure. 12 MEMBER POWERS: You show a very sharp initial transient, some minor oscillations, and then 13 14 a period of very short passes in the power. Are those 15 oscillations such that, and the time is wrong here. It's 10 seconds for those hash marks there, such that 16 your fuel is successfully disposing all of 17 enthalpy into the coolant, and not getting any --18 19 MR. DIAMOND: Yes. Well, this is the 20 the enthalpy levels enthalpy here, and so 21 relatively low. Don't forget, full power enthalpy is 22 about 45 calories per gram, so okay. You have a situation here where you're hotter than normal. 23 24 VICE-CHAIRMAN WALLIS: Well, it's 25 percent power, but you've got something like a BWR.

1	You're boiling off the voids in there. You're cooling
2	the
3	MEMBER POWERS: Really, I'm just asking if
4	heat transfer was operational here.
5	MR. DIAMOND: Yes. I mean, as calculated
6	by RELAP5. So you have two-phase cooling, sure.
7	Okay. As I mentioned, this is really the
8	no-never-mind, because the volume of the borated water
9	is so small.
10	VICE-CHAIRMAN WALLIS: If you have a very,
11	very big slug and you put it in there slowly, you just
12	boil, and boil, and boil and fuel will be cool, and
13	there will be no greater power.
14	MR. DIAMOND: You would reach an
15	equilibrium power.
16	VICE-CHAIRMAN WALLIS: No, but you've got
17	it there. You got in the last few seconds of the
18	previous slide, essentially cooling it.
19	MR. DIAMOND: Yes.
20	VICE-CHAIRMAN WALLIS: But the boiling
21	you don't care if there's any Boron in there or not.
22	CHAIRMAN BONACA: If you have the slow
23	transient, you
24	MR. DIAMOND: Yes. I mean, the that's
25	correct.

1	MR. ROSENTHAL: My memory serves me that
2	in a pressurized water reactor, you hold out about
3	half the reactivity with soluble Boron, and about half
4	with rods. You shutdown to about 350F, 400F on rods
5	alone, so I think that if you have the rods in there
6	and totally deborated forever, you're going to end up
7	with some temperature about 400F system pressure, and
8	some power, and you'll sit there.
9	VICE-CHAIRMAN WALLIS: It doesn't matter,
10	you don't need any Boron.
11	MR. DIAMOND: To go to the cold shutdown
12	you need the Boron.
13	VICE-CHAIRMAN WALLIS: You can't get the
14	cold shutdown, but at least it's it doesn't get
15	overheated or anything.
16	MEMBER POWERS: It's called N-O-P-N-O-T
17	almost, Normal Operating Pressure and Normal Operating
18	Temperature; 450 degrees Fahrenheit, and you go up to
19	2,000 psi, and sit there. You lift the release.
20	MR. DIAMOND: All right. This slide
21	repeats what I've already said, and what Jack
22	presented earlier, so I just want to have three
23	bullets here. One to remark that RELAP5/PARCS is a
24	viable method for this analysis. As Jack pointed out,
25	it's important to recognize that RES does have

2 transients in which both the neutronics and the thermohydraulics interplay. 3 4 From the point of view of fuel enthalpy, 5 the increase is only significant if the volume of the diluted water is large enough, namely one has the B&W 6 7 lower loop scenario, and the rate of injection is large enough; namely, one has the RCP restart. And as 8 I already mentioned, the effect is only possible on 9 the first 20 percent of the cycle, which also comes 10 out of consideration of panasonics. 11 Very good, Dave, 12 MEMBER ROSEN: stuff. 13 14 MR. DIAMOND: Thank you. 15 Well, I'm still sitting MEMBER POWERS: here saying they sure are happy with 173, 180 calorie 16 17 per gram percs on the fuel. And I keep wondering why are they so happy? I mean, what is it that makes you 18 19 say gee, I've got no -- life is good, got no trouble. 20 I just rattled the fuel - I'm just not real happy 21 about taking. 22 I think my argument was MR. ROSENTHAL: 23 that I think I have a reasonably low likelihood event. 24 And for that reasonably low likelihood event, I think of the extent of heating damage would be limited to 25

methodologies now that can analyze very complex

some region of the core. And I have a scenario in which by definition I have ECCS available.

Now let's talk more specifically about the enthalpy deposition. For 30 years, we've had on 1177 on the books, which says 280 calories per gram is an acceptable enthalpy deposition. It was associated with a reactivity insertion event of an ejected rod, which is a very fast event, the order of milliseconds. And we've recently done work at Cabris, we're cosponsors of Cabris, which says that the high burn-up fuel, that number might more likely be 80 or 100 calories per gram as a value at which you might damage clad. That's the high burn-up fuel, although I cannot guarantee the fuel loading pattern in some future I think that the one that David used is a reactor. typical reloading pattern, and so that the peak is more likely to occur in the fresh fuel for which there's more likely some margin than the older fuel.

In the Cabris test, we argued over is it 10 milliseconds or is it 30 milliseconds is the right pulse - time frame to run these tests at, because if you run the test fast enough, there's time for the pellet to heat up before the clad has time to heat up and start to grow, and become more ductile. If you can heat it, you can transfer the energy to the clad,

1

2

3

4

5

6

7

8

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

so that the clad warms up. It's more ductile, you can put more energy into the pellet.

The kinds of scenarios that we're running here are slow compared to the Cabris test, and that's why Dave focused on pointing out that first bullet, the less than a second, the so many milliseconds blip, because that's the enthalpy deposition that you should think of in terms of when you're comparing it to the Cabris, in which case the experimental evidence - it looks like it's okay. So it's the sum of those considerations. And then the last thing is that we put in place explicit operator procedures to tell them don't do it.

MEMBER POWERS: Let me follow-up on my question, please.

MR. ROSENTHAL: I apologize.

MEMBER POWERS: I think you persuaded me that you have a 5 times 10 to the minus 6 event. Okay. I took half of my 1 times 10 to the minus 5<sup>th</sup>. You aren't going to get P4 out of me. For 30 years, you've had 280 calories per gram on the books. You've known it's wrong. It has always been wrong. It's a flat wrong number. You've worked at Cabris. You understand that you have to be very careful about the power inputs, because if you leave power-off into the

so you worry about short transients, in which all the
energy goes into the fuel. But here in these
analyses, you're telling me I'm getting reasonable
hits on my fresh fuel, which can be adjacent to fuel
that's not so fresh, but you haven't told me anything
about that not so fresh fuel. Okay. Is it doing
nothing? Are you getting no energy whatsoever into
that?
MR. ROSENTHAL: I think there's one item
value in the core from what I learned in school.
David, can you address that?
MR. DIAMOND: It turns out in this
particular core, all of the burn fuel has a control
particular core, all of the burn fuel has a control rod in place in there, so there's going to be quite a
rod in place in there, so there's going to be quite a
rod in place in there, so there's going to be quite a large difference in terms of the fuel enthalpy rise in
rod in place in there, so there's going to be quite a large difference in terms of the fuel enthalpy rise in the spent fuel versus what's going on in the fresh
rod in place in there, so there's going to be quite a large difference in terms of the fuel enthalpy rise in the spent fuel versus what's going on in the fresh fuel.
rod in place in there, so there's going to be quite a large difference in terms of the fuel enthalpy rise in the spent fuel versus what's going on in the fresh fuel.  MEMBER POWERS: Now have you imposed a
rod in place in there, so there's going to be quite a large difference in terms of the fuel enthalpy rise in the spent fuel versus what's going on in the fresh fuel.  MEMBER POWERS: Now have you imposed a requirement that all burn fuel have a rod in it?
rod in place in there, so there's going to be quite a large difference in terms of the fuel enthalpy rise in the spent fuel versus what's going on in the fresh fuel.  MEMBER POWERS: Now have you imposed a requirement that all burn fuel have a rod in it?  MR. DIAMOND: No.
rod in place in there, so there's going to be quite a large difference in terms of the fuel enthalpy rise in the spent fuel versus what's going on in the fresh fuel.  MEMBER POWERS: Now have you imposed a requirement that all burn fuel have a rod in it?  MR. DIAMOND: No.  MEMBER POWERS: You left something out of

1 with higher burn-ups suffering not as high as an enthalpy as a fuel assembly with zero burn-up or low 2 3 burn-up, but it would be --4 MEMBER POWERS: But see, even if I go out 5 and find new experiment, let's say if I put 50 calorie per gram into this fuel, I broke it apart. Okay. Now 6 7 you can wave your hands and say okay, there are reasons for that, maybe the water was cool, things 8 9 I mean, my point is there's something like that. 10 missing from your analysis here. You haven't given me 11 enough information to make your case. That's the 12 point I'm making here. MR. ROSENTHAL: Even if you said well --13 14 if you applied those enthalpy increases that we have 15 for fresh fuel there to high burn-up fuel, you're still less than the enthalpy step increases which led 16 to cladding cracks --17 MEMBER POWERS: Oh, no, I'm not. If I've 18 19 got 173 calories per gram in the 50 gigawatt day fuel, 20 it's going to be pulling apart. 21 MR. ROSENTHAL: No. You're talking about 22 23 MEMBER POWERS: What do you mean no? It's 24 not no, it's yes. It's guaranteed. 25 MR. ROSENTHAL: I mean those experiments

1	are single pulse experiments. You're talking about
2	from an experiment at a single pulse which put in 170
3	calories per gram which cracked the cladding. Here
4	we're getting multiple pulses. Each one is
5	contributing maybe 25 calories per gram.
6	MEMBER POWERS: Okay. Now show me all
7	your experiments which say that that will not crack
8	the clad.
9	MR. ROSENTHAL: We've had the you can
10	look at the wide pulse data where you don't get
11	cracking.
12	MEMBER POWERS: It has nothing to do with
13	multiple pulses. You're making a case that says
14	multiple pulses won't crack the cladding. You've got
15	no data to support that argument.
16	MR. ROSENTHAL: No, but there's no data to
17	contradict it either.
18	MEMBER RANSOM: I didn't think that's what
19	they were trying to make. I thought they said there
20	would be fuel damage, just not loss of coolable
21	geometry. And that satisfies the G-68.
22	MR. SCOTT: David, this is Harold Scott.
23	The Japanese did do one test in NSRR, where they did
24	have multiple pulses. I think it was called I-11 or
25	something, so there's at least one thing like that.

1	MUMPUP POMURAGO T think through he hand
1	MEMBER POWERS: I think they'd be hard
2	pressed to use it to make their case here though.
3	MEMBER ROSEN: And what was the result of
4	that Japanese test?
5	MR. ROSENTHAL: Did not fail.
6	MEMBER ROSEN: Okay.
7	MEMBER SIEBER: But that's not the
8	criterion that you're using here. You're allowing
9	failure. You just want to make sure it cools.
10	MR. BESETTE: The main objective is
11	coolable geometry, that's the governing objective.
12	MEMBER RANSOM: Is that right?
13	MEMBER SIEBER: Well, the clad may not be
14	the only effect. For example, when
15	MR. di MARZO: I am Marino di Marzo. This
16	is a presentation, the objective of this presentation
17	is essentially three objectives. The first objective
18	is to give you an idea of the mathematical models
19	which are very simple, and provide some interpretation
20	of the physical reality, and at the same time give you
21	a tool to essentially end of mixing in a way that you
22	can scale it from the U-Scale experiments that are
23	available to the typical scale without too much of a
24	controversy.
25	The other objective is to then assess the

model that was presented in RELAP5/PARCS as reasonable for the vessel. And then the third part is to show how we're going to determine the boundary condition to the vessel depending on each of the scenarios, as far as the deborate movement. So as far as the model goes, this is very old material.

MEMBER POWERS: I said it once, I'll say it again - anybody that cites Levenspiel is okay in my book.

MR. di MARZO: All right. I'm blessed. It's extremely old material in the sense that what we want to do is to look at it in a very simplistic fashion, and look at true limiting condition. On the one end we want to look at the situation where we have plug flow. That basically means that an input signal enters the volume and exits exactly the same without any alteration, just the time delay. On the other end of the spectrum, that would be a totally unmixed-type process.

On the other end of the spectrum, we have something that we call backmix flow. You can call it a mixing cup. You can call it a completely mixing reactor, or in any other way. But basically, you have a totally steered volume in which you put new and then you get whatever comes out of the other side.

1	The formulation for that is the listing
2	here, where you have a current here that is multiplied
3	by the input function that you have. Now it is
4	convenient for what we are going to do to define a
5	time, an undimensional time which is the ratio, the
6	volume of the slug divided by the volumetric flow
7	rate. That we call a transit time. That will be the
8	time it takes the slug unborated to go through a
9	cross-section. So that way we can eliminate
10	essentially time from your equation, and just get a
11	generic type profile of what the concentration look
12	like during the transient.
13	VICE-CHAIRMAN WALLIS: You're scaling.
14	MR. di MARZO: Right. So now the nice
15	thing about the equation that is up there is that the
16	only thing that matters are volumes. We are not
17	making any statement in this approach as to the amount
18	of mixing.
19	VICE-CHAIRMAN WALLIS: Ratios of volumes.
20	MR. di MARZO: Ratios of volumes, is
21	either totally mixed or totally unmixed. And that's
22	very important because it enhances the portability of
23	what we do at one scale to another scale, provided
24	that we retain the same volume.
25	So now to the left here is what has been

done in PARCS lot as shown before. You have a timedependent volume where you put your first function in
terms of dilution that feeds one node which represents
the lower head. And then there is a junction which
has no volume, it's just a junction that feeds all
this part of the channels which are your core. So
that's basically what's in there. That's the RELAP
modeling of the vessel.

Now what we tried to do here is to look at the vessel in the following simplified way, to look at plug flow in the core that is in these channels, look at the backmix flow in the lower head that is in the portion at the bottom, and then plug flow in the downcomer. This is by no means an attempt to actually model what it is, but it's just simply a concoction, if you wish, of mathematical tools that give an answer and a series of assumptions that we then have to test against, some data and some experimental areas.

Now as far as the lower head goes, the geometry is quite important. What you have is if you wish a spherical angle here, or the region between two hemisphere, which is reasonably free from impediments for the flow, and then you have a highly constricted region going from this inner structure here through a number of sets all the way to the vessel. You can

1 three, four, and five screens count one, two, essentially where the flow has to go through. 2 3 VICE-CHAIRMAN WALLIS: Marino, that lower 4 colander has a lot of holes. 5 MR. di MARZO: A lot of holes. VICE-CHAIRMAN WALLIS: Using jets which 6 7 are likely to produce --8 MR. di MARZO: That's right. So there are jets through all this --9 10 VICE-CHAIRMAN WALLIS: Particularly through the lower colander. 11 12 MR. di MARZO: The lower colander is the first, and then --13 14 VICE-CHAIRMAN WALLIS: You're not mixing 15 in that lower volume. MR. di MARZO: Absolutely. In this volume 16 here there will be a lot of mixing, and there will be 17 also mixing in the region in-between, this region here 18 19 and this region here. So an analogy of what you're looking at is a distributed head, if you wish, with 20 21 extremely strong resistance on the distribution, so 22 that is a typical reasonably well distributed head in our way of putting it. So that's the configuration of 23 24 the lower head, and that's why the idea is to use it as a backmix flow there. 25

Now let's move forward and concentrate on this picture here, which is again from Levenspiel.

What we did is this; we took an F function. An F function is essentially a step going from zero to one at time zero, and we fed that into RELAP, into the model of RELAP as presented. So as this step function goes through that one volume that represents the lower head, we measured the output out of the RELAP calculation. That output is this thick line over here. Okay. If you put that in the context of this picture, you can see that this line here is very close to the backmix flow line, which has a dispersion of

Now as far as the reactor vessel goes, where you basically have the stack of nodes, we did the same problem. We essentially sent a step function through, and we look at how this is mixed as it moves through. We compared that solution with a solution given out by G.I. Taylor of a flow of a certain concentration following a flow of a different concentration, and we compare the result of RELAP with the results of the theoretical case. And again we

volume. In any case, it's in a region where you will

say there is a large amount of dispersion, or a large

In other words, it's a completely mixed

amount of mixes.

1	find low levels of dispersion. In other words, we are
2	in a situation close to this line over here, between
3	this line over here, but less.
4	VICE-CHAIRMAN WALLIS: Since RELAP models
5	complete mixing - doesn't it - why doesn't it lie on
6	the line?
7	MR. di MARZO: Because when you have a
8	stack of nodes, basically it's like having a series of
9	
10	VICE-CHAIRMAN WALLIS: A stack of nodes.
11	MR. di MARZO: It's a stack of nodes, so
12	in that sense you get something your arithmetical
13	diffusion but
14	VICE-CHAIRMAN WALLIS: This the lower
15	plenum plus the downcomer?
16	MR. di MARZO: No, this is just the
17	vessel, inside the core. Inside the core there are
18	only channels. Channels behave
19	VICE-CHAIRMAN WALLIS: It says lower head,
20	that's why I was asking.
21	MR. di MARZO: The lower head behaves like
22	this. Okay. Which is a fully mixed volume. The
23	channels in the core behave like this line here.
24	VICE-CHAIRMAN WALLIS: I just wondered why
25	that doesn't follow the

1	MR. di MARZO: Because it's a stack of
2	nodes. It's not just one the lower head is only
3	one node.
4	VICE-CHAIRMAN WALLIS: And it's mixed.
5	MEMBER ROSEN: It's very totally mixed.
6	VICE-CHAIRMAN WALLIS: I'm just puzzled by
7	why RELAP doesn't run exactly along the theory, since
8	it's modeling a mixed node.
9	MR. di MARZO: That I do not know, but the
LO	problem is this - I just took the answer that RELAP
l1	was giving, because there are options in RELAP, and I
L2	don't know it must have been exercised in that
L3	particular node, so I do not know. But what I know is
L4	what comes out of it. And looking at that response,
L5	essentially what it does is what's depicted here.
L6	MEMBER ROSEN: Now what you're saying is
L7	that in the core now there's very little mixing. It's
L8	axial flow.
L9	MR. di MARZO: Right.
20	MEMBER ROSEN: No cross-flow, very little
21	cross-flow.
22	MR. di MARZO: Very little according to
23	RELAP. Remember, this is only what RELAP does. Now
24	in the lower head we have total mixing according to
25	RELAP again. The downcomer is not present in the

model formulated by RELAP5 in that supply to PARCS. So the only way you can represent it in that model is essentially a plug flow, because it's just missing. So that's basically the model that has been coupled with PARCS. That's what's there. I'm just simply using these simple mathematical tools to explain what RELAP is doing; no more, no less. No attempt to say it's right or wrong. It's just something like this. Now on the other end, we have performed experiment at Maryland, actually it wasn't even me, it was another crew when I was not into the project any more, in the framework of a CS&I experiment, where essentially front was sent through the cold leg, went down the downcomer, and then was measured at that elevation. In research there was a CFD computation performed of the same geometry, exact same geometry of the experiment for all the downcomer, the lower head, up to the core entrance. Those two --MEMBER RANSOM: This is a model of the Babcock & Wilcox system. Right? MR. di MARZO: It is a model of the Maryland facility, which is a model of the Babcock & Wilcox. MEMBER RANSOM: Okay. Right. MR. di MARZO: And the results I have, but

1

2

3

4

5

6

7

8

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

1	in the interest of time, I'm going to move on and not
2	show. But basically, those two the CFD computation
3	and the Maryland experiment are in extreme agreement.
4	There's very good representation of that.
5	So here what you have is the simplified
6	model where there is a totally unmixed downcomer, and
7	then there is a fully mixed lower head going to the
8	core. And superimposed on this is the CFD
9	calculation.
LO	Now what these bars represent is the
L1	distribution that you have about that difference,
L2	about that remember, this is just a location across
L3	the entrance of the core, so there's a distribution.
L4	VICE-CHAIRMAN WALLIS: No experiment in
L5	this
L6	MEMBER RANSOM: That's data you're talking
L7	about.
L8	MR. di MARZO: This is CFD calculation
L9	validated against data.
20	VICE-CHAIRMAN WALLIS: No, against the MM.
21	It's the MM versus CFD. The experiment must be
22	somewhere else.
23	MR. di MARZO: Yes, you want to see the
24	experiment
25	VICE-CHAIRMAN WALLIS: It's not shown in

1 that figure. 2 MR. di MARZO: It's not showing in that 3 figure, but I can go --4 VICE-CHAIRMAN WALLIS: No. I'm just 5 pointing out that you haven't said over there, but it's not --6 7 MEMBER SIEBER: We did it already. MR. di MARZO: You did it already. Okay. 8 9 MEMBER RANSOM: For the error bars or just from the CFD calculation? 10 11 MR. di MARZO: The error bars to the CFD Now refer to the previous 12 calculation. Okay. What it is that gets you into trouble 13 presentation. 14 here are two things; is the magnitude of the slug, and 15 essentially how low does it go in terms of Boron 16 concentration, one. But most important is the 17 sharpness of the entering flow. Now in the model that we have used to 18 19 generate the input that generated the result that 20 you've just seen, basically we used a black line and 21 look how sharp the entering slug is compared to what 22 it would be if you use a less conservative, if you 23 wish, approach of using the CFD calculation. So that 24 already there introduces a quite conservative element

in the results that you're getting.

1 VICE-CHAIRMAN WALLIS: I suppose they could be sharp if you actually use those error bars. 2 3 You could create a --4 MR. di MARZO: You could go there, and 5 then if you use the top --VICE-CHAIRMAN WALLIS: No, use the top of 6 7 one, and then you zip down to the bottom of the other. What does it -- what the 8 MR. di MARZO: error bar means is this; is essentially 10 percent of 9 -- there are fingers of high concentration and low 10 concentration. That's basically what that means. Now 11 12 on the low end we bound the lower edges of those concentrations, and so essentially we are conservative 13 14 again. So this representation is a very simplistic 15 mathematical representation, has the feature of adding a sharper edge here, and has the feature of adding a 16 low concentration over here. So in a sense, it's very 17 simply. It enables us to port it from this use scale 18 19 to the large scale because the only argument we have 20 to make is volumes, and therefore, we use that as 21 input to the RELAP/PARCS computation. So that is what 22 we are doing for the vessel. first 23 Now the the we've seen 24 conclusion, but what we have said is that the model

that's present in PARCS/RELAP is reasonable, albeit

conservative with respect to what reality could be, at least for the data and the computation that we're performing.

Now we have to solve the problem of what do we feed to the downcomer. And that depends on a variety of initial conditions. You start the pump, you start the - whatever the situation, where the slug is, and how do you form the slug and all these things. So in order to do that, we conducted a series of experiments again at Maryland, and they were based on a set of assumptions. And the assumptions were as follows; this is the steam generator, the lower portion of the steam generator. This is the steam generator outer plenum, and these are the two legs. So for the pump case, this pump will be activated and essentially will draw from the tubes and we also draw from the other side, typically. So what we're trying to establish here is can we use simple models like before in order to represent this situation. And the idea is to use plug flow in the PARCS, because PARCS do not mix much. And to use instead completely mixed volumes in the steam generator outer plenum, because there are two effects here that comes into play. First, the flow comes out of all the tubes, and those are again jets coming into the plenum; and therefore,

1

2

3

4

5

6

7

8

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

enhanced mixing. And second, there is flow from the adjacent leg coming in and mixing, stirring up the volume as well. So this will be a fully mixed volume.

The other fully mixed volume is the volume of the pump. Now there is nothing magic about the volume of the pump. It's just an assumption; the idea being that the pumping pellet being moving addressed will generate some volticity and therefore some mixing in the flow downstream. The equivalents of all this mixing is a fully mixed volume of the That's just the assumption that we're making. pump. So we made these two basic assumptions, and then we ran a test. And I have the results of the test if you want, but basically we activated the pump and measured what was going through. And then we calculated with this simple model that they explained to you what happens, and the front of the slug, which is here at this point as you activate the pump, we go only through the pump, so the mixing that the front experienced is only one mixing volume, the volume of Therefore, it maintains its sharpness. the pump. Depending on the slug, which is back into the steam generator on the other end experience mixing because it goes through the steam generator outer plenum first, and then through the pump second, so it's a

1

2

3

4

5

6

7

8

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

1	much more slanted-type process. What we get is this
2	line.
3	VICE-CHAIRMAN WALLIS: That's your
4	measurement at the outlet site.
5	MR. di MARZO: Yes, the dots are the
6	measurement at the outlet pipe. And the line is what
7	you get from these are close form solution of the
8	same equation that I showed you on the very first
9	slide. And again, I've got the case if you want.
10	So this gives me a tool to predict the
11	input to the calculation, so that's basically the
12	methodology of the tools that were used to generate
13	the results that David Diamond just showed you for a
14	variety of conditions.
15	VICE-CHAIRMAN WALLIS: This is also a peer
16	review document, and
17	MR. di MARZO: This is right.
18	MEMBER RANSOM: This has got the
19	equivalent of an ACRS standing ovation silence.
20	MEMBER POWERS: That's the best thing that
21	could happen to you.
22	MR. di MARZO: These are my conclusions.
23	So the RELAP/PARCS model for the in-vessel mixing is
24	reasonable, albeit conservative. These mixing models
25	are used to generate the boundary condition to it, and

basically what we do with that, we fill them in the time dependent volume, that's at the bottom of -- the input of the RELAP code, as shown.

MEMBER RANSOM: Thank you. I think this was really the key behind resolution of this issue, because all of the work that had been done in the past that brought this issue to the front assumed plug flow throughout, so the step change, instantaneous entrance to the core, and that did create reactivity transients that would bring about core damage, and so this was a very important contribution I think, and it adds realism, as well as still some conservatism to the analysis. So thank you.

VICE-CHAIRMAN WALLIS: If he had also done the other extreme, like putting in a slug with no mixing, it's showing that that gave a bigger reactivity transient. So you didn't do that actually, you just put in a more realistic one. It's perfectly okay, just careful about the word "conservative" if you didn't do the alternative thing -- it's been done before. You did it, that's right.

MR. ROSENTHAL: Right. And they use a point kinetics, we used a 3D kinetics model. In my branch, of course we do reactor physics and we do thermohydraulics code development. I also have a

substantial fuel program underway. And Ralph Meyer sits on the other side of a partition from me.

MEMBER ROSEN: Never heard of him.

MR. ROSENTHAL: It would have been I think improper to use the regulatory limits on acceptable fuel enthalpy deposition when research itself had issued a letter to NRR, and we're working with NRR advising them for high burn-up fuel, the permissible enthalpy deposition in a reactivity insertion event, you have an injected rod specifically might well be lower. Dana, of course, is familiar with that work, and I asked Ralph to come down, Dana, because I thought that he might be able to better answer questions on relative fuel time constants, et cetera, than I am.

MEMBER POWERS: Ralph, the question that I have posed is that in the course of discussing this resolution some power inputs to the fuel over relatively long time schedules compared to what we're used to for reactivity transients are predicted, but — and there was a confidence that this was okay. And the articulated basis of that confidence was the 280 calorie per gram geriatric criterion. And that's only one issue.

The other issue is that it seems to me the

analyses have been done not looking at the most pathological configuration of fuel; that is, configuration that was examined, clearly the most energetic events occur in the fresh fuel, but the question is what about adjacent assemblies that have some burn-up, the adjacent assemblies that were examined had rods in them. So one obviously asks the question what happens if the adjacent burned-up assemblies don't have rods in them. And so I quess the question being put to you is, is it, in fact, okay to have a fairly potent energy inputs to fuel rods that over some protracted period of time - well, protracted, of course, is measured in seconds, but not measured in milliseconds - and how do you know? And necessarily single impulses, but multiple not impulses.

MR. MEYER: Okay. I'm Ralph Meyer from NRC's Research Office. Harold showed me out in the hall before I came in, showed me slide 11 in David Diamond's presentation, and pointed out the two pulses that you were thinking about. The first one was the initial pulse, which is very sharp, but had an energy content of something on the order of 40 calories per gram.

Now at 40 calories per gram, we know from

1

2

3

4

5

6

7

8

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

1 test pulse experiments that 40 calories per gram is 2 not sufficient to cause cladding failure or crack in 3 the cladding, or perforation of the cladding in any 4 way. So I would say that you can rule out any concern 5 over that initial spike, because the energy content is too low. 6 7 The next one that Harold points out is very broad, if I'm looking at the right figure, and 8 9 has a peak fuel enthalpy of 180 calories per gram. 10 So you can see that on the scale here on the right-hand side. And as you mentioned, Dana, it's the 11 12 half-width of this pulse, the full width at halfmaximum is several seconds. 13 14 MEMBER POWERS: I'm not sure that's a good 15 measure for this particular scenario. I don't think you want the half-width - I mean, pulse width at half-16 17 height. I think you want the ramp time here. Well, you want the which? 18 MR. MEYER: 19 MEMBER POWERS: The ramp, how fast you get 20 up to the peak. And it's over 2 seconds. It's slow. 21 MR. MEYER: Actually, what matters is how 22 much time elapses until you cause a failure of the 23 cladding, and now it depends on several variables, and 24 we could talk about whether this is high burn-up fuel

or low burn-up fuel, whether it is heavily corroded or

1 lightly corroded. And all of those would make a 2 difference --This is fresh fuel. 3 CHAIRMAN BONACA: 4 Right? 5 MEMBER POWERS: It's fresh fuel. MR. MEYER: I can't guarantee the loading 6 7 pattern, so for the purpose of this meeting you have to assume that the enthalpy deposition that we're 8 showing in the fresh fuel, in fact, could conceivably 9 occur in burned fuel where we know the limit is lower. 10 11 MEMBER ROSEN: Typically in accord with a 12 thrice burning fuel, this would -- the beginning of the third cycle. 13 MEMBER SIEBER: But the key point is that 14 15 the fuel after it goes through this transient has to 16 only be in coolable geometry, and so that's a different criteria than the burn-up one, and enthalpy 17 limits that we're talking about here. 18 19 BESETTE: Actually, there's only 20 really one pulse in this event. And basically, you're 21 sitting around 100 percent power, and you heat up over 22 the course of about 5 seconds. And, in fact, these 23 other things you start to think about, and most 24 importantly, some of these rods end up in DNB for a

period of 10 seconds or more. So you're no longer

you're dealing more with a
MR. MEYER: The thing that we're really
that's relevant. And the thing that we're really
concerned with here is not the failure of the
cladding, but whether you're going to eject fuel in a
manner that would cause a fuel coolant interaction.
MEMBER SIEBER: That's right.
MR. MEYER: Because if you just lose a few
fuel particles rolling out into the coolant, this is
benign. And now that I see that picture clearly,
we're not talking about 180 calories per gram, except
in wait a minute.
CHAIRMAN BONACA: Some things that could
be actually 20 percent above. That's an assembly-wise
average enthalpy, as we heard before.
MR. MEYER: Okay. What I see in this
figure is different from what I thought I heard from
Harold, so maybe we're going to have to recalibrate
here. Th is initial pulse reaches 180 calories per
gram?
MEMBER ROSEN: No.
MR. MEYER: Is it the red line or the blue
MR. MEYER: Is it the red line or the blue line that

MR. MEYER: Oh, the blue line. Okay. Yes, yes, yes, yes. I see it now. I see it now. Okay. Yes. Okay, so now I see where the 40 is, now I see where the 180 is. And it's starting at hot conditions around 16 or 18 calories per gram. Okay.

The overriding factor is the time here, and the dispersal of fuel is going to require one of two things. It's going to require either enough fuel enthalpy to cause significant melting, which we know from experimental work is about 230 calories per gram, so we're nowhere near that; or it's going to require a lot of fission gas on the grain boundaries, which can only come from high burn-up.

MEMBER SIEBER: Right.

MR. MEYER: And a narrow pulse with a fuel enthalpy of greater than about 80 calories per gram. Now what you have is a very broad pulse with a fuel enthalpy of 180 calories per gram. This pulse may result in cladding damage and cladding failure from a high temperature excursion, but based on the test results, would not be expected to drive hot fuel particles into the coolant, so it would be benign.

MR. ROSENTHAL: Maybe we should stop at this point and just summarize, because we're not doing frap tran analysis as we sit here, but we will be able

to couple that in a year or two, and do an integrated total picture. Okay. So what we've argued is that for CNE and Westinghouse plants, just based on the size of the piping, you don't have a recriticality. You can dismiss the event. But B&W plants, it's an issue, not for raised loop, for lower loop plants, the majority of the plants.

We've argued that the likelihood of the event is reasonably low. Should we have that event, I can end up in natural circulation for which we've mechanistically shown that we've have low enthalpy deposition, and the fuel will survive.

I cannot be dispositive that for the perverse pump case that I won't damage some fuel. We've argued that the damage of that fuel would be limited in radial and axial extent, and coolable and with ECCS available by virtue of the scenario we're talking about here. So for the one case where I cannot be dispositive, the B&W pump case, we know that there are procedures that have been put into their EOPs, and the bases document explains why they're there, and that's the basis that we think that no further action is necessary.

MEMBER ROSEN: The only thing I can quarrel with with all of this is the use of the word

1	"benign" when one talks about this event. It would be
2	a very unbenign thing for the plant manager and his
3	staff.
4	MEMBER SIEBER: Yes, but getting there is
5	
6	MEMBER ROSEN: I think I know what you
7	mean, but it's not a benign thing.
8	MEMBER POWERS: Getting there is not
9	benign either.
10	CHAIRMAN BONACA: Vic, are you going to
11	wrap it up?
12	MEMBER RANSOM: I think we're through.
13	MEMBER POWERS: Very good. I guess I
14	still have one question. I have a lot of questions,
15	but I'll ask one question. The famous blue line here
16	which isn't that some place in Baltimore - reflects an
17	assembly average the worst broad looking line.
18	MEMBER DENNING: The black line, that's
19	not assembly average.
20	MEMBER POWERS: Oh, that's not the
21	assembly average.
22	CHAIRMAN BONACA: Well, we were told it
23	was assembly average.
24	MR. MEYER: I said there was a difference
25	of about 20 percent.

1 CHAIRMAN BONACA: Okay. So the assembly 2 average would be lower than that, and the 20 percent 3 is added on top. Okay. 4 MEMBER SHACK: But Jack's slide said that 5 you will get some fuel melting, center line melting. That's right. 6 MEMBER SIEBER: 7 where the hotter --8 MR. MEYER: Let me comment on that because we have experimental data for fairly narrow pulses 9 And I'll just repeat it again. 10 that address this. 11 You've got to get about 230 calories per gram in 12 there, which would involve already some incipient melting which may start around 150 calories per gram; 13 14 but we know experimentally that you need over 200 15 before you start really breaking up the fuel, and putting small pieces into the coolant. 16 17 MR. ROSENTHAL: The last thing I'm reminded that we've made a reasonable technical, 18 19 multi-discipline case, and what we need from the ACRS 20 is a letter. 21 MEMBER RANSOM: Thank you, Mr. Chairman. 22 CHAIRMAN BONACA: Okay. Thank you. If we 23 have enough time at this meeting, we'll have a letter. 24 We're struggling with that. You will have a letter 25 from us. Okay. We still have one presentation on the

	384
1	agenda, and as I said, at 6:00 I'm going to head out,
2	and we need to absolutely have a discussion tonight
3	about some issue, so we'll try to do the best we can
4	with the next presentation.
5	MEMBER SHACK: We have one hour. Is that
6	what you're saying, Mario?
7	CHAIRMAN BONACA: Yes, we have just about
8	one hour. And if we need two, then we'll have to
9	postpone the rest of the presentation.
10	MEMBER SIEBER: I'll give the
11	introduction, by the way, in an effort to cut off at
12	the pass things we've already are we ready to
13	begin?
14	CHAIRMAN BONACA: Yes.
15	MEMBER SIEBER: Thank you. Our last
16	subject today is a review of a document that is
17	provided to each of us at Tab 5 in our books, which is
18	a draft NUREG entitled FX-XXX, that reports on the
19	analysis of the results of the pilot program along
20	with six recommendations that the staff believes
21	should be incorporated into a final mitigating system
22	performance indicator program.
23	I would point out that this project has
24	been going on since September, 2002, and originally

started in 1999 when Chairman Jackson gave the

suggestions that the regulations be risk-informed. One of the early projects was the development of the ROP, which relies first on inspection findings which through the significance determination process are color-coded for risk-importance, and performance indicators which initially were not risk-informed and, therefore, did not meet the original guidance where risk information was to be used to the extent possible.

the Mitigating System Performance Indicators area, there was safety system which for unavailability PWRs tracked the unavailability of high head injection, low head injection, RHR, diesel generator, service water, and so forth in the equivalent pieces of equipment for BWRs, HPSI, RCSI and emergency power and so forth. So you ended up in the Mitigating or in the safety system unavailability indicator a number of indicators which now under the Mitigating System Performance Index will all be rolled into one.

The new proposed index, the development of that was started in September, 2002. We met twice on that as a subcommittee, and at one time had a full committee presentation to describe what those were.

And briefly, the Mitigating System Performance

1

2

3

4

5

6

7

8

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

Indicators are risk-informed. They are based on SPAR models which have been indexed to the plants' PRAs, and therefore, are plant-specific. And they really are a summation of the Birnbaum Importance Factors, and take into account both unavailability and unreliability of each of the components selected to be a part of this.

During the development phase, which lasted about six months, the basic structure of the index was developed and a 20 plant pilot program was begun, which again lasted for six months, during which a lot of Lessons Learned occurred, and now we have this draft NUREG which I'm sure we've all read, and I have read it. And it provides a number of suggestions, which were already transmitted of previously; the idea of front stops and back stops, parameters and sensitive and unsensitive were important factors that have been known for probably about a year now, and incorporated into the process. So what we'd like to do this afternoon is to review the draft NUREG report which is the analysis of the results of the pilot program, and see the extent to which the MSPI is now ready for integration into the ROP.

I would point out that the ROP does not

1

2

3

4

5

6

7

8

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

represent anything safety-related or safety-significant. It is an administrative tool that is an outcome of the ROP action matrix to guide the staff in allocation of resources toward licensees. So from that standpoint, the MSPI may not and need not be perfect in every respect, but suitable for the purpose for which it's intended, which is the operation of the inspection and enforcement part of the Commission's mission.

So with that, Pat, I think you can proceed. Anything I've covered, you may skip because we must end at 6 p.m. The microphones are shut off at 6 p.m.

BARANOWSKY: Okay. I am Patrick Baranowsky, Chief of the Operating Experience Risk Analysis Branch, and I have Donald Dube, who is a Senior Risk Analyst in my branch here who will talk about the MSPI, and Stu Richards from NRR's Inspection Program Branch who will talk about implementation I'd like issues. And to thank you for introduction because it's going to make my job a lot I don't have to repeat things that you said, easier. and we will move along accordingly.

We are going to give you the status of implementation. Stu will actually present that.

1

2

3

4

5

6

7

8

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

We're going to go over a few technical issues that were still open, I think, at the last meeting. You did have the report which provides a fairly significant discussion of those issues. And at the end, we want to talk about having a letter from the ACRS. So this is the content. We made a few changes in order here. I'm going to do the MSPI overview, Don will do the technical discussion, I'll get back to the summary, and at the very end we'll follow-up with the implementation issues.

We think that the work that we've done indicates that the MSPI is a robust performance indicator that can differentiate risk-significant changes in system performance, and is reasonable for the intended application. It's been tested, evaluated through the pilot program, as you mentioned. We have a good understanding of its characteristics, its strengths, its limitations, and we have pretty significant documentation on all the issues that are associated with MSPI that we did quite a bit of study on during and after the pilot, and that's in the report that we sent.

We think it's pretty clear that the indicator is a better measure of system performance for many reasons than the safety system unavailability

indicator, and that it addresses the known problems of the safety system unavailability indicator.

I'm not going to go all the history that John gave a great discussion on, but I do want to mention that the MSPI was formulated to address known the safety system performance issues with unavailability performance indicator, specifically the way fault exposure time was used, the fact that unreliability elements were not in the indicator. definition There were some differences and unavailability in that indicator, and some other indications, such as what's used in the Maintenance Rule and INPO WANO indicators. There was a cascading of failures using the SSU from support system to front line systems, which gave multiple hits for a single issue and was problematic in terms of dealing with the And the thresholds were minimally action matrix. risk-informed, and certainly not plant-specific, so we went through the history of developing the indicator, as discussed.

Our conclusions are that we've tested, evaluated this through a pilot program. I'm at the wrong thing. And now I go to Don. I' almost skipped the whole hour.

MR. DUBE: Thank you. I'll go through

1

2

3

4

5

6

7

8

9

10

11

12

13

14

15

16

17

18

19

2.0

21

22

23

24

this quickly. The MSPI accounts for unavailability and unreliability which occur indicated as an I, and it uses the plant-specific PRA model to derive risk-important measures, so it really captures the plant-specific configuration and performance which the current indicator does not.

The data will be consistent with current PRA methods which is not necessarily the case of the current SSU, and will be consistent with the maintenance rule. The data will be integrated with the consolidated data entry program under INPO's jurisdiction, so it's going to be kind of a one-stop shopping for data. Licensees will send their data to INPO and it will be used for a number of things looking at equipment performance, system performance, but also part of it will be used for the MSPI.

MEMBER APOSTOLAKIS: I am a little bit surprised that you guys don't put as part of your advantages for going with MSPI the fact that, I think it addresses the - what flaw was that, fundamental flaw of the ROP. What do we call it, it was another adjective.

MEMBER SIEBER: Which one?

MEMBER APOSTOLAKIS: The ACRS identified a fundamental flaw, which was changing each indicator,

1	and then seeing what happens to CDF and then based on
2	that, setting the thresholds. And we argued that you
3	can't do it one at a time. You shouldn't be doing it
4	one - because the core damage will not occur because
5	one indicator or one unavailability went too high. It
6	will be the combination of things. And I think by
7	putting this Birnbaum measure there, you're actually
8	addressing this issue.
9	MEMBER SIEBER: That's right.
10	MEMBER APOSTOLAKIS: And I would make a
11	big deal out of it.
12	MR. DUBE: I would say an ACRS letter
13	could make a big deal out of it.
14	MEMBER APOSTOLAKIS: No, but you go back
15	to that letter. I mean, our major complaint in all
16	the letters we've written on ROP has been that. You
17	understand the issue?
18	MR. DUBE: Yes, I understand
19	MEMBER SHACK: If you set the threshold
20	based on this, you still have that problem, if you're
21	looking at the if you use the Birnbaum, it
22	integrates it, but you're still looking at the change
23	due to this specific set of
24	MR. BARANOWSKY: We are holding other
25	factors constant.

1	MEMBER SHACK: Other factors constant.
2	MR. BARANOWSKY: We are holding them
3	constant, but we're adjusting them to whatever they
4	are at that time. They're not being held constant
5	forever. They get updated
6	MEMBER SIEBER: It's the combination of
7	these factors that go in there.
8	MEMBER APOSTOLAKIS: But it's a step
9	toward resolution of that.
10	MEMBER SIEBER: And rather than look at
11	peer comparisons
12	MEMBER APOSTOLAKIS: The other guys are on
13	the PRA, so you better not refer to it.
14	MEMBER SIEBER: Rather than look at peer
15	comparisons for green and white threshold, you're
16	looking basically at risk information, which I think
17	is an improvement. And that's certainly in there, and
18	it's one of the features.
19	MEMBER APOSTOLAKIS: Do you have to tie
20	this to train unavailability? Is it to be able to, as
21	you say, be consistent with what other people are
22	doing?
23	MEMBER SIEBER: It's train unavailability.
24	MR. DUBE: It's train unavailability
25	MEMBER APOSTOLAKIS: I know what it is,

1	but does it have to be? It doesn't look like it has
2	to be. I mean, it can be a component, internal
3	component, couldn't it?
4	MEMBER SIEBER: There was arguments in the
5	paper why it was better off being train rather than
6	MEMBER APOSTOLAKIS: Well, one of the
7	reasons is the Maintenance Rule, I think.
8	MEMBER SIEBER: Yes.
9	MR. DUBE: Won't have to collect extra
10	data.
11	MR. BARANOWSKY: The way the formulation
12	is, we could actually take any set of items in the
13	plant. It doesn't make any difference whether it's
14	trains, or components
15	MEMBER SIEBER: And apply those.
16	MR. BARANOWSKY: So that's a kind of
17	unique thing about it.
18	MEMBER APOSTOLAKIS: No, because you have
19	some limitation that you don't include common cause
20	failures. But if you went to a component level, then
21	you could include it.
22	MR. BARANOWSKY: Well, we include common
23	cause failure as a factor to recognize the importance
24	of failures, but what we have trouble doing is taking
25	a common cause failure event and as a result of it,

1 making change the failure to common cause 2 parameters, because the time frame for updating 3 information is too short to get a good estimate of the 4 common cause parameter. 5 MEMBER SIEBER: One of the other factors is the back-stop provision in a way provides a 6 7 mechanism so the common cause factors aren't overlooked all together for insensitive parameters. 8 9 So even though it's sort of in the abstract there, there is a consideration, a process that must be gone 10 11 through when people analyze what the MSPI really means 12 as it's applied to the matrix for a given plant, as I see it. 13 14 MR. BARANOWSKY: Yes. The methodology 15 presumes that common cause failures can be treated through correlations of single failures. 16 17 MEMBER SIEBER: Right. MR. BARANOWSKY: But that the occurrence 18 19 of a common cause failure where multiple components 20 fail is so significant that we want to look at that 21 separately, so we put that off to the significance 22 determination process. It's a blend of things. 23 MEMBER SIEBER: And that's because the 24 common cause failure of that nature is probably a

cross-cutting event.

1 MR. BARANOWSKY: Yes, it has biq 2 implications. MEMBER SIEBER: That's right. 3 4 MEMBER SHACK: Well, the back-stop is also 5 purely a performance measure. MEMBER SIEBER: That's right. 6 7 MEMBER SHACK: So it does solve some of the problems that we originally had with the ROP. 8 9 MEMBER SIEBER: Yes. MR. BARANOWSKY: Well, we were listening 10 11 to you guys, and we --12 MEMBER SIEBER: Well, the way I addressed all that in my draft letter was to say you have 13 14 listened to and incorporated our comments in the past, 15 which include all of these things. I decided to use a layman's 16 MR. DUBE: 17 definition, so there are no equations here. But a good way to relate what the MSPI is, it's a measure of 18 19 the deviation of plant system unavailability and component unreliabilities from historical baseline 20 21 values, so you have HPSI pump unreliability at a 22 plant, minus a historical value. If it's positive, 23 that's bad because unreliability of that pump at the 24 plant is worse than the industry norm. But we can 25 relate unavailability and unreliability by their

1	impoortant, their risk-importance, so that factor, if
2	you will, that coefficient is what relates
3	unavailability and unreliability, and makes them an
4	apple-to-apple comparison, which I think is somewhat
5	unique. And then we can also compare the importance
6	of a pump in a system, or the valve in a system again
7	by the importance, weighting by the importance
8	measure. So it's an interesting way to combine
9	unavailability and unreliability into a single system
10	measure.
11	MEMBER SIEBER: The valves have been
12	excluded from the analysis.
13	MR. DUBE: Well, low risk important valves
14	can be excluded, because
15	MEMBER SIEBER: Even though they're
16	active.
17	MR. DUBE: Yes, because we determined that
18	if we excluded low risk important valves, it would not
19	change the index by any measurable amount. It would
20	be insignificant.
21	MEMBER SIEBER: Just so that's clear.
22	MR. DUBE: And so in that way, if a valve
23	is important to the PRA results it will be included.
24	If it's below some truncation level, some threshold,
25	we decided that the cost of collecting the data did

1	not outweigh whatever impact it had on the MSPI.
2	MEMBER SIEBER: Right.
3	MR. DUBE: It would leave out.
4	MEMBER ROSEN: The low risk importance of
5	a valve is known in every plant? I mean, the risk
6	importance of each valve?
7	MR. DUBE: There's a threshold. It would
8	be a Birnbaum of 10 to the minus 6, so licensees will
9	calculate this, and if they're below if a valve is
10	below it, they can leave it out of the system.
11	MEMBER ROSEN: I'm trying to get to the
12	question of is there a plant out there still who is so
13	non-PRA informed that they can't tell you the risk
14	importance of their valves?
15	MR. DUBE: No, they should all have it.
16	MEMBER ROSEN: They all have them.
17	MR. DUBE: Yes.
18	MEMBER ROSEN: Maintenance Rule forced
19	that.
20	MR. DUBE: Oh, yes, definitely.
21	MR. BARANOWSKY: Where or not their PRA is
22	complete
23	MR. DUBE: It can be easily calculated.
24	MR. BARANOWSKY: Yes, whether the PRA is
25	adequate or not, we have an issue on that. But they

1	have something.
2	MEMBER SIEBER: That's for another day.
3	MR. DUBE: So I'm on the technical
4	approach, I'll go quickly. But basically, I mentioned
5	it before - it's an approximate change in CDF, and
6	it's not an exact because it's tail expansion, if you
7	will, and we're only using the first term, and there
8	are other terms. But for what we're looking at, which
9	is trying to look at deviation of system performance
LO	from the norm, we feel that it does a good job. It
L1	includes unavailability and unreliability, and as I
L2	said before, it accounts for plant-specific features,
L3	and plant-specific core damage frequency.
L4	MEMBER RANSOM: Is the baseline that it's
L5	compared to plant-specific, or is that an industry
L6	baseline?
L7	MR. DUBE: Industry baseline, generic
L8	industry baseline on unreliability.
L9	MEMBER SIEBER: The system and component
20	level depends on whether you're talking
21	unavailability of unreliability.
22	MR. DUBE: Yes, there are some
23	differences, but basically it's generic industry data.
24	MEMBER APOSTOLAKIS: Let me understand
25	that a little better. Aren't you updating as you go?

1	MEMBER SIEBER: Yes.
2	MR. DUBE: No, we're using data that's
3	roughly representative of 1995 to 1997 industry
4	performance which has been deemed by policy to be
5	acceptable.
6	MR. BARANOWSKY: Plus the standard that
7	was set during the ROP development, the Commission
8	actually bought into that. And even though we're
9	using data that's more current, what we've done is
LO	benchmarked it to see whether it's it's a little
L1	bit conservative, so we got somewhat conservative
L2	improvement over that `95 to `97.
L3	MEMBER APOSTOLAKIS: So the SPAR model is
L4	plant-specific only in the sense of the full event is
L5	being plant-specific.
L6	MR. DUBE: SPAR models currently don't
L7	have plant-specific failure rates. It could. That's
L8	the next step.
L9	MR. BARANOWSKY: And when we put the MPSI
20	data in, that is plant-specific failure rates, and
21	then we compare that to the baseline, which is a
22	generic number of `95 to `97 time frame.
23	MEMBER SIEBER: But the SPAR models have
24	been benchmarked and are within a factor of 2 to 4 of
25	the plant's PRAs as I understand it.

1	MR. DUBE: WE've had a major effort on
2	that.
3	MR. BARANOWSKY: Yes. We're actually able
4	to get a lot closer but where we are factors of 2 to
5	4, we've identified the factors within the models that
6	cause that difference, and that's part of our PRA
7	adequacy resolution activity to get those things
8	worked out.
9	MEMBER SIEBER: But this has been
10	addressed by the staff as an issue.
11	MR. BARANOWSKY: Yes.
12	MEMBER SIEBER: An ongoing issue in the
13	development of the MSPI.
14	MR. BARANOWSKY: Yes.
15	MEMBER SIEBER: And it's in-hand now.
16	MR. BARANOWSKY: Yes.
17	MR. DUBE: These are the systems, I won't
18	spend any time, but it's basically high pressure
19	systems, aux feed. Generally, the most risk-important
20	systems. And what we have that's not in the current
21	ROP are support system cooling water systems, service
22	water, emergency service water, component cooling
23	water.
	Now I'm going to shift over to the
24	Now I iii going to shirt over to the

we've discussed before, but we've reached a decision on these, both the NRC as an agency, as well as the working group with the industry.

Velocity behind the front stop is that expected performance variation should not result in crossing a performance threshold. In other words, there is some distribution, a component, an automobile, a pump, there's some normal distribution to failure rates, and within some range, one would expect some variation. And just because it's slightly worse than average, or slightly better than average, that's a normal expected variation.

MEMBER SHACK: But why didn't you define the front stop as sort of the inverse of the back stop? I mean, you defined the back stop in exactly the way I thought you would. You would look at sort of the number of failures you would expect to get, and if you got more failures, you knew you had a problem. Here, why didn't you do it in the same way - define the sort of number of failures you expected to get, and accept it. And you somehow introduce this artificial capping or the risk cap, and I can't quite figure out --

MR. DUBE: Well, because the expected number of failures typically is like .1 or .2 on many

components on many systems, so --

1

2

3

4

5

6

7

8

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

25

MEMBER SIEBER: And it can result in a risk number greater than what you would normally expect, and that's why the cap is there.

MEMBER SHACK: So you're really saying that one is the smallest integer that corresponds really to what you're expecting there is.

MEMBER SIEBER: Right.

MR. DUBE: That's the challenge.

MEMBER SHACK: That's the challenge.

Okay. That's reasonable enough.

MR. DUBE: So the front stop is mechanism and it is just that it minimizes the likelihood that one failure or one failure beyond baseline, which is generally about one or two, in a three-year period results in white. But we built into this the allowance that the index could still become white with one or even zero failures if there's significant system unavailability, so I mean it was -there's so many degrees of freedom, but we built into it an allowance that even with the front stop, if the particular system had large amount of а unavailability, it would still become white. And that's why we thought it was a better mechanism than having a white failure, a hard and fast one failure

1 not be white, and so we think it's kind of the best of 2 all worlds. 3 So a decision has been made to move 4 forward with the front stop. It's one of the 5 recommendations in the NUREG report. MEMBER SHACK: They're going to still do 6 7 an SDP on that failure. Right? That was 8 MR. DUBE: Yes. the biq 9 difference between four months ago, six months ago 10 when we met and now. The back stop is a recognition that there 11 12 are some lower risk significant components, but the algorithm would allow a large number of failures 13 14 before it turned white, but we just didn't feel that 15 that was appropriate, so the back stop is a mechanism that results in white if a component type exhibits a 16 statistically significant departure from the expected 17 number of failures in a three-year period, regardless 18 19 of risk-significance. 20 And just quickly moving on - the decision 21 has been made to move forward with the back stop as 22 recommended. And actually, there wasn't 23 controversy on that. 24 MEMBER SIEBER: Yes. ON the other hand, 25 that does take you out of the risk-informed area,

1	except to the extent that it deals tangentially with
2	a common cause failure, but it takes some management
3	insight to get there in each case.
4	MR. BARANOWSKY: I think but everybody
5	agreed that when you have performance that's degraded
6	to that extent, it's hard to say it's just oh, one
7	component. There may be a lot more to it, and so
8	pretty much agreement, industry and everybody else
9	that that's something that we want to correct.
10	MEMBER APOSTOLAKIS: Let's go back to what
11	Don just said, that if there is a statistically
12	significant deviation from what's expected, it moves
13	on to white, so it's not tied to CDF then.
14	MEMBER SIEBER: No, it's not
15	MR. DUBE: The back stop is performance-
16	based.
17	MEMBER SIEBER: It's not risk-informed.
18	MEMBER APOSTOLAKIS: So it's really
19	performance-based, which is good.
20	MR. DUBE: And it's an or situation. You
21	could turn white
22	MEMBER APOSTOLAKIS: Which is what we
23	also argued that.
24	MEMBER SIEBER: That's right.
25	MR. DUBE: It could turn white because you

1	exceed the CDF threshold, or it could turn white if
2	you exceed the performance-based back stop.
3	MEMBER APOSTOLAKIS: Now from the pilots,
4	which one did you see dominating?
5	MR. DUBE: Well, we designed the back stop
6	so that it would be invoked infrequently, and we
7	didn't see it - we came very close. San Onofri had a
8	back stop limit on the salt water pumps of seven, I
9	believe, and they had six failures in a three-year
10	period. They could still get that seventh one
11	sometime in the future.
12	MEMBER APOSTOLAKIS: So the delta CDF.
13	MR. DUBE: Was low.
14	MEMBER APOSTOLAKIS: No, my question is
15	there are two ways of getting into white, as I
16	understand.
17	MR. DUBE: Yes. Delta CDF.
18	MEMBER APOSTOLAKIS: Delta CDF, and the
19	other is the deviation.
20	MR. DUBE: Or the deviation.
21	MEMBER SIEBER: Or the back stop. Yes.
22	MEMBER APOSTOLAKIS: And you say that the
23	Delta CDF was the one that put it to white
24	MR. DUBE: Most of the time in the pilot,
25	yes. And the back stops invoked a fraction of

1	MEMBER APOSTOLAKIS: But isn't that a
2	little strange?
3	MEMBER SHACK: Well, they have a fairly
4	high you know, that would be one thing I'd quibble
5	over is you're asking for a lot of statistical
6	confidence. I don't know how you came up with those
7	numbers and whatever judgment, but you could have made
8	those numbers a little lower, and then your back stop
9	would have gotten you there faster.
10	MEMBER APOSTOLAKIS: We first let's say
11	a plant starts deviating, wouldn't you first deviate
12	from the industry average significantly before you hit
13	a Delta CDF? I mean, that's what I would expect.
14	MR. DUBE: It's a function of the risk-
15	importance of a particular component. It's a strong
16	function of the risk-importance of the component too.
17	MEMBER APOSTOLAKIS: Well, intuitively I
18	would expect it the other way.
19	MR. DUBE: But we specifically designed
20	the back stop to be infrequently invoked as a last
21	measure.
22	MR. BARANOWSKY: And you'll recall, we are
23	tracking some component, specifically valves with very
24	low risk-importance.
25	MEMBER APOSTOLAKIS: Essentially there you

are saying --

MR. BARANOWSKY: Those are the ones where you could have a lot of failures before you ever get near risk.

MEMBER APOSTOLAKIS: So that's where you see the move to white before.

MR. BARANOWSKY: So at least these have some measure of risk-importance that's worth looking at, but it's not that high.

MEMBER SIEBER: Okay. Why don't we go to the short-term back stop.

MR. DUBE: Well, when we did a benchmark and we took all of the whites and near white from the pilot plant, and tried to understand them, tried to compare them to what SDP, Significance Determination Process, showed, what the SSU showed, there was one that we couldn't explain where the SDP gave it a very clear white. It was a high white, and the MSPI for a number of reasons showed it to be a high green. More unavailability or one more failure would have made it a white, but we tinkered around with the idea of a short-term back stop, but we reached the conclusion, which would have been expected number of failures over one or two quarters instead of three-years. And the long and short of it is we felt that it would

1 complicate the index. It was not in keeping with the 2 monitoring trend over a three-year period, which is 3 what -- we kind of went into this pilot program with 4 the understanding. And then the decision to keep the 5 SDP somewhat obviated the need, because this event would have still been white. It would have been top 6 7 white by SDP and not by MSPI, but it wouldn't have 8 snuck through the cracks, if you will. 9 MEMBER SHACK: Suppose I settled for a one 10 chance in 25 of a false positive for my back stop, would I have caught it then? I mean, you've got one 11 chance in a hundred now. 12 No, I don't think so. 13 MR. DUBE: 14 MEMBER SHACK: You still wouldn't have 15 gotten it. 16 MR. DUBE: No. 17 MEMBER SIEBER: But the only reason you got a white out of the SDP is because an inspector had 18 19 an inspection finding to which the SDP was applied, so 20 now you're relying on the inspector and the inspection 21 findings to determine the most significant weight that 22 you would apply to the specific events. 23 MEMBER ROSEN: But isn't it true, Jack, 24 that four EDG failures in the third-quarter would 25 likely catch an inspector's attention?

1	MEMBER SIEBER: I would think so.
2	MEMBER ROSEN: So I don't think
3	MEMBER SIEBER: Caught my inspector's
4	attention, except it was only two that caught his
5	attention.
6	MEMBER ROSEN: But the point is it
7	wouldn't slip through.
8	MEMBER SIEBER: That's true. And I think
9	that's justification for not further messing with the
10	concept of a short-term back stop. I think it's okay
11	as is, what you've done.
12	MR. DUBE: There was some staff concern on
13	the use of a constrained non-informative prior. This
14	is the prior distribution that's used, that we used
15	plant-specific data, the Baysian update.
16	MEMBER ROSEN: By the way, I'm glad you
17	didn't have that word in your definition of MSPI,
18	"constrained non-informative prior".
19	MR. DUBE: We had looked at the CNIP along
20	with others. It had the best false positive/false
21	negative characteristics in our earlier report. With
22	no prior, NUREG 17.53 found the index would have been
23	much too volatile leading to very high false positive
24	probability, so we decided it's good enough to
25	proceed.

Now there are other promising possibilities, one of the authors, Dr. Atwood is here, but it would require much more data. We'd have to basically -- we are now with that where common cause parametric models were with calculating the parameters 25 years ago perhaps, so it has promise, but it would require much more data analysis and more development. So we feel that the CNIP is adequate to move on, and so the decisions have been made to move forward the CNIP, knowing that it's not perfect, but it seems to be the best of what we can do.

The final open issue had to do with PRA quality, and so as not to hang up the implementation of the MSPI, a separate working group has been formed that consists of three members from the NRC staff and two from industry. Basically, it's to determine the PRA quality needs for the MSPI application, the appropriateness of the ASME standard, what kind of documentation is needed, what are the main modeling issues. And they are building upon some of our insights from some of the SPAR and plant PRA modeling benchmarks that we did. And so that's moving forward, Garreth Perry is the chairman of that committee.

Finally, a couple of slides. We received comments from six persons or organizations. They were

industry reps endorsed all six recommendations in the draft NUREG report. We did get some comments from Dr. Vesley who has his name on the importance measures so he knows something about it. The cohort effect, which has to do with the fact that it's only a linear approximation to change a core damage frequency, and there perhaps synergistic effects that could result. And we spent a lot of time and effort, did a lot of analysis, and ended up putting a whole appendix in the report, Appendix M, that we feel addresses those concerns.

We recognize that the MSPI is a linearized approximation to the change in CDF for given change in system unavailability/unreliability, but as I said, with the basic definition of the MSPI, is that we use the plant-specific importance measures as weights to look at the -- weighting the difference between actual plant performance and generic baseline. And that's their primary purpose, so they're derived once when a PRA model is updated, the values will be derived once and can be input into the consolidated data entry program at INPO.

CHAIRMAN BONACA: Is the cohort effect a result of your use of mains rather than components?

MR. DUBE: No. It's more a function of
the fact that when you do a tailor expansion, we're
only looking at Delta we're literally adding Deltas
from Pump A, Pump B, Pump C, Valve A, Valve B - but
if you look at cut sets, there are changes in Pump A,
and changes in Pump B in certain cut sets.
MEMBER APOSTOLAKIS: So all you need is
one extra term.
MR. DUBE: We could go to second order
MEMBER APOSTOLAKIS: Second order are
three terms. Two of them drop out, don't they,
because they require a second derivative.
MR. DUBE: No, we don't have second
derivative.
MEMBER APOSTOLAKIS: So it would be only
one term, the cross-term, so it's not a big deal.
MR. DUBE: Implementation-wise it would be
a big deal. And Dr. Atwood wrote a nice treatise in
Appendix M on how one might do it in theory, but it
does add a significant complication because you need
to do get that second derivative, and for 50
components getting that second derivative of various
combinations would be a PRA practice nightmare.
MEMBER APOSTOLAKIS: What do you mean 50
components?

Ī	413
1	MR. DUBE: Well, the MSPI has 50
2	components on it, typically.
3	MEMBER APOSTOLAKIS: System.
4	MR. DUBE: Total.
5	MEMBER APOSTOLAKIS: For one system.
6	MR. DUBE: For all six systems. You get
7	cross-terms of Diesel A with Aux B, Pump B and so on
8	and so forth, so it could get very complicated. It
9	could be done, in theory
10	MEMBER APOSTOLAKIS: Because the diesels
11	are
12	MR. DUBE: Right.
13	MEMBER ROSEN: This MSPI - excuse me,
14	George.
15	MEMBER APOSTOLAKIS: Go ahead.
16	MEMBER ROSEN: This MSPI-PRA quality task
17	group, is that going to hold up the train leaving the
18	station? Is it something that needs to get done
19	before we go ahead with MSPI?
20	MR. BARANOWSKY: It's being done. Are you
21	going to address that or do you want me to say
22	anything about that?
23	MR. RICHARDS: Well, in short the answer
24	is yes, it has to be done before MSPI can move along
25	its timeline.

1 MEMBER ROSEN: And how long is that going 2 to take? MR. RICHARDS: We scheduled it, I believe, 3 4 to roughly go until the end of this month, so it's in 5 the near term. It's a couple of weeks 6 MEMBER ROSEN: 7 then. Mike, do you have better 8 MR. RICHARDS: information? 9 This is Mike Cheok. 10 MR. CHEOK: We are 11 supposed to come up with a -- we're scheduled to come 12 up with a draft recommendation in December to be discussed with, I quess, the agency and industry reps. 13 14 MR. DUBE: Bottom line is we feel that the 15 formulation as is is good enough for its intended use. 16 And if this were a, let's say an online risk monitor, 17 clearly just using the first term would be inadequate, because here when you remove a component from service, 18 19 we're not talking about Delta CDFs of 10 to the minus 20 We want to be talking about risk achievement 21 factors of two and ten, meaning doubling, or even ten-22 fold increase in core damage frequency in that time 23 frame when that equipment is removed from service. So 24 obviously, this formulation wouldn't be adequate to 25 that, but for the range of changes in CDF that we

1	expect and that we've seen from the pilot plant, we
2	feel that it's adequate. And that's all I have.
3	MR. BARANOWSKY: Okay. So now we get to
4	
5	MEMBER APOSTOLAKIS: Your assignment on
6	the frequency of initiators, it appears to me you can
7	handle them the way you're handling the
8	unavailability, because all you're doing is you're
9	finding the
10	MR. DUBE: Right.
11	MEMBER APOSTOLAKIS: If at all that has a
12	problem. You can't find it all for the frequency of
13	initiating events, but you could include them in this.
14	MR. DUBE: You mean a change in initiating
15	event frequency?
16	MEMBER APOSTOLAKIS: Yes. Why not?
17	MR. DUBE: Well, the next generation
18	MEMBER APOSTOLAKIS: It's already an
19	indicator.
20	MR. DUBE: The next generation might do
21	that to combine an MSPI-type formulation with a
22	MEMBER APOSTOLAKIS: No, I'm not saying
23	combined. Have an MSPI for initiators.
24	MR. DUBE: We could do that.
25	MEMBER APOSTOLAKIS: Nothing would change.

1	MR. BARANOWSKY: That would be an
2	initiator indicator.
3	MEMBER SIEBER: I'm not sure that that
4	adds much to the ROP. Now you can make the ROP so
5	complicated that it doesn't
6	MEMBER APOSTOLAKIS: Well, the ROP already
7	has an indicator, doesn't it?
8	MR. BARANOWSKY: Well, I think the better
9	I like the way we did this one, because there were
10	specific problems that were identified, and we tried
11	to design something that addressed the problems, and
12	met the objectives of being risk-informed. And I
13	think there are, as I identified, some other problems
14	with other indicators. We would work with them to try
15	to come up with some improvements.
16	MEMBER SIEBER: Good luck.
17	MEMBER APOSTOLAKIS: So the major
18	improvement here is that the thresholds are not
19	generic any more?
20	MR. DUBE: I think the major improvement
21	is that we now account for unreliability.
22	MEMBER APOSTOLAKIS: Yes, that too,
23	absolutely. Absolutely.
24	MR. DUBE: We now take into account the
25	fact that every plant is different, and they have

1	different plant-specific configurations and that is
2	reflected so they have threshold the number of
3	failures that they need to reach the threshold will be
4	different from plant to plant, depending - and system
5	to system depending on the
6	MEMBER APOSTOLAKIS: That's what I'm
7	saying, that the thresholds are not generic any more.
8	MEMBER SIEBER: Right.
9	MEMBER APOSTOLAKIS: Is that correct?
10	MR. DUBE: In terms of the number of
11	failures they're not generic. But in terms of 10 to
12	minus 6, 10 to minus 5, 10 to minus 4 they're
13	MEMBER APOSTOLAKIS: Yes.
14	MR. DUBE: But the number of component
15	failures and the percent increase in unavailability
16	will vary from plant to plant, depending on how
17	important it is.
18	MEMBER APOSTOLAKIS: Only to the extent
19	that one plant has two diesels and the other has three
20	diesels. But not including the data action, because
21	you are using the data from `95 to `97 as a reference.
22	MR. DUBE: Right. Data will have an
23	impact in the deviation of their performance
24	MEMBER APOSTOLAKIS: From that point of
25	reference.

1	MR. DUBE: From the baseline.
2	MEMBER APOSTOLAKIS: Which is a point of
3	reference for everybody.
4	MR. DUBE: Right.
5	MEMBER APOSTOLAKIS: Not plant-specific.
6	MR. DUBE: Correct. So it accounts for
7	unavailability, it accounts for unreliability, plant-
8	specific configuration, and plant performance
9	deviation from the norm. Those are the strengths.
10	MR. BARANOWSKY: I would also add that
11	we're using plant-specific PRAs, including looking at
12	PRA adequacy issues in a way that could be done
13	consistently across all plants here. We're learning
14	a lot about that.
15	MEMBER SIEBER: That's a secondary effect.
16	MR. BARANOWSKY: Yes, it is, but it's
17	MEMBER SIEBER: It's important to the
18	ultimate outcome, that failure to do that in a timely
19	fashion would not prevent initiating the MSPI. I
20	mean, it's not a precursor step.
21	MR. BARANOWSKY: I think a decision has
22	been made that we need to have adequate PRA quality
23	for the application of MSPI. So it was a fallout
24	thing that we didn't expect when we first started this
25	

1 MEMBER SIEBER: That can add to the 2 timeline. MR. BARANOWSKY: It's adding to 3 4 timeline, but we've learned a lot about what causes 5 folks to have differences of opinion on the risk associated with plant operating issues, that might 6 7 have taken years to discover without a systematic way 8 that we've looked at it. 9 MEMBER SIEBER: So when do you think the MSPI will become a fact of life as far as the matrix 10 11 that is on the NRC website? 12 Well that's why we're MR. BARANOWSKY: going to listen to Stu Richards as soon as I do the 13 14 conclusions. 15 MEMBER SIEBER: Okay. Do the conclusions, 16 and let's listen. 17 MEMBER ROSEN: I think you left important thing out of that page, which is the support 18 19 It includes cooling water support system. system. 20 That's another big event. 21 MR. BARANOWSKY: Okay. So to conclude, as 22 you've heard, we've tested and evaluated in a pilot 23 program the MSPI, and discussed it at numerous public meetings. There were many issues that were raised, 24 25 and we looked at them fairly thoroughly and documented

1 that in the report. The problems associated with the 2 current PIs are clearly addressed, and we know a lot 3 about the capabilities, strengths, and limitations of 4 the MSPI, which is why I think I'm safe in saying it's 5 a fairly robust performance indicator. We looked at the sensitivity of how the 6 7 MSPI performs when you vary certain issues about common cause failure, and putting valves in and 8 9 leaving them out, and whether or not you get the same That makes it robust, if you get the same 10 outcomes. 11 results by making a few changes, and it's not really 12 twitching, it's a robust indicator. mentioned, it desirable 13 As has 14 qualities with respect to plant-specific risk 15 implications, reliability and availability treatment, 16 captures system performance degradation. computation has some complexities, but it's structured 17 and programmable so you can easily implement it with 18 19 a computer. 20 MEMBER APOSTOLAKIS: You mean individual 21 licensees will not have to worry about cross-train, 22 non-informative --23 No, it's algebra. MR. BARANOWSKY: Ι 24 presume that we can do algebra. 25 MEMBER ROSEN: I suppose you're going to

1	issue a template some place
2	MR. BARANOWSKY: There will be a template
3	
4	MEMBER ROSEN: Plug your failures in and
5	it will do the calculation.
6	MR. BARANOWSKY: I think INPO is making
7	the template.
8	MEMBER SIEBER: Yes, I want
9	MR. DUBE: And what will have the official
LO	calculation, I believe, the licensee will have their
L1	own mini programs for what-ifs, but the official will
L2	be with INPO.
L3	MEMBER SIEBER: Before we conclude this
L4	session, I'd like to review some of these details as
L5	to what has to be in place, what steps you will take,
L6	so we can decide if there's anything else we need to
L7	look at, or if we just give a global blessing or
L8	criticism in the letter that you're requesting.
L9	MR. BARANOWSKY: Okay. We think based on
20	discussions that we've had internally and with the
21	industry, MSPI is consistent with the Maintenance Rule
22	implementation, technical specifications, and SECY 99-
23	007. The PRA adequacy issue is being addressed. It's
24	not completely addressed yet, but it will be. And so
25	we get to the last thing, which is we'd like to get

1	MEMBER SIEBER: Yes, you did show that.
2	MR. BARANOWSKY: This thing here. We'd
3	like to request an ACRS letter on this, which you knew
4	even in our prior meeting. You might recognize the
5	MSPI as a significant development in the application
6	of PRA methodology in the regulatory program, and
7	endorse it for the intended use in the reactor
8	oversight process, or something like that.
9	MEMBER APOSTOLAKIS: Now when you say
10	let me understand something.
11	CHAIRMAN BONACA: Non-constrained
12	MR. BARANOWSKY: Just came off the top of
13	my head.
14	MEMBER APOSTOLAKIS: You say it's
15	consistent with the Maintenance Rule.
16	MR. BARANOWSKY: Yes.
17	MEMBER APOSTOLAKIS: In what way?
18	MEMBER SIEBER: Same data.
19	MR. BARANOWSKY: The definitions of
20	unavailability and you don't get
21	MEMBER APOSTOLAKIS: But the Maintenance
22	Rule uses different thresholds, doesn't it?
23	MEMBER SIEBER: Yes.
24	II
	MEMBER APOSTOLAKIS: Based on raw.

off in two different directions.  MEMBER APOSTOLAKIS: The data collection is the same on unavailability, and so on.  MR. BARANOWSKY: Yes.  MEMBER APOSTOLAKIS: Does the Maintenance Rule include unreliability? I don't remember. I think it's only unavailability.  MR. BARANOWSKY: Yes, it includes unreliability.  MEMBER APOSTOLAKIS: Includes unreliability.  MR. BARANOWSKY: Yes.  MEMBER APOSTOLAKIS: Includes unreliability.  MR. BARANOWSKY: Yes.  MEMBER SIEBER: The concept of it.  MR. BARANOWSKY: The concept of it.  MEMBER APOSTOLAKIS: What does that mean?  MR. DUBE: It means you have so many failures, you elevate your action.  MR. BARANOWSKY: And in particular one of the things we talked about was unavailability during our operations versus shutdown, for instance, and why those should be separated when you're trying to look at thresholds, because the risk is different, and the drivers are different. Okay.  MEMBER SIEBER: Okay.	1	MR. BARANOWSKY: But you don't get going
is the same on unavailability, and so on.  MR. BARANOWSKY: Yes.  MEMBER APOSTOLAKIS: Does the Maintenance Rule include unreliability? I don't remember. I think it's only unavailability.  MR. BARANOWSKY: Yes, it includes unreliability.  MEMBER APOSTOLAKIS: Includes unreliability.  MR. BARANOWSKY: Yes.  MEMBER SIEBER: The concept of it.  MR. BARANOWSKY: The concept of it.  MEMBER APOSTOLAKIS: What does that mean?  MR. DUBE: It means you have so many failures, you elevate your action.  MR. BARANOWSKY: And in particular one of the things we talked about was unavailability during our operations versus shutdown, for instance, and why those should be separated when you're trying to look at thresholds, because the risk is different, and the drivers are different. Okay.	2	off in two different directions.
MR. BARANOWSKY: Yes.  MEMBER APOSTOLAKIS: Does the Maintenance Rule include unreliability? I don't remember. I think it's only unavailability.  MR. BARANOWSKY: Yes, it includes unreliability.  MEMBER APOSTOLAKIS: Includes unreliability.  MR. BARANOWSKY: Yes.  MEMBER SIEBER: The concept of it.  MR. BARANOWSKY: The concept of it.  MEMBER APOSTOLAKIS: What does that mean?  MR. DUBE: It means you have so many failures, you elevate your action.  MR. BARANOWSKY: And in particular one of the things we talked about was unavailability during our operations versus shutdown, for instance, and why those should be separated when you're trying to look at thresholds, because the risk is different, and the drivers are different. Okay.	3	MEMBER APOSTOLAKIS: The data collection
Rule include unreliability? I don't remember. I think it's only unavailability.  MR. BARANOWSKY: Yes, it includes unreliability.  MEMBER APOSTOLAKIS: Includes unreliability.  MR. BARANOWSKY: Yes.  MR. BARANOWSKY: Yes.  MEMBER SIEBER: The concept of it.  MEMBER APOSTOLAKIS: What does that mean?  MR. BARANOWSKY: The concept of it.  MEMBER APOSTOLAKIS: What does that mean?  MR. DUBE: It means you have so many failures, you elevate your action.  MR. BARANOWSKY: And in particular one of the things we talked about was unavailability during our operations versus shutdown, for instance, and why those should be separated when you're trying to look at thresholds, because the risk is different, and the drivers are different. Okay.	4	is the same on unavailability, and so on.
Rule include unreliability? I don't remember. I think it's only unavailability.  MR. BARANOWSKY: Yes, it includes unreliability.  MEMBER APOSTOLAKIS: Includes  unreliability.  MR. BARANOWSKY: Yes.  MEMBER SIEBER: The concept of it.  MR. BARANOWSKY: The concept of it.  MEMBER APOSTOLAKIS: What does that mean?  MR. DUBE: It means you have so many failures, you elevate your action.  MR. BARANOWSKY: And in particular one of the things we talked about was unavailability during our operations versus shutdown, for instance, and why those should be separated when you're trying to look at thresholds, because the risk is different, and the drivers are different. Okay.	5	MR. BARANOWSKY: Yes.
think it's only unavailability.  MR. BARANOWSKY: Yes, it includes unreliability.  MEMBER APOSTOLAKIS: Includes unreliability.  MR. BARANOWSKY: Yes.  MEMBER SIEBER: The concept of it.  MR. BARANOWSKY: The concept of it.  MEMBER APOSTOLAKIS: What does that mean?  MR. DUBE: It means you have so many failures, you elevate your action.  MR. BARANOWSKY: And in particular one of the things we talked about was unavailability during our operations versus shutdown, for instance, and why those should be separated when you're trying to look at thresholds, because the risk is different, and the drivers are different. Okay.	6	MEMBER APOSTOLAKIS: Does the Maintenance
9 MR. BARANOWSKY: Yes, it includes 10 unreliability. 11 MEMBER APOSTOLAKIS: Includes 12 unreliability. 13 MR. BARANOWSKY: Yes. 14 MEMBER SIEBER: The concept of it. 15 MR. BARANOWSKY: The concept of it. 16 MEMBER APOSTOLAKIS: What does that mean? 17 MR. DUBE: It means you have so many 18 failures, you elevate your action. 19 MR. BARANOWSKY: And in particular one of 20 the things we talked about was unavailability during 21 our operations versus shutdown, for instance, and why 22 those should be separated when you're trying to look 23 at thresholds, because the risk is different, and the 24 drivers are different. Okay.	7	Rule include unreliability? I don't remember. I
unreliability.  MEMBER APOSTOLAKIS: Includes  unreliability.  MR. BARANOWSKY: Yes.  MEMBER SIEBER: The concept of it.  MR. BARANOWSKY: The concept of it.  MEMBER APOSTOLAKIS: What does that mean?  MR. DUBE: It means you have so many  failures, you elevate your action.  MR. BARANOWSKY: And in particular one of  the things we talked about was unavailability during  our operations versus shutdown, for instance, and why  those should be separated when you're trying to look  at thresholds, because the risk is different, and the  drivers are different. Okay.	8	think it's only unavailability.
MEMBER APOSTOLAKIS: Includes unreliability.  MR. BARANOWSKY: Yes.  MEMBER SIEBER: The concept of it.  MR. BARANOWSKY: The concept of it.  MEMBER APOSTOLAKIS: What does that mean?  MR. DUBE: It means you have so many  failures, you elevate your action.  MR. BARANOWSKY: And in particular one of  the things we talked about was unavailability during our operations versus shutdown, for instance, and why  those should be separated when you're trying to look at thresholds, because the risk is different, and the drivers are different. Okay.	9	MR. BARANOWSKY: Yes, it includes
unreliability.  MR. BARANOWSKY: Yes.  MEMBER SIEBER: The concept of it.  MR. BARANOWSKY: The concept of it.  MEMBER APOSTOLAKIS: What does that mean?  MR. DUBE: It means you have so many  failures, you elevate your action.  MR. BARANOWSKY: And in particular one of  the things we talked about was unavailability during  our operations versus shutdown, for instance, and why  those should be separated when you're trying to look  at thresholds, because the risk is different, and the  drivers are different. Okay.	10	unreliability.
MR. BARANOWSKY: Yes.  MEMBER SIEBER: The concept of it.  MR. BARANOWSKY: The concept of it.  MEMBER APOSTOLAKIS: What does that mean?  MR. DUBE: It means you have so many  failures, you elevate your action.  MR. BARANOWSKY: And in particular one of  the things we talked about was unavailability during  our operations versus shutdown, for instance, and why  those should be separated when you're trying to look  at thresholds, because the risk is different, and the  drivers are different. Okay.	11	MEMBER APOSTOLAKIS: Includes
MEMBER SIEBER: The concept of it.  MR. BARANOWSKY: The concept of it.  MEMBER APOSTOLAKIS: What does that mean?  MR. DUBE: It means you have so many  failures, you elevate your action.  MR. BARANOWSKY: And in particular one of  the things we talked about was unavailability during  our operations versus shutdown, for instance, and why  those should be separated when you're trying to look  at thresholds, because the risk is different, and the  drivers are different. Okay.	12	unreliability.
MR. BARANOWSKY: The concept of it.  MEMBER APOSTOLAKIS: What does that mean?  MR. DUBE: It means you have so many  failures, you elevate your action.  MR. BARANOWSKY: And in particular one of  the things we talked about was unavailability during  our operations versus shutdown, for instance, and why  those should be separated when you're trying to look  at thresholds, because the risk is different, and the  drivers are different. Okay.	13	MR. BARANOWSKY: Yes.
MEMBER APOSTOLAKIS: What does that mean?  MR. DUBE: It means you have so many failures, you elevate your action.  MR. BARANOWSKY: And in particular one of the things we talked about was unavailability during our operations versus shutdown, for instance, and why those should be separated when you're trying to look at thresholds, because the risk is different, and the drivers are different. Okay.	14	MEMBER SIEBER: The concept of it.
MR. DUBE: It means you have so many failures, you elevate your action.  MR. BARANOWSKY: And in particular one of the things we talked about was unavailability during our operations versus shutdown, for instance, and why those should be separated when you're trying to look at thresholds, because the risk is different, and the drivers are different. Okay.	15	MR. BARANOWSKY: The concept of it.
failures, you elevate your action.  MR. BARANOWSKY: And in particular one of the things we talked about was unavailability during our operations versus shutdown, for instance, and why those should be separated when you're trying to look at thresholds, because the risk is different, and the drivers are different. Okay.	16	MEMBER APOSTOLAKIS: What does that mean?
19 MR. BARANOWSKY: And in particular one of 20 the things we talked about was unavailability during 21 our operations versus shutdown, for instance, and why 22 those should be separated when you're trying to look 23 at thresholds, because the risk is different, and the 24 drivers are different. Okay.	17	MR. DUBE: It means you have so many
the things we talked about was unavailability during our operations versus shutdown, for instance, and why those should be separated when you're trying to look at thresholds, because the risk is different, and the drivers are different. Okay.	18	failures, you elevate your action.
our operations versus shutdown, for instance, and why those should be separated when you're trying to look at thresholds, because the risk is different, and the drivers are different. Okay.	19	MR. BARANOWSKY: And in particular one of
those should be separated when you're trying to look at thresholds, because the risk is different, and the drivers are different. Okay.	20	the things we talked about was unavailability during
at thresholds, because the risk is different, and the drivers are different. Okay.	21	our operations versus shutdown, for instance, and why
drivers are different. Okay.	22	those should be separated when you're trying to look
	23	at thresholds, because the risk is different, and the
MEMBER SIEBER: Okay.	24	drivers are different. Okay.
	25	MEMBER SIEBER: Okay.

1 MR. BARANOWSKY: So now Stu will tell you 2 about what's happening implementation-wise. 3 MR. RICHARDS: All right. I'm Stu 4 Richards. I'm the Chief of the Inspection Program 5 Branch in NRR, and we're along with industry the enduser for MSPI, so when Research goes home, we're going 6 7 to still be using it. And we've had a lot to do with 8 it. 9 Slide 19, I'll go through this pretty We have three slides. 10 quick. It was already 11 mentioned, we piloted this at nine sites and 20 units. 12 We've touched on it briefly at two commission meetings. The commission gave us some guidance in two 13 SRMs and they have encouraged us to go forward and 14 15 work with industry to make this happen. 16 MEMBER SIEBER: That last one was a good 17 one. MR. RICHARDS: It was already mentioned, 18 19 we have monthly meetings with industry on MSPI. 20 think we've had over 35 meetings over the last couple 21 Some of these meetings take all day. 22 There's been a tremendous amount of hard work that's 23 gone into this, and I'd like to compliment Research on 24 their work. They've done a real good job. 25 For us it's cumulated in NRR sending a

letter to NEI just this past month, September,
agreeing to go forward with MSPI implementation. And
they said they needed that letter in order for the
industry to start making some investment in the
process it's going to take to set this up.
MEMBER SIEBER: Let me ask a question
about NEI. They have a document 99-03 which is part
and parcel to this. It's mentioned in your analysis
report, and it says that revisions will be needed to
99-03. Is that really true? Does NEI have to do
something?
MR. DUBE: It's been significantly
revised.
MEMBER SIEBER: Okay. So the revision is
done. It would meet the recommendations that's in
your report.
MR. DUBE: Definitely.
MR. RICHARDS: Is that different than 99-
02?
MR. DUBE: No. In 99-02, Appendix F is
the NEI guidance.
MEMBER SIEBER: 99-03 is the number I
have. Is that the right
MR. DUBE: It's 99-02.
MR. RICHARDS: We'll touch on that briefly

1 on the third slide. Next slide, please. We already 2 touched on agreeing with industry for creating the front stop, and we already touched on the concept of 3 4 this task group working on what constitutes the 5 minimum PRA requirements for MSPI. On the implementation side, we see that as 6 7 important because we're counting on that task group to 8 provide us some insights on what we need to inspect as 9 far as implementation of MSPI, and what we should be looking at long-term current feeding of it. 10 11 MEMBER SIEBER: What will you send the 12 licensees to inform them that the MSPI is now in effect, and that the data will come through the INPO 13 14 Is that going to be a generic letter, or process? 15 something like that, or what will it be? MR. RICHARDS: It will probably be a Req 16 17 INPO summary, and we'll touch on that a little bit further down the line here. Well, it really touches 18 19 on the last bullet we have here. 20 MEMBER SIEBER: And along with that, how 21 will you inform the public that you're switching over 22 and when they look at the action matrix results on the 23 website, how will they interpret this new indicator, 24 and how will they know what it means?

MR. RICHARDS:

25

Well, we plan to have a

1 communication plan. The indication has said they will 2 have a communication plan also. One of the challenges 3 of MSPI is to explain it to the public in a way 4 somebody can understand. 5 MEMBER SIEBER: Yes, that will be a 6 challenge. 7 MR. RICHARDS: That will be a challenge, 8 so we are going to put together a communication plan. 9 We intend to put information out to the public and make it available through our ROP website. We're in 10 the formulation stages of that. 11 MEMBER APOSTOLAKIS: Don's interpretation 12 is a first good step. 13 14 MR. RICHARDS: I'm sorry. 15 MEMBER APOSTOLAKIS: showed Don definition without any equations. 16 That was a first 17 good step on the way of informing the public. I mean, what else can you do? 18 It's a measure of this and 19 that, and this and that. MR. RICHARDS: Part of the ROP is the idea 20 21 that somebody, an interested stakeholder can take the 22 inputs and understand how you came out with green, white, yellow, or red. Of course, in this case it's 23 not going to be so simple to do, and now because of 24

the security restrictions, we're no longer allowing

1 public access to a lot of PRA information, so that 2 pretty much precludes anybody from going through that 3 exercise. So it will be a challenge. 4 MEMBER SIEBER: Well, there's the public, 5 and then there's the public. There's the public that, for example, when I was in industry, the financial 6 7 people looked at all the SALP reports and performance reports to make their own judgment as to how well the 8 9 company is running the plant. There are other public 10 that want all the details in preparation 11 allegations and so forth, and then there's a third 12 class of public that takes general views. So I think somehow or other, you've got to recognize all three 13 14 are out there and tailor communications to reach all 15 three. 16 MR. RICHARDS: We agree. 17 MEMBER SIEBER: Okay. MR. RICHARDS: All right. The last bullet 18 19 on this slide, I'd like to touch on very quickly, but 20 it is important for us. We agree with the industry 21 that the implementation of MSPI has to occur at all 22 sites at the same time. We're not going to end up 23 with two different Pis, one for plants who can't 24 there, and one for plants who can.

Because the PI program is a voluntary

program, the burden to get all the plants lined up and ready to implement basically falls on the industry, and the industry understands that.

MEMBER SIEBER: Right.

MR. RICHARDS: Next slide. Some of the challenges that we're working on right now in concert with NEI, we need to get the interpretation issues as much as we can straightened out. We found out from other Pis that once a PI is in place and you start arguing about what the details mean, and it makes a difference about a plant going green or white, sometimes that can be tough, so we want to iron that out on the front end, hopefully, and minimize the amount of resources it's going to take to answer those kind of questions down the road.

I mentioned already we're working with NEI on their implementation guidance, which is contained in their 99-02 document. I mentioned already the communication plan and the reg INPO summary to tell the industry what we're doing in this area. I think there is a minor detail as far as aligning the data entry for MSPI and the Maintenance Rule that needs to be worked out.

The industry plans to have three public workshops primarily to inform the industry on how to

implement MSPI. We'll probably participate or at
least attend those, and when we do have some internal
training that we're going to have to do to get the
inspection staff up to speed in implementing the MSPI.
MEMBER SIEBER: You have to modify the
inspection manual too, do you not?
MR. RICHARDS: Yes, we'll have to change
our we have a procedure to go out and verify PI
entry data. So, of course, we'll change that for
MSPI.
MEMBER SIEBER: You've got to change that.
MR. RICHARDS: The one question that will
answer my last bullet, when are we going to implement
this. The industry proposes that we implement this in
the first quarter of calendar year 2006, so that data
would be received by us after that quarter is over in
April of 2006, and that's when we would post it.
MEMBER SIEBER: I'll be an old man by that
time.
MEMBER ROSEN: Did you agree to that time?
Have you agreed to that time frame?
MR. RICHARDS: We have agreed to that
schedule, as long as all the things that have to occur
in-between now and then occur. We're not locked into
that.

1	MEMBER ROSEN: It sounds like a pretty
2	leisurely schedule to me.
3	MEMBER SIEBER: It certainly does. I'll
4	be an old man before you're done.
5	MR. RICHARDS: Well, part of the schedule
6	is actually driven by outages at plants. When you
7	look at them having their three workshops and when
8	they have to schedule that, the work that has to be
9	done by industry to go and make sure peoples' PRAs are
10	ready to use MSPI, and the fact that everybody has to
11	be there, I think you could probably argue that maybe
12	most of the plants right now are in good shape. But
13	there's going to be some population that's going to
14	have to do some work.
15	MEMBER ROSEN: Did you say the first
16	quarter of 2006?
17	MR. RICHARDS: First calendar quarter.
18	MEMBER ROSEN: I would think that people
19	would that most of the industry is already there
20	participating in pilots and whatever, and the ones
21	that aren't there need to get hot, I'd say.
22	MEMBER APOSTOLAKIS: It's only a year. I
23	mean what's the big deal. It's only a year, right?
24	MR. RICHARDS: We had 20 units out of 103
25	units.

1	MEMBER SIEBER: There were some
2	adjustments even with those 20 units, because things
3	weren't working out properly initially, and so there
4	had to be some interaction. I can understand some
5	time, but in a way I'm a little frustrated, as
6	probably Steve is also, that that seems to be a long
7	time. Okay. Anything else that you want to add?
8	MR. RICHARDS: No. Thank you for the
9	opportunity.
10	MEMBER SIEBER: If we write a letter, it
11	will I don't know whether you would issue that
12	NUREG with or without our concurrence, but that would
13	probably be one factor that would be in any letter we
14	might write, provided my colleagues would agree with
15	it.
16	MEMBER APOSTOLAKIS: What is the
17	condition?
18	MEMBER SIEBER: The concurrence with the
19	NUREG that's Tab 5 in our manuals, and some kind of
20	concurrence that the staff should proceed with the
21	implementation of the MSPI. I think we would be
22	interested in the future in knowing progress, but I
23	don't think in the future we need to have meetings to
24	deal with technical issues upon which we would write

you additional letters. I think we're now far enough

along that those issues are behind us now, and
satisfactorily concluded. Steve.
MEMBER ROSEN: Jack, I only want to say
one more thing. I think the staff and the industry
both need to be congratulated on bringing this issue
to this kind of resolution. I think the ROP will be
quite a bit stronger with the new MSPI, and that's in
part why I wanted to get on with it.
MEMBER SIEBER: Okay. Well, that will be
in the record, and maybe in our letter, too. So if no
one has any additional questions or the staff has no
additional comments, Mr. Chairman, I turn it back to
you, and I've gained 35 minutes.
CHAIRMAN BONACA: Good for you.
Appreciate the presentation.
MEMBER SIEBER: Six o'clock is not until
five more minutes. I request a break.
_
CHAIRMAN BONACA: Yes. A short break,
CHAIRMAN BONACA: Yes. A short break,
CHAIRMAN BONACA: Yes. A short break, because we need to get to this, but let's get a break
CHAIRMAN BONACA: Yes. A short break, because we need to get to this, but let's get a break until five after, 10 minutes.
CHAIRMAN BONACA: Yes. A short break, because we need to get to this, but let's get a break until five after, 10 minutes.  MEMBER SIEBER: That's good.
CHAIRMAN BONACA: Yes. A short break, because we need to get to this, but let's get a break until five after, 10 minutes.  MEMBER SIEBER: That's good.  CHAIRMAN BONACA: And thank you very much

434 entitled matter went off the record at 5:55 p.m.) 1