Official Transcript of Proceedings NUCLEAR REGULATORY COMMISSION

Title: Advisory Committee on Reactor Safeguards 521st Meeting

Docket Number: (not applicable)

Location: Rockville, Maryland

Date: Friday, April 8, 2005

Work Order No.: NRC-311

Pages 1-120

NEAL R. GROSS AND CO., INC. Court Reporters and Transcribers 1323 Rhode Island Avenue, N.W. Washington, D.C. 20005 (202) 234-4433

	1
1	UNITED STATES OF AMERICA
2	NUCLEAR REGULATORY COMMISSION
3	+ + + + +
4	ADVISORY COMMITTEE ON REACTOR SAFEGUARDS (ACRS)
5	521st MEETING
6	+ + + +
7	FRIDAY, APRIL 8, 2005
8	+ + + + +
9	ROCKVILLE, MARYLAND
10	+ + + + +
11	The Committee met at the Nuclear Regulatory
12	Commission, Two White Flint North, Room T2B3, 11545
13	Rockville Pike, at 8:30 a.m., Dr. Graham B. Wallis,
14	Chairman, presiding.
15	MEMBERS PRESENT:
16	GRAHAM B. WALLIS Chairman
17	WILLIAM J. SHACK Vice Chairman
18	GEORGE E. APOSTOLAKIS Member
19	MARIO V. BONACA Member
20	RICHARD S. DENNING Member
21	THOMAS S. KRESS Member
22	DANA A. POWERS Member
23	VICTOR H. RANSOM Member
24	STEPHEN L. ROSEN Member
25	JOHN D. SIEBER Member-At-Large
ļ	I

		2
1	ACRS STAFF PRESENT:	
2	JOHN T. LARKINS	Director
3	MICHAEL L. SCOTT	Chief, Technical
4		Support Branch
5	SAM DURAISWAMI	ACRS Staff, Designated
6		Federal Official
7	HOSSEIN NOURBAKHSH	ACRS Staff
8		
9		
10		
11		
12		
13		
14		
15		
16		
17		
18		
19		
20		
21		
22		
23		
24		
25		
I	1	

3

		4
1	AGENDA ITEMS	PAGE
2	Opening Remarks, Chairman Graham B. Wallis	4
3	Accident Sequence Precursor Program and	
4	Development of SPAR Models	4
5	9.1) Remarks by the Cognizant Subcommittee	
6	Chairman, Member Jack Sieber	5
7	9.2) Briefing By and Discussions with	
8	Representatives of the NRC Staff	
9	Regarding the Status of the	
10	Accident Sequence Precursor Program	
11	and Development of the Standardized	
12	Plant Analysis Risk (SPAR) Models,	
13	Mr. Nilesh Chokshi	6
14	Mr. Gary DeMoss	28
15	Mr. Patrick O'Reilly	86
16	Mr. Michael Cheok	107
17	Adjournment	128
18		
19		
20		
21		
22		
23		
24		
25		
	I	

	5
1	PROCEEDINGS
2	(8:25 a.m.)
3	CHAIRMAN WALLIS: Okay. The meeting will
4	now come to order. Good morning. This is the second
5	day of the 521st meeting of the Advisory Committee on
6	Reactor Safeguards.
7	During today's meeting, the Committee will
8	consider the following: Accident Sequence Precursor
9	Program and development of SPAR models, future ACRS
10	activities, the report of the Planning and Procedures
11	Subcommittee, reconciliation of ACRS Comments and
12	recommendations, and preparation of an ACRS report.
13	This meeting is being conducted in
14	accordance with the provisions of the Federal Advisory
15	Committee Act.
16	Mr. Sam Duraiswamy is the Designated
17	Federal Official for the initial portion of the
18	meeting.
19	We have received no written comments nor
20	requests for time to make oral statements from members
21	of the public regarding today's sessions.
22	A transcript of a portion of the meeting
23	is being kept and it is requested that the speakers
24	use one of the microphones, identify themselves, and
25	speak with sufficient clarity and volume so that they
Į	I

(202) 234-4433

	6
1	can be readily heard.
2	The first item of business is the ASP
3	Program and development of SPAR models. I turn to my
4	right-hand man Dr
5	MEMBER SIEBER: Mister.
6	CHAIRMAN WALLIS: Mr whatever, Jack
7	Sieber to lead us through this. Thank you, Jack.
8	MEMBER SIEBER: Thank you.
9	To me, I consider the work that is being
10	done by the staff here as important work. It's sort
11	of the check and balance on both licensee activities
12	and our modeling of events and their likelihood and
13	the possible outcomes. And so this, to me, is sort of
14	a quality control check on that.
15	And today the staff will tell us about a
16	couple of incidents that have occurred which have been
17	analyzed by the staff to determine their significance.
18	And one of the things that I had asked
19	early on for the staff to possibly address, to the
20	extent that they can, is what insights does the ASP
21	Program give the staff and us with regard to the
22	ability of the SPAR models to be able to predict or
23	forecast or tell us something about the safety of the
24	fleet of nuclear plants as they exist today.
25	To me, that's an important aspect of this.
	I

(202) 234-4433

	7
1	Since the Agency has adopted a risk informed approach
2	to regulation, this becomes one of the cornerstones
3	for that risk approach.
4	And so with that, I would like to
5	introduce the staff. The Branch Chief responsible for
6	this is Mr. Chokshi and with that, I will turn it over
7	to the staff to give us introductory remarks and the
8	presentation.
9	MR. CHOKSHI: Well, good morning. And as
10	Dr. Sieber mentioned, my name is Nilesh Chokshi. And
11	this is my first appearance in front of this Committee
12	in this new position. And after having been in the
13	Division of Engineering for 15 years, this has been
14	quite a change. But the change has been an
15	exhilarating and very rewarding learning process.
16	And I think more importantly to me on a
17	personal note, I'm enjoying every bit of working with
18	my new colleagues as I did with working with my
19	colleagues in the old position or previous position.
20	So that has been good.
21	With that, now I think I want to thank
22	Committee for giving us opportunity to come and talk
23	about three or four programs.
24	In the Branch, the OERA, the Operating
25	Experience Risk Analysis Branch, has several major
	1

(202) 234-4433

functions. And I think with the development of plantspecific risk assessment models, SPAR models, has been used by Agency for many risk-informed regulatory activities. That has been one of our major activities.

and 6 We develop maintain operating 7 experience database systems. We are providing input to the Agency's industry train programs and we are 8 9 using accident sequence precursor analysis to evaluate the risk associated with the conditions and events. 10 And you're going to hear a lot more about this today. 11

12 been monitoring the Reactor We have Oversight Program, development of the performance 13 14 indicators, particularly the MSPI, the Mitigating 15 Systems Performance Index. And you are also going to 16 hear a little bit about the relatively new program, 17 the standardization of the Agency risk assessment 18 process, RASP.

19 About a year and a half back, I think in 20 October 2003, the Branch had a day-long briefing with 21 the Reliability and Probabilistic Risk Assessment 22 Subcommittee on all of the programs. Today we're 23 going to concentrate on the SPAR model development and 24 ASP. And hopefully I think we'll get to some of the 25 insights, particular insights, that you requested.

> NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433

1

2

3

4

5

The briefing is divided into the four main technical elements. Gary DeMoss, who is operating the slides, he's going to brief on the ASP-related projects. And Pat, to my right, will discuss the progress of the SPAR model development project. And Mike, in the end, I think is going to focus on the part forward, where we are going and what are the challenges.

9 While Gary and Pat are going to do the briefings, the technical briefings, what I really want 10 11 to point out that both ASP and SPAR are team 12 activities. And many of the Branch members are involved if not all. Some are involved in directly 13 14 supporting, doing the -- conducting the ASP analyses, 15 reviewing the ASP analyses, developing SPAR models while others are supporting the data development, 16 17 procedures development.

I want to also mention some of the key 18 19 players. And Don Marksberry has been the PM for the 20 ASP Projects for the last five years. And he has 21 really led a well-organized and excellent program. 22 And along with Don, Gary has been providing the 23 technical oversight. And Gary also has the special 24 privilege of presenting today because he has done the 25 Davis-Besse analysis and a few other things.

> NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433

1

2

3

4

5

6

7

8

(202) 234-4433

9

	10
1	Pat, I think I don't know whether he
2	needs introduction but he's been SPAR guru for over
3	many years. But he is also being assisted by Salim
4	Sanjector and I don't see him here. But he's
5	developing actual event models. And Eli is developing
6	the hot models.
7	And as Don is going to we are going to
8	focus on modeling the ASP plans and insights. So Eli
9	is taking over the project management responsibility.
10	I also want to, again, I think mention
11	that, you know, many others are involved. And I'm
12	particularly, I think, are too important, I think that
13	there are about half of the ASP analyses are
14	conducting in-house. Okay, and we are in process of
15	getting some more new staff members.
16	So I think our focus is going to be on
17	involving these people because it's a good, I think,
18	training and developing skills on using risk
19	assessment procedures. So this is I think this
20	project has been very good in terms of training some
21	of the people. In fact the two examples we're going
22	to discuss today are both in-house analysis examples.
23	Let's go to the next now I view this as
24	an information briefing. And you can, you know,
25	correct me but we are going to update you on the

(202) 234-4433

	11
1	current status of the ASP Program and also describe
2	some of the trends. But the bulk of the material is
3	going to come from the SECY paper we just had in
4	November 2004 and supplement with some other
5	information.
6	And I think as requested by the Committee,
7	we will also discuss the Davis-Besse ASP analyses.
8	The analyses is now out in the public. Now we have
9	included the August 14th, 2003 nuclear event analysis
10	that I think is another important informative example.
11	There are about two slides. But I think
12	if time begins to be a problem, I propose that this
13	may be one we may want to skip over because I think
14	even with the two slides, the question/answer phase
15	could be pretty extensive on that.
16	And Pat is going to describe the SPAR
17	models and the insights and then Mike will follow.
18	Let me just briefly mention about this
19	Risk Assessment Standardization Project. I think both
20	Pat and Mike will be alluding to that later. As you
21	know, the risk assessment of reactor events and
22	conditions are performed by many groups in the NRC.
23	And there has been an issue of different answers.
24	So I think there are a lot of benefits of
25	standardizing some of the procedures, methods, and
I	1

(202) 234-4433

	12
1	models. And this will, I think this includes
2	having duplication of efforts, inconsistent outputs,
3	conflicting results. And if nothing else, the
4	detailed documentation will help save time for people
5	to go and find out what to do, how to do, and also,
6	again, it's an educational tool.
7	So we have been working with in fact
8	with NRR, as a user need, and working with the region
9	and the NRR in developing standardized procedures. At
10	this point, I would consider that we are in the
11	beginning phases of that. And at some point, maybe
12	later, we can come and tell you as we progress
13	forward.
14	We'll briefly talk about the background of
15	the ASP Program, which I don't think there's need to
16	go too much into the details. But I think I'll just
17	mention a few things. The ASP Program was established
18	in 1979 in response to the risk assessment review
19	group report.
20	And the primary purpose, I think, as
21	stated on the slide is to systematically evaluate
22	operating experience to identify and document events
23	likely to lead to core damage. I think in other
24	words, in ASP analysis is a plant-specific analysis
25	performed to determine the condition or likelihood of
	I

(202) 234-4433

	13
1	a core damage given an initiating event and in plant
2	equipment failures or
3	CHAIRMAN WALLIS: Likely is a funny word
4	here because really it's not very likely that there
5	will be core damage.
б	MR. CHOKSHI: Well, the conditional
7	probability of
8	CHAIRMAN WALLIS: A very low conditional
9	probability.
10	MR. CHOKSHI: Right.
11	CHAIRMAN WALLIS: But the word likely sort
12	of implies it is quite a high probability.
13	MR. CHOKSHI: Yes. And I think on the
14	next slide where you see more formal, I think it's
15	conditional probability.
16	MEMBER APOSTOLAKIS: Those events that
17	might lead to core damage.
18	MR. CHOKSHI: Right. The ASP Program
19	provides the basis for two performance indicators.
20	The no event per year are identified as significant
21	precursor of a nuclear reactor accident and also they
22	put the statistically significant adverse industry
23	trend.
24	In addition to those performance measures
25	which are required to be put into the accountability
ļ	I

(202) 234-4433

	14
1	and performance report, the other objectives are, you
2	know, to categorize the precursors by their plant-
3	specific and generic implications and factor insights
4	into the regulatory process I think to provide the
5	potential PRA scenarios and models. And I think that
6	was in the ACRS letter of May 16th, 2003.
7	CHAIRMAN WALLIS: So how do you check a
8	PRA scenario?
9	MR. CHOKSHI: Okay. I was just going to
10	say that there was a letter from ACRS on May 16th,
11	2003. And they had particularly said that the ASP
12	Program, they agreed that it is a very important
13	element. And I will draw up under my
14	CHAIRMAN WALLIS: So if the PRA scenarios
15	deal with the probabilities and ASP deals with real
16	events that happen and the connection, because they're
17	rare events, must be very tenuous.
18	MR. CHOKSHI: Right.
19	MEMBER APOSTOLAKIS: No, ASP
20	CHAIRMAN WALLIS: You can get the sequence
21	but you can't get the probabilities, can you?
22	MEMBER APOSTOLAKIS: No, ASP also
23	considers scenarios, right? It starts with what
24	happened and then it becomes a PRA.
25	CHAIRMAN WALLIS: And then it becomes a
ļ	I

(202) 234-4433

	15
1	PRA. Then it goes into what might have happened.
2	MEMBER APOSTOLAKIS: Then it becomes
3	logical in Russia.
4	(Laughter.)
5	MR. CHOKSHI: And the insights, in fact,
6	come from, for example, I think about 20 percent of
7	the events require developing some modeling and
8	things, you know, which was not in the PRA models. So
9	there is a feedback process.
10	CHAIRMAN WALLIS: So one is reality and
11	the other is realistic.
12	MEMBER SIEBER: That 20 percent is an
13	important number.
14	MEMBER APOSTOLAKIS: What is that?
15	MEMBER SIEBER: You know it basically says
16	that PRAs don't model everything.
17	MR. CHOKSHI: Right. And so there is a
18	feedback process.
19	MEMBER APOSTOLAKIS: Well, you know, a
20	major problem with the ASP Program over the years has
21	been the dissemination of information and having
22	people who actually do PRAs pay attention. It's not
23	your fault. But, I mean, this is really an important
24	part of what the Agency does.
25	MEMBER SIEBER: That's right.
I	I

(202) 234-4433

	16
1	MEMBER APOSTOLAKIS: And you go out there
2	and people don't seem to, you know, be aware or they
3	say oh yes, well I've heard of it. But you never hear
4	a PRA analyst say, oh, in this sequence, you go that
5	way because ASP found such and such.
6	I don't know. I mean is there a solution
7	to that? I mean I know that you guys are issuing
8	reports.
9	MEMBER BONACA: Well, I would like to
10	comment on that. I mean in the past, okay, one of the
11	issues has been the quality of the models that the NRC
12	has used to develop the scenarios. And the
13	credibility of the results to the very licensees that
14	were being evaluated.
15	So typically you had an evaluation. It
16	was off by an order of magnitude of two, the results.
17	You look back at the modeling, you find the certain
18	fundamental elements of the plant were missing from
19	the models. So you communicated back the information.
20	This was when it was being done I think
21	it was outsourced at that time. And you can get back
22	to have them consider the modeling aspects. Then the
23	document would be issued with certain numbers that
24	really were off the wall. So it became unimportant
25	because it didn't provide credible results.
I	I

(202) 234-4433

	17
1	Now I think, you know, I see this as very
2	positive. You know, the development of the SPAR
3	models that are becoming more and more close to the
4	model. And I think that would bring about credibility
5	to the program and to the results.
6	MEMBER APOSTOLAKIS: But in answer to
7	that, first of all, the situation you described, I
8	think, is kind of old. Now, I mean
9	MEMBER BONACA: I don't know.
10	MEMBER APOSTOLAKIS: the program has
11	been has improved significantly over the years.
12	MEMBER BONACA: I would expect so, yes.
13	MEMBER APOSTOLAKIS: But second, it's not
14	so much the number I'm talking about. I'm talking
15	about the dependencies and the paths that these guys
16	find which is independent of well, I mean you can
17	say no, they missed the particular component or system
18	or action. But by and large, I don't think that the
19	various dependencies or scenarios that have been
20	identified as part of the operating experience have
21	really influenced the event trees that people develop.
22	Now that doesn't mean that these event
23	trees are no good because maybe they have other
24	sequences that subsume these sequences. But it would
25	be nice to see a more active use of what this Branch
	I

(202) 234-4433

	18
1	is producing.
2	MR. CHOKSHI: Sure.
3	MEMBER APOSTOLAKIS: I think obviously you
4	have looked at the ACRS letter. I think we mention
5	that every now and then.
б	MEMBER ROSEN: Well, I think the early
7	problem was the one that Mario described. They were
8	not credible. But the staff has done a good job
9	bringing these models to the plants and benchmarking
10	them against the plants' PRAs.
11	And when the plant PRAs and the SPAR
12	model, in whatever stage of development, were
13	different, the differences were explored. And either
14	the plant model was corrected or the SPAR model was
15	corrected to bring them closer together.
16	Now that's not to say that the SPAR model
17	is exactly the same as the plant model. It can't be.
18	I don't think they can be that big. But that's the
19	state of knowledge right now.
20	So the plants you can understand why
21	the plants weren't too interested, as Mario described,
22	in the early times. Now they're very interested. And
23	they expect the answers for a given event to come out
24	very much the same.
25	And if they don't, then there is an issue.
1	

(202) 234-4433

	19
1	And that issue is on the table in front of both the
2	staff and the industry and the plant and the public.
3	And one can see the difference.
4	And the difference comes down to saying,
5	for example, we talked yesterday about HRA, the Human
6	Reliability Announcement. What numbers are you using
7	for human actions? Well, you, of all people, know,
8	George, you can pick a lot of different numbers can
9	be picked.
10	So those differences now are worthy of
11	discussion whereas before they weren't because the
12	models were so wrong.
13	In the early days, I must confess that I
14	didn't think this program was a good idea. And the
15	reason I didn't was because the models were so not
16	credible. They were so far behind the plants' models.
17	To the extent that I even proposed at one time that
18	the whole program be stopped and instead that the
19	plant models be given to the NRC.
20	Then you could do whatever you want with
21	them but at least you'd be starting at the same point.
22	Well, that's no longer necessary, of course, because
23	you've come across to the point where SPAR models are,
24	I think, universally have you gone through every
25	plant and benchmarked them?
	1

(202) 234-4433

	20
1	MR. O'REILLY: Yes, we have.
2	MEMBER ROSEN: Okay. So now you're at the
3	point where this becomes quite useful I think. And I
4	think Jack's earlier point that the Agency needs an
5	independent method is true. And this becomes that.
6	MEMBER SIEBER: Yes.
7	MEMBER ROSEN: But to the degree that it's
8	independent is only because you each have a model that
9	was generated by your own generating process rather
10	than taking a model and cloning it and then using it.
11	But I would say that's the reason the plants weren't
12	interested in the early days.
13	They were just a problem to have to deal
14	with the fact that, okay, you come in for a given
15	event that the plant has said is a no, never mind,
16	because we know that this plant, there are all kinds
17	of systems and go look at the and then the staff
18	says no, it's an extremely serious event.
19	And you go look at it and the model
20	doesn't include two or three systems. Well, it's not
21	the plant.
22	MEMBER SIEBER: I think one of the things
23	that has enhanced the licensee attention is the use of
24	risk analysis for significance determination. And now
25	all of a sudden it's under the reactor oversight
	I

(202) 234-4433

	21
1	process. It's in the licensee's best interest to have
2	pretty good models that will describe the probability
3	of events. It's in their financial interest and in
4	also their operational interest.
5	And so you may want to address a little
6	bit about the connection between this kind of work
7	perhaps when you talk about the Davis-Besse event and
8	the significance determination process. And give us
9	your insight.
10	MEMBER ROSEN: With this introduction,
11	would you also address the fact that plant models are
12	evolving. They're not static. They're being
13	improved. And we heard yesterday that some models are
14	less than perfect. And so there may be some rather
15	large improvements someplace.
16	So how do you intend to deal with that?
17	Are you going to go back to plants and re-benchmark on
18	a regular basis? Or something
19	MEMBER APOSTOLAKIS: I have a
20	clarification question. Is ASP and SPAR the same
21	thing? I know physically it isn't. But in terms of
22	body of knowledge, what they represent. Because we
23	keep using the words interchangeably it seems to be.
24	MR. CHEOK: Well, let me try to clarify
25	that. SPAR is basically our PRA models.
Į	I

(202) 234-4433

	22
1	MEMBER APOSTOLAKIS: It's a model, right.
2	MR. CHEOK: And ASP is basically the
3	program to evaluate
4	MEMBER SIEBER: It's a process.
5	MR. CHEOK: operating events at the
6	plants using the SPAR models.
7	MEMBER APOSTOLAKIS: But does the SPAR
8	model, though, reflect all the findings of ASP? Or is
9	it a model that is produced, you know, as the result
10	of the efforts of the staff and then interactions with
11	the utility?
12	MR. CHEOK: We will update the SPAR models
13	on an event-specific basis to be able to model the
14	events correctly. I guess I'd like to elaborate on
15	what the Committee has talked about earlier. You know
16	we have the ASP Program has, in the past,
17	identified events like the fragile ice and the seaweed
18	in the intakes. And these are events that are now
19	being taken into account in plant PRAs.
20	We also have identified events like
21	operator actions that are not in the procedures. Or
22	alternate success paths that the plants have taken in
23	response to plant events but because these paths and
24	procedures they're not officially in procedures, a lot
25	of plants will not take credit for these procedures in
	I

(202) 234-4433

	23
1	the PRAs because of the different standards.
2	So although we do identify about 20
3	percent that's not modeled in PRAs, a lot of times
4	there's a good reason for why they are not in there
5	because the plants feel that the sequences that they
6	model are conservative enough that they do not have to
7	include sequences that, you know, they could do based
8	on operator knowledge that may not be "acceptable"
9	under the AMSE PRA standards.
10	MEMBER APOSTOLAKIS: So, Mike, are you
11	then answering in part or in total the finding that
12	Carl Flemming had in his report that he was told by
13	the staff, the NRC staff or some of the NRC staff that
14	about 20 percent of the initiating events identified
15	in ASP are not included in the PRA or something like
16	that?
17	MR. CHEOK: Well, it could be they were
18	not included at that point. But like I have the
19	example I provided, once they are identified and
20	eventually if they become prominent enough or
21	important enough to a plant, I believe that they will
22	be included in the plant PRA.
23	MEMBER APOSTOLAKIS: And do you have any
24	idea how that happens? Is it because somebody is
25	pushing? Or

(202) 234-4433

	24
1	MEMBER ROSEN: No, it's the update
2	requirement.
3	MEMBER SIEBER: Yes, the event occurs and
4	you
5	MEMBER ROSEN: You have a two-year update
6	requirement to input operating experiences.
7	MEMBER APOSTOLAKIS: Well, update
8	MEMBER ROSEN: The models and the data.
9	MEMBER APOSTOLAKIS: Yes, but I mean, you
10	know, I can update it and I mean update is a very
11	general term.
12	MEMBER ROSEN: Yes, but I know a good
13	update includes the operating experience of the plant
14	itself since the last update and any new models, any
15	new sequences that have been determined to be
16	significant.
17	MEMBER SIEBER: I think it's important to
18	recognize that the 20 percent will never go to zero.
19	And that's because of the issue of what do you take
20	credit for which is your point.
21	MR. CHEOK: To answer George's question
22	directly, the staff has no formal process to make a
23	licensee include some of the events that we find. But
24	I want to substantiate what Mr. Rosen said basically
25	is that if you follow the PRA ASME standards
I	1

(202) 234-4433

25 procedures, it requires that you update your PRA with 1 2 plant-specific events, especially those that are 3 relevant to your plant. 4 So if they follow those procedures, they 5 will pick up on the --Wait a minute -- if is not 6 MEMBER ROSEN: 7 the right word. Some plants have gotten license changes that require updating in accordance with the 8 9 ASME standard. It's a part of the license of a plant. 10 So the if isn't -- it's when they follow their procedures that require updates. 11 12 MR. CHEOK: Sorry. MEMBER ROSEN: All right. I just wanted 13 14 to correct that. It's not so loosey-goosey as you 15 say. 16 VICE CHAIRMAN SHACK: But we could let the 17 staff proceed with their presentation rather than our freeform discussion if it's okay with --18 19 MEMBER APOSTOLAKIS: We could. 20 (Laughter.) 21 MEMBER SIEBER: We could. 22 We have not typically done MEMBER ROSEN: 23 so. 24 MEMBER SIEBER: You basically had a 25-25 minute introduction. So let us move on.

> NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

	26
1	MR. CHOKSHI: We will come back and
2	address the question you raised about the SPAR models
3	also during the presentation. I think I was going to
4	also mention the National Academy of you know,
5	their study about the use of accident precursor
6	sequence analysis and its value. It has been very
7	positive. And I won't say any more than that.
8	MEMBER APOSTOLAKIS: But this workshop
9	took place what three years ago?
10	MR. CHOKSHI: But the report came out
11	MEMBER APOSTOLAKIS: Yes, I know.
12	PARTICIPANT: It took three years to
13	write.
14	MEMBER APOSTOLAKIS: Speaking of updates.
15	(Laughter.)
16	MR. CHOKSHI: Well, let me move on to the
17	next slide because I think that as part of the SDP and
18	the ASP issue, the question, I know, often comes up,
19	you know, why we are doing both and what are the
20	differences.
21	ASP, you know, as I mentioned, it's to
22	evaluate whether a particular event or condition is a
23	significant precursor. And I think as noted in the
24	applicability, it considers concurrent multiple
25	degraded condition. And you'll see that in the Davis-
I	1

(202) 234-4433

27 1 Besse discussion. And some differences between SDP 2 and ASP. While SDP is basically -- using risk 3 4 insights to consider degraded condition or inspection 5 findings to determine the significance in the model for regulatory response. So I think the timing is a 6 7 big factor. The SDP should be done pretty much, you 8 know, very quickly to make some decisions. And that 9 timing effects how we can do the analysis. 10 Ι think that's basically this. The 11 difference is here on the information, on the 12 modeling, uncertainly, it reflects the and availability of time and information. 13 14 MEMBER APOSTOLAKIS: But the idea is the 15 same, though. 16 MR. CHOKSHI: It is true. We are trying 17 to get to the -- but I think the big difference is these multiple conditions. 18 19 MEMBER APOSTOLAKIS: Even SDP considers 20 multiple, doesn't it? This Committee recommended that 21 that's not the way it should be done and we got the 22 reply yes, we agree. Wait a minute, wait a minute. 23 We made a big deal out of it, you remember? That if they find three -- if they have 24 25 three findings, they shouldn't do each one separately

> NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433

	28
1	if they are concurrent. And we got the response from
2	the EDO that yes, we agree with you.
3	MR. CHEOK: I think the purpose of the SDP
4	Program is to evaluate the significance of one
5	particular plant degradation. And, I guess, it's in
6	their therefore, I guess to combine events will not
7	be useful for that purpose.
8	MEMBER APOSTOLAKIS: Well, I mean what
9	they're saying, Mike, is we declare what we do to be
10	the right thing. No, I'm really clear. We have to go
11	back and find that recommendation
12	MR. CHOKSHI: We will also go back.
13	MEMBER APOSTOLAKIS: because we did get
14	a response that agreed with us. That was one of the
15	few cases where the EDO agreed with us.
16	VICE CHAIRMAN SHACK: Although I must
17	confess in my experience in working with the staff on
18	SDPs in certain situations, I think they're very
19	narrowly focused on the exact condition that was
20	found.
21	MEMBER APOSTOLAKIS: Because maybe there
22	was no other condition response.
23	MR. CHOKSHI: But I think in part, you
24	know, the RASP Program, it is trying to get some of
25	the differences ironed out and lead to some
I	I

(202) 234-4433

	29
1	standardization.
2	I think rather than spending too much
3	time, I'm going to turn it over to Gary. And, you
4	know, he will start with the ASP plans. And, I think,
5	a number of questions might be answered during that
6	discussion.
7	MR. DeMOSS: Good morning. I'm Gary
8	DeMoss, ASP Analyst and tasked with presenting the
9	Davis-Besse the grid LOOP but first the results and
10	insights of trends that we presented to the Commission
11	in SECY-04-210 last November.
12	In SECY-04-210 we reported there were no
13	significant precursors in FY 2003 or 2004. Davis-
14	Besse was a significant precursors in FY 2002.
15	At that time, we reported that there were
16	ten important precursors during the 2001-2004 time
17	frame. And we characterized that as being based on
18	preliminary data. The important precursors were three
19	at Point Beach due to a design deficiency in the
20	auxiliary feed systems and failure to correctly
21	implement design changes.
22	Additionally, Davis-Besse was greater than
23	ten to the minus fourth and a 2003 Palo Verde LOOP was
24	ten to the minus fourth. The other five were based on
25	the preliminary analysis of the northeast grid
I	

(202) 234-4433

	30
1	disturbance. Now as we approach the completion of the
2	final analyses, we're now getting less than ten to the
3	minus fourth for all of them due to some data changes
4	in the SPAR model that we're going to talk about
5	later.
6	There was no significant trend in the rate
7	of occurrence of precursors during the period from FY
8	1993 to FY 2002. Mike, you've given the next slide.
9	I'm going to speak to this a little bit. This would
10	be different if we took the trend back further than
11	ten years, as you can see from the chart here.
12	To go through this chart, you can see in
13	the maroon color, the late `80s and 1990s, the number
14	of precursors per year was quite a bit higher. The
15	current ten-year period as trended is in the light
16	blue.
17	VICE CHAIRMAN SHACK: Now are those
18	corrected for what Mario and Steve claim was your
19	extreme conservatism in the old days? Or, you know
20	MR. DeMOSS: The answer
21	VICE CHAIRMAN SHACK: is part of this
22	transient due to the fact that your modeling has
23	improved?
24	MR. DeMOSS: That's one of the possible
25	effects here. We don't we have a policy to not go

```
(202) 234-4433
```

	31
1	back and re-quantify old events with newer models.
2	There's no particular value to it. So I think that is
3	a contributor. Another major contributor is reduction
4	in trip frequency in general. And so I think it is
5	safe to say some of this is licensee performance.
6	We'll be looking a little more into that
7	in a more detailed study we're going to start on
8	trends.
9	MEMBER APOSTOLAKIS: Now which precursors
10	are you reporting here? All of them? What condition
11	or probability?
12	MR. DeMOSS: This is a number of
13	precursors with the conditional probability greater
14	than ten to the minus six. We reject anything less
15	than ten to the minus six.
16	MEMBER APOSTOLAKIS: One would question
17	even something like the standard of minus five. I
18	mean why do I care, right?
19	MR. DeMOSS: We certainly tabulate that
20	also. And I'll show it to you on the next slide.
21	MR. CHEOK: Well, I would kind of like to
22	respond to what you just said, George. I mean if you
23	look at the base PRAs for a lot of plants, significant
24	events tend to be in the ten to the minus five range.
25	So I guess we cannot say why do we care.

(202) 234-4433

32 1 MEMBER APOSTOLAKIS: Significant in what 2 sense? 3 MR. CHOKSHI: In other words, when we say these are significant scenarios. In the IPD space, we 4 5 are told that we need to identify significant 6 scenarios. 7 MEMBER APOSTOLAKIS: But remember these 8 are conditional probabilities. 9 MR. CHOKSHI: That is true. 10 MEMBER APOSTOLAKIS: So presumably the unconditional frequency of the sequence is well below 11 ten to the minus five. 12 That's true. 13 MR. CHEOK: 14 MEMBER ROSEN: I have a question. I don't 15 understand. You named five events. Three at Point Beach, the Davis-Besse, and one other, the Palo Verde 16 17 event --18 Right. MR. CHEOK: 19 MEMBER ROSEN: -- as being particularly 20 significant. But if you multiple .1, which is the 21 bottom line of precursors per reactor year times the 22 number of reactor years, which is about 100 per year, 23 times .1 is about 10. Then you get about -- you 24 should expect to be told about 10 per year. And yet 25 you only told us about five.

> NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433

	33
1	Now am I getting things mixed up here? I
2	don't
3	MR. CHEOK: I think what Gary was talking
4	about, those five events you are talking about, is
5	what he called important precursors which were ten to
6	the minus four and above precursors.
7	MEMBER ROSEN: Oh, oh, oh.
8	MR. CHEOK: These are all precursors which
9	are ten to the minus six and above.
10	MEMBER ROSEN: Oh, okay. Fine. Thank you
11	very much.
12	MR. DeMOSS: Okay.
13	MEMBER APOSTOLAKIS: So, again, why are
14	some of them historical and the others are final?
15	MR. DeMOSS: Well, we use the last ten
16	years for all of our trending studies rather than a
17	much longer term. I think we get into irrelevant data
18	if we go back any further than that.
19	MEMBER APOSTOLAKIS: I don't understand
20	that. The data from `95, they're not historical?
21	MR. DeMOSS: The word historical means
22	that they are far enough in history back that we don't
23	use them in our trending.
24	MEMBER APOSTOLAKIS: Oh.
25	MR. DeMOSS: And really nothing more.
	I

(202) 234-4433

	34
1	MEMBER APOSTOLAKIS: So the maroons are
2	not part of the trending?
3	MR. DeMOSS: They're not part of the
4	trending analysis but I thought interesting to include
5	on this slide.
6	MEMBER APOSTOLAKIS: So the year `97 was
7	the best?
8	MR. DeMOSS: Ninety-seven was a good year
9	apparently.
10	MEMBER APOSTOLAKIS: It was a very good
11	year.
12	(Laughter.)
13	VICE CHAIRMAN SHACK: Not a great one but
14	a good one.
15	MR. DeMOSS: Now I'll cover it on the next
16	slide. I guess the other
17	PARTICIPANT: In the white portion of the
18	bars in `01 or `02 indicate
19	MR. DeMOSS: That's the other
20	interesting portion of this is that we have some CRDM
21	cracking events mostly from DMW plants. And we
22	haven't been able to quantify the initiating event
23	probability, the ejection in a way that we can use for
24	the ASP calculation.
25	This chart shows them assuming that they
	I

(202) 234-4433

	35
1	are precursors. I think they probably would be
2	depending on the calculation.
3	The one important thing about that is
4	another possibility is we'll decide not to spend the
5	resources to do that, to do the difficult
6	metallurgical calculations and classify those as
7	events that we just can't analyze probabilistically
8	and there have been a lot of those throughout history.
9	MEMBER APOSTOLAKIS: But let's not forget
10	that, you know, this may be encouraging if you see the
11	trend going down, of course. But still, all it takes
12	is one of these events to create a problem, right. So
13	let's not forget that.
14	MR. DeMOSS: Certainly, certainly. That's
15	why we're keeping them alive. Certainly, the
16	possibility is not trivial.
17	All right. Here's a little more detailed
18	trending of the events of the last ten years. And,
19	again, these slides are taken from the SECY. Starting
20	at the upper left, the significant precursors, which
21	is just one per year here we show in the last ten
22	years are the Wold Creek drain down even in 1994, the
23	Catawba LOOP in `96, and the Davis-Besse event.
24	MEMBER APOSTOLAKIS: And you have reports
25	on each one?
I	I

(202) 234-4433

	36
1	MR. DeMOSS: And we have reports on each
2	one. The Davis-Besse recently released.
3	MEMBER APOSTOLAKIS: Yes, we
4	MR. DeMOSS: And the other two have been
5	available for a long time.
6	MEMBER APOSTOLAKIS: What were the other
7	plants? I'm sorry.
8	MR. DeMOSS: The first bar, the 1994 is
9	the Wolf Creek drain down while shut down.
10	MEMBER APOSTOLAKIS: Wolf Creek.
11	MR. DeMOSS: The second bar, the `96 bar,
12	is a LOOP at Catawba where a diesel generator breaker
13	failed.
14	MEMBER APOSTOLAKIS: Yes.
15	MR. DeMOSS: And then 2002's data.
16	MEMBER APOSTOLAKIS: Thank you.
17	MR. DeMOSS: Again, this is not enough
18	data to trend as you would expect.
19	MEMBER APOSTOLAKIS: But let me ask
20	another question. You know I'm always I'm a little
21	concerned about this ten to the minus X. No matter
22	what happens in the world, we're always at very low
23	numbers. How certain are you about this ten to the
24	minus six? How high could it be? Reasonably high?
25	I mean even if something really bad
I	1

(202) 234-4433

	37
1	happens and we have editorials in the newspapers and
2	so on, still the condition of probability is one in a
3	thousand? This is a remarkably robust system. How
4	high could this be?
5	MR. DeMOSS: Well, I mean we've had
6	since `69, we've had three precursors greater than ten
7	to the minus one.
8	MEMBER APOSTOLAKIS: One?
9	MR. DeMOSS: One of them was one,
10	obviously.
11	MEMBER APOSTOLAKIS: No, but ten to the
12	minus three, what kind of uncertainty do you have
13	around that?
14	MR. DeMOSS: Well, the uncertainty is
15	roughly an order of magnitude. Around a little bit
16	more than that for Davis-Besse. And we'll display
17	that later.
18	MEMBER APOSTOLAKIS: So even with Davis-
19	Besse, it was still in the one in a hundred condition
20	of
21	MR. DeMOSS: Yes.
22	MEMBER APOSTOLAKIS: probability.
23	MR. DeMOSS: Six to the minus three is
24	MEMBER APOSTOLAKIS: Wow.
25	MR. DeMOSS: Well, the LOCA mitigation
	I

(202) 234-4433

	38
1	systems were available with some deficiencies but not
2	and, again, years ago, significant precursors were
3	more common. We've had 26 since 1969. But relatively
4	few lately.
5	MEMBER BONACA: That's an important
6	observation, however. I mean the number is low, you
7	know, thinking of core damage. But the point you were
8	making, the ECCS was available so a significant
9	contribution to the low number is that you have
10	MEMBER APOSTOLAKIS: But this raises
11	another question in mind. I mean sure the CCDP is a
12	very important metric but should that be the only one
13	we are looking at?
14	MEMBER BONACA: Because, I mean, the
15	significance of
16	MEMBER APOSTOLAKIS: I mean how close were
17	we to having a LOCA?
18	MEMBER BONACA: Right.
19	MR. DeMOSS: Well, we'll try to explain
20	that when I get to the Davis-Besse.
21	MEMBER APOSTOLAKIS: Yes, but I mean you
22	could do it in general.
23	MR. DeMOSS: Although we won't be
24	emphasizing the metallurgy in this one, we'll be
25	talking about
I	I

	39
1	MEMBER APOSTOLAKIS: Okay, okay, okay.
2	MR. DeMOSS: the probabilities.
3	MEMBER APOSTOLAKIS: You know but do you
4	understand my point? That CCDP is not necessarily the
5	metric the only metric of interest.
6	MR. DeMOSS: That's right.
7	MEMBER APOSTOLAKIS: The conditional
8	probability of having an initiating a serious
9	initiating event would certainly be something of great
10	interest it seems to me.
11	MR. DeMOSS: Well, and that's included.
12	Since this was a condition
13	MEMBER APOSTOLAKIS: It's included but not
14	reported here.
15	MR. DeMOSS: Not here, no.
16	MEMBER APOSTOLAKIS: I know you're doing
17	it because in order to get here, you have to do the
18	other thing, right?
19	MEMBER BONACA: It's an important
20	observation.
21	MEMBER APOSTOLAKIS: Right.
22	MEMBER BONACA: The owners at times,
23	you know, I mean you look at the bottom line of the
24	number and you say well, you know, yes, but again, you
25	have to worry about the event itself.
	I

```
(202) 234-4433
```

```
(202) 234-4433
```

	40
1	MEMBER APOSTOLAKIS: Of course.
2	MEMBER BONACA: And if you come down to
3	MEMBER APOSTOLAKIS: Think of the
4	consequences of actually having the LOCA.
5	MR. DeMOSS: Well
6	MEMBER APOSTOLAKIS: Yes, you don't need
7	to go to core damage.
8	MR. DeMOSS: Well, no, the consequences to
9	the plant are very significant.
10	MEMBER APOSTOLAKIS: Or the industry.
11	MR. DeMOSS: And to the industry, that's
12	right. That we can't measure with our tools.
13	Okay. Going through these the ten to
14	the minus four events, as shown, are showing a
15	decreasing trend but not a statistically significantly
16	trend. You can see the line there.
17	Again, we have had one more that is not on
18	this graph which is the Palo Verde event of 2004.
19	Again, that's still preliminary but likely to stay in
20	that range.
21	The ten to the minus five bin, which is
22	obviously a more common occurrence to get a ten to the
23	minus five precursor is statistically significantly
24	decreasing over the last ten years as shown by the
25	curve.
	I

(202) 234-4433

	41
1	An interesting thing and I'm not sure why
2	is the number of ten to the minus six bin of events is
3	increasing. And that is statistically significant.
4	MEMBER DENNING: Let me speculate and see
5	what you think. Could that be the result of less
6	conservatism in the SPAR models? That things we had
7	been interpreting as being a higher probability, as
8	you get more realistic in the SPAR models, may move
9	down into the lower is that possible?
10	MR. DeMOSS: Yes. That's possible. And,
11	in fact, we're going to start a study and I'll have a
12	slide about that later that's going to look at that
13	and a variety of other things.
14	And I think that and increased event
15	identification by the SDP are going to be the reason
16	for that rather than any performance. But that's my
17	personal speculation on a study that hasn't started
18	yet.
19	Okay. Moving on to the next slide which
20	talks about what we're going to do. We are starting
21	about now a detailed study into the trends and, in
22	fact, the former ASP project manager is going to lead
23	that study. And, you know, the trends that we have
24	are the major trends we've noticed are precursors
25	involving initiating events are decreasing. Again,
ļ	I

(202) 234-4433

	42
1	that trip frequency-type thing.
2	Precursors involving conditional
3	unavailability of equipment may be increasing. That's
4	that ten to the minus six increasing trend.
5	Precursors involving loss of offsite power are
6	increasing recently.
7	MEMBER APOSTOLAKIS: So, I'm sorry, why do
8	you talk about the conditional unavailability of
9	equipment and not the conditional probability of
10	having an initiator? Is that covered in the first
11	bullet?
12	MR. DeMOSS: Well, the first bullet is
13	actual initiating events. When we model
14	MEMBER APOSTOLAKIS: Okay.
15	MR. DeMOSS: the conditional
16	unavailability of equipment, we use the nominal
17	probability of an initiating event for the period the
18	condition that the equipment was unavailable.
19	MEMBER APOSTOLAKIS: Okay. All right.
20	MEMBER ROSEN: Does the second bullet
21	imply that the unavailability of equipment is
22	increasing in the plants? Because that's
23	counterintuitive
24	MR. DeMOSS: I mean that's one possible
25	conclusion. I don't think that's the one we're going
	I

(202) 234-4433

	43
1	to come up with though. I think we're detecting it
2	and reporting it more rather than we're really seeing
3	more unavailability of equipment. But I think with a
4	study we could begin to identify that.
5	MEMBER ROSEN: That's counterintuitive to
6	my experience that over time, unavailability with
7	the maintenance rule programs in place now, generally
8	decreases slowly. Now I can provide one explanation
9	of why this could be true and that is more plants are
10	taking equipment out of service under (a)(4),
11	5065(a)(4) than previously, do maintenance while
12	they're online.
13	MR. DeMOSS: Right. We wouldn't pick that
14	up in the ASP Program because that's not a conditional
15	unavailability due to a failure or anything like that.
16	That would be picked up in some data work we do and
17	monitored by NRR.
18	We would look to see if something was out
19	during an equipment failure at that plant and maybe we
20	would start seeing that. But that would be a kind of
21	a random luck chance to really catch a problem there.
22	MEMBER SIEBER: It seems to me that, you
23	know, we look into the future to a situation where
24	risk information will be used to potentially
25	liberalize a lot of outage times for pieces of
	I

(202) 234-4433

	44
1	equipment. It seems to me that you have to answer
2	this question first before one treads down the path of
3	allowing more outage time because obviously, it will
4	have an impact on event frequencies and mitigating
5	strategies and potential results.
б	And so I think this work is pretty
7	important but you have to answer that question.
8	MEMBER ROSEN: Jack, that's a good point.
9	What we're going to be faced with pretty soon is the
10	risk management tech specs.
11	MEMBER SIEBER: That's right.
12	MEMBER ROSEN: Changes to tech specs based
13	on risk that with varying lengths, depending on the
14	risk significance of equipment. And that's coming
15	down the pike.
16	MEMBER SIEBER: That's right. That's
17	right. It's on our agenda.
18	MEMBER ROSEN: Yes.
19	MR. CHEOK: I guess and we will know more
20	when we finish the study but I think from what we've
21	seen so far, we do not believe that it could be an
22	equipment licensee performance issue. It could be an
23	identification versus a current rate issue.
24	In other words, starting in 2000, for
25	example, we have the SDP and if you note that in the
ļ	1

(202) 234-4433

	45
1	ASP Program, we used to identify events based on LERs.
2	Starting in `02, a bigger percent of our events are
3	coming from SDP inspection reports, 20 to 30 percent.
4	Recently, we have increased our technology
5	whereby we're now analyzing most if not all events.
б	In the past, we had a category called impractical to
7	analyze, which we did not analyze. So we are looking
8	at maybe a case where we are now identifying more
9	events as opposed to the events occurring more often.
10	So we will have to come to a better conclusion with
11	respect to that.
12	MEMBER SIEBER: Yes, right now what you're
13	telling us is your speculation. And what we're trying
14	to do is encourage you to change that to something
15	with a little more firmness.
16	MR. DeMOSS: Okay. Just other preliminary
17	information to set the stage for this next study is
18	that we haven't seen any apparent trend related to
19	plant type, the BWRs and PWRs appear to be behaving
20	about the same.
21	We've noticed there are some years, like
22	somebody pointed out, 1997 was a particularly low year
23	and 2004 looks like it might be. We'll look into why
24	some of the things fluctuate and we'll look at causes
25	of precursors as opposed to just occurrences.
ļ	I

(202) 234-4433

46 1 The contribution to these trends, and 2 we're going to try to map these contributions up to 3 this list of trends are -- and see where they fit --4 is introduction to significant determination process and its maturation, revisions to the SPAR models. 5 6 They've gone from a very simplified model to a 7 detailed PRA. Possibly changing licensee performance, 8 9 we're going to look for it. Plant aging, we'll look for it to see if something comes out in our data. 10 Industry and NRC initiatives may attribute to some of 11 12 it and possibly the maintenance rule, we're looking for that. 13 14 Look for outliers in plant performance. 15 Several plants seem to be padding the ASP statistics a little more than others. And we'll try to identify 16 that and make a conclusion. 17 Changes in ASP screening criteria and 18 19 analysis methodology, the program has evolved some and we'll see what the effects of that are. 20 21 And we're also going to look at the ASP And the 22 Index which is shown here on the next slide. 23 Index is calculated by adding the total ASP 24 conditional core damage probabilities of all 25 precursors in a year and dividing it by the total

> NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433

1 number of reactor years for that year. And so the chart looks fairly similar to the -- at a first glance 2 3 to the number of precursors per year. But a little 4 closer look and we start to see that it's heavily 5 driven by significant precursors, remembering а significant precursor is a one to the minus three or 6 7 above event and now this chart shows it divided by the 8 roughly 100 reactor years. Again, we include the older data as well 9 10 as the last ten years which is really what we'll be But you can see the spikes in `94 and 11 focusing on. '96, the years of significant precursors. And another 12 spike in '02 due to the Davis-Besse event. 13 14 MEMBER APOSTOLAKIS: I'm -- I think maybe 15 I don't fully appreciate what you're presenting here 16 but it seems to me we're spending too much time 17 looking at statistical information which, I don't know -- it has some value to it by why do we really care 18 19 about all these trends? 20 I mean it seems to me we should be 21 learning more about what is actually happening, what 22 the ASP is telling us about --23 MR. DeMOSS: And that's -- I think that's 24 where need to go with this study as I described on the 25 last slide. We're missing the whys. And all we've

> NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433

(202) 234-4433

47

	48
1	reported is these trends. And you're right.
2	MEMBER APOSTOLAKIS: I mean what can
3	Agency do with this? This particular slide, what
4	can you go to the Commissioner and recommend two or
5	three decision options given this within you can do A,
б	or B, or C. Or is it just it makes us feel good?
7	MEMBER POWERS: George, isn't it a
8	question that everybody is going to ask?
9	MEMBER APOSTOLAKIS: Sorry?
10	MEMBER POWERS: I mean even if you can't
11	act on it, isn't it a question that people are going
12	to ask? You're going to have the answer in your
13	pocket no matter what.
14	MEMBER APOSTOLAKIS: What question is
15	that?
16	MEMBER POWERS: You know, with the trends.
17	MEMBER APOSTOLAKIS: Yes.
18	MEMBER POWERS: Are we getting better or
19	worse?
20	MEMBER SIEBER: Yes, how are we doing?
21	MEMBER POWERS: They're always going to
22	ask that question.
23	MEMBER APOSTOLAKIS: Okay. So you can
24	have one slide. I think we're spending too much time.
25	It's a matter of emphasis. It seems to me what
ļ	

```
(202) 234-4433
```

49 1 actually happened -- I mean are the human errors 2 increasing? What kinds of human errors? Under what conditions? Do you have any slide on these things? 3 4 MR. DeMOSS: No, we don't. 5 MEMBER APOSTOLAKIS: You see, that's my 6 point. It's a matter of emphasis. I'm not saying 7 that this is useless but it's just a matter of 8 balance. 9 And you are in a unique situation to give 10 us insights regarding these things. MEMBER ROSEN: What's the far right? 11 W/O mean on this chart? 12 MR. DeMOSS: Oh, that's without the Davis-13 14 Besse event in '02 to show the difference with and 15 without the event just to show how a significant 16 precursor --17 MEMBER ROSEN: Just for that one bar, '02? 18 MR. DeMOSS: Yes. 19 MEMBER APOSTOLAKIS: Don't misunderstand 20 I'm not saying this is not useful. It's just me. 21 that I think that the balance is not right. MR. DeMOSS: Okay. I'm agreeing with you. 22 23 I can't disagree with that. And that's where we're 24 going. 25 MEMBER SIEBER: Why don't we move forward.

> NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433

	50
1	MR. DeMOSS: Yes, okay.
2	MEMBER APOSTOLAKIS: We really have to go
3	to Davis-Besse because
4	MR. DeMOSS: Yes, well, okay.
5	MEMBER APOSTOLAKIS: that will answer
6	a lot of my questions.
7	MEMBER SIEBER: The time is right.
8	MR. DeMOSS: Yes, you're right. We are
9	falling behind our planned time here. And this slide
10	simply summarizes that major points that we've
11	discussed for the last 20 or 30 minutes here. And it
12	introduces the fact that we're going to spend the rest
13	of the presentation on the unique condition at Davis-
14	Besse.
15	The Davis-Besse event we strove to develop
16	an analytic approach that would give a realistic
17	integrated risk analysis of the three conditions that
18	existed at Davis-Besse. A construct of the ASP
19	Program as we only treat them for the year that they
20	existed. They actually probably existed quite a bit
21	longer.
22	One condition was latent debris in
23	containment caused unqualified coatings, uncontrolled
24	fibrous materials and other debris that could clog the
25	ECCS sump following a LOCA. We drew heavily on the
I	I

(202) 234-4433

	51
1	work from GSI-191 to quantify the probabilities
2	associated with sump performance.
3	The second condition we included in this
4	is a design deficiency in the high-pressure ejection
5	pumps that would cause pump failure during a
6	recirculation mode.
7	MEMBER APOSTOLAKIS: Latent debris, is
8	that the property? I guess nobody else is
9	MR. DeMOSS: That's the stuff that you're
10	leaving in the containment.
11	PARTICIPANT: Right. It's just junk.
12	MEMBER APOSTOLAKIS: It's latent?
13	MR. DeMOSS: Yes, concrete, dust
14	MEMBER APOSTOLAKIS: I understand what it
15	is.
16	MR. DeMOSS: Dust bunnies and concrete
17	dust.
18	MEMBER APOSTOLAKIS: I just wondered
19	whether this is the proper English. Is it the proper
20	English?
21	MR. DeMOSS: That's the word used in the
22	LER.
23	MEMBER APOSTOLAKIS: Oh, then it must be
24	right, okay. Latent debris, wow.
25	MR. DeMOSS: But it is okay. Testing
I	I

	52
1	and analysis proved that the high-pressure
2	recirculation would fail due to a bearing that is
3	cooled and lubricated by process fluid at Davis-Besse.
4	And it's a unique situation to their high-pressure
5	injection pumps.
6	VICE CHAIRMAN SHACK: Very unique. I
7	think when I asked the question, no other plant has a
8	high-pressure injection pump like that.
9	MR. DeMOSS: I asked the same question.
10	I was told that is true so
11	VICE CHAIRMAN SHACK: Okay.
12	MR. DeMOSS: And the final condition is,
13	of course, the head, which was CRDM nozzle crackage
14	and leakage that led to a cavity formation and could
15	have resulted in a LOCA.
16	To quantify these risks, we use an expert
17	elicitation to determine the distribution of possible
18	conditions to the head a year prior to discovery. And
19	we also used these same group of experts,
20	metallurgists, to determine the degradation rates.
21	DET and their contractor created a Monte
22	Carlo analysis of alternate scenarios to determine the
23	possibility of failure and the failure mode and output
24	the LOCA probabilities I need for an ASP model.
25	MEMBER APOSTOLAKIS: So these are your

(202) 234-4433

	53
1	References 11 and 14 in the report, which I would like
2	to get a copy of.
3	MR. DeMOSS: Okay. I'll take your word on
4	the reference numbers, but yes.
5	MEMBER APOSTOLAKIS: They are.
6	MEMBER SIEBER: Just give him what he asks
7	for.
8	MEMBER APOSTOLAKIS: Because every time I
9	went to somewhere where I thought I was going to learn
10	something, it says but this was done in Reference 14.
11	MR. DeMOSS: Okay. Yes.
12	MEMBER APOSTOLAKIS: So somebody let me
13	understand that somebody said the conditional
14	probability of getting a small or medium LOCA given
15	what we have observed
16	MR. DeMOSS: Given the degradation
17	MEMBER APOSTOLAKIS: is such-and-such
18	
19	MR. DeMOSS: Right.
20	MEMBER APOSTOLAKIS: And how did they do
21	that?
22	MR. DeMOSS: That's a two hour
23	presentation in itself.
24	MEMBER APOSTOLAKIS: No, no, but you can
25	summarize it.

	54
1	MR. CHOKSHI: I think that we have one or
2	two slides.
3	MR. DeMOSS: Right. We have a couple of
4	slides next.
5	MEMBER APOSTOLAKIS: Okay.
6	MR. CHOKSHI: That was part of my work.
7	MR. DeMOSS: And we've got a couple of
8	brief slides to describe quite a bit of work that was
9	done by the metallurgists here. The metallurgists
10	MEMBER ROSEN: You skipped over the last
11	bullet on the last slide which is also of quite a bit
12	of significant interest on how one can estimate the
13	probability of control rod ejection given the
14	circumstances at Davis-Besse.
15	MR. DeMOSS: And that's
16	MEMBER ROSEN: And that was a nozzle
17	rejection.
18	MR. DeMOSS: Yes, that's a nozzle.
19	MEMBER ROSEN: Is that part of what you're
20	going to tell us about?
21	MR. DeMOSS: We're going to tell you just
22	briefly about that. Again, it's not a detailed
23	presentation. It's a model. And actually Dr. Shack
24	was involved in developing it.
25	MEMBER APOSTOLAKIS: You just shut him out
I	

(202) 234-4433

	55
1	of the discussion.
2	MR. DeMOSS: Yes.
3	MEMBER APOSTOLAKIS: But let me is this
4	Committee interested in having actually an information
5	briefing on the Davis-Besse analysis? I would like to
б	see that.
7	MEMBER ROSEN: That might be a good idea.
8	But let's hear some more before we decide.
9	MEMBER SIEBER: Yes. But we can't do that
10	today.
11	MR. DeMOSS: No, we're going to go rapidly
12	through these slides.
13	MEMBER APOSTOLAKIS: But do you remember
14	roughly what the relative probabilities of the three
15	LOCAs were?
16	MR. DeMOSS: Yes. The total was about 20
17	percent chance of a LOCA in the construct we made.
18	And about 18 percent of that was a small LOCA
19	generally due to the crack opening up.
20	And then in rough figures, the medium and
21	large LOCA were each one percent the medium driven
22	by the CRDM nozzle ejection and the large LOCA driven
23	by the upper end of possible degradation of corrosion
24	rates, I should say, to unback a larger piece of
25	cladding.
I	I

(202) 234-4433

	56
1	MEMBER APOSTOLAKIS: So the medium and
2	large were equally likely?
3	MR. DeMOSS: Roughly.
4	MEMBER ROSEN: And is the consequence of
5	those in your study also?
6	MR. DeMOSS: Oh, absolutely.
7	MEMBER SIEBER: Corrosion was occurring at
8	a rapid rate.
9	MEMBER ROSEN: So the consequence
10	MEMBER APOSTOLAKIS: But every time people
11	talk about this, they talk about the medium LOCA. Now
12	this is news to me.
13	MR. DeMOSS: Well, this is because you've
14	got the hole in the head. You know losing the nozzle
15	is a medium LOCA.
16	MEMBER SIEBER: That's right.
17	MR. DeMOSS: The hole in the head
18	MEMBER ROSEN: But my question about the
19	sequence
20	MR. DeMOSS: Well, the accident right,
21	if we were to have a large LOCA, the probability of
22	core damage is much larger than if we were to have a
23	small LOCA. The PRA models basically automatically
24	take care of that.
25	MEMBER ROSEN: Sure. But I'm not I'm

(202) 234-4433

	57
1	interested in what happens to the control rod drive
2	mechanism itself. Is that analyzed to be ejected?
3	The rod is actually ejected? And there's a reactivity
4	addition because of that?
5	MR. DeMOSS: Right. But the analysis says
6	that that's not an atlas one ejection is not an
7	atlas issue.
8	MEMBER ROSEN: Okay. But you do take the
9	analysis out through the reactivity effects of a rod
10	ejection under these conditions?
11	MR. DeMOSS: The answer a general no
12	because the reactivity addition is not an atlas. And
13	so for the risk sequence, we're aren't getting an
14	atlas condition.
15	MEMBER ROSEN: Well, I think, George, now
16	I'm interested enough
17	MEMBER APOSTOLAKIS: Yes, me, too.
18	MEMBER ROSEN: to have
19	MR. CHOKSHI: Yes, okay. So let's plan
20	it.
21	MEMBER APOSTOLAKIS: It would be extremely
22	informative actually.
23	MR. DeMOSS: I mean that was analyzed.
24	MEMBER APOSTOLAKIS: We should do this in
25	the near future. Michael, are you taking notes of
Į	I

(202) 234-4433

	58
1	this?
2	MR. SNODDERLY: Yes, sir.
3	MR. DeMOSS: All right. The DET and the
4	contractors did quite a bit of analytic work and
5	laboratory testing to understanding the situation at
6	Davis-Besse.
7	They had three objectives in their study.
8	One was to assess the structural integrity of the
9	primary coolant pressure boundary for the conditions
10	exactly as existed on February 16th. In other words,
11	what was your margin at that point.
12	The other was to see how much longer
13	Davis-Besse could have gone if it were undetected and
14	not taken off line in February 2002.
15	And the third was in support of the ASP
16	Program to go back a year and then hypothetically
17	quantify what alternate scenarios in metallurgy,
18	corrosion, and cracking rates could have lead to a
19	LOCA on or before February 16th, 2002.
20	MEMBER APOSTOLAKIS: That was pretty good.
21	I like what you did there. Don't be shocked. We
22	don't always criticize.
23	(Laughter.)
24	MR. DeMOSS: Many aren't thrilled with
25	that.
ļ	I

	59
1	Okay. And this slide shows a brief
2	overview of the methodology used for the three
3	calculations. And, again, not going into much detail,
4	they did a geometrically accurate and complete
5	analysis of the as-found condition.
6	MEMBER APOSTOLAKIS: Geometrically
7	accurate? This is like latent debris?
8	MR. DeMOSS: Right. In other words, they
9	didn't use a circle or a simply football shape or
10	something like that to quantify it. They actually did
11	the finite element. And you're out of my league here
12	real quickly because I'm not a metallurgist. A finite
13	element analysis.
14	They then used that to tune a model that
15	used simplified shapes and then incorporated the
16	corrosion and crack growth rates for the forward-
17	looking analysis, how long would it last, and the ASP
18	analysis, the backward-looking method. And it is
19	interesting.
20	Okay. The key findings and I think
21	they're all important are, of course, there is no
22	failure by the day of discovery and, in fact, there
23	was a factor of about one and a half safety margin on
24	the operating pressure. And still a significant
25	amount from a relief value set point pressure at the
I	I

(202) 234-4433

	60
1	time of discovery.
2	Using their Monte Carlo simulation, their
3	best estimate for the median time of continued
4	operation for failure is about five months. And
5	there's a large uncertainty in that because this is
6	kind of a non-standard groundbreaking metallurgic
7	analysis.
8	You basically have a horse race between
9	the corrosion growing, the unbacked cladding area, and
10	the crack growth rates within the cladding.
11	VICE CHAIRMAN SHACK: But you loss with
12	both races.
13	(Laughter.)
14	PARTICIPANT: Which one won the race?
15	MR. DeMOSS: The other participant was the
16	licensee and the NRC that shut the plant down and put
17	a new head on.
18	MEMBER APOSTOLAKIS: Wait a minute.
19	MR. DeMOSS: So we won.
20	MEMBER APOSTOLAKIS: You're on the second
21	bullet, right?
22	MR. DeMOSS: Yes.
23	MEMBER APOSTOLAKIS: Approximately five
24	months with large uncertainties so what does that
25	mean? How large is it?
I	

```
(202) 234-4433
```

	61
1	MEMBER SIEBER: It's plus or minus five.
2	MR. CHOKSHI: I think it is a very
3	complex, you know, with cracks and the assumptions you
4	make length of the crack, the depth of the crack,
5	whether it is a continuous crack
6	MR. DeMOSS: Yes.
7	MR. CHOKSHI: what the core requires.
8	So based on all of these different conditions of basic
9	knowledge and on the median estimates, it went from
10	five to 13, Allen? Or would you say five was the
11	lower boundary?
12	MEMBER APOSTOLAKIS: Wait a minute. Five
13	is the median.
14	MR. CHOKSHI: Yes. These are median
15	estimates. Median estimates range from five to 13
16	months depending on different assumptions.
17	MEMBER APOSTOLAKIS: So this number there
18	is the low bound?
19	MR. CHOKSHI: Then I will let Allen then
20	give the accurate numbers.
21	MR. HISER: I'm not sure if I can give
22	accurate numbers but
23	MEMBER ROSEN: Allen, could you
24	MR. HISER: maybe explain a little bit.
25	MEMBER APOSTOLAKIS: Who are you?
ļ	1

(202) 234-4433

	62
1	MR. HISER: I'm Allen Hiser, Materials
2	Engineering Branch in Research.
3	One of the biggest uncertainties was that
4	there were cracks identified in the cladding and how
5	one models those has a big impact on who loses the
6	race earlier.
7	The five months relates to using an ASME
8	code type of definition for the cracks. So looking at
9	the largest extent of the cracks and the deepest
10	crack, modeling that as the overall crack geometry
11	provides you with a five month.
12	I believe eight months is the same length
13	of crack but a shallower depth that more represents
14	the average, I believe. About 13 months would
15	represent a shorter crack with the same average depth.
16	So there are a lot of parts of the analysis that are
17	really driven by the assumptions.
18	MEMBER APOSTOLAKIS: Oh, absolutely.
19	MR. HISER: And the cracks are one part.
20	MEMBER APOSTOLAKIS: So what is the range?
21	Five to 13?
22	MR. CHOKSHI: Five to 13.
23	MR. HISER: Five to 13 would be a 50
24	percent failure.
25	MEMBER APOSTOLAKIS: So this bullet is not
I	I

(202) 234-4433

	63
1	quite right?
2	VICE CHAIRMAN SHACK: You've just talked
3	about the cracks, Allen. How about the, you know,
4	eroding away the materials?
5	MEMBER APOSTOLAKIS: Did you say five to
6	13 or would you say the best estimate between five and
7	13?
8	MR. HISER: Yes.
9	MR. DeMOSS: Well, no, there are two
10	separate medians to two separate approaches to the
11	analysis are the five and 13. Is that stated
12	correctly?
13	MR. HISER: Yes, the five and 13 just
14	related to whether you assume an ASME-type crack or
15	you assume a less severe crack.
16	MEMBER APOSTOLAKIS: No, but, you see, the
17	way it is stated it says the median is five with a
18	large uncertainty. So my mind says in my mind, oh,
19	so it could be as low as one?
20	MEMBER BONACA: Absolutely.
21	MEMBER APOSTOLAKIS: See, it's not stated
22	well.
23	MEMBER BONACA: Yes, I'm just puzzled
24	MEMBER APOSTOLAKIS: A median between five
25	and 13 or the best estimate of the median is eight.
ļ	

```
(202) 234-4433
```

	64
1	MEMBER BONACA: Yes, just I have a
2	question regarding this. If I understand it, I mean
3	the issue as identified by the fact that as they were
4	working on the head, the nozzle simply fell off,
5	right?
6	MEMBER SIEBER: Fell over. It tipped
7	over.
8	MEMBER BONACA: So that gives me a picture
9	of, you know, instability that is inconsistent with
10	some of the estimates here. It seems as if this thing
11	was ready to just fall off.
12	MR. HISER: Yes. Let me clarify one part.
13	It when they took the head off the vessel, the
14	nozzle was still secured by the J-groove weld. It
15	tipped when they were doing repairs of the nozzle. So
16	at that point, they had, in effect, machined out the
17	entire J-groove weld. So there was nothing to support
18	the head or to support the nozzle.
19	MEMBER KRESS: Does the growth of the
20	crack until it penetrates the head result in a small
21	break LOCA, a medium break LOCA, or what?
22	MR. HISER: If the crack grows through to
23	the point that you have an unstable ligament in the
24	cladding, then you would get a small break LOCA, I
25	believe.

(202) 234-4433

	65
1	MR. DeMOSS: I think there was a they
2	had a failure parameter in that Monte Carlo that could
3	have gone to small or medium in that case but almost
4	all of them, as I recall, went to small.
5	MEMBER KRESS: Went to small? That's what
6	I was going to say.
7	MR. CHOKSHI: And, you know, some testing
8	was done to basically pin down what kind
9	MR. DeMOSS: Yes, I think there was some
10	possibility that the crack could fish-mouth wide
11	enough coupled with maybe a high corrosion because
12	that was in the bin, too, that you could possibly go
13	to medium that way.
14	MEMBER DENNING: What are minimum
15	safeguards under that condition? Is that high
16	pressure pump, is it critical in recirc for that? Or
17	do you have other pumps that can still handle that
18	condition?
19	MR. DeMOSS: Well, the large pumps are
20	still available and working as well as the sump is
21	available as well as the sump is working for
22	recirculation.
23	MEMBER DENNING: And the pressure at that
24	time would be such that the low head pumps would be
25	effected you're saying in recirc?
I	I

(202) 234-4433

	66
1	MR. DeMOSS: The licensee would have to
2	take action to depressurize for a medium.
3	MEMBER DENNING: They'd have to take
4	action to depressurize?
5	MR. DeMOSS: Yes.
6	MEMBER SIEBER: Yes, the pressure would
7	hang up then.
8	MR. DeMOSS: But it is proceduralized
9	action. It's not heroic or anything like that.
10	MEMBER SIEBER: I think we're really
11	falling behind.
12	MR. DeMOSS: We are. But we'll pick it up
13	as best we can.
14	MEMBER SIEBER: It's just as bad for me as
15	it is for you to say.
16	MR. DeMOSS: Okay. Again, as I've stated
17	before in response to a question, we had about a 20
18	percent likelihood of a LOCA under the risk construct.
19	This slide shows the results of the
20	analysis. And we're going to spend a minute on this
21	one. And then we'll speed back up.
22	Starting with the upper left corner, you
23	see a diamond. That's the best estimate of core
24	damage probability. That's 60 to the minus three with
25	the three conditions set at our best estimate for the
ļ	I

(202) 234-4433

	67
1	sump parameter, the failure of the high-pressure
2	recirculation pumps, and the LOCA probabilities.
3	The first error bar is our sensitivity to
4	LOCA parameters. The metallurgists ran a large number
5	of scenarios and assumptions through their Monte Carlo
6	code to come up with LOCA probabilities. And then we
7	ran them through the PRA models and came up with that
8	range of answers.
9	This is not an uncertainty. It's a range
10	of sensitivities. We don't really have the technology
11	or it would have cost a lot more money to propagate
12	uncertainties through the metallurgical model so that
13	was not done.
14	MEMBER APOSTOLAKIS: Of course, you pay a
15	price for that. I'll go to the microphone.
16	MR. DeMOSS: Okay. Again, in that time,
17	we
18	MEMBER APOSTOLAKIS: Isn't there a certain
19	arbitrariness in the sensitivity studies?
20	MR. DeMOSS: Yes. That's inherent in any
21	sensitivity study done by Monte Carlo analyses and
22	MEMBER APOSTOLAKIS: So why do it then.
23	I mean if there is a quantity that you think should be
24	increased by a factor of four to see what happens, why
25	not a factor of ten?
I	

(202) 234-4433

	68
1	MR. DeMOSS: Well, the
2	MEMBER APOSTOLAKIS: Somehow you have
3	MR. DeMOSS: quantities in a
4	metallurgic analysis had probability distributions on
5	them. And they would change a Monte Carlo rule or
6	metallurgical rule for that more than just changing
7	quantities.
8	But the Monte Carlo analysis puts out, you
9	know, repeated runs of scenarios through those
10	probability distributions. And then you have what
11	look like discreet results. So we don't try to
12	establish a true uncertainty with that.
13	MEMBER APOSTOLAKIS: But you have some
14	idea who likely these results
15	MR. DeMOSS: Well, I think the sensitivity
16	analysis, the way we did it, gives you some idea how
17	uncertain you are about these results.
18	MEMBER APOSTOLAKIS: All I'm saying is
19	that it is not very difficult to go the next step and
20	actually say something about the distribution because
21	deep in your mind or whoever did it, when they did the
22	sensitivity, they had some idea that this is
23	reasonable.
24	MR. DeMOSS: Yes.
25	MEMBER APOSTOLAKIS: And since we are
I	I

(202) 234-4433

	69
1	elevating expert opinion elucidation to a science
2	here, you know, that's the natural next step.
3	Sensitivity analysis are remnants of the old way of
4	doing business. Now that we're using probability
5	curves, we should do it with probability curves.
6	MR. DeMOSS: Yes. You'd have to
7	there's a lot of probability curves to propagate
8	through that metallurgical analysis.
9	MEMBER APOSTOLAKIS: Oh, okay.
10	MR. DeMOSS: I don't know how difficult it
11	would have been. It would have been
12	MEMBER APOSTOLAKIS: I think Nilesh
13	understands what I'm saying.
14	MR. CHOKSHI: I probably have to show you
15	the, you know, those two reports what was done.
16	MEMBER APOSTOLAKIS: I know. There are
17	statements there to the effect that the sensitivity
18	analysis were done.
19	MR. DeMOSS: Okay. The next
20	MEMBER APOSTOLAKIS: But we will have
21	another briefing so we'll discuss it in far more
22	detail.
23	MR. DeMOSS: The next bar is sensitivity
24	to assumptions about how the sump would have
25	performed. And with our LOCA probabilities and our
ļ	I

(202) 234-4433

high-pressure recirculation system set up at their best estimate values.

3	The sump was analyzed using the work of
4	GSI-191. And remember most PRAs, including the SPAR
5	models, have an epsilon value of R to the five e to
6	the minus five value probability of a sump plugging in
7	a LOCA. GSI-191's quantification is not really well
8	along to come up with an accurate probability estimate
9	but they, I think, clearly show it is not the near
10	negligible value that is floating on the PRAs.
11	So what I did is take the basic PRA up to

So what I did is take the basic PRA up to the best GSI-191 estimates for Davis-Besse. And then add a delta for their reported deficiencies in containment, their unqualified coatings, and debris in containment. And see what delta risk was brought up. GSI-191 developed curves based on the

17 solid debris, and the particulate debris, and the fibrous debris possibly in containment that could be 18 mapped to a probability of containment failure. 19 And there are different assumptions that could be used in 20 21 going through those curves. And that's where I 22 developed a different sensitivity cases for mγ 23 analysis of the sump.

And you can see it was actually slightly more sensitive to sump failure assumptions than it

> NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433

1

2

(202) 234-4433

70

	71
1	even was to the LOCA assumptions. But they went
2	together and that's not surprising because our
3	dominant cut sets were medium LOCA and large LOCA
4	followed by a sump plugging.
5	And finally we did a sensitivity to high-
6	pressure recirculation system which was really
7	focuses mainly on the small LOCA and it was not nearly
8	as important.
9	As we move further to the right, we set
10	we start verifying what SDP did and doing some other
11	for instance calculations. The vessel head only
12	calculation uses the same sensitivity analysis points
13	for LOCA probabilities that we used earlier but the
14	sump and high-pressure recirculation system are
15	nominal.
16	The purpose of this is simply to show that
17	the vessel head only would have given you a red
18	finding. There was an SDP done for just the vessel
19	head per our earlier conversation. And it was a red
20	SDP.
21	The next one over is the CRDM only. The
22	NRC, although they didn't have as sophisticated models
23	as I had to work with for the CRDM LOCA probability,
24	the NRC knew that there were CRDM problems. That's
25	why they asked for a shutdown of the susceptible
	I

(202) 234-4433

	72
1	plants, mainly B&W plants.
2	So for a year with just the CRDM problem,
3	we would have had a high ten to the minus five
4	increase in risk for Davis-Besse.
5	The next calculation is to show how much
6	risk we allowed or we incurred by allowing Davis-Besse
7	to operate the additional six weeks. They received
8	special permission to not shut down by the first of
9	January and to operate about six weeks until December.
10	And you'll see we've added a I think it was about
11	eight times ten to the minus six delta risk by
12	operating that long.
13	VICE CHAIRMAN SHACK: If you only had the
14	CRDM finding
15	MR. DeMOSS: If we only had the CRDM and
16	that's based on the premises that, quite frankly, NRC
17	really couldn't have expected the other problems. And
18	so those values were nominal in my risk model.
19	VICE CHAIRMAN SHACK: The other problems
20	being the high-pressure injection and sump?
21	MR. DeMOSS: The high-pressure injection,
22	the sump, and the cavity. All three were essentially
23	unpredictable. And, you know, the two were caught
24	during the shutdown. And the vessel head was
25	discovered.

(202) 234-4433

	73
1	The next one is just a for information
2	run. And as we go to the right of the line, we reset
3	our LOCA frequencies back to nominal. And so this is
4	done for the purposes of checking the SDP runs and to
5	make sure that we're modeling the same way and that
6	sort of thing.
7	And the first one is not an SDP analysis
8	because it has two degraded conditions in it, the HPR
9	and the sump simultaneously degraded. That shows that
10	risk estimate.
11	We then run the sump failure probability
12	through with nominal LOCA frequencies and you see you
13	get no worse than about a ten to the minus five
14	increase in risk. So that's what we're getting
15	probably at most plants due to sump problems.
16	MEMBER DENNING: I'm missing something and
17	that is these are conditional probabilities here. Now
18	when you go and you use nominal LOCA frequencies, are
19	we still dealing with a conditional probability? Or
20	are we dealing with an annual
21	MR. DeMOSS: We're calculating a
22	conditional probability still. Actually at the delta
23	CDP due to just the sump problem. With everything
24	else at a nominal good likelihood.
25	CHAIRMAN WALLIS: Now wait a minute. You
ļ	1

(202) 234-4433

	74
1	mean that the sump only contributes D to the minus
2	five?
3	MEMBER SIEBER: Yes.
4	MR. DeMOSS: Correct. Alone. Remember
5	they're multiplicative, not additive, especially these
6	three conditions, which is why they come up to such a
7	high risk together. And relatively low risk
8	VICE CHAIRMAN SHACK: Is that a delta CDF
9	you've multiplied the conditional by the nominal
10	LOCA frequency to get the ten to the minus five?
11	MR. DeMOSS: Correct.
12	CHAIRMAN WALLIS: That's where I was
13	trying to get at. I mean most of the low the
14	reason that it is so low is because of the nominal
15	LOCA frequency.
16	MR. DeMOSS: Right. So if this were at
17	another plant
18	CHAIRMAN WALLIS: The conditional
19	probability for the sump is way up there, right?
20	MEMBER DENNING: I'm still missing the
21	units. It still looks to me like this is per reactor
22	year on the right.
23	MR. DeMOSS: It is.
24	MEMBER DENNING: But on the left it's not.
25	MR. DeMOSS: No.
I	I

(202) 234-4433

	75
1	MEMBER DENNING: That's conditional.
2	MR. DeMOSS: It's the same units on both
3	places. They're both delta CDPs, which is the
4	increase in core damage probability over a year since
5	our construct has us doing this analysis for a year.
6	MEMBER DENNING: Now wait a second. Over
7	a year I'm missing these over here are not over
8	a year. This is conditional on isn't it?
9	CHAIRMAN WALLIS: No, it's not
10	conditional.
11	MR. DeMOSS: They're conditional on the
12	problems.
13	MEMBER DENNING: Yes.
14	MR. DeMOSS: But the increase is the delta
15	core damage over a year because we didn't actually
16	have an initiating event. We calculated pure
17	conditional probability
18	MEMBER DENNING: For a year?
19	MR. DeMOSS: following an initiating
20	event. Here we but for a condition, a piece of
21	equipment that the plant operating with operated
22	while it was in a failed state, we calculate a delta
23	CDP. In other words, we subtract out the baseline
24	CDP, if you will, the unflawed CDP, during that period
25	of time.
I	

(202) 234-4433

	76
1	Now in a lot of ASP analyses, it would be
2	a pump out for a month or something. This one was a
3	condition that went undetected for a year.
4	MEMBER ROSEN: To nail down my
5	understanding, let's take a plant with an annual CDF
6	of 1.5 e to the minus five.
7	MR. DeMOSS: Okay.
8	MEMBER ROSEN: And let's just say it has
9	the sump problem.
10	MR. DeMOSS: Right.
11	MEMBER ROSEN: That's the only problem it
12	has. And is it now 2.5 e to the minus five?
13	MR. DeMOSS: That's correct.
14	MEMBER ROSEN: Okay.
15	MR. DeMOSS: So the delta CDP that I'm
16	reporting here is one e to the minus five. That's the
17	increase due to the problem. And that's what the SDP
18	also calculates.
19	CHAIRMAN WALLIS: But the probability of
20	the sump failing could be
21	MR. DeMOSS: It's quite high.
22	CHAIRMAN WALLIS: pretty high.
23	MR. DeMOSS: Right.
24	CHAIRMAN WALLIS: It could be 22 or
25	something.
I	1

	77
1	MR. DeMOSS: Yes, GSI-191 told me it was
2	better than .5 for a large LOCA.
3	CHAIRMAN WALLIS: Right. For a large LOCA
4	it's almost one. It's getting up there.
5	MR. DeMOSS: Right.
6	CHAIRMAN WALLIS: Okay. That makes sense.
7	MR. DeMOSS: But large LOCAs with a good
8	head is very unlikely. And even fairly unlikely with
9	Davis-Besse's head.
10	Okay. So and again, this shows that it
11	is consistent with the sump is conditioned with a
12	yellow finding, the ten to the minus five, or the SDP.
13	And the HPR was actually a white finding in the mid
14	ten to the minus six range. And that is consistent
15	with the SDP.
16	Okay. Running through the Davis-Besse
17	results, it is a significant precursor. In all of
18	history, there have been 11 ASP events higher than
19	Davis-Besse. All of them occurred all the ones
20	higher than Davis-Besse occurred in 1985 or before.
21	We haven't seen anything like this in a while. We've
22	had two other significant precursors in the last ten
23	years, as I spoke earlier.
24	MEMBER APOSTOLAKIS: I'm having difficulty
25	reproducing your 6.1 ten to the minus three in your
I	

(202) 234-4433

	78
1	report. There is a table there Table 1 that has a
2	bunch of numbers. And I'm trying to figure out how
3	this 6.1 ten to the minus three came about. And I
4	can't.
5	So if we're going to have another
6	briefing, maybe we can do that there
7	MR. DeMOSS: Okay.
8	MEMBER APOSTOLAKIS: because this is
9	until 10:30 and it's going to take forever if we are
10	to do that. But by looking at the SECY, I cannot
11	reproduce it.
12	MR. DeMOSS: From the SECY?
13	MEMBER APOSTOLAKIS: Well, whatever you
14	call this.
15	MEMBER BONACA: The report you gave us.
16	MR. DeMOSS: Okay.
17	MEMBER BONACA: What is it? I mean you
18	are so surprised.
19	MEMBER APOSTOLAKIS: The final precursor
20	that's part of something. Now I just noticed that
21	the infamous Reference 14 has Mr. Cheok as a coauthor.
22	So maybe I can get the copy today? Right?
23	MR. CHEOK: I'm not sure what Reference 14
24	says.
25	MEMBER APOSTOLAKIS: It says Cheok.
I	I

(202) 234-4433

	79
1	Right? The mention of increase in medium LOCA
2	frequency attributed to circumferential tracking
3	potential in leaking CRDM nozzles.
4	MR. CHEOK: I think that's a memo
5	MEMBER APOSTOLAKIS: A memo.
6	MR. CHEOK: to me. I can provide that
7	to you.
8	MEMBER APOSTOLAKIS: Oh, it's a memo to
9	you. Yes, I'm sorry.
10	But anyway, the number I cannot reproduce.
11	Okay?
12	MR. DeMOSS: Okay. Well, I can either go
13	with that individually or whatever you need.
14	MEMBER APOSTOLAKIS: Okay. And I'm really
15	disturbed by the use of the word significant here.
16	You haven't gone to the second red bullet. But DB had
17	a significant loss of safety margin.
18	Then you're telling us that the margin
19	could be as low as ten to the minus two. Ten to the
20	minus two margin in my mind, after all these bad
21	things have happened, is pretty good. If this is the
22	worst thing that ever happens in reactor safety, I'll
23	be very happy.
24	MR. DeMOSS: Well, by our calculations
25	MEMBER APOSTOLAKIS: One in a 100. I mean
I	I

(202) 234-4433

Í	80
1	think about it. That's a pretty low number.
2	MEMBER BONACA: For core damage.
3	MR. DeMOSS: For core damage, right.
4	MEMBER APOSTOLAKIS: Yes, for core damage.
5	MR. DeMOSS: But like I say we haven't
6	been to one in 100 in quite a long time is the point
7	I'm making.
8	MEMBER APOSTOLAKIS: Oh, well, that's
9	different. That's unusual.
10	MR. DeMOSS: I'll let you interpret good
11	or bad.
12	MEMBER APOSTOLAKIS: It's unusual.
13	MR. DeMOSS: Yes.
14	MEMBER APOSTOLAKIS: It's rare. But it's
15	not significant.
16	MEMBER BONACA: Let me make the analogy
17	that support this evaluation consider the hole in the
18	head the thermalhydraulics, I mean.
19	MR. DeMOSS: Right. Who did the
20	thermalhydraulics?
21	MEMBER BONACA: Yes.
22	MR. DeMOSS: NRR did it.
23	MEMBER BONACA: Yes, I'm saying did they
24	consider the hole in the head for a small break LOCA?
25	MR. DeMOSS: Yes. They verified it was
I	

	81
1	bounded by the small LOCA recovery models in a PRA.
2	And bounded it's actually a fairly good place to
3	have a LOCA if you're going to have one.
4	You don't lose any of your injection flow
5	and you have a steam leak, which are really the two
6	driving criteria for that. So it's not too bad.
7	All right, again, getting back to the
8	slide, the reason for the loss of safety margin, which
9	is significant relative to other events we've seen in
10	recent times, is the fact that you had three major
11	problems at the same plant.
12	And, again, our sensitivity analysis show
13	that we're clearly and well into the ten to the minus
14	three or possibly ten to the minus two range. We're
15	not lower than that or higher.
16	MEMBER APOSTOLAKIS: Could we skip the
17	agreed portion, I think, and go to the SPAR models.
18	MEMBER SIEBER: Yes.
19	CHAIRMAN WALLIS: Let's see how does this
20	number change if you wait longer? If this had waited
21	for another few months
22	MR. DeMOSS: Okay. ASP is always a
23	backward-looking program so we didn't look at that.
24	Certainly the likelihood of a LOCA would have been
25	higher.
	I

(202) 234-4433

	82
1	CHAIRMAN WALLIS: It would have been much
2	higher?
3	MR. DeMOSS: Right. But by construct, we
4	look at what risk we incur.
5	CHAIRMAN WALLIS: So how much of the
6	you know we've got a multiplicative thing here. How
7	much of the six times ten to the minus three is low
8	because the pressure boundary was still likely to
9	hold? Can you tell us that? How much of the
10	contribution was from the pressure boundary?
11	MR. DeMOSS: Well, the main the
12	contribution was the sum of all LOCAs. The dominant
13	contributions were from a large LOCA, which is the
14	tail of that distribution times the high likelihood of
15	the sump failing in a large LOCA.
16	Another roughly equally dominant cut set
17	was a medium LOCA which is
18	CHAIRMAN WALLIS: Since the containment
19	sump failure is high and that doesn't account for the
20	six times ten to the minus three.
21	MR. DeMOSS: Well
22	CHAIRMAN WALLIS: And the high-pressure
23	injection system, is that a big contributor to this
24	low number? Or is it just
25	MR. DeMOSS: It's not a tremendously large
I	

(202) 234-4433

	83
1	contributor.
2	CHAIRMAN WALLIS: So it's really the fact
3	that the pressure boundary was able to hold, which
4	makes this thing so low? Is that what it is?
5	MR. DeMOSS: Right. The pressure boundary
6	
7	CHAIRMAN WALLIS: Okay.
8	MR. DeMOSS: did hold. If the pressure
9	boundary hadn't I don't have a calculation and it
10	would be a little tough to do off the top of my head
11	for if the pressure boundary had failed with these
12	other problems, it would be pretty likely. I mean we
13	have a 20 percent chance of failing the pressure
14	boundary. And most of that failure probability is a
15	small LOCA.
16	But the medium and large LOCAs are about
17	one in a 100. So forgetting about the small LOCA,
18	we'd have something like a .6 if we had had one of
19	those LOCAs. That's real rough. But you're getting
20	above .1 certainly.
21	MEMBER DENNING: See there's an element of
22	this that surprised me because I thought that what you
23	were really doing I didn't realize that you were
24	annualizing a probability when you did.
25	And I was thinking if we come and we have
Į	I

(202) 234-4433

	84
1	this condition, and if we hadn't done anything for
2	however long it would have taken, if we hadn't
3	recognized that condition, what is the probability we
4	would have had core melt? Not on a change in a core
5	damage frequency but a conditional probability core
6	melt.
7	MR. DeMOSS: So in other words
8	MEMBER DENNING: It's a different way of
9	looking at it.
10	MR. DeMOSS: Right.
11	MEMBER DENNING: But in this case with a
12	degrading condition where presumably eventually it
13	would have blown one way or the other, it may give you
14	a different perspective. And, you know, I'm kind of
15	surprised because I thought that's what you really
16	meant by a conditional core damage probability. And
17	it isn't.
18	MR. DeMOSS: No. It's a conditioned
19	analysis in other words.
20	MEMBER DENNING: It's conditioned analysis
21	but
22	MR. DeMOSS: Right.
23	MEMBER DENNING: it's still an
24	annualized
25	MR. DeMOSS: It's an annualized condition
ļ	I

	85
1	analysis with degraded equipment at the plant.
2	MEMBER DENNING: Yes, yes.
3	MR. DeMOSS: And one of the pieces of
4	degraded equipment is the head.
5	MEMBER DENNING: But it doesn't look at
б	suppose we had continued on for two years or three
7	years? Does it lead to
8	MR. DeMOSS: Well, it leads to
9	MEMBER DENNING: core melt?
10	MR. DeMOSS: just doing the calculation
11	in my head, if it went on if you let it run until
12	it broke
13	MEMBER DENNING: Yes.
14	MR. DeMOSS: and yet we don't know
15	which break, there is a probability of each size of
16	break, you're probably greater than .1 chance that we
17	would have gone to core damage.
18	MEMBER KRESS: I'm having trouble
19	reconciling the crack growing and failing the pressure
20	vessel with what we know about pressurized thermal
21	shock. It seems like they have an awfully high
22	probability of failing that vessel just by the crack
23	growing.
24	VICE CHAIRMAN SHACK: It's a crack in a,
25	you know, a three-eighths, sixteenth inch stainless

(202) 234-4433

	86
1	steel skin.
2	MEMBER SIEBER: With 2,000 pounds
3	CHAIRMAN WALLIS: Which is already there,
4	there's a crack there.
5	MEMBER SIEBER: Right.
6	MR. CHOKSHI: It's in the cladding, yes.
7	MR. DeMOSS: Yes, we've lost the wall.
8	MEMBER KRESS: So the growth rate from
9	that
10	MR. DeMOSS: Well, once he gets that
11	crack, you know, it's a question then of whether it
12	rips to give you, you know, how big will it rip?
13	MEMBER SIEBER: How big is the rip?
14	MR. DeMOSS: I think a crack is actually
15	good news here. That gives you the chance of a small
16	LOCA. If you wait until the things corrodes around
17	the back and the thing goes pop, then you've got the
18	large LOCA.
19	MR. CHOKSHI: If you look at it sort of
20	from the metallurgical delimiter as you go forward,
21	and then it's the rates of the head corrosion becomes
22	pretty significant and the LOCA distribution is
23	changing.
24	MEMBER KRESS: Well, in answer to your
25	question about whether you can skip the grid, it's
I	I

(202) 234-4433

	87
1	been the ACRS there's very high interest in the
2	grid reliability. And I would vote against.
3	MR. DeMOSS: Well, I can run through
4	quickly with an overview. The grid, from an ASP
5	standpoint, the plants behaved as expected. And no
6	major equipment problems, as you know. So the
7	analysis of the grid LOOP were important but
8	relatively uneventful from an ASP standpoint.
9	The important thing is the reliability of
10	the grid which I don't have any additional information
11	to add for you.
12	MEMBER SIEBER: Okay. Well, that was
13	pretty quick.
14	(Laughter.)
15	CHAIRMAN WALLIS: Did they all have
16	diesels or something that started?
17	MR. DeMOSS: All diesels worked just fine.
18	And so ASP looked at probabilities of diesels not
19	working coupled with other things necessary to get to
20	core damage.
21	MEMBER SIEBER: Okay. So we covered this.
22	You can move to Slide 19 now.
23	MR. DeMOSS: Okay. With that, Pat
24	O'Reilly will take over.
25	MR. O'REILLY: All right.
ļ	I

(202) 234-4433

88 1 VICE CHAIRMAN SHACK: But what's your 2 conditional failure probability with eight plants 3 undergoing this trend? I mean you presumably have 4 that number, right? 5 MR. DeMOSS: The conditional probability for the eight plants, the final answers are from 40 to 6 7 the minus six to three times ten to the minus five. 8 MEMBER SIEBER: Per plant. 9 MR. DeMOSS: Per each plant. 10 MEMBER SIEBER: Right. MR. DeMOSS: And so they average about one 11 times ten to the minus five. 12 MEMBER SIEBER: Yes, multiplied by --13 14 MR. DeMOSS: If you care to multiply by 15 eight, which we don't have any guidance to do. 16 CHAIRMAN WALLIS: But it's just like ten. It's another factor. 17 18 Right. MR. DeMOSS: 19 CHAIRMAN WALLIS: Like e to the minus. 20 MR. DeMOSS: Right. 21 MEMBER SIEBER: Okay. Slide 19. 22 I'm here to give you MR. O'REILLY: Okay. 23 brief overview of the SPAR Model Development а 24 Program. The purpose of the program is to develop 25 PRA-based models which are used by staff analysts in

> NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

```
(202) 234-4433
```

	89
1	performing their risk-informed regulatory activities.
2	And to date the SPAR Model Development
3	Program consists of the following areas. We have
4	model development work going on in Level 1 in internal
5	events, modeling full-power operation in internal
6	events, modeling all-power shutdown operation in
7	internal events, excuse me, and in Level 1, modeling
8	external events which include fires, floods, and
9	seismic events, and so forth.
10	In the Level 2 area, to date we have
11	developed models in the Large Early Release Frequency,
12	or LERF category. Those models are deliberately
13	designed to be expanded at some later date to consider
14	full Level 2.
15	MEMBER ROSEN: On that slide
16	MR. O'REILLY: Yes?
17	MEMBER ROSEN: No. 19
18	MR. O'REILLY: Yes?
19	MEMBER ROSEN: you say you are working
20	on Level 1 external events? Are you including fire?
21	Are you re-quantifying the fire models along the lines
22	of the risk re-quantification work that's been done as
23	a joint project between EPRI and NRES? Do you
24	understand the question?
25	MR. O'REILLY: I understand the question.

(202) 234-4433

	90
1	The person is here I mean is not here that could
2	answer it with certainty.
3	But what we're doing in that particular
4	area is we're working in tandem with NRR and as NRR is
5	going around visiting plants to gather information for
6	their shutdown excuse me SDP process external
7	events phase, we're collecting information from the
8	licensee about their external events models, their
9	PRAs. And we're using that information.
10	Now if that same information is the basis
11	of
12	MEMBER ROSEN: What's going to happen now,
13	all plants have different fire models in their
14	relatively immature technology. The current SPAR
15	models have something in them for fire I assume as
16	well. Is that correct?
17	MR. O'REILLY: Only two.
18	MEMBER ROSEN: Only two of all the models
19	you have have fire?
20	MR. O'REILLY: Right. We consider fires
21	to be an external event.
22	MEMBER ROSEN: Right.
23	MR. O'REILLY: Right. So the Revision 3
24	SPAR models do not have fire in them.
25	MEMBER ROSEN: Oh, okay. So plants that
I	1

	91
1	have fire modeling have higher CDFs because they've
2	taken whatever the contribution is from fire and
3	included it and then you have.
4	MR. O'REILLY: Yes.
5	MEMBER ROSEN: Okay. Well
6	MR. O'REILLY: At the present time, we're
7	trying to
8	MEMBER ROSEN: You're about to get passed
9	by again. As the risk models are re-quantified on the
10	basis of the new work by the plants, which will
11	happen, not immediately but over time, then the Agency
12	needs to follow along and not get too far behind.
13	MR. CHEOK: I think I'd like to respond to
14	that. I don't think we're being passed by again. I
15	think we're trying to keep up. And I think we will
16	it's in our plans to incorporate external events,
17	LOCA, and shutdown models within the next two years.
18	MEMBER ROSEN: Okay. Do keep up.
19	MR. O'REILLY: As long as the budget
20	MEMBER ROSEN: We don't want to end up
21	back where we were before with the plants saying it's
22	not credible because they don't have external events.
23	MR. O'REILLY: Right. And we don't want
24	to be in that position either.
25	MEMBER ROSEN: Okay.
Į	I

(202) 234-4433

92 1 MR. O'REILLY: Okay. Next slide. In the area of internal events full power, we have the Level 2 3 1 Revision 3 SPAR models. And they consist of 72 4 plant-specific event tree-fault tree linked models analysts 5 that are used by the staff in their activities such as the significance determination 6 7 process. They're used in Phase 3 analyses in the 8 9 They're used by the analysts in the Accident SDP. 10 Sequence Precursor Program. And they're also used in generic safety issue resolution. And they're used in 11 12 other activities as well. VICE CHAIRMAN SHACK: Now what's a III 13 14 model? 15 MR. O'REILLY: The III, in that, Dr. Shack, the Is stood for Interim -- that meant that 16 17 that particular model had not received an onsite review against the licensee's PRA. We no longer have 18 19 any III models that are being used. They're all The set of Revision 3 models was 20 Revision 3. 21 completed in August of 2003. 22 Some recent accomplishments, well, one of 23 the discussions that has gone on here several times 24 has been the comparison of the SPAR models with the 25 licensee's PRAs. We have, as we said, we've reviewed

> NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433

93 1 every one of the 72 Revision 3 models against the 2 respective licensee's PRAs. We also conducted a pilot program within 3 4 the context of the Mitigating System Performance Index 5 Development Program in which we did a cut set level specific SPAR model the 6 review of the aqainst 7 licensee's PRA. And we identified the differences between the licensee's PRA and the SPAR model. 8 And we 9 ended up -- there's a presentation we gave at the NSRC last fall on the results of that specific review. 10 We've also gotten feedback from a lot of 11 our users, both the ASP analysts and the regional 12 office SRAs that are using the SPAR models in Phase 3 13 14 analyses in the SDP. As a result of all of this information, we 15 have identified a number of modeling issues which are 16 contributing to the differences between the licensee's 17 PRA results and the results obtained with the specific 18 19 SPAR model. We have prioritized these issues in the 20 order in which they impact that difference between the 21 two sets of results. 22 We have put together а program for 23 addressing the key significant issues that are driving 24 those differences. And we are embarking upon an 25 effort which most of them entail engaging the industry

> NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433

	94
1	at one level or another, be it industry-wide, be it
2	owner's groups, or some specific portion of the
3	industry, to try and reach agreement on these issues.
4	The agreement then would be factored back
5	into the specific SPAR models that are appropriate.
6	Yes?
7	MEMBER DENNING: Yes, I'd like to know
8	what you do with regards to uncertainty in modeling.
9	The thing that concerns me about what you're are doing
10	is I think that it is important that we do the
11	comparison with industry and see where the difference
12	is. And where it is clear that there is a preferred
13	method or values, to use those.
14	But I'm concerned that we artificially
15	drive a uniformity. We have a process in which the
16	industry models look just like the NRC models. And
17	they both have uncertainties that are being washed
18	under the rug.
19	And so the question is we not only have to
20	know that SPAR agrees with industry and that in
21	itself is not essential. I think the essential thing
22	is to know for our analyses of the SPAR model, how
23	uncertain are they.
24	MR. O'REILLY: We handle uncertainty in
25	the SPAR models in two ways. The first is parameter
I	I

(202) 234-4433

uncertainty. We have the capability and we are doing it now in the ASP analyses that we produce, to propagate the uncertainty in the equipment failure probability input value to the SPAR models as well as the capability to propagate the uncertainty in the human error probabilities that are used in the SPAR models.

8 In the issue of model uncertainty, that 9 becomes a little more problematic as you well know. 10 And in that particular case right now, we are 11 addressing that by performing sensitivity studies in 12 individual cases to see if we can get a handle on the 13 model uncertainty.

14 MEMBER DENNING: So in a typical 15 application, are you indeed running those uncertainty 16 analyses? Because all I tend to see are single-valued 17 results and I don't see the uncertainty bands on the results when I see what we use -- what we see when 18 19 we're looking at risk informing and this kind of 20 stuff.

21 In an application, do you run this 22 uncertainty?

23 MR. O'REILLY: We do that within the 24 context of the ASP Program, yes. I cannot speak for 25 the rest of the uses of the SPAR models right now.

> NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433

1

2

3

4

5

6

7

	96
1	I'd have to go check with all the users.
2	MEMBER ROSEN: Well, I saw error bands on
3	some of your charts. But typically if you're
4	reporting a number, say one e to the minus five for
5	some conditional core damage probability, would you
6	report that with a plus or minus, you know, along with
7	it?
8	MR. O'REILLY: Yes, we would in the ASP
9	Program, that's correct.
10	MR. CHEOK: In all our recent ASP
11	analysis, we report a mean value with uncertainty
12	bands so that's included.
13	MEMBER ROSEN: E value and what?
14	MR. CHOKSHI: Plus the uncertainty.
15	MEMBER ROSEN: I think on that other chart
16	that we saw, though, we saw sensitivity studies as
17	opposed to the uncertainty bins.
18	CHAIRMAN WALLIS: Yes. Plus or minus
19	would be dangerous because you might get negative
20	values because it's probably a low arrhythmic thing.
21	VICE CHAIRMAN SHACK: On the MSPI, you
22	know, we hear that the industry, in some cases, has
23	quality problems. Are these model quality that you're
24	getting different answers than they are for the MSPI
25	or are they QA problems that the documentation isn't
I	I

(202) 234-4433

	97
1	right?
2	MR. O'REILLY: Well, I don't have a lot of
3	time to go into the detail on how we did the review
4	during the MSPI Program but what we did do was a
5	series of calculations where we compared the SPAR
6	model as was against the licensee's PRA as it was, as
7	we were given the information at the cut set level.
8	We then looked at the differences. We
9	discussed with the licensee where the differences were
10	to see if we could get some idea of what was causing
11	the differences. Most of the time, it was due to
12	differences in input data, either for the equipment
13	failure probabilities or the human error probabilities
14	or both. And sometimes it was due to the treatment of
15	common cause failure probability.
16	What we did then was we went and took
17	make a change set using all of the licensee's data
18	input, ran that with the SPAR model. And most of the
19	time after we had determined that the response of the
20	plant had been modeled correctly, that's what we
21	wanted, we found that we had an absolute overlay with
22	the licensee's results.
23	Now, given that, we then went back and
24	determined how many of those input value assumptions
25	we could accept. Some of them were not consistent
I	I

(202) 234-4433

	98
1	with our licensing policy.
2	Because if we were to accept a specific
3	assumption within the context of the SPAR Model
4	Development Program, that would give the impression
5	that the Agency had approved that assumption. And in
6	some cases, we just could not do that.
7	So we essentially agreed to disagree in
8	those case. And that specific difference cause became
9	a modeling issue. So the answer to your question is
10	it is a mix. It really is.
11	But a lot of the differences that still
12	remain are due to modeling issues although from what
13	we have seen we just did a data update, which I'll
14	refer to in a few minutes, which has made a very stark
15	change in our basic results that may have taken away
16	some of those big issues.
17	MEMBER ROSEN: Modeling issue?
18	MR. O'REILLY: Yes.
19	MEMBER ROSEN: The stark change was that
20	the modeling issue delta
21	MR. O'REILLY: Yes.
22	MEMBER ROSEN: if I can call it that,
23	has narrowed?
24	MR. O'REILLY: Yes.
25	MEMBER ROSEN: Okay. Well, I expect that.
l	I

(202) 234-4433

	99
1	MR. O'REILLY: Yes.
2	MEMBER ROSEN: I mean unexpected and
3	the reason would be that you have better data of what
4	is in the plants. And what they're modeling.
5	MR. O'REILLY: Right.
б	MEMBER ROSEN: And they've been able to
7	justify that to you.
8	MR.O'REILLY: Right. Now right now we're
9	using industry average values because on a plant-
10	specific basis, there are a number of plants for which
11	there just isn't enough data to have much confidence
12	in.
13	MEMBER ROSEN: For failure rates, sure.
14	But I'm just talking about the one plant in 100 or 50
15	that happens to have a LOCA seal or RCP pump seal
16	injection system.
17	MR. O'REILLY: Okay.
18	MEMBER ROSEN: And you didn't have that in
19	your SPAR model, let's say.
20	MR. O'REILLY: Originally. Until we went
21	to the site.
22	MEMBER ROSEN: And then found out yes,
23	indeed, the plant has this seal injection system on
24	the RCP. See, we didn't know that.
25	MR. O'REILLY: Right.
Ĩ	I

	100
1	MEMBER ROSEN: Well, if you read the FSAR,
2	you would have know it but when you can go out in the
3	plant and kick the pump, but it's there so you model
4	it. So that's the difference.
5	MR. O'REILLY: That's correct.
6	MEMBER ROSEN: I mean those kinds of
7	things are just a question of maturation of the data
8	interchange.
9	MR. O'REILLY: Yes. Once we got the
10	modeling the fidelity of the model to the plant's
11	response, then it zeroed in on other issues now. And
12	that's where we are.
13	MEMBER BONACA: On failure data, what
14	you start with a generic database and then you look at
15	the significant differences? I mean the licensees,
16	many of them use plant specific.
17	MR. O'REILLY: That's correct. And what
18	we use in the model, the default values are industry
19	averages. But if you were performing an ASP analysis
20	of a condition or an event that occurred or was
21	discovered at a specific plant, then if the data
22	became an issue and the licensee had better data and
23	it was well supported technically, then we would use
24	that.
25	MEMBER BONACA: Okay.
ļ	I

(202) 234-4433

	101
1	MR. O'REILLY: That did not mean that we
2	would go back and use the default values in the SPAR
3	model. Don't get me wrong yet.
4	MEMBER BONACA: Okay.
5	MR. O'REILLY: We're still working on
6	where to go with that. That would be the ideal
7	situation if some day we could go there.
8	Okay. We also incorporated an improved
9	loss of outside power and station blackout module.
10	And we put in new reactor coolant pump seal LOCA
11	models for PWR models in the case of Combustion
12	Engineering and Westinghouse PWRs.
13	We updated the equipment failure data, the
14	initiating event frequency data, and the common cause
15	failure alpha factor data that are in the SPAR models
16	with more recent data.
17	We completed a cut set level review of six
18	models. That is in addition to the 11 plant models
19	that we had already done within the context of the
20	MSPI Program.
21	MEMBER ROSEN: Does that mean that you
22	check the truncation levels?
23	MR. O'REILLY: Absolutely.
24	MEMBER ROSEN: Is that what that bullet is
25	about?
ļ	1

(202) 234-4433

	102
1	MR. O'REILLY: Yes. We start out with a
2	minimum of 5,000 cut sets. And go to that level of
3	detail because we're trying to duplicate the MSPI. We
4	want to make sure that if we are estimating the MSPI
5	that we and the licensee are not going to have big
6	MEMBER ROSEN: Dropping off different
7	numbers of sequences.
8	MR. O'REILLY: Yes.
9	MEMBER ROSEN: Okay.
10	MR. O'REILLY: Future plans for the
11	Revision 3 SPAR models, and I want to recognize Mr.
12	Rosen's contribution in this because he jogged my
13	memory. First of all, we're going to complete
14	development of the set of enhanced Rev 3 SPAR models
15	by April of 2007.
16	And that's a two prong project. First is
17	to incorporate resolution of the significant key
18	modeling issues that we've described. And that's a
19	set of about ten issues.
20	There are probably 30 issues altogether
21	but some of them don't have much of a significant
22	impact on any models. But we've identified them as
23	reasons for the differences between the SPAR models
24	and the PRA results.
25	And we'll complete cut set level reviews
	1

(202) 234-4433

	103
1	for the rest of the 61 non-MSPI pilot program plants.
2	We also will prepare guidelines for using
3	the SPAR models in events analysis which are
4	consistent with the objectives of the Risk Assessment
5	Standardization Project or RASP that you've heard
6	about here.
7	And finally, we will establish a mechanism
8	for updating the SPAR models accordingly as licensees
9	update their plant PRAs. We thought we had something
10	in process earlier in the MSPI Development Program
11	whereby the industry had committed to provide us with
12	periodic notices of updates of their PRAs. And that
13	kind of fell through. So we're having to work another
14	avenue or two.
15	And you mentioned it brought it to my
16	mind. I wanted to bring that out. We will do that.
17	In the area of low power shutdown SPAR
18	models, we currently have 11 low power shutdown SPAR
19	models of which five have been through an onsite QA
20	review process to review the SPAR models against the
21	licensee's shutdown PRAs.
22	And we will continue to develop additional
23	models and to review the models onsite against the
24	respective licensee's PRA.
25	We'll issue the SPAR-H Methodology Report
	I

(202) 234-4433

	104
1	as a NUREG/CR. I believe we came to the Committee
2	last year and gave a presentation on that. It's been
3	through peer review. We had on the order of 100
4	comments.
5	And it's taken quite a while to get the
6	comments sorted out, and addressed, and resolved
7	appropriately. But sometime before the end of the
8	fiscal year, we should get that report published and
9	you will have a copy of it.
10	We also want to prepare guidelines for
11	performing risk analyses using the low power shutdown
12	SPAR models.
13	Events analysis capability, this is one
14	that you probably haven't had too much information
15	about up until now. The objective of this is to
16	develop models that are capable of estimating the risk
17	associated with external events initiators.
18	To date we have completed a feasibility
19	study which showed the technical and economic
20	feasibility of incorporating external events into the
21	existing Revision 3 SPAR models by simply expanding
22	them to include initiators that are external event
23	related.
24	We've completed an effort to incorporate
25	external events into the SPAR models for the Limerick
I	I

(202) 234-4433

	105
1	One and Two plant and the Salem Units One and Two
2	plant.
3	Our future plans include developing
4	external events models for all Rev 3 SPAR models and
5	preparing guidelines for performing analyses using
6	those models.
7	MEMBER ROSEN: I don't want to necessarily
8	complicate this.
9	MR. O'REILLY: Sure.
10	MEMBER ROSEN: But just a thought for you
11	to put in the back of your head is that someday you're
12	going to have to incorporate external events in low
13	power and shutdown models as well.
14	MR. O'REILLY: That one is one that is
15	giving us grief right now as we speak. Yes.
16	MEMBER ROSEN: If you want to stay up,
17	you're going to have to do that, too.
18	MR. O'REILLY: To put the LERF, it is not
19	a problem. It's the low-power shutdown one that's
20	MEMBER ROSEN: We could talk about it
21	later maybe.
22	MR. O'REILLY: Okay. Because we're open
23	to suggestions on that one.
24	MEMBER POWERS: Just a question. You
25	implied the industry is moving aggressively to make

(202) 234-4433

	106
1	their PRAs extremely comprehensive. And yet we can't
2	seem to get them to do this parameter uncertainty
3	analysis.
4	MEMBER ROSEN: Well, Dana, it's always a
5	case of some are moving aggressively to make their
6	PRAs comprehensive. And some can't spell PRA. It's
7	just a mixed bag. But if the Agency wants to keep up,
8	perhaps they could go to the places where they're
9	moving comprehensively and see what's being done more
10	aggressively.
11	MR. O'REILLY: That's where we've started.
12	MEMBER ROSEN: Yes.
13	MR. O'REILLY: Yes. In the area of LERF
14	SPAR models, there again the objective is to develop
15	analysis tools that allow us to perform risk
16	assessments involving LERF or Level 2 considerations.
17	We've completed the LERF SPAR models for
18	two lead plants. One is the Westinghouse PWR with
19	large dry containment. There the lead plant was
20	Comanche Peak.
21	And a SPAR model for BWR three or four
22	with a Mark One containment. There the lead plant was
23	Peach Bottom.
24	We're currently working on a third LERF
25	SPAR model for a Westinghouse PWR with an ice
I	1

(202) 234-4433

	107
1	condenser containment and Sequoyah is the lead plant
2	for that.
3	And that concludes the SPAR model part of
4	the presentation.
5	MEMBER KRESS: I presume these SPAR models
6	are containment, early failures.
7	MR. O'REILLY: Yes.
8	MEMBER KRESS: And don't include fission
9	products.
10	MR. O'REILLY: Oh, no. Not yet. That's
11	correct.
12	MEMBER KRESS: Well, do you have any plans
13	for doing a complete Level 2 that includes light
14	containment failure or all containment failure types
15	along with fission products?
16	MR. O'REILLY: As I mentioned I think when
17	I first started the presentation, the LERF SPAR models
18	are deliberately designed to be expanded at a later
19	date
20	MEMBER KRESS: Yes.
21	MR. O'REILLY: if the need comes to
22	have to model full Level 2 later releases. So the
23	answer is yes.
24	MEMBER KRESS: Well, you know, if you're
25	just looking at the plant fatality safety goal, the
I	

```
(202) 234-4433
```

	108
1	LERF that you're doing is adequate. But I don't think
2	that's a complete picture.
3	MR. O'REILLY: Nor do we.
4	MEMBER KRESS: So I would like to see you
5	think along the lines of a complete Level 2 at some
6	point.
7	MR. O'REILLY: Right. We attempted to get
8	that into the users need the first time around and it
9	didn't make it.
10	MEMBER KRESS: Right. Okay.
11	MR. O'REILLY: But we're ready and willing
12	to go that next step.
13	MEMBER KRESS: Would it be any help if the
14	ACRS wrote a letter?
15	MR. O'REILLY: It wouldn't hurt.
16	(Laughter.)
17	MEMBER APOSTOLAKIS: An ACRS letter that
18	would not hurt.
19	(Laughter.)
20	MEMBER SIEBER: Okay, I think we're ready
21	
22	MR. CHEOK: Okay, I'd like to wrap up our
23	discussions
24	MEMBER SIEBER: ready for the summary.
25	MR. CHEOK: Okay by just providing a
Ĩ	

	109
1	quick summary of the ASP and SPAR Programs and by
2	highlighting some upcoming activities.
3	I guess first of all, I'd like to say that
4	the ASP Program continues to be an important Agency
5	program used to evaluate significant operating events.
6	For example, the analysis of the event at
7	Wolf Creek and the analysis of the 2003 loss of
8	outside power events in the northeast U.S. provide
9	valuable and timely insights to guide further NRC
10	actions.
11	The ASP analyses have been used to support
12	AIT at plant sites. The most recent example is the
13	2003 loss of outside power event at Palo Verde for all
14	three units last June.
15	The ASP insights have also been used to
16	identify potential generic issue. For example, there
17	in D.C. Cook, we raised about 100 issues, the most
18	significant ones being the equipment qualification
19	issues, high energy line break issues, and the sump
20	issues.
21	So the ASP Program has evaluated
22	approximately 700 precursors. We maintain the
23	information on these precursors in our database.
24	This data is used in programs such as the
25	Regulatory Effectiveness Program. For example, NUREG-
Į	I

(202) 234-4433

	110
1	1784, published in 2003, provided insights into the
2	potential risk from grid events prior to the August
3	2003 events.
4	The next bullet basically says that we
5	provide results of the ASP Program to the
6	Commissioners in an annual SECY paper and to the
7	Congress in an annual Performance and Accountability
8	Report. This provides a historical documentation of
9	the events and provides measures of industry
10	performance. Both of these reports are available to
11	our stakeholders.
12	I guess last, as Dr. Apostolakis said
13	earlier, we do a good job performing ASP analysis but
14	we really do not do that good of a job using the
15	results and insights from these analyses. We are
16	currently initiating a task to do just this.
17	MEMBER APOSTOLAKIS: Well, yes, I mean I
18	wouldn't use the words you're not doing a good job.
19	I mean I think
20	MR. CHEOK: Well, we can do a better job.
21	MEMBER APOSTOLAKIS: we all need to
22	find a way
23	MR. CHEOK: We can do a better job.
24	MEMBER APOSTOLAKIS: to disseminate
25	information. I mean I would never think of
l	I

(202) 234-4433

	111
1	criticizing your job.
2	MR. CHEOK: Thank you.
3	MEMBER ROSEN: Well I think from listening
4	to this, you have come a world ahead of where you were
5	years ago.
6	MEMBER APOSTOLAKIS: It's one of the best
7	groups at the NRC.
8	MEMBER ROSEN: So I think, you know, you
9	should not be too bashful.
10	MEMBER APOSTOLAKIS: Well, Mike can't help
11	it. But the other guys
12	(Laughter.)
13	MR. CHEOK: So where do we go from here.
14	I think
15	MEMBER APOSTOLAKIS: You remember him from
16	1174, right?
17	MR. CHEOK: Yes, I was.
18	MEMBER SIEBER: Right.
19	MEMBER APOSTOLAKIS: An old horse.
20	MR. CHEOK: So where do we go from here?
21	I guess first and foremost, we need to improve on the
22	timeliness of ASP analysis. Dr. Wallis, among others,
23	have pointed out when they've seen our ASP trend
24	charts that the data only goes up to 2002.
25	We, I guess, for various reasons, for
	l

(202) 234-4433

example the modeling of complex issues like Davis-Besse, the including of new methods like uncertainty methods, we have fallen behind a little bit on our analysis. Our goal is to get back to providing you with an analysis within four to 12 months of the event happening.

7 We have a program in place for this catch 8 up and it is working. For example, for the Palo Verde 9 LOOP event in last June, we finished our analysis in 10 three weeks. And that analysis was used to support 11 AIT at the site.

The current status calls for us to finish FY '04 events by the fall of this year. So essentially we should be up to date by the end of this year.

The second bullet basically says that 16 17 using RASP initiatives, we'd like to interact more with the other programs in the Agency, the 18 SDP 19 programs and the MDA.3 programs. We believe that we 20 will achieve a lot better efficiencies performing 21 analysis in this way. However, the ASP Program will 22 continue to concentrate on potentially significant 23 events, those unique events, and those events that may 24 have generic importance so we continue to learn from 25 these events.

> NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

Finally, as we have said several times before, we will continue to look at the events in our ASP database to see if there are additional trends, insights, or lessons learned that would be useful for our Agency's processes.

6 Pat had mentioned many users of the SPAR 7 Program and the SDP Program, the ASP Program, GSI 8 Resolution. We use them to support reviews of our 9 risk-informed license amendments and we also use them 10 to support MSPI implementation.

Just recently there has been some talk, and Mr. Rosen raised this, of using licensee PRA models in place of SPAR models. Although there are some advantages of using the licensee models, we believe there are a lot of many advantages of using SPAR models.

First, the use of standardized models will 17 reduce the variability in the results. By this we 18 19 that when we have differing results mean from 20 different plant models, we can be confident that these 21 differences from plant-specific design are or 22 operational differences and not from differences in the use of HRA methods or seal LOCA models or 23 24 different assumptions.

So this feature is actually quite

NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433

25

important for the work we do, especially in things like GSI resolution, ASP and SDP analysis, and other applications.

4 Secondly, I think the use of a single 5 software package and common PRA model is efficient. When different analysts have to learn three or four 6 7 different licensee packages and when they have to learn to use the different nomenclature in these 8 9 packages, not to mention the different event treefault tree methods, for example Risk Man versus 10 Capital, this could lead to potential analyst errors. 11 12 The use of a single common software in models will tend to eliminate these kinds of errors. 13

And finally, as Mr. Sieber had said at the beginning, the use of SPAR models will provide an independent verification of the licensee risk evaluations and findings.

MEMBER BONACA: Well, I would a couple of additional considerations. One is that it seems to me that at some point, you will beyond the capabilities of some of the licensees in that you'll have models like shutdown of the power that they don't have.

And the other benefit that I see is that use of a single model allows you to begin to make comparisons among different results for different

> NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433

1

2

3

	115
1	plants which right now is very difficult to do.
2	MEMBER ROSEN: I suggested stopping the
3	SPAR model development years ago when the models were
4	not credible and you didn't have the kind of expertise
5	and effort that you've got going now. I no longer
6	support that earlier view that I had. I think this is
7	a better solution for the Agency what you're doing
8	now.
9	MR. CHEOK: Thank you.
10	MEMBER SIEBER: Well, if you do make a
11	mistake, it's consistent.
12	(Laughter.)
13	MR. CHEOK: That's true.
14	MEMBER ROSEN: It's still, you know,
15	important and valid to go to the plants and check what
16	you're getting out of your SPAR model because you
17	might still learn something. But then again, so might
18	the plant. And that's a good thing, too.
19	MR. CHEOK: We totally agree with that.
20	I think we learn things when we go to the plant. And
21	the licensees learn things when we come to the plant.
22	A recent example is when the licensees
23	update their models when we show them what we have in
24	the SPAR models so it is mutually beneficial.
25	MEMBER ROSEN: It's a two-way street.
I	I

(202) 234-4433

116 1 It's the best of all possible worlds. It's a win-win 2 situation. So what are the steps forward 3 MR. CHEOK: 4 for the SPAR Program, as Pat said, we would like to 5 complete all Revision 3 enhancement by next year. We would like to increase the scope of our analysis so 6 7 that we can provide tools to enhance Agency riskinformed decision-making. This is consistent with the 8 9 Reg Guide 1.174 philosophy. We would like to enhance user friendliness 10 of our models and software. We will continue to 11 12 interact with our analysts in the regions and in NRR for the SPAR model users group to get feedback as to 13 14 where these improvements need to be. And we will 15 continue to train our regional NRR analysts in the use of SPAR models. 16 17 Finally, over the next few years, we would like to perform a peer review of the SPAR models 18 19 against industry PRA standards. As with all PRA 20 quality initiatives, we will have to keep the intended 21 users of the SPAR models in mind during this peer 22 review process. 23 MEMBER ROSEN: And when you do the peer 24 review process, you are going to get facts and 25 observations and correct the SPAR models I presume?

> NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433

	117
1	You'll go the whole way?
2	MR. CHEOK: We will get lessons learned as
3	to how we can improve the models, that's correct.
4	MEMBER ROSEN: You won't just do it as an
5	exercise. You'll do it to do just what the utilities
6	are doing. Go through the certification. Get the
7	facts and observations. Categorize them. And go and
8	improve the models.
9	MR. CHEOK: I'm not sure. This process
10	has not been clear yet.
11	MEMBER ROSEN: Well, I would recommend
12	MR. CHEOK: I'm not sure what the process
13	will do but we will do a similar process.
14	MEMBER ROSEN: I would recommend that you
15	not enter this as an exercise in an academic you
16	need to enter it as an exercise in improvement.
17	CHAIRMAN WALLIS: What was the word
18	academic used for in that context?
19	(Laughter.)
20	MEMBER APOSTOLAKIS: Exercises in academia
21	are taken very seriously.
22	MEMBER ROSEN: Which has to do with not
23	doing anything with the result except publishing and
24	putting on the shelf.
25	MR. O'REILLY: Oh, no. We
	I

(202) 234-4433

	118
1	MEMBER ROSEN: You need to fix the models
2	if you find things wrong with them.
3	MR. O'REILLY: that's what actually
4	we've had this performed once already. And we got a
5	lot of good information out of that. And we have
6	improved that particular SPAR model as a result of
7	that review.
8	MEMBER ROSEN: The process inherently uses
9	peer review which means that you might even use some
10	people from the industry to help you.
11	MR. O'REILLY: That's exactly what we did.
12	CHAIRMAN WALLIS: As long as they're up to
13	academic standards.
14	MEMBER ROSEN: As long as they're
15	academically superior. And non-academic in terms of
16	the use of it.
17	MR. O'REILLY: Well, they had been the
18	team leader on a couple of the peer reviews from the
19	industry, yes.
20	MEMBER SIEBER: I presume that concludes
21	your presentation?
22	MEMBER DENNING: Now, we
23	MEMBER SIEBER: Go ahead, I'm sorry.
24	MEMBER DENNING: Well, right now we did
25	not have a plan to write a letter.
	I

	119
1	MEMBER SIEBER: That's right.
2	MEMBER DENNING: But we could decide to do
3	that, I guess, if we discuss that later.
4	MEMBER SIEBER: We could.
5	MEMBER DENNING: Will they come what's
6	the periodicity with which we hear this program? I
7	certainly thought it would be
8	MEMBER SIEBER: Just about every year.
9	MEMBER DENNING: annual at least.
10	MEMBER SIEBER: It's about every year.
11	MEMBER DENNING: Yes, okay.
12	MEMBER SIEBER: We had a similar
13	presentation last year.
14	MEMBER APOSTOLAKIS: We have a
15	subcommittee as you know, we are reviewing the
16	research quality of various activities. And one of
17	them is SPAR. And there is a subcommittee that oh,
18	you are fully aware of it.
19	PARTICIPANT: Oh, definitely, yes.
20	MEMBER APOSTOLAKIS: We probably need a
21	subcommittee meeting. So sometime in the June, early
22	July frame, the subcommittee is Mario Bonaca, Rich
23	Denning, and me.
24	Others are welcome to come, of course, but
25	the three of us will probably be there for sure. So
ļ	I

(202) 234-4433

	120
1	don't be surprised if we do that.
2	MEMBER ROSEN: Dana, as an aside, are we
3	moving ahead with those efforts? Where do we stand?
4	MEMBER POWERS: Well, George has
5	everything he needs, I think, right?
6	MEMBER APOSTOLAKIS: I got a big binder.
7	I'm going
8	MEMBER POWERS: I have now the materials
9	for the thermalhydraulics for Mr. Wallis.
10	I have for the Steam Generator for Mr.
11	Sieber.
12	MEMBER SIEBER: Yes.
13	MEMBER POWERS: The containment capacity
14	for Dr. Shack.
15	And I think we'll probably discuss those
16	at P&P?
17	MEMBER APOSTOLAKIS: Very good.
18	MEMBER SIEBER: Okay. Any further
19	questions from Members?
20	(No response.)
21	MEMBER SIEBER: I'm impressed with the
22	presentation. And I'm glad that you made an effort to
23	make the presentation schedule with us. And we'll be
24	interested in keeping track of your progress. And
25	with that, Mr. Chairman, I'll turn the meeting back to
I	

```
(202) 234-4433
```

	121
1	you.
2	CHAIRMAN WALLIS: Thank you very much.
3	Thank you for your presentation.
4	We will now take a break, 15 minutes. And
5	I don't think we need the Reporter any more. Thank
6	you very much the transcript. We'll take a break
7	until five minutes before eleven.
8	(Whereupon, the above-entitled meeting was
9	concluded at 10:42 a.m.)
10	
11	
12	
13	
14	
15	
16	
17	
18	
19	
20	
21	
22	
23	
24	
25	
	I I