Official Transcript of Proceedings

NUCLEAR REGULATORY COMMISSION

## Title: Advisory Committee on Reactor Safeguards 541st Meeting

Docket Number: (not applicable)

Location: Rockville, Maryland

Date: Thursday, April 5, 2007

Work Order No.: NRC-1514

Pages 1-297

NEAL R. GROSS AND CO., INC. Court Reporters and Transcribers 1323 Rhode Island Avenue, N.W. Washington, D.C. 20005 (202) 234-4433

		1
1	UNITED STATES OF AMERICA	
2	NUCLEAR REGULATORY COMMISSION	
3	+ + + + +	
4	ADVISORY COMMITTEE ON REACTOR SAFEGUARDS (ACRS)	
5	541 <sup>st</sup> MEETING	
6	+ + + + +	
7	THURSDAY,	
8	APRIL 5, 2007	
9	+ + + + +	
10	The meeting was convened in Room T-2B3	
11	of Two White Flint North, 11545 Rockville Pike,	
12	Rockville, Maryland, at 8:30 a.m., Dr. William A.	
13	Shack, Chairman, presiding.	
14	MEMBERS PRESENT:	
15	WILLIAM A. SHACK Chairman	
16	GRAHAM B. WALLIS Vice Chairman	
17	SAID ABDEL-KHALIK ACRS Member	
18	GEORGE E. APOSTOLAKIS ACRS Member	
19	J. SAM ARMIJO ACRS Member	
20	MARIO V. BONACA ACRS Member	
21	MICHAEL CORRADINI ACRS Member	
22	THOMAS S. KRESS ACRS Member	
23	OTTO L. MAYNARD ACRS Member	
24	DANA A. POWERS ACRS Member	
25		

1	NRC STAFF PRESENT:
2	JOHN MONNINGER
3	ERASMIA LOIS
4	GARETH PERRY
5	ANTHONY MENDIOLA
6	PAUL CLIFFORD
7	RALPH LANDRY
8	SHI-LIANG WU
9	HAROLD SCOTT
10	BOB TJADER
11	ANDREW HOWE
12	MARK RUBIN
13	DONNIE HARRISON
14	
15	ALSO PRESENT:
16	JOHN FORESTER
17	JEFF JULIUS
18	ROBERT MONTGOMERY
19	ODELLI OZER
20	BIFF BRADLEY
21	SCOTT HEAD
22	RICK GRANTOM
23	
24	
25	
I	1

	3
1	AGENDA
2	OPENING REMARKS BY THE ACRS CHAIRMAN 4
3	HUMAN RELIABILITY ANALYSIS MODELS
4	BREAK
5	PROPOSED REVISIONS TO STANDARD REVIEW PLAN (SRP)
б	SECTION 4.2 REACTOR FUELS
7	LUNCH
8	RISK-MANAGEMENT TECHNICAL SPECIFICATION INITIATIVE
9	4b-
10	FLEXIBLE COMPLETION TIMES
11	BREAK
12	ACRS REPORT ON THE NRC SAFETY RESEARCH PROGRAM
13	SUBCOMMITTEE REPORT
14	BREAK
15	PREPARATION OF ACRS REPORTS
16	
17	
18	
19	
20	
21	
22	
23	
24	
25	
	I

	4
1	P-R-O-C-E-E-D-I-N-G-S
2	(8:33 a.m.)
3	CHAIRMAN SHACK: The meeting will now come
4	to order. This is the first day of the 541 <sup>st</sup> Meeting
5	of the Advisory Committee on Reactor Safeguards.
6	During today's meeting, the committee will consider
7	the following; Human Reliability Analysis Models,
8	Proposed Revisions to the Standard Review Plan (SRP)
9	Section 4.2 Reactor Fuels, Risk Management Technical
10	Specification Initiative 4b Flexible Completion Times,
11	Format, Content, and Assignments for ACRS report on
12	the Safety Research Program, Subcommittee report on
13	the Interim Review of the License Renewal Application
14	for the Pilgrim Nuclear Plant, and preparation of ACRS
15	reports.
16	This meeting is being conducted in
17	accordance with the provisions of the Federal Advisory
18	Committee Act. Mr. Sam Duraiswamy is the Designed
19	Federal Official for the initial portion of the
20	meeting. We have received no written comments or
21	requests for time to make oral statements from members
22	of the public regarding today's session. A transcript
23	of portions of the meeting is being kept, and it is
24	requested that the speakers use one of the
25	microphones, identify themselves, and speak with
	I

(202) 234-4433

5 1 sufficient clarity and volume so they can be readily 2 heard. interest. 3 Begin with some items in 4 Members are scheduled to interview two candidates 5 during lunchtime today, and I hope you all have the the schedules that give 6 packets and you that 7 information, and where you'll be. It'll be in the 8 subcommittee room, in the caucus room. 9 If you look under your items of interest, the pink package, you'll see a number of speeches 10 11 there from the commissioners at the RIC. It's a good 12 way to review some of the high-level presentation You may also be interested in looking further 13 there. 14 into the package. There's an Op-Ed about the ACRS 15 interactions with Oyster Creek, and the interactions with the State of New Jersey on that that could be of 16 17 interest. 18 Our first item today is on Human 19 Reliability Analysis Models, and George will be leading that discussion. 20 21 DR. APOSTOLAKIS: Thank you, Bill. We met with the Commission on October 20<sup>th</sup> 22 23 of last year, and during the discussion the issue of 24 -- several comments were made on Human Reliability; in

particular, that there are several models that this

NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433

25

1 agency has, plus there are models that the industry 2 has developed. And following that, we received Staff 3 Requirements Memorandum on November 28 of 2006, in 4 which the Commission directed the ACRS to work with the staff and external stakeholders to evaluate the 5 different Human Reliability models in an effort to 6 7 propose either a single model for the agency to use, 8 or quidance on which models should be used in specific 9 circumstances.

Following that, we had a subcommittee 10 meeting, the Subcommittee Reliability 11 on and 12 Probabilistic Risk Assessment. We met with staff and representatives of EPRI and the industry on March 13 14  $22^{nd}$ , 2007, and we discussed briefly the models, and some of the assumptions behind these models, and the 15 differences. And the staff also presented to us their 16 17 plans to organize a benchmark exercise in Halden, It was a very constructive meeting, in my 18 Norway. 19 We sensed that there is willingness on the opinion. 20 part of both the staff and EPRI to work together, 21 which is very good. There are some administrative 22 issues that have to be resolved, and maybe the staff 23 will address those today, so things are looking good. 24 There may be a plan soon to address the 25 Commission's request, and without any further comments

> NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433

(202) 234-4433

	7
1	on my part, I will turn it over to Dr. Lois from the
2	staff, or Mr. Monninger. Okay. I understand we have
3	at least one person, and possibly three on the
4	telephone. Right? John Forester, you're there?
5	MR. FORESTER: Yes, I am. Good morning.
б	DR. APOSTOLAKIS: Is Jeff Julius there?
7	MR. JULIUS: Yes, I am. Good morning.
8	DR. APOSTOLAKIS: Okay. Scientech
9	representing EPRI. Did I say that correctly, Jeff?
10	MR. JULIUS: That's correct.
11	DR. APOSTOLAKIS: Okay. And Susan Cooper?
12	She is not. Okay. John.
13	MR. MONNINGER: Thank you, Professor
14	Apostolakis. My name is John Monninger. I'm the
15	Deputy Director for Probabilistic Risk in Applications
16	from the NRC's Office of Nuclear Regulatory Research.
17	I want to thank you very much for allowing us this
18	opportunity to address the ACRS once again on the
19	NRC's Human Reliability Analysis program. With me, I
20	have Dr. Gareth Perry of the Office of Nuclear Reactor
21	Regulation.
22	One of the things I think is very
23	important as we undertake this potential new project
24	or effort is these interactions that we do have with
25	the ACRS and external stakeholders. It's very
ļ	I

(202) 234-4433

(202) 234-4433

important for us to understand the issues out there, the context behind the issues so that we can undertake any new projects with a full appreciation, and develop an approach forward to address those issues, as opposed to undertaking a project and briefing the ACRS when we're halfway through, whatever. I think these meetings are very beneficial and important to the staff.

9 Over the past year, we've been down here probably four, five, six different times discussing 10 the NRC's HRA program with the ACRS. We've had 11 discussions on our Good Practices, our beliefs on what 12 some HRA Good Practices are out there, and we issued 13 14 a NUREG last year or so. We've discussed the various HRA methods out there, and evaluation of those HRA 15 16 methods against the Good Practices.

Also, we've had some discussions on our 17 international benchmarking project, which you will 18 19 also hear some more about this morning from Dr. Lois. 20 And, also, we've been down to discuss our project on 21 allowing some type of credit for manual fire actions, 22 and we're also coming back to the ACRS in a month or 23 two to discuss resolution of public comments. 24 That's pretty much all I wanted to say,

but I just want to say, these meetings are extremely

NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433

25

1

2

3

4

5

6

7

8

1 important for the staff as we undertake the beginning 2 or the initiation of a new project to make sure that 3 we have a full understanding and appreciation as to 4 where the ACRS interests and concerns are. And we 5 then take them into consideration in development of our project. So with that, I'll turn it over to Dr. 6 7 Erasmia Lois. 8 DR. LOIS: Thank you. My name is Erasmia 9 Lois, working for the Probabilistic Risk Assessment Directorate of the Office of Research. 10 I guess the context of the meeting has 11 12 been defined by Dr. Apostolakis and John Monninger. And, also, what is the issue, also Dr. Apostolakis 13 14 described it, and probably I shouldn't spend any time here. What I would like to note is that the NRC's 15 action plan for stabilizing the PRA quality raises, in 16 general, the issue of PRA quality and addressing the 17 uncertainties with the PRA, and HRA is one aspect. 18 19 And, therefore, the staff started working on the issue 20 addressing uncertainties since six, seven years ago. 21 We continue to -- we haven't addressed all of the 22 issues, but we believe that we've done tremendous 23 addressing progress and minimizing the in 24 uncertainties that are produced as a result of --25 DR. WALLIS: Not just the uncertainties.

> NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433

(202) 234-4433

	10
1	I mean, HRA contributes to the mean, as well,
2	contributes to the PRA itself.
3	DR. LOIS: Absolutely.
4	DR. WALLIS: It's not just the
5	uncertainties. It's an important part of the PRA, and
6	the mean values, or the best estimate values, or
7	whatever you want to call them.
8	DR. LOIS: And it just depends on how you
9	interpret the word "uncertainties", at least in my
10	mind with regard to that.
11	DR. WALLIS: Without the uncertainties,
12	it's an important contributor.
13	DR. APOSTOLAKIS: I think you're saying
14	the same thing. But, Erasmia, I think the issue
15	really is with models that deal with human actions
16	during accidents. For routine actions, I don't think
17	the issue is that great, test and maintenance, and all
18	that. I mean, most people use the Swain and Guttman.
19	DR. LOIS: And they are happy with it.
20	DR. APOSTOLAKIS: And they are happy with
21	it, so really, the focus here is there is a LOCA,
22	there is a transient, and operators do things. That's
23	where the models differ. Okay? And this is really a
24	very difficult issue to handle.
25	DR. LOIS: So what I'm going to do quickly
ļ	I

(202) 234-4433

1 is to summarize some of the efforts that the staff has 2 done so far to address the issue of HRA contribution to risk assessment and reliability of HRA results. 3 Ι 4 will very quickly provide a very high-level summary of 5 the technical basis of our methods that are primarily used today for regulatory applications. 6 I note that 7 many more methods than those noted here, many of those used to be used in PRAs, but lately, probably the ones 8 9 that I am noting are the ones that are showing up in 10 regulatory applications. Ι

will summarize the observations 11 12 regarding the HRA methods. I will provide the status these international collaborative efforts 13 of to 14 perform an empirical study on HRA methods, and then 15 propose a plan for addressing the SRM. In the meantime, Jeff Julius from Scientech representing EPRI 16 17 will also have a talk in two instances, one, to summarize the calculator, and another to present a 18 19 plan that he proposed during the subcommittee meeting, 20 and which we believe it's a good way to go forward. 21 Quickly, we briefed the committee, the PRA 22 status, especially the ASME PRA status is an effort 23 that addresses PRA quality, in general, and the HRA, 24 in particular. After the ASME status, we developed

more detailed guidance, the HRA Good Practices,

NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433

25

(202) 234-4433

1 evaluated the various methods against the practices. 2 We have an effort here to develop data that will help 3 to improve our assessment of human reliability using 4 field data or simulator data in a more objective way. 5 We are going to publish a user guide for the ATHEANA method, which is a method that was developed by the 6 7 NRC lately, and it hasn't been used as much. But all of these efforts that I'm noting here gave us the 8 opportunity to have significant interactions with the 9 ACRS and other stakeholders. 10

In particular, we involved domestic and 11 12 international expertise in human reliability and in human performance. We supported the Halden reactor 13 14 project that has experience on how to perform 15 simulator experiment to assess human performance. That experience was used primarily from human factors 16 17 engineering purposes during the last three, four years with our strong interactions through a visit exchange 18 19 and staff exchange, et cetera. Halden took off and 20 started doing research focusing on human reliability 21 analysis. We believe this is a very important effort, 22 because it gives us the opportunity to interact 23 collaboratively with international entities without 24 actually paying additional money than what we do as 25 part of our regular support of Halden reactor project.

> NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433

(202) 234-4433

ĺ	13
1	Also, I'm noting that every time that we
2	have international meetings, or even domestic
3	meetings, we take the opportunity to have meetings on
4	HRA and how we could move forward to address the
5	issues that SRM asked us today to do.
6	DR. APOSTOLAKIS: All right. Let me ask
7	something here. Is the policy an approach of the
8	three phases that the Commission issued some time ago
9	that by the end of December of 2008 or something, the
10	agency is supposed to have standards, or consensus
11	documents for the PRA applications. Does this include
12	human reliability? Is that something we have
13	forgotten? Should we try to develop a consensus
14	document so that the applicants can use this? How is
15	that working now?
16	MR. PERRY: Okay. This is Gareth Perry
17	from NRR. What the Commission's phased approach for
18	the plan to deal with the Commission's phased approach
19	states is that by December 31 <sup>st</sup> , 2008, the standards
20	for PRAs for various contributors, internal events,
21	external events, fires, low power and shutdown should
22	have been published and endorsed by the staff. And,
23	also, guidance for performing the various applications
24	that are envisaged should also be endorsed.
25	It doesn't go as far as to say that there

(202) 234-4433

should be documents on the how-to aspects of the performance of the PRA, and it doesn't address whether we should have clear guidance on how to do HRA, for example. Although, clearly, there was an element of the phased approach that said that some work should be done in that regard, but it's not as crisp as it is in relation to the standards.

8 DR. APOSTOLAKIS: But I thought the whole 9 idea was that we would have documents that would 10 advise or quide both the industry and us as to what is expected, or the minimum expectations when it comes to 11 uncertainty analysis, and so on. 12 And that should That would make -- in fact, I remember 13 include HRA. 14 there was a sentence there that if the industry or an 15 application didn't follow these consensus documents, the staff would give it very low priority. 16 I think 17 the ACRS objected. But, anyway, the argument was that you really have to have those, so I don't understand 18 19 why HRA is not included.

20 MR. PERRY: No, HRA is not not included. 21 There have to be methods -- the standards are going to 22 allow for flexibility in the choice of methods. 23 DR. APOSTOLAKIS: Sure. 24 MR. PERRY: But what all the guidance 25 documents do, is they state that you have to address

> NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433

1

2

3

4

5

6

7

1 the uncertainties associated with a choice of specific 2 methods. So what I think you'll find is that in all quidance 3 the documents there will be specific 4 reference to addressing uncertainties. And, 5 typically, HRA is included as one of the things where uncertainties really need to be singled out as a 6 7 specific item in recognition of the fact that there 8 are a number of different methods that give 9 different --10 DR. APOSTOLAKIS: That's not my understanding. I mean, yes, I understand that you 11 12 have to state the uncertainties, but I thought these documents would go beyond that. Like the standards, 13 14 for example, the ASME standard, it doesn't tell you 15 exactly how to do it. 16 MR. PERRY: Right. 17 DR. APOSTOLAKIS: But it gives you some requirements, you have to --18 19 MR. PERRY: Right. And those requirements 20 \_ \_ Why shouldn't there be 21 DR. APOSTOLAKIS: 22 a document on HRA that does a similar thing? That's 23 what I'm saying. Well, the standard has a 24 MR. PERRY: 25 section on HRA that says what attributes the HRA has

> NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433

(202) 234-4433

	16
1	to meet to meet the standard. It doesn't say how to
2	meet it.
3	DR. APOSTOLAKIS: I know, and it doesn't
4	do that in any other area either.
5	MR. PERRY: Right. Exactly.
б	DR. APOSTOLAKIS: But isn't the idea of a
7	phased approach that by the end of 2008, there will be
8	a set of documents there that would facilitate the
9	whole approach to risk-informing the regulations, in
10	the sense that if you follow the guidance, the review
11	is facilitated, the whole thing.
12	MR. PERRY: Right.
13	DR. APOSTOLAKIS: So there are no plans to
14	develop such a document for HRA. That's really where
15	we are.
16	MR. PERRY: Well, to the extent that I
17	think the Good Practices document, and the evaluation
18	of the methods against the Good Practices at least
19	give guidance on what the capabilities of the various
20	quantification methods are, and their limitations. I
21	think the Office of Research has actually done a very
22	useful task in that area, because I think that has to
23	be incorporated into the decision making.
24	DR. APOSTOLAKIS: But as a result of this
25	cooperation that we're talking about, shouldn't there
	I

(202) 234-4433

be some NUREG somewhere at some time, answering the SRM and saying for this class of problems, this is a good model. And why shouldn't that be part of the phased approach?

5 DR. LOIS: So we believe that we are going 6 to revise the methods evaluation document out of this 7 exercise in terms that we're going to have a better 8 understanding of the methods, and, therefore, the 9 limitations and strengths, and, therefore, suitability 10 for addressing --

MR. MONNINGER: I think it's -- we had 11 12 intended the Good Practices, the methods always evaluation, the benchmarking project, all those to be 13 14 supportive of the NRC's reviews and industry's efforts 15 to proceed to risk-informed regulation. I think the notion is the explicit timing, what has been committed 16 to in terms of December 2008. 17

We clearly view these projects as being 18 19 supportive of that, but whether explicitly we 20 committed to complete the benchmarking project or this project here by 2008, I think that's -- the notion was 21 22 to get the standards out there, to have the standards 23 endorsed by NRC through the Reg Guides, and then 24 develop additional how-to methods. But those how-to 25 methods, I don't believe are as tied to the December

> NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433

	18
1	2008. I mean, even after this, for years and years to
2	come we will continue to pursue additional research
3	and development in the PRA area, so I think
4	MR. PERRY: And to be realistic, I think
5	that you know how long we've been developing HRA
6	methods. I don't think you're going to have consensus
7	in the next year.
8	DR. APOSTOLAKIS: We have to reach closure
9	soon. The thinking is that I really was under the
10	impression that by the end of 2008, there would be a
11	set of guidance documents out there that would
12	facilitate this process.
13	MR. PERRY: And I think that's true, but
14	the guidance will be what it will be, and I think it
15	has to you have to I think what we'll have to do
16	is take into account what we can glean from those
17	documents, and make the decisions, as appropriate.
18	And if it means that we're having to be a little more
19	careful with certain areas, like HRA and perform more
20	sensitivity studies, then that's what we will do to
21	reach the appropriate decision. We need to understand
22	where the weaknesses of the methods are, primarily,
23	and then to come
24	DR. APOSTOLAKIS: Well, I was hoping this
25	collaboration would do that.
I	

(202) 234-4433

	19
1	MR. PERRY: Yes, and I think to some
2	extent the Good Practices document has already done
3	that.
4	DR. APOSTOLAKIS: No, I disagree with
5	that. Let's go on. The Good Practices does the usual
б	thing. This method has good aspects, this method also
7	has bad aspects.
8	MR. PERRY: It states what
9	DR. APOSTOLAKIS: If I'm a reviewer, I
10	have no idea what to do with that.
11	MR. PERRY: It states what they are.
12	DR. APOSTOLAKIS: It states what they are,
13	yes. That's nothing
14	DR. LOIS: This summary table of two
15	pages, it's not very readable over here, but you do
16	have a copy of the table. And the purpose of this
17	table is to quickly show that methods were developed
18	over the years for different purposes. I started out
19	with what we call THERP method, which was developed
20	after WASH-1400 and it was the first method, HRA
21	method developed, recognizing the need for a detailed
22	evaluation of human performance in a PRA. THERP
23	proved to be resource intensive, and I guess for the
24	purposes of NUREG-1150, we developed ASEP, which is a
25	high-level, more conservative screening tool.
I	I

(202) 234-4433

1 The industry and EPRI developed at the 2 same time the HCR/ORE method, whose objective was to 3 address some of the limitations that THERP had, 4 provide a more objective way to calculate the human 5 error probabilities on the basis of time availability curves, and at the same time, developed what we call 6 7 the course-based decision tree method that would 8 supplement the HCR/ORE for those human actions that 9 would need -- would have many long times available to 10 perform those. SPAR-H was developed, started out from a 11 12 need to have a high-level, guick HRA tool to perform precursor analysis. And then as the SPAR bundles were 13 14 developed and becoming more and more detailed, I guess 15 human reliability aspect was becoming the more detailed. And usually today it's been used in the 16 17 ASEP program, as well as the SDP program. ATHEANA is the method that has been developed lastly, and it's 18 the one that was developed out of the need to address 19 20 real events, observations that we've seen, such as 21 TMI, et cetera, the need to address our error of 22 and become more realistic, commissions, and the 23 capability to do more realistic analysis for the kinds of human actions that we're bundling in probabilistic 24 25 risk assessments.

> NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433

(202) 234-4433

	21
1	Therefore, these methods have different
2	scope. And what I have here, under attributes doesn't
3	mean that all of these are some attributes are
4	good, some are not, as I'm going to go to the next
5	page. But this is a way to demonstrate how different
6	the methods are, do every method provides if you
7	look at the very last row here, all methods are
8	quantification tools. That's the bottom line, and
9	that's the common characteristics.
10	Now, some methods provide guidance on how
11	to identify, to incorporate the human error events in
12	the PRA, helps you to provides guidance on how to
13	really explore what's going on, and understanding why
14	people are making mistakes.
15	DR. WALLIS: Erasmia, could you review for
16	me what the output of all this is? I mean, the
17	purpose of all this is presumably when you have a
18	situation in the control room as they had at TMI at
19	various times, operators do things. Do all of these
20	methods predict what the operators are going to do?
21	DR. LOIS: Yes.
22	DR. WALLIS: They do?
23	DR. LOIS: Yes. That's the purpose.
24	DR. APOSTOLAKIS: To various degrees,
25	though.
I	I

(202) 234-4433

	22
1	DR. WALLIS: To various degrees.
2	DR. APOSTOLAKIS: I think SHARP and
3	ATHEANA do a better job searching.
4	DR. LOIS: It is to various degrees. The
5	scope of these methods is different. Some of those
6	are high-level, some of those are more detailed
7	analysis. Also, they get there through different
8	algorithms, but that's what they are. Mainly,
9	quantification tools, some provide guidance on how to
10	incorporate your HFE with a PRA, or how to search to
11	understand why different why people may make
12	DR. WALLIS: Well, guidance isn't a
13	formula. I'm surprised. I think they have to be
14	formulae for calculating.
15	DR. LOIS: Yes, they do. They have
16	DR. WALLIS: So guidance is more than just
17	guidance. It's actually a method, it's a methodology.
18	It's not just guidance.
19	DR. APOSTOLAKIS: I think the SHARP, what
20	Erasmia calls SHARP under the EPRI approach, and the
21	ATHEANA, they do an excellent job looking at the
22	sequences and trying to understand
23	DR. WALLIS: They give you a methodology
24	for doing it.
25	DR. APOSTOLAKIS: The deviation
I	

(202) 234-4433

	23
1	DR. WALLIS: It's very, very vague to me.
2	DR. LOIS: SHARP is like the Good
3	Practices.
4	DR. APOSTOLAKIS: Well, it's a method for
5	finding
6	DR. LOIS: It's a Good Practices
7	DR. APOSTOLAKIS: Yes, but these two
8	methods, I think, spend considerable amount of time
9	trying to understand the sequences, and what possible
10	actions the operators might take, which is really the
11	hard part. Then they differ on the quantification.
12	DR. LOIS: All of these methods have
13	different algorithms, or they have guidance. Yes, it
14	is guidance in a way, because if you look at THERP,
15	THERP guides you to develop to do what it's called
16	task analysis, to find out what it would take to
17	accomplish that, and then gives you generic gives
18	you tables where you can go and pick up numbers, and
19	then modify the numbers on the basis of some
20	performance
21	DR. WALLIS: If I gave ten students a
22	problem, they'd all come up with the same answer?
23	DR. APOSTOLAKIS: No.
24	DR. LOIS: May not. We haven't tested.
25	DR. APOSTOLAKIS: Yes. That's one of the
	I

(202) 234-4433

	24
1	things they're going to test.
2	DR. LOIS: We haven't done enough
3	validation.
4	DR. APOSTOLAKIS: You remember that table
5	from the ISPRA exercise of 25 years ago.
6	DR. WALLIS: It didn't work.
7	DR. APOSTOLAKIS: That was all over the
8	place. Hopefully, this time it won't be like that.
9	CHAIRMAN SHACK: Well, but there's two
10	sources of there's the question if you had a single
11	method and people applied it, you get one set of
12	answers. If you have multiple methods, you get
13	DR. APOSTOLAKIS: The same people using
14	different methods get uncertainties, and then the same
15	method used by different people gives also it's
16	really a very disturbing result, so hopefully these
17	guys are going to do a better job.
18	DR. LOIS: I don't know. Shall I
19	DR. APOSTOLAKIS: There's one issue here
20	that I would like to raise, because I'm not sure
21	you're addressing it explicitly. From reading the
22	EPRI calculator methods and so on in the ATHEANA, it
23	seems to me that an issue is the following. EPRI in
24	its approach really emphasized the issue of how do we
25	develop a method that can be used at least in routine
I	1

(202) 234-4433

1 applications by a lot of people who are not 2 necessarily real experts in HRA? So in that spirit, 3 they tried to develop more specific guidance with 4 curves and so on.

5 ATHEANA pays more attention, Ι quess decided on the side of rigor, so everything is done 6 7 rigorously with experts being guided at the end to evaluate the situation, and come up with the numbers; 8 9 which, of course, makes it a very expensive exercise, and scares people that they will have to do that for 10 every single human error in the PRA. 11

It's important to understand that, because 12 there are two different philosophical approaches. 13 14 ATHEANA is really rigorous, always, in every little -every human action; whereas, EPRI says look, we are 15 16 not going to gather experts every time, and most of the time you have engineers doing the PRA. 17 They understand a little bit what it's all about, but they 18 19 are not expert, and those guys should be able to do a 20 lot of this.

21 DR. LOIS: Well, first of all, the NRC 22 SPAR-H, for example, has elements of that aspect. 23 ASEP was developed for that purpose, and it's more 24 streamlined.

DR. APOSTOLAKIS: Okay. Fine.

NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433

25

	26
1	DR. LOIS: However, to the EPRI right
2	now is making tremendous amount of efforts to
3	streamline the HRA to make it more consistent, adopted
4	the we haven't reviewed the calculator yet, but it
5	seems that they have adopted the Good Practices. They
6	are addressing the limitations of HRA methods
7	DR. APOSTOLAKIS: Yes, but a philosophical
8	approach was not changed. They still want to give
9	guidance to the average PRA analyst to do it, and
10	that's what I'm saying.
11	Now, SPAR-H, by the way, is really an a
12	posteriori approach. Given that something has
13	happened, they go in and do their evaluation, so I
14	wouldn't really put SPAR-H in the same group as
15	ATHEANA and the HCR/ORE.
16	DR. LOIS: And the issue
17	DR. BONACA: That's one point that was
18	made during the meeting, was that by expert, however,
19	I mean, within the plant, the operators are considered
20	the experts that have been
21	DR. APOSTOLAKIS: Yes, by and large.
22	DR. BONACA: That was an interesting point
23	that was made there, because I think within the
24	context of the PRA, the plant, and how it's being
25	maintained, or the decisions that are made, then those
ļ	I

(202) 234-4433

	27
1	experts are available.
2	DR. LOIS: ATHEANA has not been tested.
3	We believe that may be very cumbersome, but we haven't
4	tested that.
5	DR. APOSTOLAKIS: My point is
6	DR. LOIS: The user's guide may give us
7	the opportunity to test that.
8	DR. APOSTOLAKIS: Let's not talk about
9	what may happen. The fundamental difference seems to
10	be that EPRI goes out of its way to accommodate the
11	average analyst; whereas, ATHEANA, so far, has not
12	done that. I think that's a true statement. And this
13	is the "weakness" of ATHEANA in the sense that a lot
14	of people are scared when they look at what you have
15	to do, and they just don't do it. That's a fact.
16	DR. CORRADINI: What do they do instead of
17	that then?
18	DR. APOSTOLAKIS: They pick another
19	method. Because when you do a PRA, it's a tremendous
20	effort. It's a lot of work. I mean, to hear that you
21	have like in NUREG-1150, when they had the severe
22	accident expert elicitation, that's essentially what
23	these guys are doing.
24	DR. CORRADINI: For every human action?
25	DR. APOSTOLAKIS: Well, yes. But they

(202) 234-4433

	28
1	don't fly experts from around the world, they use
2	their operators, primarily. But still, it's quite a
3	lot of work.
4	DR. BONACA: And they were talking about
5	a limited number of critical actions, too.
6	DR. APOSTOLAKIS: See, that's the thing,
7	can we eventually reach a point where certain human
8	actions are handled in the EPRI kind of approach? But
9	we have to wait for that, but I thought it was
10	important for the members to appreciate
11	DR. WALLIS: So you said ATHEANA was
12	cumbersome and not being tested. Has it ever been
13	used?
14	DR. LOIS: It has been used, limited use
15	for the
16	DR. WALLIS: Been used by licensees to try
17	to in their PRA?
18	DR. LOIS: I don't believe so.
19	DR. WALLIS: Well, why is it on the list
20	at all, if it's cumbersome, never been used, and never
21	been tested?
22	DR. LOIS: The NSE used, developed ATHEANA
23	as a method to address the errors of commission and
24	other issues. It has been used for it was used for
25	the PTS project. ATHEANA development experience has
ļ	I

(202) 234-4433

	29
1	helped tremendously in identifying the Good Practices,
2	and evaluating the method. So, although ATHEANA
3	hasn't been used in the field tremendously, or as
4	much, it has really tremendously influenced the
5	thinking for HRA today.
6	DR. APOSTOLAKIS: Graham, I was just told
7	that you can view ATHEANA as the HRA equivalent of
8	TRACE for thermal hydraulics.
9	DR. WALLIS: That's not true at all.
10	TRACE is tested, and
11	(Simultaneous speech.)
12	DR. LOIS: So, with that, I don't think I
13	should shall I explain here? Do you want me to?
14	DR. APOSTOLAKIS: I don't think it's worth
15	going into the details.
16	DR. LOIS: No, okay.
17	DR. APOSTOLAKIS: I mean, the
18	DR. WALLIS: I would have liked to have
19	seen sort of a list of evaluation criteria for
20	deciding which of these are any good, not describing
21	what they do, but how do you tell which are any good?
22	Are you going to tell us that?
23	DR. CORRADINI: I think you should go on,
24	take your time for the people that I don't
25	understand. I'm listening carefully, or trying to
	I

(202) 234-4433

	30
1	listen carefully, but I don't understand all this, so
2	I'm going to ask the obvious question for a novice.
3	So is there a standard problem that is done in the
4	eight ways to see eight answers, or one answer, or
5	something? I mean, usually in the world of what we
6	do, there's a standard problem, and you watch the
7	various tools torture themselves trying to get some
8	result. Is there an equivalent here?
9	DR. LOIS: That's what I'm going to talk
10	about.
11	DR. CORRADINI: Okay.
12	DR. APOSTOLAKIS: That's what this
13	DR. CORRADINI: Okay.
14	DR. APOSTOLAKIS: So shall we have Jeff
15	now say a few words?
16	DR. LOIS: Yes.
17	DR. APOSTOLAKIS: Jeff?
18	MR. JULIUS: Good morning.
19	DR. APOSTOLAKIS: Good morning.
20	MR. JULIUS: The short answer to that
21	question is no, there's not a standard problem that
22	was done eight ways to see a range of responses.
23	DR. APOSTOLAKIS: But there may be.
24	MR. JULIUS: But there have not been, at
25	least recently. I mean, there's qualitative
Ĩ	

(202) 234-4433

	31
1	discussions in the development of NUREG-1842 that
2	looked at the basis for the methods, and where does
3	the data come from, but did not sit down and do a
4	problem. The EPRI approach is to use the PRA analyst
5	to the maximum extent possible, and you're right, that
6	there is - the two aspects, as we see it, are the
7	methods give formulas and an approach, but because
8	there's such a wide variation when you make selection
9	in the inputs used for those methods, that to produce
10	human error probabilities that are consistent, so
11	different analysts producing equivalent results, you
12	need some guidelines.
13	For example, some methods use stress as an
14	input, and you see this in SPAR-H, as well. There's
15	a set of performance shaping factors, but the range of
16	selections in there can vary orders of magnitudes, so
17	when do you say that somebody is under a time
18	pressure, or not under a time pressure? That's where
19	the guidance supplements the methods. It's a hand-in-
20	hand thing.
21	DR. APOSTOLAKIS: Now we have your Slide
22	2 on the screen.
23	MR. JULIUS: Okay.
24	DR. APOSTOLAKIS: Is that the one you're
25	going to speak to?
	I

(202) 234-4433

	32
1	MR. JULIUS: Yes.
2	DR. APOSTOLAKIS: Okay, Jeff, go ahead.
3	MR. JULIUS: Okay. What I wanted to point
4	out in my slide was that EPRI followed the process
5	developed first in SHARP, and then implemented by
6	ASME, so it covers the various aspects of
7	identification, the screening, the qualitative
8	characterization, that's a definition of what we call
9	performance shaping factors, what's the time
10	available, what's do the procedures say, what are the
11	cues and indications. Then in part of the qualitative
12	there's a feasibility determination, is this action
13	even feasible given the context of the accident
14	scenario? And then the quantification is done using
15	what we call the appropriate method. We have a
16	variety of methods that are in the calculator. We
17	have two main methods for doing the cognitive, does
18	the operator even recognize the situation, do the
19	correct diagnosis and decision making?
20	DR. APOSTOLAKIS: Excuse me, Jeff.
21	MR. JULIUS: Sure.
22	DR. APOSTOLAKIS: Not all members are so
23	familiar with these issues.
24	MR. JULIUS: Okay.
25	DR. APOSTOLAKIS: Can you explain a little
I	I

(202) 234-4433

	33
1	bit what the calculator is?
2	MR. JULIUS: Oh, the calculator is a
3	software tool that EPRI has developed for its 70
4	utility members and six corporate vendor members to
5	support the qualitative evaluation of human failure
6	events, and the quantitative calculation of the human
7	error probabilities for a PRA.
8	DR. APOSTOLAKIS: Great. Thanks.
9	MR. JULIUS: So the quantification
10	decomposes the problem into the cognitive and
11	execution, and then gives the possibility of one or
12	two methods for each, and also has included the SPAR
13	method. So, already we have
14	DR. WALLIS: So you can pick different
15	methods?
16	DR. APOSTOLAKIS: Just a moment, Jeff.
17	There's a comment.
18	MR. JULIUS: Okay.
19	DR. WALLIS: So you can pick all different
20	methods, and you can come up with a lot of different
21	answers then, depending on which you pick.
22	MR. JULIUS: That's right. In the very
23	small print on the screen on the upper right, you see
24	the red is one basic event, and there's three or four
25	options below it, so you can see the variation for
I	I

(202) 234-4433

1 doing different methods, because there are some cases 2 where the methods are driven by different factors. 3 One may be affected primarily by time, and that 4 overrides some of the other things. Another method, 5 there's plenty of time, and there's other aspects that are driving the quantification. So we allow for the 6 7 selection of methods, and then we provide a process for doing the documentation and reporting. And then 8 9 we provide guidelines to supplement this tool, because as has been pointed out, that there's -- the same 10 utility guys, a group of two or three evaluating the 11 same problem can produce a variation in results. 12 DR. CORRADINI: Can I just have you say 13 that again, please? I'm looking at the fine print, 14 15 and can I just say it back to you so I get it right? 16 MR. JULIUS: Sure. 17 DR. CORRADINI: So let's say, I don't know what any of this is, so let's say FEEDBLEED-1, there 18 19 are three, I assume, probabilities calculated, 1.3 ten 20 to the minus two, 1.3 ten to the minus three, 5 ten to 21 the minus three under P(Coq) and P(Exec), three other 22 And then I gather then these guys are added numbers. 23 That gives you a total human reliability together. 24 number for the event, so it's like a branch point 25 probability?

> NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433

(202) 234-4433

	35
1	MR. JULIUS: That's correct.
2	DR. CORRADINI: Okay. And then the
3	person, somebody sees that it could be 3.4 ten to the
4	minus two 1, or 1.6 ten to the minus one. They choose
5	something, and then must justify it in a documentation
б	format?
7	MR. JULIUS: That's correct.
8	DR. CORRADINI: And then move on to the
9	next branch point, and so the calculator gives them
10	various ways to estimate a branch point probability.
11	MR. JULIUS: That's right.
12	DR. CORRADINI: Okay.
13	MR. JULIUS: That's right, so that we can
14	explore the very differences in the human error
15	probability caused by the differences in methods. And
16	then you see on that the FEED2 item right below the
17	FEEDBLEED1, the blue indicates that that was the
18	method that has been picked as the quantification
19	method that is then exported to the PRA. So out of
20	the different possibilities, that's the one that's
21	actually in the model.
22	DR. WALLIS: Now if the operator were a
23	computer, then presumably there would not be this
24	great spread of probabilities. If the computer took
25	in the information available to the operator and made
	1

(202) 234-4433

	36
1	the decision, presumably would not be such a great
2	variability, so why have a person there at all?
3	DR. APOSTOLAKIS: The person has to pick
4	the model. Right?
5	DR. WALLIS: No, why have an operator
6	there?
7	I'm trying to think about why do we have people there?
8	We have people there to respond to something which
9	isn't routine. Isn't that why you have people there?
10	And now you're just evaluating how they respond to
11	routine stuff, which a computer could do better, or
12	are you evaluating how they respond to something where
13	you need a person?
14	MR. JULIUS: Well, that's partly why we
15	have this disparity in the approaches, because some of
16	the actions are modeling the routine response. For
17	example, if an automatic actuation comes in on one
18	channel and it doesn't on the other, the operator is
19	supposed to manually start the train that didn't start
20	automatically to the point where there's a local
21	manual action out in the plant that's really recovery
22	of a failed component where the guidance may be less,
23	or he's going out and doing more of a troubleshooting,
24	so really the range of the things we are quantifying
25	range from something simple and pretty clear-cut, to
ļ	l

(202) 234-4433

37 1 something that's really challenging from a detection, 2 and diagnosis, and decision making point of view. 3 DR. CORRADINI: So can I ask Graham's 4 question a little bit differently, just so that --5 because you're at least helping me understand. So in my mind, the two asymptotes are, if these becomes 6 7 regularized based on procedures, the probability of failure approaches zero, and the more it becomes 8 9 something unique to the operator having to diagnose, 10 the probability approaches like flipping a coin. DR. APOSTOLAKIS: Not exactly. 11 12 DR. CORRADINI: I mean, aren't those the it would be probability one, 13 two Ι mean, 14 necessarily, but it would approach probability one the more unusual it is for the individual to diagnose it. 15 16 So, obviously, all of these calculators have those two 17 asymptotes, or something like that? 18 MR. JULIUS: That's right. 19 DR. APOSTOLAKIS: In general terms, you're 20 right. 21 DR. WALLIS: I mean asymptote and flipping 22 a coin is a little difficult. 23 DR. CORRADINI: But I quess what I'm 24 saying, though, as you said, it becomes more and more 25 unusual that they have to diagnose this.

> NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433

	38
1	DR. WALLIS: That's when you need the
2	person.
3	DR. CORRADINI: Right. But it becomes
4	harder, though, to come up with a branch point
5	probability which would essentially be like, it could
б	be this or this.
7	DR. APOSTOLAKIS: And this is really the
8	issue, what do you do in those situations? If you can
9	say this is they're just following the procedures, I
10	don't think the disagreement big, but when you go to
11	these unique situations where you have identified now
12	things that
13	DR. WALLIS: What you can test, though,
14	using simulators tends to be
15	DR. APOSTOLAKIS: Well, they will talk
16	about what they plan to do.
17	DR. WALLIS: the procedures one, where
18	you think
19	DR. APOSTOLAKIS: They have a plan.
20	DR. WALLIS: the probability should be
21	one, but when you actually do the test with people,
22	you find it's .7.
23	DR. APOSTOLAKIS: Yes. What will happen
24	in the future, I think Dr. Lois has
25	MR. PERRY: This is Gareth Perry, again.
	I

(202) 234-4433

	39
1	I don't think you're quite right. I think most of
2	these actions are actually procedure-driven actions,
3	and there is a difference in interpretation of these
4	different methods of what factors are that will drive
5	the operators either to perform this on time, or not
6	perform it on time. So I think that this is a real
7	reflection of the differences that the methods give
8	for procedure-driven actions. The diagnosis is
9	really, I think in many ways, a misnomer given the
10	type of procedure we have. It's really a decision
11	making based on the instructions that he has in the
12	procedures, given the perception he has of where the
13	plant is, so it's not really strictly speaking a
14	diagnosis.
15	DR. APOSTOLAKIS: Because the symptom-
16	oriented procedures go far.
17	MR. PERRY: Right.
18	DR. APOSTOLAKIS: Far beyond
19	mR. JULIUS: That is correct. I would
20	endorse what Dr. Perry said. I mean, the diagnosis is
21	really a broader term that talks about how the
22	information is given to the operator, and what he's
23	reading in the procedures. We do include the
24	possibility, and this is endorsed by ASME, that some
25	of these may have a weak or no procedural link. But,
	1

(202) 234-4433

(202) 234-4433

Í	40
1	in general, it's and this is where ATHEANA gets
2	into some, what are the different error-producing
3	conditions? Is it the fact that the instrumentation
4	is giving a different view of what's really going on?
5	So some of those elements do overlap with what we have
6	in the calculator, and I didn't put it on this slide,
7	but we do foresee that there are ties between this
8	generalized approach with the qualitative and the
9	quantitative to support ATHEANA, as well.
10	DR. APOSTOLAKIS: Have you thought at all
11	about putting ATHEANA in the calculator?
12	MR. JULIUS: Yes, we have.
13	DR. APOSTOLAKIS: And you decided
14	something, or you're thinking about it?
15	MR. JULIUS: Well, we've decided that I
16	think the calculator would provide a good tool to
17	develop the baseline HEP, and to identify those types
18	of factors that would be explored with this expert
19	group in terms of the deviations from the space
20	scenario. For example, if the instruments - what's
21	the impact of the faulty or inconsistent
22	instrumentation that may be causing a problem with the
23	decision making? So we think that the calculator
24	provides a good basis for starting an ATHEANA
25	analysis, and doing a lot of the documentation aspects
	1

(202) 234-4433

	41
1	of it.
2	DR. APOSTOLAKIS: Okay. We are running a
3	little behind, so shall we go back to Dr. Lois?
4	MR. JULIUS: Yes. Thank you for the
5	opportunity.
6	DR. APOSTOLAKIS: Okay, Jeff. Thank you
7	very much. You will stay on line?
8	MR. JULIUS: Yes, I will.
9	DR. APOSTOLAKIS: Okay. Good.
10	DR. LOIS: So if we would like to
11	summarize what are the issues about the HRA methods,
12	although they continue to be used, the underlying
13	assumptions are different and haven't been updated,
14	that data on which they were developed have not been
15	updated. So we have a list of factors that we assume
16	that are affecting human performance, and their
17	definitions and interpretation of these factors to
18	agreement on which factors should be there are
19	methods we're using, as many as three or five other
20	methods allow the analyst to determine what the factor
21	is, and what is the inputs, to agree on the how do
22	you determine and define the level of each factor.
23	And, for example, what is it when we say high work
24	load or high stress, and how to characterize the
25	influence of the factor on the HEP. All of these
I	

(202) 234-4433

42 1 issues haven't been addressed extensively yet. 2 And very little benchmarking or validation 3 has been performed to test the methods against actual 4 performance, if you wish, so that we need to 5 understand how important are these differences. Ιt may be at the end, if you have very good analysts, 6 7 they come up with the same number, or the same 8 conclusions, doesn't matter what the instrument is, 9 the method is. So to understand the importance of the 10 differences, it's also an important aspect for improving the reliability of HRA. And the question is 11 12 what are we going to do about errors of commission? For example, ATHEANA is preaching that 13 14 error of commission may be the most important aspect 15 when you're dealing with more difficult circumstances 16 than circumstances that the operators have the right procedures, and they could just deal with the event in 17 a very easy way. And, therefore, we haven't addressed 18 19 the issue to what extent we should rate them as part 20 of human reliability analysis. 21 DR. APOSTOLAKIS: I would add a fourth 22 Maybe it's not an observation, but I'll come element. 23 back to my earlier comment. I think there needs also 24 to be a reconciliation between the two philosophical 25 approaches with one which says let's make this as easy

> NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433

	43
1	as we can for the average PRA analyst. It's like
2	Einstein said, let's make it as simple as possible,
3	but not simpler. And then identify the human errors
4	where a more detailed rigorous analysis is required.
5	Another way of putting it, can we screen
6	these, and some of them can be done using computer
7	help, and others will require a more detailed I
8	think that's a very important point.
9	DR. WALLIS: It seems to me if we're just
10	following procedures, and every step if the pressure
11	is bigger than 1000 psi, do A, if it's less, do B.
12	The computer does that much better than a person. The
13	computer can follow through the procedures and tell
14	when you are violating or not violating procedures.
15	That's the kind of decision you're asking for. But if
16	you're asking for using judgment in unusual
17	circumstances, then that's an awfully different one.
18	DR. APOSTOLAKIS: But that's one of the
19	issues.
20	DR. WALLIS: That's where you need the
21	people.
22	DR. APOSTOLAKIS: Right. Right.
23	DR. ABDEL-KHALIK: But really, I mean
24	listening to this discussion, the question in my mind
25	now is, are there any scenarios identified in the PRA
I	I

(202) 234-4433

	44
1	that do not sort of fall within the emergency
2	operating procedures?
3	DR. APOSTOLAKIS: Very few.
4	MR. PERRY: And, actually
5	DR. APOSTOLAKIS: After TMI, I think
б	MR. PERRY: And, actually, in the PRA
7	standards, if the actions that are required are not
8	addressed in the procedures, there's guidance not to
9	take much credit.
10	DR. ABDEL-KHALIK: I beg your pardon?
11	MR. PERRY: The guidance in the PRA
12	standard is not to take credit when there are no
13	procedures for performing actions, typically.
14	DR. ABDEL-KHALIK: Everything we're
15	discussing here pertains to operator actions as the
16	operators follow the guidance provided by the
17	procedures.
18	DR. BONACA: And, in fact, one issue is
19	will you will the procedure be always correct. The
20	more you go beyond your design-basis events
21	DR. ABDEL-KHALIK: But the consequences of
22	following the procedures is a separate issue, but
23	whether you actually go, ultimately end up with
24	success or failure. But if that is the case, why
25	haven't we been collecting data from simulator
l	I

(202) 234-4433

45 1 experience to check against these specific operator 2 actions within the procedure? I think you have to be careful 3 MR. PERRY: 4 about collecting data from simulators, because a lot 5 of that would be from routine training exercises, which would really not be valid. These would have to 6 7 be unannounced casualties, if you like. You could do 8 that, but still, I don't know that it's being done on 9 a -- it hasn't been done in a comprehensive way. EPRI did it for a certain amount, and I think in most of 10 those cases, you do run across most of the situations 11 where, in fact, the operators do, in fact, succeed. 12 I think in the EPRI experience, there were actually no 13 14 real failures to perform the significant actions that 15 you would model in the PRA. DR. ABDEL-KHALIK: You know, a cynic would 16 17 interpret your argument as saying, you know, all this training emergency operating procedures is 18 on 19 essentially worthless. 20 I hope not. MR. PERRY: 21 DR. ABDEL-KHALIK: But that's sort of the

interpretation, by saying that I don't trust any datathat I would collect from simulator training.

24 MR. PERRY: No, no, no, no. No. That's 25 not what I was saying. What I was saying is that the

> NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433

	46
1	data has to be relevant to the actual scenarios that
2	you're modeling in the PRA, which would be that the
3	operators didn't know what was coming.
4	DR. ABDEL-KHALIK: But, presumably, some
5	training programs do that.
6	MR. PERRY: They do some of that, sure.
7	Yes.
8	DR. ABDEL-KHALIK: So are you questioning,
9	then, whether
10	MR. PERRY: No, what I'm saying
11	DR. ABDEL-KHALIK: or not the training
12	programs are comprehensive enough to encompass the
13	scenarios that we're trying to follow?
14	MR. PERRY: No, I'm not questioning any of
15	that. I'm just pointing out that the data collection
16	in those unannounced scenarios has not been performed
17	in a comprehensive way. And that would be the
18	database that you would need to generate human error
19	probabilities of the type that we want in the PRA
20	models.
21	DR. ABDEL-KHALIK: Well, if that's what we
22	need, why aren't we starting to do that?
23	DR. LOIS: HRA has not been benefitted
24	from systematic collection of data for so many years,
25	although we're developing methods for I don't know
	I

(202) 234-4433

	47
1	whether they use
2	DR. APOSTOLAKIS: I think
3	DR. LOIS: For whatever reason, we haven't
4	done that.
5	DR. APOSTOLAKIS: The issue of relevance
6	of simulator-based data has been discussed forever.
7	CHAIRMAN SHACK: I mean, there are
8	practical problems, too. I mean, these probabilities
9	are fairly low, so you've got to run a lot of stuff.
10	DR. APOSTOLAKIS: Right. And with
11	different themes and so on.
12	CHAIRMAN SHACK: Right.
13	MR. PERRY: And different procedures, too.
14	DR. APOSTOLAKIS: One of the challenges
15	that these models have is to identify the factors,
16	what they call performance-shaping factors that affect
17	the performance of the operators in a real setting.
18	So that's a perennial problem. I mean, there is a lot
19	of good information in the simulator exercises, but is
20	it like flipping coins, and then estimating the
21	probability of heads? It's not quite the same thing,
22	so that's where the issues are.
23	John, you want to say something?
24	MR. MONNINGER: I guess the only thing,
25	you mentioned procedures, and if you look at, you
I	I

(202) 234-4433

1 know, capitalize emergency operating procedures. Ι 2 mean, you have normal operating procedures, startup, annunciator response, all 3 the way to emergency 4 operating procedures, but then beyond the emergency 5 operating procedures you have something called your severe accident management guidelines. So I just 6 7 wanted to mention that when you said EOPs, there are 8 beyond the EOPs, there's the severe accident 9 management guidelines, which aren't as proceduralized, but they recognize that a tremendous amount of 10 training, knowledge, and skills are at the site, 11 12 resources are available, and you have teams of experts. And the severe accident management 13 14 guidelines try to then, when you're sort of at the end 15 of your EOPs, and if you're in a really bad accident, they try to drive you and lead you to perform some 16 17 other actions. DR. APOSTOLAKIS: I think Dr. Lois is 18 19 planning to address some of these issues in the next 20 slide, so maybe you have a chance --21 DR. LOIS: Yes. In fact, now this 22 discussion is a very good intro for what I'm going to 23 talk about. 24 CHAIRMAN SHACK: It seems to me the first 25 bullet is the only one that's really important. What

> NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433

(202) 234-4433

	49
1	are you actually going to do to benchmark these
2	methods?
3	DR. APOSTOLAKIS: Well, let's
4	DR. LOIS: Let's talk about it. What we
5	would like to do is to do method-to-data, and method-
б	to-data comparisons. And, as a result, to improve the
7	guidance, as we were talking before, guidance
8	documents, as well as the methods themselves.
9	DR. APOSTOLAKIS: You are on slide 11 or
10	12?
11	DR. LOIS: No, 12. So we have what we
12	call empirical study before we were calling
13	benchmarking study, and this is in conjunction with
14	the Halden simulators, the Halden Reactor project.
15	What we plan to do, and this is a collaborative
16	effort, many countries actually participate in this
17	exercise. It was initiated last August as a result of
18	NRC's decision to go forward and perform an empirical
19	study, and initiated this program, and other countries
20	actually get along with this.
21	What we are going to do is, we're going to
22	have Halden will have operator crews that are
23	running simulator scenarios similar to those modeled
24	in PRA, will collect crew performance data. And HRA
25	analysts use their own method, will analyze the same
I	1

(202) 234-4433

1 human actions, so an information package has been sent 2 to the different groups that participate in this exercise that includes all of the information; what is 3 4 the scenario, what is the human action to be 5 performed, what are the characteristics of the plan, what procedure is used, dah, dah, dah, everything that 6 7 an HRA analyst would need to have in order to perform 8 this analysis. And the results of these analysis will 9 be reported back in terms of actual predictions. Failure probability, probably percent success. 10 DR. WALLIS: Now I have a question. 11 I'm 12 Erasmia, about same actions for the same sorry, It seems to me that actions taken early in 13 scenarios. 14 the scenario at different times change the later 15 scenario, so someone who switches on or off a high-16 pressure injection at the beginning of some window he has, or the end of it, changes what happens later. 17 In something like that the AP1000, whether or not those 18 19 makeup tanks drain at certain times depends on what someone did earlier, and when he did it. 20 21 whole thermal hydraulic scenario The 22 changes as the actions and the timing of them changes. 23 So don't see how you can have the same actions for the 24 same scenarios, because the actions themselves change 25 the scenario.

> NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433

(202) 234-4433

1 MR. FORESTER: This is John Forester, 2 Sandia Labs. I'd just like to note that the scenario 3 is actually run on the simulator, and the operators 4 are responding, so certainly what they do affects what 5 happens later, obviously. But in terms of the analyst predicting what's going to happen, they will predict 6 7 a failure probability, and they'll identify what kind of factors would affect a performance for a particular 8 9 And then if they're looking at later actions action. 10 in the scenario, then they're going to assume that that action was successful when they're making their 11 12 And to the extent there's failures in predictions. earlier actions, then their predictions probably won't 13 14 be relevant later, so it really relates to what 15 actually happens in the scenario in the actual 16 simulator. 17 DR. APOSTOLAKIS: But are the analysts going to identify various ways that a scenario may 18 19 In other words, the SHARP approach or the evolve? 20 ATHEANA approach to identify deviations, that is part 21 of the exercise. 22 No, that's not part of the MR. FORESTER: 23 exercise right now. This is a pilot study, and the scenarios themselves have been defined ahead of time 24 25 so that the crews can be run through them, obviously.

> NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433

(202) 234-4433

52

will be doing, but the ATHEANA team, for example, will not be identifying deviation scenarios at this point. I think we'll plan to do that later on, but at this point, we're basically assessing the quantification of explicitly being the actions addressed in the experiment.

DR. LOIS: But, John, we're talking about 8 9 the pilot versus the actual study, so we just started 10 the study, we're piloting it to test out the whole 11 method how we would do, but eventually, we hope, if we 12 have the resources and the time, we would test out all the various aspects of the methods. 13

14 DR. APOSTOLAKIS: Because if you start 15 looking at the first action of the operators, and then everybody knows that, and analyze it, but then the 16 operators do something that takes a scenario on a 17 different path, then if you don't try to identify the 18 19 different paths, then you're dead in the water. You 20 can't do it.

21 DR. LOIS: So within the method, analysts 22 will have the capability given the procedure, the 23 operation, et cetera to say that operators will do 24 okay, and, therefore, the next step will be to do 25 Will that do okay? And then the next step may that.

> **NEAL R. GROSS** COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433

1

2

3

4

5

6

7

	53
1	be this.
2	DR. APOSTOLAKIS: So they will identify
3	deviations at some point.
4	DR. LOIS: Absolutely. Absolutely, within
5	the constraints of the method.
6	DR. APOSTOLAKIS: Right.
7	DR. LOIS: And then, on the other hand,
8	we're going to have the crews, the observations of
9	what the crews did, and to what extent crews really
10	took the scenario in an entirely different point.
11	DR. APOSTOLAKIS: Another interesting
12	point here, because it has been discussed in the past.
13	At the subcommittee meeting we were told that there
14	will be at least one American crew participating,
15	because in the past the issue was raised, Halden is in
16	Norway. They tended to use Swedes, and Norwegians,
17	and Finns. And now there will be, I believe, two
18	crews from the United States?
19	DR. LOIS: Actually, it should be more
20	than two. Halden is willing to even come in the
21	United States and run some of these experiments, so
22	there are negotiations. And EPRI is participating in
23	the study; therefore, we hope that we'll have the
24	opportunity to do it. Right now, we are piloting the
25	study, so what happened is at Halden last December, 14
I	I

(202) 234-4433

1 crews of a European plant, Westinghouse, three new 2 plant run steam generator tube scenarios, two - one, 3 which is the one that pretty much predictable through 4 the emergency procedures, et cetera, one more 5 complicated. And the HRA teams are given the scenarios and are analyzing those two scenarios with 6 7 their methods. And Halden is collecting the observations and documenting those. 8 9 And what is going to happen is, we have an independent group of experts that will evaluate the 10 11 results from the various teams with respect to Halden 12 observations, Halden results. And then we plan to document --13 14 DR. WALLIS: Can I ask you what you mean 15 by "evaluate the results"? They're comparing what all these different people did with what all the models 16 would predict they would have done? Is that what 17 they're doing? 18 19 DR. LOIS: Well, for example, if a 20 specific method, a group of analysts will determine 21 that this specific human action has a high probability 22 of failure. And the reason --23 So you will be comparing, DR. WALLIS: 24 you'll be saying this action had actually, in 25 practice, an 80 percent probability of -- failed 80

> NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433

(202) 234-4433

	55
1	percent of the time in the data.
2	DR. LOIS: Yes.
3	DR. WALLIS: And the prediction from
4	various models were so and so, and so on.
5	DR. LOIS: Yes.
6	DR. WALLIS: Okay.
7	DR. APOSTOLAKIS: I suspect, though, that
8	there will be a problem. I think what Gareth said
9	earlier will happen. The crews will not fail.
10	DR. WALLIS: Never?
11	DR. APOSTOLAKIS: I doubt it.
12	DR. WALLIS: So nothing will be
13	established.
14	DR. APOSTOLAKIS: I doubt it, so the
15	probabilities that the various teams will evaluate
16	will really be used to compare method-to-method.
17	DR. WALLIS: But if you know no one is
18	going to fail, it's not an experiment.
19	DR. APOSTOLAKIS: I don't think we're
20	going to get to the point that Said wants, where you
21	have a set of data and calculate probabilities,
22	because these guys are experienced.
23	DR. WALLIS: But if they never fail,
24	there's no data.
25	DR. ABDEL-KHALIK: These are not fully
	I

(202) 234-4433

	56
1	simulator exercises.
2	DR. LOIS: So the difficult scenario
3	John Forester would like to say something here, but
4	we have two scenarios, one which is probably what we
5	call the vanilla scenario, the one that probably
6	DR. APOSTOLAKIS: What scenario?
7	DR. LOIS: We call it vanilla scenario.
8	DR. APOSTOLAKIS: Vanilla.
9	DR. LOIS: The one that people may not
10	fail, but Halden has surprised us. The study that I
11	mentioned at the beginning when they set about doing
12	the actual simulator runs for human reliability,
13	although some of the scenarios were very easy, and the
14	assumption is that following the procedures, they will
15	not make a mistake. Some people did make a mistake.
16	DR. ABDEL-KHALIK: But, you see, that's
17	where I have the most concern. Halden is a completely
18	different animal than a power reactor, anyway. And,
19	therefore, the operator's success or failure in
20	following the procedures prescribed to respond to an
21	event at Halden, it may have very little to do with
22	how the operator would succeed or fail responding to
23	an event in a power reactor on which they have been
24	trained for many years.
25	DR. APOSTOLAKIS: Why do you say it's a
ļ	I

(202) 234-4433

	57
1	completely different animal?
2	DR. ABDEL-KHALIK: Oh, it's a completely
3	different reactor.
4	DR. MAYNARD: In our subcommittee meeting,
5	several of us raised that concern. The validity of
6	this where you're going to a simulator that you're not
7	familiar with, and it would depend on how it's laid
8	out and structured here. I think it going to be
9	extremely difficult, because you're introducing
10	probably more factors than you can factor into your
11	HRA analysis.
12	MR. FORESTER: This is John Forester. I'd
13	like to comment on that. The simulator is they use
14	the same procedures from the plant. There's a few
15	minor differences, but their operating crews are doing
16	the same basic job they would always do, and it
17	follows very closely what would go on in their plant.
18	Now the interface is different in the sense there is
19	a digital control room in the simulator, but the
20	operating crews are given training on how to use the
21	interfaces, and the different ways to interact with
22	the systems. And experience has been that they do
23	very well with that, and really don't have any
24	problems in terms of how they interact. Their job is
25	still the same, they're still using the same basic
I	I

(202) 234-4433

	58
1	procedures, and responding as they would in a real
2	accident. So there are some minor differences, but
3	the sense of it is, is that in terms of the cognitive
4	processes involved, and the decision making processes,
5	and what they end up doing, it's very close to what
6	they would actually experience.
7	They may actually start a pump in a
8	different way, but it's deciding to start the pump.
9	And as long as they've had some practice in terms of
10	how to do that on a simulator, then the assumption is
11	that cognitively speaking it's a very, very close
12	replication.
13	DR. APOSTOLAKIS: Mr. Monninger.
14	MR. MONNINGER: Yes. Erasmia, you can
15	correct me if I'm wrong, but there's a difference
16	between the Halden reactor over there and the actual
17	simulator. It's my understanding that the simulator
18	over there is for a Westinghouse 3-loop plant, which
19	would be similar to a U.S. design. They use standard
20	Westinghouse procedures, so it's not the Halden
21	research reactor simulator, it's a simulator over
22	there, but of a Westinghouse 3-loop design.
23	DR. MAYNARD: But you're still introducing
24	environmental changes in there. It may be the same
25	overall controls, but if it's digital versus the
I	

(202) 234-4433

(202) 234-4433

	59
1	panels that they've got to work with, when you get
2	into time pressure situations, and even though the
3	decision may be the same, the way you physically do it
4	is different. It introduces more variables there.
5	I'm not sure if that keeps it all balanced.
6	DR. LOIS: I believe that the Halden
7	experts have addressed these issues, the reliability
8	and validity of the experiment. And my recommendation
9	would be to, since Halden is an integral part of this
10	study, to have Halden briefing the committee on their
11	approach, and addressing these issues. We feel
12	comfortable with the experiment because we know the
13	details of the experiment, but definitely should be
14	addressed.
15	DR. APOSTOLAKIS: Okay. The concern has
16	been noted. I suggest, though
17	DR. WALLIS: Is this the only test you're
18	using?
19	DR. APOSTOLAKIS: Wait, wait, wait. I
20	suggest that we spend a lot of time on this. You go
21	to slide 16, which is really the proposed approach.
22	DR. WALLIS: I'd like to go
23	DR. APOSTOLAKIS: And then we come back.
24	Yes, sure.
25	DR. WALLIS: Try to respond to the SRM.

(202) 234-4433

	60
1	You're going to decide on the basis of this experiment
2	that one method is totally superior and should be
3	used?
4	DR. LOIS: No.
5	DR. APOSTOLAKIS: She will address the
6	response to the SRM now in slide 16, and then your
7	question.
8	DR. WALLIS: I'm just wondering what
9	DR. LOIS: So what we're going to do from
10	this experiment is learn about the methods. We're
11	going to have the opportunity to understand how people
12	are using their methods, why they decide certain
13	things, how their underlying assumptions of the
14	methods are influencing the results, so we have this
15	method-to-method comparison opportunity, as well as
16	method-to-data opportunity.
17	DR. APOSTOLAKIS: Let's talk about
18	right. And then we can place everything in this
19	context, because this is really, on 16, this is the
20	heart of the matter.
21	DR. WALLIS: Are you really going to come
22	up with an unequivocal recommendation for one method?
23	DR. APOSTOLAKIS: Well, let's see what
24	they plan to do here.
25	DR. WALLIS: Okay.
I	I

(202) 234-4433

	61
1	DR. APOSTOLAKIS: This is a proposal.
2	DR. LOIS: Jeff Julius, this is the EPRI
3	proposal during the subcommittee, we will have Jeff
4	Julius talking to it.
5	DR. APOSTOLAKIS: Okay, Jeff, tell us what
6	you guys are proposing. We are on slide 16. I assume
7	you have the presentation in front of you.
8	MR. JULIUS: Okay.
9	DR. APOSTOLAKIS: So this is what the
10	committee will have to address in the letter to the
11	Commission at this meeting.
12	MR. JULIUS: All right. In the ACRS PRA
13	Subcommittee meeting on March 22 <sup>nd</sup> , I proposed a
14	series of activities that may be included as elements
15	of a plan to address the staff response memo. And
16	these activities were, at that time, not necessarily
17	meant to be all-inclusive, but the gist of these
18	activities was to look at this problem from a
19	different perspective. The past NUREGs and approaches
20	have looked from the bottom up, if you will, to look
21	at what are the methods, what's the basis for the
22	method, what's some of the assumptions or limitations
23	behind the method. And the approach I've outlined is
24	to say now let's go around to the other end and look
25	at the applications where these methods are used, and
	I

(202) 234-4433

	62
1	to see does the selection of the methods of the
2	selection of shaping factors within the method, would
3	that have changed the decision making? And so the
4	plan starts in at the top of the slide with
5	establishing a joint team between the industry and the
6	NRC, so this goes to the point of this should be an
7	activity that's got involvement of the staff, as well
8	as the external stakeholders. Then from that team, we
9	establish common terms and an integrated overall
10	approach.
11	One of the lessons learned from NUREG-
12	1842, for example, this was the evaluation of methods,
13	was the methods different methods were meant to do
14	different things. If one method was meant to lay out
15	the whole process, which I've called the framework,
16	but the whole big picture for doing the HRA, but not
17	specifically prescribe what method. Another one meant
18	to go in, I'm going in to quantify a cognitive error,
19	or a time-limited situation. So once we have a common
20	set of terms and an overall big picture of what the
21	whole process is, then we can understand how the
22	context where these methods are used.
23	Then the third bullet there is to review
24	the applications, and the role of the HRA in the
25	decision making. Some of these applications I expect
ļ	I

(202) 234-4433

1 there would be, perhaps, insensitive to the HRA, maybe 2 something like an integrated leak rate test extension 3 for the containment, that may be more of a function of 4 where the plant is in the Level 3 PRA, and not 5 necessarily the Level 1 human errors. Some may be dominated by the human reliability, and we've seen 6 7 that in cases for the significance determination 8 process as part of the reactor oversight, as well as 9 the implementation of Management Directive 8.3. 10 8.3 is the Management Directive that says when an event happens, or a potential event happens at 11 12 a plant, that the conditional core damage probability would be evaluated to determine to what extent the 13 14 staff will respond. Will it be a single guy that goes out to talk about what happened, or will it be an 15 16 augmented inspection team? 17 Some of these applications, you might expect, might have had more influence from the HRA, 18 19 but to really look at the applications and document 20 the insights of the review, and decide to what extent 21 the HRA methods, or the selections within the methods 22 influence the decision. Because if we have these 23 differences, and it isn't going to change the 24 decision, then this -- maybe there's better uses for 25 the money elsewhere.

> NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433

(202) 234-4433

64 1 DR. APOSTOLAKIS: But, Jeff, is the main 2 objective of doing a good job in the PRA without necessarily facing a particular decision, is that 3 buried somewhere here? In other words, I'm doing a 4 5 PRA, and as was said earlier, I want to make sure that the numbers I produce and the scenarios I produce are 6 7 meaningful. Wouldn't that be part of this evaluation? I mean, we don't always have to make a decision like 8 9 a power uprate or something. I mean, we just want to 10 have a good model of the plant. 11 MR. JULIUS: Yes, you're right. That is 12 an important aspect of it. And I guess that would be buried in here in terms of the -- I mean, any of these 13 14 applications you do the baseline, and then you do the 15 delta, so the decision would be the delta, but maybe the first step is an evaluation of the baseline. 16 DR. APOSTOLAKIS: I would add a bullet 17 there saying that the baseline PRA has to be a solid 18 19 piece of work, and then look at the various decisions 20 that might be --21 LOIS: Mr. Perry wants to add DR. 22 something here? MR. JULIUS: Yes. I think -- I mean, it's 23 24 all very well to say just having the PRA is an aim in 25 itself, but that's like saying having a saw is an aim

> NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433

	65
1	in itself. But without a piece of wood to cut, it's
2	really not very useful. So I think you have to
3	when you say you want a PRA, you have to say how are
4	you going to use that PRA. And maybe you're using it
5	to get insights on the safety aspects of the plant,
6	and it's those aspects that I think that should be
7	addressed in these applications, not just a PRA for
8	the sake of it. You need it for a purpose, you need
9	it for an assessment of CDF, you need it for an
10	identification of vulnerabilities, you need it for an
11	assessment of the insights. So I think in the context
12	of applications, those are the aspects that I think
13	you need to address.
14	DR. APOSTOLAKIS: These are too specific.
15	And what I'm saying is yes, I want to understand the
16	CDF. And I don't see that anywhere.
17	MR. JULIUS: Gareth is right, you develop
18	the saw, is it a band saw, or a crosscutting saw? I
19	mean, the typical application that maybe we've used as
20	the baseline is maybe configuration risk management,
21	because the plants are using that as day-to-day
22	application of the PRA to control maintenance.
23	DR. APOSTOLAKIS: When they come here and
24	they ask for a license extension, usually there's a
25	question, what is a CDF? Well, I would like to know
Į	

(202) 234-4433

	66
1	that this CDF is based on some method. I don't
2	necessarily base my decision on that. That's all I'm
3	saying.
4	DR. WALLIS: But when a BWR comes up,
5	you've got a little box and it says the probability of
6	the operator making this decision right is .325.
7	Well, where does that come from?
8	DR. APOSTOLAKIS: Anyway, it was just I
9	mean, this is
10	DR. WALLIS: But, seriously, it does. I
11	mean, you get all kinds of numbers. You get some
12	numbers which are surprisingly big for false
13	decisions.
14	DR. APOSTOLAKIS: Okay. Let's go on.
15	MR. JULIUS: That was the third step then,
16	to review the applications. But then keep in mind,
17	this is typically, these evaluations and
18	comparisons have been done, or have been the Level 1
19	internal events, which was the primary basis for the
20	model up until now. But with the scope and quality
21	initiative, the SECY-04 pushing towards full scope
22	models, then we need to also look ahead to spatial
23	PRAs that are fires and floods, and external events,
24	and shutdown initiators, and perhaps severe accident
25	management types of actions that are part of the Level
	1

(202) 234-4433

1 2 analysis, or using the PRAs for advanced reactors 2 with digital controls. So I think the other aspect of 3 this discussion is that maybe some of these 4 differences are hard to tell, because it was meant for 5 the internal events and power, and now as we turn to these other uses, we might find that the limitations 6 7 are even more glaring, or important to the development of the PRA for these other situations. So the plan 8 9 was then to establish a team, establish a common set terms and an approach, and then to look at 10 of applications, or look at the PRA to be used for 11 configuration risk management even in the application, 12 maybe as a baseline, but then to determine from the 13 14 application end of it what are the influences of the 15 HRA. 16 DR. APOSTOLAKIS: Okay. 17 DR. LOIS: So that was the EPRI proposal, and from our perspective, we believe that this is a 18 19 good proposal, addresses the SRM needs. If we 20 establish collaborative efforts, we'll be able to 21 achieve better handling of HRA for internal event 22 Note that all the discussion we've had analvsis. 23 before on HRA methods is focused more on internal 24 event analysis, and expand and modify the methods for 25 what I call here emerging applications, the need that

> NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433

(202) 234-4433

	68
1	now we have to address HRA applications for external
2	events, for actions that are performed outside the
3	control room, et cetera. And it will allow us to
4	optimize resources and timeliness. So we're going to
5	evaluate, develop a draft MOU, and find out whether or
6	not we can do it collaboratively, and yet retain the
7	independence as regulatory agencies.
8	DR. APOSTOLAKIS: But there is a precedent
9	for that, the fire collaboration.
10	DR. LOIS: Yes.
11	DR. APOSTOLAKIS: So it can be done. I
12	mean, it's not
13	DR. LOIS: We believe it can be done, but
14	we're not in the position to say it will be done right
15	now, because
16	DR. APOSTOLAKIS: Who is the ultimate
17	decider?
18	DR. LOIS: OGC will have a big role.
19	DR. APOSTOLAKIS: Yes, but if there is
20	precedent, I hope things will move smoothly.
21	DR. LOIS: Assuming that the MOU will be
22	established, we believe that the review of regulatory
23	applications for importance of HRA is important, and
24	should be done first, establishing common terms, and
25	a framework should also be done. And we believe that
I	I

(202) 234-4433

	69
1	it will be achieved through the empirical study, or
2	the empirical study will start and will help a lot
3	towards the achievement of this integrated approach.
4	And collaboration on new needs will help facilitate a
5	timely resolution, which is another important aspect
6	for human reliability.
7	DR. APOSTOLAKIS: Is the empirical study
8	limited to the Halden analysis, or are you going to
9	include actual operating experience of what people
10	did?
11	DR. LOIS: That's what the project does.
12	We are also collecting data, LERs, and we hope that
13	we'll use those, as well. You have to realize, or we
14	have to realize that these are not one-year efforts.
15	In order to be able to establish the procedures or the
16	methods for using field data, to understand how these
17	models should be changed and improved, it will take
18	some time.
19	DR. WALLIS: Could I ask you something
20	here? I mean, you were suppose you were trying to
21	propose a single model for the agency. Has the Halden
22	study been designed in order to be able to distinguish
23	the characteristics of these seven models in such a
24	way that you are going to end up with a conclusion
25	that one is superior to all the others?

(202) 234-4433

	70
1	DR. LOIS: Right now we don't know.
2	DR. WALLIS: Perhaps, you need a different
3	experiment.
4	DR. LOIS: We haven't done a pilot. We
5	believe that the Halden data will help us understand
6	the methods, understand how people are using those,
7	and how we can
8	DR. WALLIS: But there may be some methods
9	which are not properly tested by these tests.
10	DR. ARMIJO: Is that your objective, or
11	shouldn't that be your objective, to come up with one,
12	maybe two methods, depending on the situation that the
13	Commission will use?
14	MR. MONNINGER: I don't believe - this is
15	John Monninger, a priori, that our objective is to say
16	that it should be explicitly one model. I think
17	DR. ARMIJO: Well, one, maybe two others,
18	but certainly not seven.
19	MR. MONNINGER: Well, the objective is to
20	clearly go in and evaluate the models, and say these
21	models are good for these purposes. And if that ends
22	up that a couple of models aren't good for any
23	purposes, so be it, but it may end up that two models
24	are potentially equally acceptable for a given
25	purpose, but good enough.
I	

(202) 234-4433

	71
1	DR. ABDEL-KHALIK: Whatever program you're
2	going to do at Halden, have you found a volunteer
3	utility that would allow the NRC/the rest of the
4	industry to do exactly the same thing on their
5	simulator, and find out whether you actually get the
6	same results? I mean, allow a totally independent
7	team to just observe. I mean, you have five crews that
8	go through simulator training once every six weeks,
9	you have three or four hot license trainees, you have
10	shift technical - you have a lot of people going
11	through the simulator. And I'm sure you'll find a
12	volunteer utility that would allow an independent
13	observation team to go through and watch what's going
14	on, and essentially collect similar data to whatever
15	you are going to collect at Halden, and see whether
16	it just would be a sanity check as to whether or not
17	what you're collecting is really meaningful.
18	DR. LOIS: This is within our objectives.
19	We would like to have repeated experiments, preferably
20	in U.S. plants, and we hope that the utilities will
21	volunteer to have the experiment. So the actual study
22	we're piloting, we hope it will include experiments
23	where you use different scenarios and different
24	plants, we hope.
25	DR. APOSTOLAKIS: Jeff, do you think that
ļ	

(202) 234-4433

	72
1	EPRI can help with that?
2	MR. JULIUS: Yes. My knowledge on this
3	one was that the Halden folks have come out and
4	participated for the last two years in our annual EPRI
5	HRA User's Group meeting, and that at least one
6	utility has gone over and volunteered to participate
7	in the experiment there. What I don't know is to what
8	extent they have discussed this idea of taking them
9	back and re-running the experiments on the utility
10	simulator in the United States. That sounds like a
11	good idea, but I don't know if that's been discussed
12	yet or not.
13	DR. WALLIS: Let me ask you something very
14	specific. How will Halden help you evaluate ATHEANA?
15	ATHEANA assumes that highly trained staff using good
16	guidance just do not make random or inadvertent
17	errors. Now how can you test
18	DR. LOIS: So the experiments, we have
19	DR. WALLIS: And they also use expert
20	DR. LOIS: Including more complicated
21	scenarios, and simpler scenarios, so that's one way to
22	evaluate that.
23	DR. WALLIS: I think you ought to give us
24	some sort of a matrix which says how the Halden tests
25	will evaluate these various seven methods.
Į	

(202) 234-4433

	73
1	DR. LOIS: Absolutely. We haven't
2	we're not briefing you today on the pilot, on the
3	empirical study. It will take a few hours to brief
4	you on how we set up the experiment, what are the
5	measures, how we would interpret the results. And
6	we're here to tell you that we have that study. We'll
7	be more than happy to brief you on another day.
8	DR. WALLIS: But it seems to me the key
9	test, isn't it, the only test?
10	DR. LOIS: We hope we are doing - we are
11	designing the study appropriately, and we will be more
12	than happy to brief you on it.
13	DR. APOSTOLAKIS: I think you should give
14	more emphasis to the actual operating experience. I
15	have found the augmented inspection team reports to be
16	extremely useful when it comes to operator actions and
17	so on. The LERs are not that useful, but any time
18	there is something serious at the plant, they send a
19	special team, and these AIT reports are really great.
20	They go into a lot of detail, and I would give them
21	equal weight.
22	I get the impression from this, maybe it
23	was not intended, that you are relying on the Halden
24	experiment a lot, or 90 percent. But I would say
25	DR. LOIS: This is the first actual
I	I

(202) 234-4433

	74
1	testing of the methods with the same data.
2	DR. APOSTOLAKIS: I understand that, and
3	I think it's a very important task, but I would also
4	emphasize everywhere I could that the AIT reports, for
5	example, will be a very important input here, because
6	they tell you what happened in real settings. And
7	there may be another interesting result would be to
8	look at what happened, and maybe compare with what you
9	get, if you could, from Halden, and say something,
10	because this issue of the relevance of simulator
11	results is always there. I would give it a little
12	more
13	DR. LOIS: Thank you very much for that.
14	Ten years starting from now I'll be
15	DR. APOSTOLAKIS: Why do you guys keep
16	bringing up that. I mean, we're talking about the
17	technical content of the results.
18	DR. LOIS: Definitely, we
19	DR. APOSTOLAKIS: We don't get involved in
20	
21	dR. ABDEL-KHALIK: I would carry this idea
22	a little further in a sense, if you have a detailed
23	report prepared following a specific incident at a
24	specific facility, why don't you go back and apply
25	these reliability models to that specific incident,
I	I

(202) 234-4433

and see what would they predict, what they would have predicted?

Well, the majority of the 3 MR. PERRY: 4 methods are really methods for quantification of human 5 error probabilities. One event does not make a human error probability, particularly because you don't know 6 7 what the denominator is. All you've got is one data 8 point, so you can't really do that. But what you 9 could do with that information is to try and understand the influences that made the errors, and 10 that's where I think you'll get the qualitative 11 12 information that will support the models.

DR. APOSTOLAKIS: Also, not only the inferences, but also, what they actually did, because both SHARP and ATHEANA worry about these things. And that qualitative information is extremely valuable.

DR. ABDEL-KHALIK: But observing what happens in a simulator to all the crews over a oneyear period would give you enough events in the denominator to allow you to estimate reasonable probabilities.

22 MR. PERRY: Yes, and that's -- well, I 23 don't if it will ever get you the probabilities, but 24 it would certainly give you a lot of information. But 25 you've got to also understand that that's a very

> NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433

1

2

	76
1	expensive undertaking.
2	CHAIRMAN SHACK: I mean, that data is
3	collected, isn't it? I mean, that would seem, to me,
4	a fairly a relatively inexpensive exercise, to
5	essentially record those results, and just put them in
6	a database somewhere.
7	DR. APOSTOLAKIS: Which results are these?
8	CHAIRMAN SHACK: The simulator results
9	from all the tests, just build a database of that.
10	MR. PERRY: It depends whether you
11	well, you also need a lot of qualitative information,
12	and that may be the
13	CHAIRMAN SHACK: That may be the difficult
14	part.
15	MR. PERRY: That may be the difficult
16	part.
17	DR. LOIS: But, indeed, we have what we
18	call the HERA project, which has developed a structure
19	to collect data. And if we collaborate with the
20	industry, it will be much easier to collect that
21	information, and create a database which will allow to
22	test the methods on the basis of this empirical data.
23	So it may be possible, and we will take those
24	recommendations in our planning.
25	DR. APOSTOLAKIS: I guess the comments you
I	I

(202) 234-4433

	77
1	are getting are going to the direction that there is
2	a lot of information out there that should be
3	integrated into this, and not just the Halden
4	exercise.
5	DR. LOIS: And probably, I have over-
6	emphasized the empirical study since we're having data
7	collection efforts
8	DR. APOSTOLAKIS: You're excited.
9	DR. LOIS: for the same purpose.
10	DR. APOSTOLAKIS: Right. Eighteen, let's
11	make sure we go through this.
12	DR. LOIS: So we believe that we should -
13	I don't know - prioritization of items, if we go ahead
14	with the collaborative effort. We should some
15	activity should be in parallel. EPRI is participating
16	in the empirical study, and review of the regulatory
17	applications with respect to the influence, or the
18	importance of HRA results should be a priority. This
19	will clarify, at least, where we should pay attention
20	up front.
21	Assuming that the MOU is approved, the
22	review of the applications will be rather short-term
23	activity, establishing common terms and integrated
24	approach. Probably, we may be able to establish a
25	preliminary framework, one that we agree up front
I	I

(202) 234-4433

	78
1	earlier, but it seems to be at least about two years
2	effort. And in addressing emerging needs, should we
3	determine from the regulatory and agency needs, for
4	example, there is work, some work planned on HRA work
5	for advanced reactors. At this time it's NRC
6	dependent work. I don't know if it would be possible
7	to do this as a collaborative effort. It all depends
8	on what the MOU will allow us to do. With that, I
9	would like to thank you very much.
10	DR. APOSTOLAKIS: But you don't have
11	anything about the timing, or the time in which you
12	will actually respond to the SRM. When are we going
13	to have one, or two, or three models appropriate for
14	the application? That's what they are asking. Is
15	that three years, four years? I mean, this is the
16	scheduling of the EPRI proposed tasks.
17	DR. LOIS: Yes.
18	DR. APOSTOLAKIS: Now if the Commission
19	asks, we asked you to propose either a single model,
20	or guidance
21	DR. LOIS: So then this is the certain -
22	establishing common terms and integrated approach will
23	be in about 10 years.
24	DR. APOSTOLAKIS: So in about two years,
25	we'll have the answer. Okay.
I	I

(202) 234-4433

	79
1	DR. LOIS: We believe that we'll have the
2	answer.
3	DR. APOSTOLAKIS: Okay. And you have a
4	slide that's called conclusions. Do you want to
5	address that?
6	DR. LOIS: Sure.
7	DR. APOSTOLAKIS: Nineteen, or you have
8	already covered it?
9	DR. LOIS: I think I have.
10	DR. APOSTOLAKIS: Okay. So are there any
11	comments or issues that members will want to - or
12	maybe the staff wants to say a few words. John?
13	MR. MONNINGER: No. I guess just from the
14	start, I think it is very important for us to
15	understand the ACRS' issues and concerns, and we
16	definitely appreciate the guidance and advice that
17	you're providing.
18	In terms of schedules and resources, we
19	tried to give a rough estimate. Now one of the
20	things, you know, this hasn't always been within our
21	planning horizon. This is essentially a new task, so
22	currently it is not in our budget, so what we have to
23	do is, we have to look at this in terms of, is it high
24	priority, medium, low? What other projects do we have
25	ongoing? What can potentially be shed, slowed down,
ļ	I

(202) 234-4433

	80
1	et cetera, so to a certain extent, we're trying to
2	work the budget, we're working the schedule, we're
3	trying to work the MOU, the approach, et cetera.
4	I'm not sure what the ACRS will propose
5	back to the Commission, but I wouldn't see that within
6	a four, five, six month time frame the ACRS - well, I
7	don't want to put words in your mouth. It would seem
8	to be extremely difficult to say that going forward
9	there should be one model, or these are the three
10	within the six, seven months that the ACRS was given.
11	I think it would be fair to say that - something along
12	the lines as an approach has been developed, the
13	notion of working collectively with stakeholders, if
14	possible, something along those lines would be
15	appropriate.
16	I mean, I think the question is whether
17	the conceptual framework laid out will ultimately lead
18	us into a decision to coalesce around a few models or
19	not. I think that's very important as to what
20	DR. APOSTOLAKIS: At this stage, I think
21	the most we can say - we'll discuss this this
22	afternoon - we, essentially, comment on the plan.
23	Right? That's the only thing we can comment on. And
24	I realize and appreciate that you have your own
25	problems regarding budget and all that.

(202) 234-4433

1 Okay. Any other comments, or any 2 suggestions? I think the common terms that Jeff 3 proposes, doing that would be a very important thing 4 to do. Just stating, it seems to me, assumptions 5 without evaluating them, and whether they're reasonable or not, is not really very useful, so I 6 7 hope that this is what you guys are going to do, this 8 joint team. 9 And, also, I will repeat - when I reviewed the EPRI documents, and also, we were told here, both 10 11 Jeff and Mr. Elawar, who is the utility by 12 representative with EPRI, they really tried very hard to develop a method and put in their computer that 13 14 would help an average PRA quy include human 15 reliability in the PRA. And the price you pay for that is that you are not as rigorous as maybe another 16 method. You proceduralize the process too much. 17 I think in a lot of cases, this is a good 18 19 thing to do, because otherwise, you scare people away, 20 if you tell them they have to do expert opinion 21 elicitation all the time. So this is something that 22 I think should really be discussed among the group. And, in other words, it's not just a theoretical needs 23 24 to be rigorous and so on, you have to address the 25 practical issues, too. Okay?

> NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433

(202) 234-4433

81

	82
1	DR. WALLIS: Practical issues are
2	paramount, George.
3	DR. APOSTOLAKIS: What?
4	DR. WALLIS: The practical issues are
5	paramount.
6	DR. APOSTOLAKIS: Of course, yes. So it
7	really should be something that you should have as
8	part of the deliberations.
9	DR. ABDEL-KHALIK: Can I just summarize my
10	
11	DR. APOSTOLAKIS: Absolutely, Said. I was
12	expecting you to do it.
13	DR. ABDEL-KHALIK: observations.
14	Number one, I think sort of following up on something
15	that Mike brought up, I think it would be a good idea
16	to establish a set of standard problems against which
17	various models could be compared.
18	Number two, I think it would be a good
19	idea to establish a goal, that by the end of `08, that
20	the agency will publish a NUREG on the application of
21	various human reliability models consistent with the
22	goal of the December `08.
23	And the third thing, just to make the
24	Halden experiment worthwhile, recommend that one or
25	more volunteer utilities should be sought to

(202) 234-4433

	83
1	essentially duplicate the program at their own
2	simulator facilities, so that the validity of that
3	data can be further checked. Those are my
4	observations.
5	DR. ARMIJO: Basically, run that same set
6	of problems.
7	DR. ABDEL-KHALIK: Correct.
8	DR. MAYNARD: I'd like to add just a
9	couple of comments along Said's. First, I would like
10	to see some stronger goals set for completion. I'm
11	concerned that two, three, four years from now we may
12	be sitting here, especially when you get into
13	collaborative efforts, and a lot of different people
14	involved, and if we keep taking a long time, that you
15	have to question do we really need it, because they've
16	already made a lot of decisions between now and then.
17	So I'd like to see some stronger commitment, stronger
18	goals scheduled. And I would like to see a little bit
19	stronger desire to reduce the number. I don't really
20	get the feeling that everybody is willing to reduce
21	it. And I think that seven models and what we're
22	doing is not manageable. And I think we may be trying
23	to make too scientific a non-scientific action of
24	human performance.
25	I would really go along I think we'd be
ļ	I

(202) 234-4433

	84
1	better off if we establish some criteria that
2	utilities started gathering on their simulators,
3	because they're running simulator scenarios all the
4	time. And I think you'd actually end up with a better
5	database to use numbers to plug in. You actually end
6	up with site-specific PRAs, numbers, human reliability
7	numbers to plug in. So I think from a practical
8	sense, that that would actually give you better data
9	to use in your PRAs.
10	DR. BONACA: Well, many utilities have
11	already done that in a way. I mean, their PRAs,
12	they've really based a lot of decisions on operator
13	action probabilities coming from PRA observations.
14	DR. MAYNARD: If they're running simulator
15	scenarios every week, sometimes the crews knows what's
16	coming, most of the time they don't, especially in the
17	distractors and stuff, but there could be a set of
18	criteria put out in what you measure. And maybe
19	there's one scenario a week or something. Over time,
20	with the time that we've invested in these HRA models,
21	if we would have started gathering data, we would have
22	a database right now that would be very large, and
23	probably much more reliable for what number do we use
24	in a PRA.
25	Those may not help you, particularly from
I	

(202) 234-4433

	85
1	a human reliability, from a design standpoint of how
2	do you reduce human error, but as far as for a number
3	to plug into a PRA, I think it would give you better
4	data.
5	DR. KRESS: Do you see this as a voluntary
6	program from all the utilities? You can't say go do
7	this, you know.
8	DR. APOSTOLAKIS: Gareth.
9	MR. PERRY: Yes. I've got a couple of
10	comments. First of all, on the standard problem, I'm
11	not really sure what you mean by that, because, in
12	fact, in terms of the quantification of human error
13	probabilities, I don't think we have a database to
14	compare with set of standard problems. For example,
15	we don't have a database that will tell us that the
16	probability that operators fail to evidence, operators
17	fail to initiate SLIC during an ATWIS in a boiler, for
18	example. So that's one difficulty; otherwise, what
19	you're doing is you're just getting comparisons of
20	methods for a standard definition of a human failure
21	event.
22	DR. ABDEL-KHALIK: What is the basis,
23	then, for selecting the research program at Halden?
24	What elements of the program?
25	MR. PERRY: I'm not sure about that. I'm
ļ	I

(202) 234-4433

	86
1	not involved with that program, so I'm not going to
2	respond to that. But let me, also, add a couple of
3	other thoughts, which I think might have been missed
4	in here; and that is, that there are two aspects to
5	human reliability analysis. One of them is to
6	identify the right human failure events to put in the
7	model. That aspect of it is not addressed by the
8	quantification models, which is the I think,
9	principally, what we've been focused on.
10	The identification of human failure events
11	is a function of SHARP-1, and it's a function of
12	ATHEANA. It's a very important function. It's also
13	addressed in the ASME standards. These are the things
14	that you need to do to make sure that your logic model
15	correctly reflects the use of the procedures by the
16	operating crews. That aspect has to be done
17	correctly.
18	The quantification aspect of it, the
19	important thing there, given that you've identified
20	the events, is that the probabilities of the various
21	human failure events is ranked appropriately according
22	to the factors that determine the probabilities.
23	And in terms of applicability of PRA and
24	the results to decision making, I think what we need
25	to do is to establish whether a method is good enough
I	I

(202) 234-4433

to provide that ranking, given that the structure of the logic model is correct. Then we can deal with uncertainties and the absolute values of those probabilities by performing sensitivity studies,

things like that. So I think you have to put this thing in the context of PRAs, how they're being used, and how they're being developed.

8 The important task of understanding how 9 the operators interact with the plant as the accidents 10 are developing, I think is probably well-addressed by 11 ATHEANA and SHARP-1. George mentioned that. And what 12 we're really dealing with is differences in the 13 methods of the quantification.

DR. APOSTOLAKIS: But the question then --I like that description, and I think Said's question - having said all this, this is the objective. How is Halden going to help me address both, or one of them, or parts of one, parts of the other? This is really the idea of designing experiments.

20 MR. PERRY: Right. And that's a good 21 question. 22 DR. APOSTOLAKIS: I would go beyond that, 23 come back to my earlier comment. And how are the AIT 24 reports going to help me in the first or second, as

you said, most likely the first one, the qualitative

NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433

25

1

2

3

4

5

6

7

part, because you actually see what they did in particular situations. I think that would be -- it would be a nice slide to have a matrix of some sort that identifies the basic elements of the HRA, and how each one of these sources of information will help us. That would be a very nice thing to do in a future presentation.

This is Jeff Julius. 8 MR. JULIUS: Yes. 9 I believe, and Erasmia can correct me if I'm wrong, I mean, that's why the Halden is set into these phases. 10 And the first phase is to look at some data that's 11 12 already been collected, and decide the usefulness of And we do that in the context of making some 13 it. 14 predictions, so we make some predictions. Then we see how useful it is, and that will influence how we 15 continue on in the subsequent phases. 16

Exactly. I guess, given the 17 DR. LOIS: breadth of the issues that we have with HRA, we have 18 19 a very small scope experiment here. Let's see how we 20 quantify human failure events for very well described 21 human failure scenarios. So that will give us the 22 understanding of how well, if different methods can 23 predict failures within this analysis, and also, how 24 the methods are applied. We haven't done that. This 25 will give us the opportunity to understand how

> NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433

1

2

3

4

5

6

7

	89
1	different analysts use their methods to come up with
2	human error probabilities, to identify potential
3	performance, certain factors that influence, believe
4	that they influence the performance, et cetera. So
5	this is assuming that we'll have some insights on
6	that aspect, which actually that aspect will be the,
7	what I call the pilot ending the real experiment, then
8	we may we'll have to expand. And assuming that
9	that's a success, we will have to expand to these
10	other issues, how the ATHEANA concept, or the SHARP
11	concept, identifying potential human failure events
12	given this scenario, what are the potential deviations
13	from the expected scenario, et cetera.
14	It will be a big experiment, and we'll
15	take very small steps to go forward. That, I agree,
16	should be these efforts should be complemented or
17	supplemented by the use of operational experience
18	data, and we are collecting those; and, therefore, we
19	have to in the collaborative efforts include that
20	aspect of it, so that we build it from both
21	DR. APOSTOLAKIS: But if you look at the
22	experience with PRA over the last 30 years, the
23	beginning, we really worried a lot about failure
24	rates, and propagating the uncertainty and all that.
25	Slowly, the importance of that decreased, because
I	1

(202) 234-4433

(202) 234-4433

people realized that the major source of uncertainty is actually predicting the scenarios. If you miss one scenario, you are in deep trouble. And whether the failure rate has a 95<sup>th</sup> percentile here or there, is more or less irrelevant.

Then, of course, the issue of common cause 6 7 failures became very important, and so on, and so on. And I suspect here, too, eventually what will dominate 8 is our ability or inability to identify what they will 9 do, rather than quantifying something that we have 10 already identified they will do. So you are 11 12 approaching it first from the quantification part, think that eventually identifying 13 where Ι the 14 scenarios will really be the big driver, because they 15 may do something that is completely unexpected, and is not there in the PRA, and so on. But that's where 16 17 operating experience can give us some advice, the qualitative part. And is there any reason, maybe it's 18 19 budgetary reason, why have we to focus on quantification first, and then do the other? 20 21 DR. LOIS: Actually, we have ongoing --22 DR. APOSTOLAKIS: Can do both. 23 DR. LOIS: Because we have the HERA. 24 DR. APOSTOLAKIS: The HERA, yes. 25 DR. LOIS: We're collecting information.

> NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433

1

2

3

4

5

(202) 234-4433

90

Í	91
1	We have this empirical study going on.
2	DR. APOSTOLAKIS: Yes.
3	DR. LOIS: We haven't been collaborating
4	with EPRI on these issues. If we do
5	DR. APOSTOLAKIS: You could.
6	DR. LOIS: it will help us to expedite
7	
8	DR. APOSTOLAKIS: One last comment,
9	because we're running out of time. I really think
10	what Dr. Abdel-Khalik said is important, and others,
11	I sense, feel the same way. Can we have some guidance
12	by the end of `08, even if it's not perfect?
13	MR. MONNINGER: I guess
14	DR. APOSTOLAKIS: You have to think about
15	it.
16	MR. MONNINGER: Yes. Thank you.
17	DR. APOSTOLAKIS: Any other comments from
18	the members? Okay. Thank you. Back to you, Mr.
19	Chairman.
20	CHAIRMAN SHACK: With 30 seconds to go,
21	George. What timing.
22	DR. APOSTOLAKIS: Don't forget, you
23	started late.
24	(Laughter.)
25	CHAIRMAN SHACK: I think it's time for a
ļ	I

(202) 234-4433

	92
1	break until 10:45.
2	DR. APOSTOLAKIS: Very good.
3	(Whereupon, the proceedings went off the
4	record at 10:29:53 a.m., and went back on the record
5	at 10:47:38 a.m.)
6	CHAIRMAN SHACK: It's time to come back
7	into session. Our next topic is Proposed Revision to
8	Standard Review Plan Section 4.2 on Reactor Fuels, and
9	Sam Armijo is going to be leading us through that.
10	DR. ARMIJO: Okay. Thank you, Mr.
11	Chairman. Earlier this week, the Materials,
12	Metallurgy and Reactor Fuel Subcommittee met with the
13	staff, and also representatives of the industry to
14	review the plan. This is a major update and revision
15	of the standard review plan, and it has many changes,
16	all developed from experience, and from research.
17	And, in general, my personal opinion, a very good
18	update.
19	There are parts of it that are some
20	criteria, particularly in the RIA criteria that are
21	interim criteria, and so parts of this Standard Review
22	Plan are for application exclusively to new plants.
23	However, there are nuances, and I've asked the staff
24	to make it clear what parts of the SRP would be
25	applied to existing plants, what parts would be

(202) 234-4433

applied to fuel only in new plants. And, also, if they can, what they believe will be the time scale for the application of the RIA criteria to existing power plants. So with that, we're going to have roughly about an hour of presentation by the staff, about half an hour presentation from industry representatives. With that, I'll turn it over to Tony.

8 MR. MENDIOLA: Good morning, everyone, and 9 please excuse my voice and my breathing pattern. I'11 10 try to make myself clear as much as possible. Anyone who doesn't know me, my name is Anthony Mendiola. 11 I'm 12 the Chief of the Nuclear Performance and Code Review Branch, a position I've only held for about a month. 13 14 Some of this information is new to me, as well as new 15 to me, of course, as making presentations in front of the ACRS Full Committee, as well as my staff making 16 the first presentation in front of the Full Committee 17 themselves. 18

19 The purpose of today's briefing is to 20 provide information to the full committee about 21 revisions to Standard Review Plan Section 4.2, Fuel 22 This presentation will be two parts. System Design. 23 The first part is fundamentally just the actual 24 revisions to the SRP Section 4.2 that have been made, 25 capturing a variety of data that has been and

> NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433

1

2

3

4

5

6

7

	94
1	collected over time. And providing staff guidance on
2	the review of new fuel system designs based on
3	information that we receive from industry operating
4	experience over the past several years, fuel research
5	programs, both foreign and domestic, as well as
6	information associated with advanced fuel designs and
7	advanced cladding materials.
8	That presentation will be conducted by Dr. Shih-Liang
9	Wu, and we'll go through each of the changes that have
10	been effected into SRP Section 4.2.
11	The second part of the presentation, and
12	the bulk of the presentation will be led by Mr. Paul
13	Clifford, who is going to discuss the reactivity-
14	initiated accident interim criteria. These criteria
15	is what we are going to apply to current ECD
16	applications and COL applications. Specifically, the
17	ones we expect to get in about a six month time
18	period. And it was associated with having those
19	criteria set forth prior to the applications, which we
20	expect to receive later this year.
21	DR. WALLIS: These apply to new reactors?
22	MR. MENDIOLA: The interim criteria.
23	DR. WALLIS: Don't apply to old reactors.
24	MR. MENDIOLA: Not at this time. No, sir.
25	We do not anticipate applying
I	

(202) 234-4433

(202) 234-4433

	95
1	DR. WALLIS: You're developing something
2	that applies to something that doesn't exist, and
3	you're not doing anything about what does exist?
4	MR. MENDIOLA: The interim criteria are
5	made to apply to the applications we expect. The
6	final criteria, which we're still in development of
7	with fundamentally getting more test data.
8	DR. WALLIS: So if they're more
9	restrictive than you have on existing plants, one
10	might ask why they're not applied to existing plants.
11	MR. MENDIOLA: That's the determination
12	the staff has yet to make, is how to apply the final
13	criteria to the operating fleet. And we expect that
14	that will be a majority of the work that we have in
15	front of us with this information with this
16	reactivity-initiated accident criteria.
17	As I mentioned, our action with the
18	criteria has to do with developing the criteria to
19	support new reactor licensing. We've interfaced with
20	the industry, thus far, with two public workshops,
21	both conducted late last year, and received a variety
22	of comments in preparation for the interim criteria,
23	which we established as part of Appendix B of the SRP,
24	Section 4.2. This provides fuel cladding failure
25	criteria, core coolability criteria, and radiological
l	I

(202) 234-4433

	96
1	source term information to apply to the DCD
2	applications and COL applications.
3	We are currently, as I mentioned,
4	finalizing this criterion guidance, and will make, of
5	course, the revisions to the impacted Reg Guides, and
6	have all this information readily available, as well
7	as an implementation schedule to provide and apply
8	these criteria to the operating fleet, as well.
9	DR. WALLIS: I'm still puzzled by this new
10	fuel reactor licensing. I mean, the criteria are
11	presumably based on fuels which are used today, or
12	they're anticipating different kinds of fuels?
13	MR. MENDIOLA: They're anticipating
14	different kinds of fuel, different reference fuels.
15	DR. WALLIS: That's the real motivation
16	for it, is it?
17	MR. MENDIOLA: To apply the information
18	we've learned over the years to the new fuels that we
19	expect to get application.
20	DR. WALLIS: And not to apply to what
21	we've got today.
22	MR. MENDIOLA: Not at this time, not until
23	we acquire more data.
24	DR. WALLIS: I'm still trying to figure
25	this out.
Ĩ	

(202) 234-4433

97 1 DR. ARMIJO: The way I understand it, 2 Graham, is the -- particularly in the RIA issue, the interim, but the new 3 criteria are still plant 4 applications need something to guide them. It's 5 recognized, I think, that there's a lot of conservatism, or maybe more conservatism than the 6 7 staff ultimately will believe is necessary, so they want to start with a conservative set of criteria so 8 9 the new plant designers can get to work. 10 DR. WALLIS: What do you mean by "new plant" then? Is AP1000 a new plant? 11 12 MR. MENDIOLA: Yes. DR. WALLIS: And ESBWR is a new plant. 13 14 MR. MENDIOLA: Yes. 15 DR. WALLIS: Okay. DR. MAYNARD: It would be anybody who 16 17 hasn't made an application yet. 18 MR. MENDIOLA: Correct. 19 DR. ARMIJO: On the other side, as far as 20 existing plants, it wouldn't make a lot of sense the 21 to apply interim criteria to existing fuel and 22 existing plants that are more conservative than they 23 need to be, so better settle apply the final criteria 24 to the existing plants on a time scale that makes 25 That was the logic -sense.

> NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433

	98
1	DR. MAYNARD: You also have different
2	regulatory requirements to impose a new requirement on
3	the existing plants, the existing licensees, a process
4	they have to go through to
5	DR. ARMIJO: It's a little more
б	complicated. But, technically, the logic makes
7	DR. WALLIS: In a way, it's a roundabout
8	way of signaling to the existing plants that you're
9	going to have new criteria.
10	DR. ARMIJO: Yes.
11	MR. MENDIOLA: Absolutely. Yes, sir.
12	DR. WALLIS: Okay. Thank you.
13	CHAIRMAN SHACK: Is Watt's Bar, if it's
14	completed a new plant?
15	(Laughter.)
16	DR. ARMIJO: I asked the staff to kind of
17	you know, there are going to be a lot of nuances to
18	the new SRP, when does the new SRP apply? And that
19	these kind of questions are going to come up, and I
20	asked them to the extent they can, just to clarify
21	that.
22	DR. KRESS: Well, speaking of reactivity
23	insertion accidents, would you include among those
24	void induced reactivity excursion in a liquid metal-
25	cooled reactor?
l	1

(202) 234-4433

	99
1	MR. CLIFFORD: Well, it is kind of a
2	general term, reactivity-initiated. The BWR has
3	reactivity-initiated from a turbine trip, but it's the
4	pulse width characteristics that separates these type
5	of events.
6	DR. KRESS: Yes. You would have an
7	entirely different situation with the liquid metal-
8	cooled reactor. It could not meet these criteria, I'm
9	sure.
10	MR. CLIFFORD: I don't believe that the
11	staff believes that these criteria applies to anything
12	by light water reactors.
13	DR. KRESS: I appreciate that
14	clarification.
15	MR. LANDRY: Mr. Chairman, if I may, it's
16	Ralph Landry from the staff. The timing on this is
17	according to the requirements of 10 CFR Part 52. Part
18	52 requires that a COL application be reviewed under
19	the guidance of the SRP section in effect six months
20	before the COL application is made. Therefore, all
21	the new plants which will be coming under COLs in the
22	fall have to have the SRP sections in place today.
23	A new old plant, or an old new plant,
24	however you want to term it, like Watt's Bar, would
25	still be a Part 50 plant. It is not coming under a

(202) 234-4433

	100
1	COL application, and under Part 52. If that comes in,
2	it will be coming in under a Part 50 review, so that
3	is not bound by the requirements of Part 52 and COL.
4	DR. ARMIJO: Thank you, Ralph.
5	MR. MENDIOLA: Fundamentally, that
6	concludes my comments. I'd like to turn over the
7	presentation to Dr. Wu to go through the changes to
8	the SRP Section 4.2.
9	DR. WU: My name is Shih-Liang Wu. I will
10	present the majority of the Section 4.2, except
11	Appendix B, which is going to be presented by Paul
12	Clifford.
13	Let me just comment that besides in a new
14	reactor and an old reactor, that's when we're going to
15	apply those. I mean, one of our concern is whether
16	the Section 4.2, the new version of it March, year
17	2007, is going to apply to where they're going to
18	apply a new field design. I think the impression is
19	we are going to apply to new fuel designs, but not
20	existing fuel designs. For example, if you have like
21	the G has I think right now currently the Gs, 14 or
22	15. They have Gs 17, then we apply this new criteria
23	of Section 4.2 to their field design, except Appendix
24	B, which they make a different schedule.
25	DR. WALLIS: It's interesting, I haven't
I	I

(202) 234-4433

	101
1	seen this yet, but the data on which you base this is
2	presumably based on the existing fuels.
3	DR. WU: Yes.
4	DR. WALLIS: You're going to apply it to
5	something else.
6	DR. WU: Yes. According to our
7	experience, I mean, the lessons learned, the industry
8	and those in the international theater, so research.
9	CHAIRMAN SHACK: We have a lot of material
10	to get through. Maybe we could get through this part,
11	and then move fast.
12	DR. WU: Okay.
13	DR. WALLIS: Get to the technical stuff.
14	CHAIRMAN SHACK: Right.
15	DR. WU: I'll go to the next slide. Well,
16	the structure we have run as a design basis, we have
17	fuel systems damage, and a fuel rod failure, and a
18	fuel coolability, three categories. And then start on
19	fuel system damage. Now those are light blue color,
20	that means we made a significant change, and those -
21	dark colors means that we didn't make any either we
22	did not make any change, or a change was very
23	insignificant. So let me go to the next one.
24	The first one is the oxidation hydriding,
25	and crud. In the past, we specify only that all these
I	

(202) 234-4433

1 effect in the thermal behavior should be considered, 2 so the new criteria is you need to specify the limits in terms of oxidation and hydriding. 3 And then all these limits has to be based on mechanical testing to 4 5 show adequate strength and ductility. And in most cases, the industry did not distinguish between 6 7 oxidation and crud, so in essence, we just -- if it 8 was along with oxidation with crud, that is also 9 acceptable for us.

10 The next slide. The dimensional change is the old rod bow and the old irradiation growth, that 11 The new phenomena is recently, I 12 was the old story. think, we discovered was in the BWR channel box. 13 Now 14 the phenomena is the BWR channel box in the past, they can cause BWR due to differential irradiation growth, 15 16 and stress relaxation. The new phenomena we found out is a shadow corrosion in the channel box. 17 And shadow corrosion we're causing the channel box to bow forward 18 19 from control blade, which it causes the control blade 20 insertion, I mean, friction.

21 DR. BANERJEE: Well, what is shadow 22 corrosion? 23 DR. WU: In this case, is the -- because 24 in the BWR they got the control blade deeply inserted 25 through the cycle, so when they pull out, it comes up

> NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433

	103
1	like they find that the channel box has a shadow,
2	which is a cruciform of the shadow. And then those
3	are corrosion product, and then got extensive hydride.
4	MR. CLIFFORD: The BWRs, if they have deep
5	insertions of their cruciforms, which are stainless
6	steel clad, and they reside next to the Zirconium
7	channel box for an extended period of time, there is
8	some belief a galvanic reaction causes corrosion
9	DR. CORRADINI: Like a small
10	electrochemical set, big electrochemical set, small
11	potential, big area, sorry. I apologize.
12	DR. ARMIJO: But the net effect, Said, is
13	that there's more oxidation on one side of the channel
14	than on the other side, and you also have more
15	hydrogen pickup that causes more actual elongation on
16	one side than the other, and you wind up bowing
17	towards getting interference with the control
18	blade. We're working on different
19	DR. WU: The side with the shadow
20	corrosion where the bolt hold the control blade. So
21	this is what we call in industry lesson learned, and
22	then we incorporate into the recent change to SRP.
23	And that's based on this, so we put this new
24	requirement, and then, also, the fourth item we
25	measure for BWRs we may require testing and
I	I

(202) 234-4433

	104
1	surveillance to ensure the control blade has
2	insertibility. But in actuality, the industry already
3	make recommendation here. Next slide.
4	The next one is the rod internal gas
5	pressure. And then in the past, we always don't
6	show no exceed system pressure, the first item. But
7	in the cultural history, actually, we already allow
8	the rod pressure to exceed system pressure, but based
9	on three different criteria. The first one is a no
10	cladding liftoff. That means no cladding moved away
11	from the field. The second one
12	DR. WALLIS: I'm sorry. By "system
13	pressure", you mean operating pressure on the
14	DR. WU: Yes, the right, the reactor
15	coolant system pressure.
16	DR. WALLIS: What happens when you reduce
17	the pressure? You don't care about that?
18	DR. WU: No, no. We are talking about
19	this junior operation.
20	DR. WALLIS: Well, presumably, if there's
21	pressure inside and you relieve the outside pressure,
22	you might get cladding liftoff.
23	MR. CLIFFORD: That's specifically
24	analyzed as part of the design analysis. It would
25	evaluate both long-term steady state.
I	

(202) 234-4433

	105
1	DR. WALLIS: Okay, but it doesn't seem to
2	be addressed by the slide.
3	DR. WU: Yes. I mean, this analysis is
4	not that simple, because all the vendors submitted
5	their methodology report, and then analyze all the
6	different scenarios to make sure that no cladding
7	liftoff. And then the second is no hydride
8	reorientation in a radial direction. And the third is
9	no hydride reorientation in a radial direction, so
10	they have demonstrated that in order to allow them to
11	exceed system pressure.
12	DR. WALLIS: So there's no cladding
13	liftoff, even when you've depressurized, and you're
14	moving the fuel around for reloading and all that?
15	MR. CLIFFORD: When you shut down, the
16	temperature drops, and the internal pressure drops
17	significantly.
18	DR. WALLIS: Okay. So that's what saves
19	you then.
20	MR. CLIFFORD: Yes. They do analyze a
21	transient where they would have a depressurization
22	over a period of time, and you would depressurize the
23	RCS towards the trip set point.
24	DR. WALLIS: So there's no cladding
25	liftoff under any circumstances.
I	I

(202) 234-4433

	106
1	MR. CLIFFORD: Correct.
2	DR. WALLIS: Thank you.
3	DR. WU: And then my understanding, all
4	the industry has already adopt the second criterion.
5	And the last item in the fuel damage is that control
б	rod reactivity and insertibility. The first one is
7	saying is a B4C material. You don't allow it to have
8	depleted B4C.
9	The second one is the change in control
10	rod configuration. If you change the shape of the
11	control rod. And then the third one, if you are
12	including new materials, any kind of new absorber.
13	DR. WALLIS: Third one, fourth one, what
14	are all these things? Are these things you analyzed,
15	or what?
16	DR. WU: Well, if you change these, it
17	would need to be reviewed by us.
18	DR. WALLIS: Need to be reviewed.
19	DR. WU: Yes. For example, the fourth one
20	is industry may allow to existing in a control rod, go
21	to a longer lifetime. But because they may change the
22	neutronic design, or may change the mechanical
23	lifetime for existing control rod. In that case, we
24	need to review that.
25	DR. MAYNARD: How much is included

(202) 234-4433

	107
1	mechanical design? I can see a whole range of
2	something very simple. Just saying the NRC would
3	have to review any mechanical
4	DR. WU: Well, depend on I guess
5	well, of course, depend on the situation, but let me
6	just mention that, for example, in the case of BWR,
7	they used to have control rod shield sheet, the
8	control blade. And then when the G introduced, they
9	call it maritime control blade, which is, in this
10	case, all stainless steel tube welded, using laser
11	weld. That's not sheet, so this is entirely different
12	mechanical design, because you guarantee, make sure
13	that all those welds the control - the timing rod has
14	to be in tact, so in that case, we would review that.
15	DR. MAYNARD: Okay. And I can understand
16	the big one. My concern is, I can envision some
17	pretty minor ones that I'm not sure would have to be
18	brought to the NRC.
19	DR. WU: Oh, yes. Well, in that case,
20	like changing roller blade, you know, the roller
21	blade, the roller yes, in that case we don't review
22	that.
23	DR. MAYNARD: Okay.
24	DR. WU: That's very minor.
25	DR. MAYNARD: Or it might be a very quick
ļ	I

(202) 234-4433

	108
1	review. You mean, it's a matter of
2	DR. WU: Well, just a general agreement
3	that they give us the information, and within 30 days
4	respond. If they don't respond it just expires
5	automatically.
6	DR. MAYNARD: I just want to make sure
7	we're not unnecessarily burdening them with reviews
8	for minor things.
9	DR. WU: No, no. Okay. So the next item,
10	we go to the fuel rod. So in this case, the blue
11	color has only three items. Now the first one,
12	excessive fuel enthalpy is referring to Appendix B,
13	which is going to be presented by Paul later on. And
14	then let me just go to the seventh item, first thing,
15	I would delay until we talk about the next one,
16	coolability, because in there, the fuel rod is
17	bursting, so in this case, I only discuss the items
18	number six, which is pellet-cladding interaction.
19	So the pellet-cladding interaction, in the
20	past we only talk about the PCI, which is pellet-clad
21	interaction, and causing by stress corrosion cracking.
22	And in the new version, we add on the PCMI, the
23	pellet-cladding mechanical interaction. And this is
24	a strength treatment, the fuel is pushing the
25	cladding, and then causing the
	1

(202) 234-4433

	109
1	DR. WALLIS: How about chemical reactions
2	between the pellet and the cladding?
3	DR. WU: Yes. Chemical is actually is
4	referring to as a general term, PCI is referring to
5	the
6	DR. WALLIS: Oxidation of the cladding
7	from the pellet. This is a very big area, this
8	pellet-cladding interaction. I don't quite understand
9	the you're going to talk about the rod insertion.
10	Isn't that the issue we're talking about?
11	DR. ARMIJO: That's the biggest issue.
12	DR. WALLIS: So why are we talking about
13	all these other things?
14	DR. ARMIJO: Which could be very
15	expensive.
16	DR. WALLIS: We keep going into these, we
17	could
18	DR. ARMIJO: Okay. We should probably
19	quickly on these.
20	DR. WALLIS: Because they all raise
21	questions.
22	DR. ARMIJO: These are ones where I think
23	there's no industry
24	DR. WALLIS: So we should be quiet about
25	these?
Į	

(202) 234-4433

	110
1	DR. ARMIJO: Probably a good idea.
2	(Laughter.)
3	DR. ARMIJO: Just for time, but not
4	because the questions aren't great questions.
5	DR. WU: That's right.
6	DR. CORRADINI: Masterfully done.
7	DR. WU: Okay. And then the PCI, the
8	general in PCI criteria is that we have 1 percent
9	strain limit and a no fuel melting, which is the old
10	story. But then in this case, the 1 percent strain
11	limit when you add on the mechanical testing will show
12	that irradiated cladding remained ductile to sustain
13	1 percent strain.
14	Now this is new in terms of that, because
15	in the past, we don't need to treat them with
16	irradiated cladding. Now in this case, referring to
17	irradiated cladding, which is because the high burn-up
18	effects.
19	DR. CORRADINI: So I'm going to turn to
20	Sam. So there's no industry issue here.
21	DR. ARMIJO: Well, if you can't make
22	cladding that'll strain 1 percent, then you shouldn't
23	be making fuel. They know how to do that. It just
24	makes it very clear what the
25	DR. WU: This was not a the high burn-up
	I

(202) 234-4433

111 1 issue, because, you know, high burn-up, and the 2 cladding may not be able to survive the --3 DR. CORRADINI: No, I understand that. So 4 just one FYI for me, so this is not new from the 5 standpoint that industry does do sort of -- does mechanical testing of irradiated cladding anyway, now. 6 7 MR. CLIFFORD: I can provide -- I have two fuel designs under review right now, and this issue 8 9 has come up, and they've provided the information to support their strain limit. So this is something 10 we've been doing for years. 11 12 DR. CORRADINI: Okay. Thank you. DR. WALLIS: It's not just irradiated 13 14 cladding, it's everything that's happened to the fuel, 15 which has affected the cladding. Let's not open that. 16 DR. CORRADINI: Yes. Right. 17 MR. WU: Okay. So the last item is the fuel coolability, and then there's three items. 18 The 19 second item, explosion of fuel is referring to Appendix B. 20 DR. WALLIS: Well, I'm not going to -- do 21 22 you know what fuel coolability means? 23 Cool geometry. DR. WU: 24 DR. WALLIS: I don't know what that means. 25 Well, in this case, I mean DR. WU:

> NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433

	112
1	whatever accident occurs, the fuel rod, the structure
2	cannot be changed.
3	DR. WALLIS: Aha, so you cool without
4	changing the structure.
5	DR. WU: That's what we call cool
б	geometry. The spacing cannot be changed, the fuel
7	cannot encounter each other. That's what we mean.
8	This cladding embrittlement, the criterion we didn't
9	change. Here we just mention that we could go to rule
10	making to implement a performance-based acceptance
11	criteria later on.
12	So the last item is fuel rod ballooning,
13	which is the same as the bursting in previously. And
14	NUREG-0630 is still there, and then they talk about
15	burst strain and flow blockage. We need to consider
16	during LOCA event.
17	Now the third bullet is referring to non-
18	LOCA event that is when we allow rod pressure to
19	exceed system pressure, there will be a tendency under
20	some other condition, it could have burst, causing the
21	similar effect in a LOCA condition, so whatever we
22	need to consider in a non-LOCA accident condition. If
23	there's no question, that completes my report.
24	DR. ARMIJO: Okay. Let's get into the RIA
25	issue.

(202) 234-4433

	113
1	MR. CLIFFORD: I guess I'm the headline.
2	DR. ARMIJO: Yes.
3	DR. WALLIS: Are we writing a letter on
4	the RIA thing?
5	DR. ARMIJO: We're writing a letter on SRP
6	4.2, which includes
7	DR. WALLIS: Are we writing a letter on
8	all those things we just went through so quickly, we
9	couldn't ask any questions?
10	DR. ARMIJO: But the focus is on this one,
11	since this the only part
12	CHAIRMAN SHACK: You could have come to
13	the subcommittee meeting.
14	DR. ARMIJO: That's true, but that's what
15	we're doing.
16	DR. WALLIS: Thank you.
17	MR. CLIFFORD: Okay. My name is Paul
18	Clifford, and I'll be presenting the interim criteria
19	for the reactivity-initiated accidents. First, I'll
20	be addressing why I'm here, why we've issued interim
21	criteria, and then we'll get to the when, when it will
22	be implemented.
23	First off, the reactivity-initiated
24	accidents is a family of accidents, that's the control
25	rod ejection for PWRs with a control rod, or control
I	1

```
(202) 234-4433
```

blade drop access for the BWRs. The interim criteria are being issued because the staff is aware that the current guidance, the current criteria are flawed. They're non-conservative, and this is based upon research's evaluation of all of the empirical database that's been conducted in the 70s, 80s, and 90s. And that was presented to the staff, or to the committee when RIL0401 was issued, and that was back in March of 2004.

The interim criteria serve two important 10 purposes, and it's important to get this out right 11 First, they provide the staff with conservative 12 away. criteria for which to go forward and license the next 13 14 generation of reactors. And, secondly, they provide 15 the industry with a target. We understand that due to 16 the restricted nature of the new criteria, it's going 17 to take some time for the industry to develop the methods and the tools necessary of implementing it. 18 19 And in order to develop a new method, and new models, 20 we need to know what the criteria might look like, so 21 we're providing this as a target for them.

We have this two-staged approach. First off, we have this SRP update, which includes the interim criteria in Appendix 4B, and we will be issuing a RIS, a Regulatory Information Summary in the

> NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433

1

2

3

4

5

6

7

8

9

	115
1	next month or two where we will try to provide
2	guidance, provide we'll communicate what
3	expectations are with respect to implementing the new
4	criteria, the interim criteria, and where we're going
5	with the final criteria. And that's the second half
6	of this approach, and that is to perform a rigorous
7	evaluation of the empirical data that's out there.
8	And, also, to gather forthcoming testing at NSRR,
9	which we're hoping will provide us with some valuable
10	insight, and allow us to fine tune the interim
11	criteria before we publish final. And when we go
12	what I mean by "publish" is, there are three Reg
13	Guides that are affected by this, Reg Guide 177, Reg
14	Guide 1.195, and Reg Guide 1.183.
15	DR. MAYNARD: I'm a little confused. You
16	say there's no safety concern due to conservative
17	methods, yet we're going to come out with more
18	restrictive requirements? Can you help me with that?
19	Why do we need it if the current methods are
20	conservative?
21	MR. CLIFFORD: We rely right now on an
22	operability assessment that was performed by research,
23	where they essentially said let's draw a line in the
24	sand based upon a more rigorous evaluation of all the
25	data we have to-date. What's the point at which
l	1

(202) 234-4433

(202) 234-4433

	116
1	cladding will fail? And they came up with an
2	oxidation dependent curve, and then using more
3	realistic three-dimensional physics codes, I believe
4	they used PARKS, they determined, based upon an
5	evaluation of several operating reactors that you
б	would never achieve the reactivity insertion or the
7	pump jump necessary to even fail the cladding.
8	In other words, the current methods of 1D,
9	2D methods are so conservative that they may calculate
10	280 calories per gram, but if you took that exact same
11	loading pattern and used a three-dimensional tool,
12	you'd be calculating about 50 to 60 calories per gram.
13	So even though they're calculating something that's
14	high, realistically, it's just not there.
15	DR. CORRADINI: So can you go that one
16	more step, maybe not now, but when you do all this
17	together. You're still about what the how the
18	criteria is affected by the methodology? Because, I
19	guess, that bothered me, too, but your explanation
20	still leaves me kind of cold.
21	MR. CLIFFORD: Okay. We have criteria
22	that's very high, that's non-conservatively high, but
23	the methods that are used to judge whether or not you
24	meet those non-conservative criteria are so overly
25	conservative that in the end it washes away. What we
l	

(202) 234-4433

(202) 234-4433

	117
1	want to do is say well, the empirical data doesn't
2	support 280 calories per gram, or whatever the value
3	is. It supports something a lot lower, so we're going
4	to lower the criteria, make it realistic. And in
5	order to meet the realistic criteria, we're going to
6	have to use realistic methods.
7	DR. WALLIS: What you're saying really is
8	there's no calories per gram until it's calculated by
9	some method.
10	DR. BONACA: I mean, the reason why the
11	methods have been so conservative through the years
12	was because the limit was high, so nobody spent the
13	money to do three-dimensional neutronic calculation to
14	get the values down. I mean, that was the reason why
15	they just kept operating with the point kinetic and
16	static calculation, no feedback, no nothing,
17	practically. And you got the value which was still
18	below 280 calories per gram for PWRs. And so the
19	industry has been living with that. Now this change
20	will force them to go to more expensive methods, if
21	you bring down the limit.
22	DR. WALLIS: What you're really saying,
23	the criterion, it cannot be independent of the
24	methodology used to make the calculation. It cannot
25	be.
	I

(202) 234-4433

	118
1	DR. ARMIJO: Sure it can.
2	DR. KRESS: It can.
3	DR. ARMIJO: You can set the criteria
4	based on the actual performance in a test.
5	DR. WALLIS: That's clearly not so if you
6	well, yes, you can do that.
7	DR. CORRADINI: That's what I think they
8	said they're doing.
9	DR. WALLIS: What you're allowed to use as
10	a calculation procedure is important, though.
11	DR. BONACA: Well, as long as you can
12	demonstrate that you have a hyper-conservative
13	calculation procedure, they let you use it.
14	MR. CLIFFORD: The problem we have in the
15	staff is, an operability assessment is a snapshot in
16	time, someone looks at past operation, past fuel
17	designs, past loading patterns, and says okay, we're
18	okay. But every day that transpires after the
19	operability assessment, somebody could be off making
20	a different fuel design, make a new loading pattern,
21	just treating the fuel differently, such that it may
22	be invalidated. It may invalidate the conclusions of
23	the operability assessment. That's why we feel we
24	need to issue conservative criteria for the next
25	generation of reactors, because we don't know what the
Į	I

(202) 234-4433

	119
1	next generation reactor cycles are going to look like,
2	or what the fuel designs may be look like, so we don't
3	have an operability assessment for the SBWR.
4	DR. ARMIJO: Okay, Paul, we better move
5	along.
6	MR. CLIFFORD: Okay. There's two parts of
7	this presentation which need to be separated, and I'll
8	do my best. The first part is the radiological
9	consequences, and this is the evaluation that's done
10	to meet 10 CFR Part 100 dose criteria. And in order
11	to do a proper dose calculation you need to know two
12	things, how many rods fail, and what's the source term
13	within each of the rods that needs to be considered.
14	The second half of the agenda is the core coolability
15	limit.
16	Fuel cladding failure - the current
17	failure criteria specified in Section 4.2, or the
18	previous Section 4.2, had 170 calories per gram as the
19	DNBR high cladding temperature failure for BWRs, and
20	it also had a DNB, statement about DNB for PWRs.
21	What's wrong with the current criteria in the SRP is
22	that all the empirical database the empirical
23	database was based on low burn-up or no burn-up fuel
24	tests.
25	Also, it was determined that the 170
ļ	I

(202) 234-4433

	120
1	calories per gram was not always adequate to protect
2	the rod integrity, and that's because the criteria was
3	based on non-PCMI failure modes. Now we realize as
4	you get corrosion and burn-up, PCMI becomes a dominant
5	failure, so we need to develop criteria to address
б	PCMI.
7	And lastly is that there's always been a
8	presumption that fuel failure occurs if you exceed
9	your critical correlations, which may be overly
10	conservative for such a fast transient.
11	DR. CORRADINI: But that's the opposite
12	effect that you're just mentioning.
13	MR. CLIFFORD: Yes.
14	DR. CORRADINI: Okay.
15	MR. CLIFFORD: The failure mechanisms
16	experienced during the reactivity-initiated accidents
17	are a high cladding temperature failure, which you
18	could characterize as post DNB cladding, oxidation,
19	and embrittlement, and fuel rod ballooning. Next is
20	pellet cladding mechanical interaction, PCMI. And
21	lastly, if you achieve extremely high fuel enthalpies,
22	you could get multi-fuel expansion, and classic
23	deformation of the cladding, and we will address each
24	of these.

The staff has taken a more rigorous look

**NEAL R. GROSS** COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433

1 at the data, worked with research, with RIL0401 and 2 developed separate criteria to address each of the previous mechanisms. The first bullet here is to 3 4 address the high cladding temperature failure mode, 5 which is 170 calories per gram for any rod with an internal pressure at or below system pressure. 6 That 7 addresses the hot zero power cases where you have post 8 DNB sort of failures. And if you have a rod internal 9 pressure that's higher than system pressure, that criteria has been reduced to 150 calories per gram, 10 and that's account for the potential for 11 to ballooning. 12 intermediate full 13 For and power 14 conditions, fuel cladding failures is presumed if 15 local heat flux exceeds design limits, so we've maintained this overly conservative approach to the 16 presumption of fuel failure if you exceed DNB. 17 The next criteria, which is the PCMI 18 19 failure criteria, we'll get into in the next slide. 20 WALLIS: Maintaining this first DR. 21 paragraph here? You're maintaining this now? 22 MR. CLIFFORD: Right. Well, I thought the next 23 DR. WALLIS: 24 figure shows values less than 170. 25 Yes, I'll get to that. MR. CLIFFORD: The

> NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433

(202) 234-4433

121

	122
1	first bullet is addressing only the high cladding
2	temperature failure mechanism, and the next two slides
3	we will be describing what the failure criteria is for
4	the PCMI.
5	DR. CORRADINI: Can I say it back to you
6	another way? This dominates at zero burn-up.
7	MR. CLIFFORD: High cladding temperature
8	failures, which is DNB, rod ballooning, dominating on
9	fresh fuel, because fresh fuel has the ductility
10	because it doesn't have a lot of corrosion.
11	DR. CORRADINI: So zero burn-up, fresh.
12	MR. CLIFFORD: Correct.
13	DR. CORRADINI: Okay.
14	MR. CLIFFORD: And PCMI becomes dominant
15	once you start to lose ductility due to corrosion.
16	DR. CORRADINI: And the change from 170 to
17	150 - I'm sorry. Yes, the differentiation was in the
18	current criteria.
19	MR. CLIFFORD: Right. The current
20	criteria mentioned 170, and the tests that were done
21	at BIGR showed that the 170 was still valid. However,
22	there were some tests done at BIGR and NSRR that
23	showed that there was failure below 170 if there was
24	rod internal pressure
25	DR. CORRADINI: But the 150, I guess
Į	I

(202) 234-4433

	123
1	that's what I was wanting to get at. I thought that
2	was new. That is new, then.
3	MR. CLIFFORD: That is new.
4	DR. CORRADINI: Okay. Thank you.
5	MR. CLIFFORD: The PCMI criteria, now this
б	is for PWRs, the staff determined that we were going
7	to develop two separate curves, one for PWRs and one
8	for BWRs. What's presented here is the PWR failure
9	criteria. The blue dotted line is what was presented
10	early in RIL0401, and that was prepared by research.
11	The red line is the proposed interim criteria being
12	developed by NRR. The difference between the two
13	lines fundamentally is that the cold BWR tests on
14	Zirc-2 were removed from the population when we drew
15	the line. There were several cold BWR Zirc-2 data
16	points down at the knee of that
17	DR. WALLIS: I guess when you presented to
18	the subcommittee you had some data on this?
19	MR. CLIFFORD: Oh, absolutely.
20	DR. WALLIS: And you somehow decided not
21	to present any data today?
22	DR. CORRADINI: It's in the stuff we were
23	sent, in the Appendices. I know it's there. I saw
24	all the little dots.
25	MR. CLIFFORD: Right.
I	I

(202) 234-4433

	124
1	CHAIRMAN SHACK: But until you analyze
2	that data, you don't know it disappears.
3	DR. ARMIJO: There's a lot of data, and I
4	think the EPRI report shows the data that are the
5	basis for this.
6	CHAIRMAN SHACK: You had another argument,
7	though, at the subcommittee meeting that that's almost
8	like your solubility limit for the hydrogen out to
9	where you put that first break.
10	MR. CLIFFORD: Correct.
11	CHAIRMAN SHACK: And that seemed to me a
12	good argument.
13	MR. CLIFFORD: Right. Right. For the
14	PWRs, hot zero power up through operating
15	temperatures. The knee in this corresponds to about
16	23 microns of oxide, which is approximately 100 ppm of
17	hydrogen, and that's roughly the solubility limit of
18	hydrogen at operating temperatures. And what you see
19	is we haven't experienced any PCMI failures below this
20	point here. There were PCMI failures here. Those
21	were the BWR tests conducted at room temperature, and
22	I'll address those in the next criteria.
23	The green dotted line here is a well,
24	these two lines here, the RIL0401, and the interim
25	criteria are both truly empirically based. There is
Į	I

(202) 234-4433

1 some minor scaling of the empirical data, but it is 2 really just an evaluation, a line drawn in the sand 3 based upon the test results. The green line is 4 something that was provided by EPRI based upon their 5 FALCON mechanistic evaluation, which they use the models in FALCON, and which are tuned to separate 6 7 effects of database. And all I'm trying to show here is, here are two entirely different methods coming up 8 with the failure criteria that are not that different. 9 10 DR. CORRADINI: And the procession from oxide wall thickness of essentially zero to .2 of the 11 wall thickness is just simply a function of burn-up. 12 MR. CLIFFORD: Well, more specifically a 13 14 cladding type. Cladding type would -- the alloy, whether it's a modern alloy like optimized ZIRLO and 15 16 M5 versus --17 DR. CORRADINI: Okay. So that also appears in the database that drew the line. 18 19 MR. CLIFFORD: Right. 20 Okay. I have another DR. CORRADINI: 21 slide. 22 When you drew these lines, DR. WALLIS: 23 you drew them to envelope the data with failures, and 24 so they're below all the failures. 25 MR. CLIFFORD: Not below all the failures.

> NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433

(202) 234-4433

125

	126
1	DR. WALLIS: Okay. Then you didn't add
2	some conservatism.
3	DR. ARMIJO: Show it quickly, Paul.
4	MR. CLIFFORD: I could pull it up real
5	quick.
6	DR. ARMIJO: Just show it quickly, Paul,
7	because I think we're going to
8	DR. WALLIS: You didn't add some
9	conservatism saying that to be sure we'll make it 10
10	percent lower or anything like that?
11	MR. CLIFFORD: This is what you're looking
12	for right now.
13	DR. WALLIS: It's very sparse data, and
14	you've got two French data you threw out and stuff
15	like that. But it seems to me very bold to draw a
16	line through this like that.
17	MR. CLIFFORD: Well, that's always a
18	problem you have with empirically based
19	DR. WALLIS: Well, you could be very
20	conservative and say because we're uncertain, we're
21	going to draw a line at 50 right across the whole
22	thing.
23	MR. CLIFFORD: You could.
24	DR. WALLIS: But why not?
25	DR. ARMIJO: Well, because you have a lot
	I

(202) 234-4433

	127
1	of success points
2	mR. CLIFFORD: We do have two different
3	mechanisms in play here. Over on this side, there's
4	no PCMI, and on this side there is PCMI. Here you
5	have really DNB related failures, and there is both a
б	lot of data to support that 150, and there's still the
7	requirement that the licensees are using DNB to
8	calculate that.
9	DR. WALLIS: If you want to be really sure
10	you have no fuel failures, you would want to draw a
11	line somewhat lower than that, it seems to me.
12	Wouldn't you, if you want to be really sure?
13	DR. ARMIJO: Remember those data are test
14	reactor data with no adjustments for a lot of things.
15	DR. WU: Simple test data in a core
16	condition it's not in a typical reactor condition.
17	DR. BONACA: I'm just confused about one
18	thing. I thought that the requirements for rod
19	ejection accident for PWRs allow you to have some
20	degree of fuel damage.
21	MR. CLIFFORD: Absolutely.
22	DR. BONACA: So you're not really drawing
23	a line here to separate fuel damage from no fuel
24	damage.
25	MR. CLIFFORD: No, this would be one line
I	

(202) 234-4433

128 1 that would be used to determine how many pins failed. 2 That would go into dose calculation. You can exceed this line, but then you have to assume that the rod 3 4 failed. 5 DR. BONACA: Which is what you have to do Simply the line is not conservative. 6 today, too. 7 MR. CLIFFORD: Well, today many of the 8 PWRs don't have a line. I think there is a 9 DR. BONACA: 10 misunderstanding that says that you expect to have below the line there will be no fuel failures. 11 Ι don't think that's the case. 12 MR. CLIFFORD: You can be below this line 13 14 and still have a calculated fuel failure based upon DNB. 15 16 DR. BONACA: That's right. 17 DR. WALLIS: Well, I just think as a member the public, it's very difficult 18 of to 19 understand your rationale. And maybe there is a very 20 good one, but it's very difficult to understand why you draw a red line like that through this point and 21 22 the other points. 23 DR. BONACA: I'm trying to understand, in what separates -- what does the red line 24 fact, 25 separate? There are some points below that where you

> NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433

	129
1	would be DNB failures.
2	MR. CLIFFORD: Right. They would okay.
3	A licensee would use this when they develop a fuel
4	loading pattern. They would run several cases where
5	they move, where they eject several rods. Say it's a
6	PWR, they eject several rods with a given fuel
7	management pattern, and they would have to determine
8	how many rods exceed this line, and that would be
9	included in their dose calculation. They would also
10	have to do a DNBR calculation using the core codes to
11	calculate how many pins were going into DNB, and you
12	have to add those to the population above this line to
13	give the total number of
14	DR. BONACA: There's a line there, what
15	
16	CHAIRMAN SHACK: It's the PCMI failure
17	line.
18	MR. CLIFFORD: It's the PCMI failure
19	line.=, which doesn't exist now.
20	DR. BONACA: Thank you for telling me. I
21	mean, I just missed it totally.
22	CHAIRMAN SHACK: It's to address this
23	mechanism. He's got other mechanisms.
24	DR. BONACA: All right. Now, is all the
25	data there to do a PCMI failure data?
Į	I

```
(202) 234-4433
```

	130
1	MR. CLIFFORD: Correct. All of the
2	points, all of the solid points were failures due to
3	PCMI.
4	DR. BONACA: Okay.
5	DR. ARMIJO: Okay. So let's go back to
6	
7	DR. WALLIS: What's the probability of
8	failure if I have .06 and I have 100. I've got one
9	point in there which failed. Now what's the
10	probability of failure?
11	MR. CLIFFORD: The reason we didn't bound
12	these points here is because we expect further testing
13	at NSR. These were conducted at cold conditions, 20
14	degree Celsius.
15	DR. WALLIS: After the testing, you might
16	move the line.
17	MR. CLIFFORD: We expect to move the line.
18	DR. WALLIS: Oh, okay. Thank you.
19	DR. ARMIJO: Analytically, EPRI has done
20	that. They'll show you what they expect that the
21	tests would show. So these are untreated data, pretty
22	much raw data.
23	MR. CLIFFORD: There is a small amount of
24	DR. ARMIJO: Small amount.
25	MR. CLIFFORD: It doesn't take into

(202) 234-4433

account a lot of things.

1

2 The line drawn here is conservative. We anticipate that when we issue final criteria, we have 3 4 to take into account the new data that's going to 5 become available, and a more rigorous evaluation of that data, which means we could back and then scale 6 7 some of these other points. We expect the line to be a little higher, but with interim criteria you don't 8 9 want to -- if you use something that's going to be overly conservative, 10 or at the same time nonconservative relative to what your final is going to 11 be, you want it to be close but maybe a little too 12 conservative. 13

14 MR. SCOTT: Paul, can I make one other --15 this is Harold Scott from the research staff who 16 helped draw the line. Think about this, and this is one of our considerations; if you drop that line 17 precipitously at .04, then it would look like there 18 19 was a cliff or a sudden change. We knew that wasn't 20 true, so we couldn't justify having that line drop 21 precipitously, so to the left of .04 we knew about 22 To the right of .08, we knew about where it was. 23 where it was, so the only thing we could do is draw a 24 straight line between them. We didn't have any basis 25 for making that curved down or curved up, but we

> NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433

132 1 couldn't have it be --- Paul, go up there and point to 2 black, right there, draw the line that top 3 precipitously down to the bottom one to go through the 4 points. There would be no explanation for that. 5 DR. WALLIS: But it's empirical, whether there's explanation or not, it happened. 6 7 MR. SCOTT: Well, there's uncertainty, 8 then. 9 CHAIRMAN SHACK: Yes, but there's also 10 uncertainty about what are the relevance of those tests that we're missing. 11 DR. ARMIJO: Yes. And there's technical 12 CHAIRMAN SHACK: All tests are not equal 13 14 here on this graph. 15 DR. ARMIJO: Right. Exactly. And you 16 have to make adjustments for pulse width, temperature. 17 DR. WALLIS: Okay. DR. BANERJEE: You know, your data on the 18 19 -- if you show it as oxide to cladding ratio, then it 20 scatters in a different way completely. MR. CLIFFORD: The reason we chose the 21 22 ratio was because there was --23 DR. BANERJEE: This isn't the ratio. This 24 is just --25 DR. WALLIS: This is the ratio.

> NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

	133
1	MR. CLIFFORD: This is a ratio.
2	DR. BANERJEE: Okay. If you chose burn-
3	up, say.
4	MR. CLIFFORD: The PCMI phenomena is
5	driven by the ductility of the cladding more than it
6	is the burn-up on the pellet. The reason we tried to
7	normalize this with wall thickness was because there
8	was a large spread in the thickness of the specimens.
9	I believe it went from I have it right here. The
10	wall thickness went from 495 microns to 915 microns.
11	So we had to take that into account because a wall
12	thickness is directly proportional to stress.
13	DR. CORRADINI: So this is kind of in the
14	weeds, and so the Chairman over there is going to tell
15	me I should have been at the meeting, so is the gray
16	circle, the three grays circles we've been messing
17	about with, is that the oxide thickness at the point
18	of failure? Is that the average oxide thickness? You
19	know what I'm asking? What you're really telling me
20	is, it's not a dot, it's like this because the rod
21	actually had a range of thicknesses. That's what I
22	think you just told me.
23	MR. CLIFFORD: No, that's not what I was
24	saying.
25	DR. CORRADINI: Oh, I thought you said the
ļ	I

(202) 234-4433

134 1 oxide thickness on the rod had a range. 2 CHAIRMAN SHACK: The wall thickness of the 3 cladding is different, different clads. 4 DR. CORRADINI: Oh. 5 DR. BANERJEE: So if you just take the oxide thickness --6 7 DR. CORRADINI: So this is the oxide 8 thickness at the point of failure. 9 MR. CLIFFORD: Point of failure, this was 10 the reported oxide thickness. It doesn't change during the transient. 11 DR. CORRADINI: No, that I understand. 12 It's the reported oxide 13 MR. CLIFFORD: 14 thickness --15 dR. ABDEL-KHALIK: So all the open circles on this graph have been ruled to be non-PCMI failure. 16 17 MR. CLIFFORD: No, they didn't fail. They did not fail. 18 DR. ABDEL-KHALIK: 19 DR. ARMIJO: They were subjected to the 20 same stresses, but they didn't fail. 21 DR. WALLIS: Well, one thing it indicates 22 is that the X axis is not the right way to predict -to plot the data. 23 24 DR. ARMIJO: Let's not change this now. 25 That's one conclusion you DR. WALLIS:

> NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433

	135
1	could reach by this kind of scale or plot.
2	MR. CLIFFORD: If you look at burn-up, it
3	actually is a lot less behavior. The RIL0401 looked
4	at it from a burn-up perspective, from a lot of
5	different perspectives, and they concluded that
6	corrosion was the best way to present the data,
7	because it is a loss of ductility driven mechanism,
8	which increases with corrosion and hydrogen uptake.
9	DR. ARMIJO: What the staff would really
10	like to have is the hydrogen concentration, because
11	that's really the embrittling material, but they don't
12	have that data. But in PWR fuel, the oxide thickness
13	is a surrogate for the hydrogen, and that's why they
14	chose that. In the BWR case, they do it directly
15	against hydrogen.
16	DR. BANERJEE: Looking at your data,
17	though, it's not obvious that oxide to wall thickness
18	ratio is much better than just oxide thickness. I'm
19	just looking at the data right now.
20	DR. ARMIJO: If all the specimens had the
21	same wall thickness, that would be true.
22	DR. BANERJEE: No, I'm just looking at the
23	data - this data plotted just against oxide thickness
24	alone. And if you look at Figure 3.0, yes, but there
25	are four figures.
I	I

(202) 234-4433

	136
1	MR. CLIFFORD: Right.
2	DR. BANERJEE: This one is 3.04, the one
3	that you're showing, basically, the data there. And
4	
5	mR. CLIFFORD: Figure 3.0 dash?
6	DR. BANERJEE: Dash four, and if you look
7	at 3.0-6, it more or less looks the same to me. I
8	mean, it's not any worse or better.
9	DR. WALLIS: It looks the same, but you
10	draw different line, wouldn't you?
11	DR. BANERJEE: You'd draw a different
12	line.
13	DR. WALLIS: You reach a different
14	criterion.
15	DR. BANERJEE: I mean, the scatter doesn't
16	look any worse or better from what I can see. How did
17	you actually decide? Did you use some regression
18	tools or something to see whether the scatter was
19	less?
20	DR. ARMIJO: You know, I'm going to have
21	to step in because look, we're at quarter of 12.
22	We've got to finish Paul's presentation, and there's
23	also a presentation by EPRI.
24	DR. WALLIS: But is he going to make a
25	convincing case or not?
I	I

(202) 234-4433

	137
1	DR. ARMIJO: I think he will.
2	DR. WALLIS: Well, I just don't see where
3	it is. That's all. And maybe it was at the
4	subcommittee presentation.
5	DR. ARMIJO: Yes, it was.
6	DR. WALLIS: Okay.
7	DR. BANERJEE: Missed the subcommittee
8	meeting.
9	DR. ARMIJO: This subject if you would
10	have been there been helpful, but I think if you look
11	at this presentation along with the EPRI presentation
12	together, you'll get a better picture.
13	DR. ABDEL-KHALIK: Now the CABRI data
14	point, the one anomalous data point way low there,
15	that's been just thrown out, judged to be
16	mR. CLIFFORD: Right. There were several
17	international conferences on this.
18	DR. ABDEL-KHALIK: Okay.
19	(Off the record comments.)
20	DR. ARMIJO: Let's move on, Paul, or else
21	we'll never
22	mR. CLIFFORD: Okay. The next one is the
23	BWR, and I might as well show this slide which has the
24	data points on it. Well, this is important. This is
25	important right now. Here we're issuing the criteria
	I

(202) 234-4433

	138
1	as a function of oxide or oxide to wall ratio, and all
2	that's then interpreted by the industry, would be that
3	they would convert that to a burn-up dependent line,
4	which is more useful when you're doing fuel
5	management. And when you do that, you need to take
6	into account the kinetics of a particular alloy, and
7	maybe even the temperature of your reactor. It could
8	be offering different fuel duties, and what you would
9	end up with, here's two examples of converting that
10	line for an advanced alloy with very low corrosion to
11	an older Zirc-4 corrosion properties. As you can see,
12	the dip in the line changes, so there's certainly an
13	advantage to using a low corrosion advance alloy here
14	because this is not taken to scale.
15	DR. CORRADINI: So just to say it
16	differently, the PCMI mechanism disappears with an
17	advanced alloy because your corrosion and your oxide
18	thickness build-up puts you back in the region where
19	the damage mechanism is the first mechanism.
20	MR. CLIFFORD: Absolutely.
21	DR. CORRADINI: Okay.
22	MR. CLIFFORD: It just takes longer to get
23	to the point where you clad loses sufficient
24	ductility.
25	DR. WALLIS: What does this mean in terms
ļ	1

(202) 234-4433

(202) 234-4433

	139
1	of operation? Does it mean that you have to take the
2	fuel out at 30, 35, or something?
3	DR. ARMIJO: You might have to berate it.
4	MR. CLIFFORD: If you have Zirc-4, if you
5	had like a high 10 Zirc-4, then you would find
6	yourself with a very low acceptance criteria, which
7	means you wouldn't be expected to fail more rods due
8	to PCMI.
9	DR. WALLIS: And, therefore, you'd have to
10	not operate.
11	MR. CLIFFORD: If your dose calculation is
12	unacceptable
13	dR. ABDEL-KHALIK: Now this conversion
14	process would be valid if your database included these
15	advanced alloys. Is that true?
16	MR. CLIFFORD: Each of the vendors would
17	present oxidation models and hydrogen pick-up models
18	which would then be used to convert the corrosion
19	dependent line
20	dR. ABDEL-KHALIK: But the line that you
21	drew before, the red line based on the data on which
22	this translation is being made, would be valid if, and
23	only if, it was developed included data that includes
24	advanced alloys.
25	MR. CLIFFORD: That's a good point. The
	I

(202) 234-4433

	140
1	database that we're using to draw was made up of
2	well, for the PWRs I'll take out the Zirc-2. It had
3	Zirc-4, it had low 10 Zirc-4, MDA, E110, Zirlo-M5. It
4	did include a large spectrum, and the upcoming tests
5	would also be done with advanced clad. I'm pretty
б	sure there's a test with M5 or MDA, so the advanced
7	cladding alloys are represented by that population.
8	DR. ABDEL-KHALIK: So what would a fuel
9	vendor with a brand new alloy do with this new
10	criterion?
11	MR. CLIFFORD: That's a very good point.
12	It's something we will need to struggle with. I would
13	expect that if you came with a new alloy, and you have
14	to demonstrate that the oxidation kinetics, you have
15	to know your oxidation kinetics so you can know where
16	to map it, but there's probably still a hurdle to
17	overcome that would probably need to be some
18	demonstration that your PCMI characteristics be a
19	separate effects testing, to show that the strain
20	rates would fail at a similar strain rate as what
21	we've seen in the population. I don't think we would
22	blindly apply this curve to any future alloy.
23	DR. CORRADINI: So you're can I just
24	Said is asking the question that I think is crucial,
25	which is, so you get a new fuel, a new alloy, never
l	I

(202) 234-4433

ĺ	141
1	saw it before. Step one is they'd have to know how
2	its hydrogen pickup and oxidation is behaving.
3	Secondly, that you would probably expect to see out-
4	of-pile tests, and I heard you kind of there was a
5	kind of vagueness there. I almost sensed that you
6	might have to look at some in-pile testing.
7	DR. ABDEL-KHALIK: You definitely have to
8	do that.
9	DR. ARMIJO: Not necessarily in-pile, but
10	irradiated tests just to make sure you didn't have
11	some other embrittling mechanism, other than hydrogen.
12	DR. CORRADINI: I understand.
13	DR. ARMIJO: So that you would maintain
14	ductility, and so that you could use that curve. But
15	that's what fuel manufacturers would do, anyway. They
16	don't want that fuel to fall apart.
17	MR. CLIFFORD: And that really is a
18	limitation to an empirically based limit. It's valid
19	over the database, and the range of the database
20	extrapolation gets dangerous.
21	DR. CORRADINI: I think that was his whole
22	point.
23	DR. ABDEL-KHALIK: Absolutely.
24	DR. BANERJEE: So what you're really
25	saying is that the oxide thickness for an advanced
	I

(202) 234-4433

	142
1	alloy grows less with burn-up.
2	MR. CLIFFORD: That's the reason they're
3	introducing
4	(Simultaneous speech.)
5	DR. ARMIJO: That's their driving force.
6	DR. BANERJEE: All right. So that makes
7	sense. But you would have to know that.
8	MR. CLIFFORD: We have to know that, and
9	we really have to know the hydrogen pickup factors
10	too. Okay. So this graph shows you how it would be
11	applied to different types of alloys.
12	The next block, I'll stay with this slide
13	package for now, is BWR. BWR PCMI failure - here's
14	our database. It's consistent with NSR tests. These
15	were all conducted between 20 and 85 degrees Celsius
16	on two conducted above 20, the rest were at 20. The
17	barbell represents the reported range in hydrogen.
18	And as was mentioned earlier, hydrogen is the
19	principal embrittlement mechanism. If we had hydrogen
20	data for all the PCMI, for all the PWR test specimens,
21	we would prefer to go that route also, and report it
22	as a function of hydrogen. We just don't have that
23	data right now, and we'll be looking into trying to
24	get some of that data over the next 18 months before
25	we go final.
I.	

(202) 234-4433

	143
1	Here we had the reported hydrogen content
2	and the failure points in the dark circles, and we
3	drew the line. Once again below this point here.
4	We've seen that we don't experience a lot of failure.
5	And PCMI becomes dominant.
6	DR. WALLIS: There's no evidence in that
7	ramp there at all. There's no evidence there. You
8	just draw a line.
9	DR. BANERJEE: You have failures on the
10	left-hand side.
11	DR. ARMIJO: You've got to connect the
12	points. That's basically
13	DR. WALLIS: But there's infinite number
14	of ways to connect two points.
15	MR. CLIFFORD: Well, we drew the 150 here
16	because it corresponds for a hot zero power PWR. It
17	corresponds to the 170 calories per gram that is the
18	limiting failure for the high clad temperature failure
19	point. In other words, even if you didn't see
20	failures due to PCMI, and there are - we have thick
21	VVER cladding that's very similar to this, where we
22	didn't have any failures, and it was up here. And we
23	didn't want to draw this up, because it makes no
24	sense, because you're always going to be limited here
25	by high clad temperature, so we didn't want to bring
Į	I

(202) 234-4433

	144
1	this up, even though you may have been able to make
2	that case.
3	DR. CORRADINI: And the reason it's 150
4	instead of 170 is?
5	MR. CLIFFORD: For hot zero power you'd be
6	starting at about 20 calories per gram.
7	DR. CORRADINI: Okay.
8	MR. CLIFFORD: I'm sorry. This is a
9	chain. Everything here is a delta, whereas the 170 is
10	an absolute.
11	DR. CORRADINI: Got it. Thank you.
12	MR. CLIFFORD: So we drew these lines
13	around these dumbbells, or whatever you want to call
14	them here.
15	DR. WALLIS: Why did you have a kink in
16	the red line at the dumbbell?
17	MR. CLIFFORD: Here?
18	DR. ARMIJO: You've got a couple of
19	successes there. See those.
20	DR. WALLIS: Yes, why did you have a kink?
21	Why did you change the slope? Why didn't you just
22	keep it going? There's an infinite number of
23	questions here.
24	CHAIRMAN SHACK: He wants to keep it going
25	down.
I	1

```
(202) 234-4433
```

	145
1	DR. WALLIS: Keep going down to zero.
2	You're on the slippery slope, just keep going.
3	MR. CLIFFORD: We hadn't seen a failure
4	which was dispositioned below 50 calories per gram.
5	DR. WALLIS: There's no data.
6	MR. CLIFFORD: Not on this slide, but on
7	the other slides, for the PWR, yes. For the BWRs.
8	DR. WALLIS: Well, I'm glad this is an
9	interim criteria.
10	MR. CLIFFORD: That's one of the reasons
11	it's interim.
12	DR. BANERJEE: Is there going to be more
13	data?
14	MR. CLIFFORD: There is going to be a
15	handful of more tests that will hopefully allow us to
16	not only add a few data points, but also do a better
17	scaling analysis.
18	DR. WALLIS: How many data points are you
19	going to add, enough to make a better decision?
20	MR. CLIFFORD: Well, once again, if you're
21	living with an empirically based limit, as opposed to
22	a mechanistic based limit where you can try to fill in
23	the blanks, but here the strategy was to just draw the
24	empirical base limit, which all you can do is connect
25	the dots the best you can with what you have.
	I

(202) 234-4433

	146
1	DR. BANERJEE: Are you doing stuff at
2	higher hydrogen content, because really, it's an issue
3	related to that line. Right? Which goes on 150 up.
4	Let's assume you have data which supports that kinked
5	line you've got now, but you haven't got any data
6	above 150 hydrogen content, from what I can see.
7	MR. CLIFFORD: Off the top of my head, I'm
8	not sure if any of the plant tests, what the hydrogen
9	concentration on the plant tests are.
10	DR. WALLIS: How high do the plants go
11	today in hydrogen content?
12	MR. CLIFFORD: Most BWRs only end up with
13	40 or 50 microns of oxide.
14	DR. WALLIS: This is PPM, it says.
15	(Simultaneous speech.)
16	MR. CLIFFORD: These correspond to a lower
17	hydrogen, but there is variability in measurements.
18	DR. WALLIS: Are there plants that operate
19	at 200 ppm?
20	MR. CLIFFORD: We don't believe so.
21	DR. WALLIS: You don't believe that? I
22	mean, what's true? I don't know what you believe.
23	MR. CLIFFORD: Industry hasn't come out
24	and said that they can't live with this curve. I'm
25	sure if they had fuel rods out
Į	1

```
(202) 234-4433
```

	147
1	DR. WALLIS: You don't know where the
2	existing plants are relative to this curve?
3	CHAIRMAN SHACK: No. Can they live with
4	Graham's curve, the one that comes straight down?
5	DR. WALLIS: Well, I want to know where
6	they are today. Do they operate now at 200 on the X-
7	axis, and 50 at the Y-axis?
8	DR. CORRADINI: That's all he's asking
9	you, where do they operate now?
10	DR. WALLIS: Operate today.
11	MR. CLIFFORD: I don't believe they reach
12	200.
13	DR. WALLIS: But do they? I don't want to
14	know what you believe, that doesn't
15	mR. CLIFFORD: Well, it's important
16	DR. WALLIS: Do you know?
17	MR. CLIFFORD: It's important to realize,
18	too, that by the time a rod reaches this sort of
19	corrosion, its reactivity is so low that it's
20	incapable of producing the power
21	DR. WALLIS: That's an important piece of
22	information.
23	DR. ARMIJO: That's one of the reasons why
24	that line is around the 50, but there's a lot of,
25	unfortunately, proprietary data, maybe it's been

(202) 234-4433

	148
1	shared, on hydrogen content in fuel. And there is a
2	lot of scatter, and I've seen stuff as high as 200.
3	DR. WALLIS: That's what you should do.
4	You've got to put the as the stuff gets older, it
5	gets more hydrogen, but it can't heat up so much.
6	DR. ARMIJO: Right.
7	DR. WALLIS: You've got to show that on
8	this figure, it seems to me, so we know where we are
9	relative to what's being done today.
10	MR. CLIFFORD: Well, this figure will only
11	be used as a point. There would have to be analytical
12	evaluation done for all sorts of fuel at different
13	burn-ups.
14	DR. WALLIS: No use presenting what's
15	going to be used unless you show what's being done
16	today is related to it. If there are plants now that
17	are way up to the right there, then something has to
18	be done.
19	MR. CLIFFORD: Right now they have 170
20	going straight across. That's their failure mode, and
21	they do not have PCMI failure mechanism. They're not
22	analyzing that.
23	DR. ARMIJO: This is going to require that
24	the analysis be done. That's going to require that
25	the hydrogen data be taken out of their vaults and put
I	I

(202) 234-4433

	149
1	on the table.
2	MR. CLIFFORD: Absolutely.
3	DR. ARMIJO: And justify that they meet
4	the requirements.
5	DR. ABDEL-KHALIK: Where would a twice-
6	burned 60,000 megawatt days per ton GE14 fuel bundle
7	fall on this graph in terms of hydrogen?
8	MR. CLIFFORD: Well, we have a GE
9	representative here.
10	(Off the record comments.)
11	MR. MONTGOMERY: Mr. Chairman, may I
12	interject a comment here?
13	CHAIRMAN SHACK: Yes, Robert. Robert,
14	just give your name.
15	MR. MONTGOMERY: My name is Robert
16	Montgomery, I with Anatech Corporation, and I'm
17	representing EPRI today.
18	The industry has taken this curve and
19	applied it to BWR fuel that's in operation today,
20	given, I would say, using better estimate, not the
21	licensed neutronics methods, but better estimate
22	neutronics methods. And there are some data points
23	above the red line here on the plot that Paul is
24	showing, but not very many. And, again, we're talking
25	about a failure line, so these would just be fuel rods
ļ	

(202) 234-4433

	150
1	that have to be counted in a dose consequence
2	calculation. So it's not a limitation, at this point.
3	It doesn't appear to be a limitation at this point to
4	industry with regards to this line. It will depend
5	somewhat on the methods that are approved to be used,
6	of course.
7	CHAIRMAN SHACK: That's not addressing the
8	question of what is the hydrogen content, though.
9	MR. MONTGOMERY: Oh, is that the question
10	we want to ask?
11	DR. ARMIJO: Yes. Is there a whole lot of
12	data out there at 250, 300 with hydrogen?
13	DR. ABDEL-KHALIK: If I have a high burn-
14	up, twice-burned assembly in a BWR core, where does it
15	fall here?
16	CHAIRMAN SHACK: In terms of hydrogen.
17	DR. ABDEL-KHALIK: Hydrogen content.
18	MR. MONTGOMERY: My comment applies to
19	beyond 150 ppm, so there are fuels out there beyond
20	150 ppm, but they're high burn-up, so they would only
21	be in the 50 to 70, maybe 100 calorie per gram zone.
22	I thought that was the question. We're talking about
23	the cloud that's out there.
24	DR. WALLIS: Is the ppm up to 200 if it's
25	above 150?
Į	I

(202) 234-4433

	151
1	MR. MONTGOMERY: Yes. You can see a few
2	rods up at 200, maybe even 250.
3	DR. WALLIS: 150 or 200.
4	MR. MONTGOMERY: Or even 250.
5	DR. WALLIS: 250. So if you're at 250, so
6	it seems to me, you ought to know where to draw the
7	red line when you're up at 250. We don't know where
8	to draw the line when we're up at 250, do we?
9	MR. MONTGOMERY: Well, we have data, as
10	Paul has shown here, we have data that goes between
11	150 and about 225.
12	DR. BANERJEE: What does that mean, that
13	little dumbbell thing? Because in your next figure,
14	which is in the report, the dumbbells disappear.
15	DR. CORRADINI: They got smarter.
16	DR. BANERJEE: Yes, this is Figure 3.1-9,
17	if you go to 3.1-10, the dumbbells have vanished now.
18	DR. WALLIS: Well, have they which way
19	have the points gone, to the left or the right?
20	DR. CORRADINI: To the left. They've gone
21	close to the line, as you'd expect. It's the left-
22	hand
23	DR. BANERJEE: What is the difference
24	mR. CLIFFORD: We just removed these
25	points from the line when we were comparing it to the
l	I

(202) 234-4433

Í	152
1	
2	DR. BANERJEE: Oh, so you just removed
3	those points?
4	MR. CLIFFORD: The VVER data.
5	DR. BANERJEE: You just removed them.
6	MR. CLIFFORD: We put the points here. We
7	just removed these points here.
8	DR. BANERJEE: Okay.
9	MR. CLIFFORD: It would be conservative to
10	use the
11	DR. CORRADINI: And you've added the VVR
12	data which you showed, which you mentioned before.
13	Right?
14	MR. CLIFFORD: Right.
15	DR. CORRADINI: Okay.
16	DR. BANERJEE: But there is no evidence of
17	what happens to the right to say what fails and what
18	doesn't fail. Right? There is no unfailed data below
19	that.
20	MR. CLIFFORD: No, there's not.
21	MR. MONTGOMERY: There are I'm sorry to
22	interrupt, but there are - if I may make another
23	comment. There are technical reasons for why there
24	would be a plateau there, in a way, and that has to do
25	with the mechanical properties of the cladding, the
I	1

(202) 234-4433

	153
1	elastic behavior of the cladding.
2	DR. ARMIJO: Why don't we just table at
3	that point, because we're bogged down on this thing,
4	and you've got to finish your presentation, which was
5	discussed on the committee, but we're running out of
6	time.
7	DR. WALLIS: We're going to have to decide
8	how to vote, or whatever.
9	DR. ARMIJO: Yes, I understand, but we
10	still have to finish the presentation.
11	DR. BANERJEE: We haven't even got to the
12	coolable core geometry.
13	DR. ARMIJO: I know. Why do we always get
14	these?
15	MR. CLIFFORD: Once again, this plot here
16	just shows what the current criteria is. This shows
17	more restrictive.
18	Radiological guidance. The current
19	criterion in guidance with respect to meeting the part
20	is 10 CFR Part 100, and the guidance states that
21	you need to be well within the guidance, which
22	corresponds to 25 percent.
23	Appendix B of Reg Guide 177 and Reg Guides
24	1.183 and 1.195 stipulate what we call the gap
25	inventory, the amount of fission product that has made
	1

(202) 234-4433

	154
1	to the gap, and is able to be released upon clad
2	failure. And it states 10 percent of the iodines, and
3	10 percent of the noble gases.
4	DR. CORRADINI: That's the assumed source
5	term.
6	MR. CLIFFORD: That is the assumed source
7	term in the Reg Guides. The problem is that there has
8	been fission gas measurements following RAI tests on
9	unfailed specimens, and these measured fission gas
10	concentrations exceed the 10 percent which is
11	stipulated, which means there's another mechanism in
12	play.
13	DR. WALLIS: But 10 percent is not the
14	right criterion.
15	MR. CLIFFORD: Ten percent represents only
16	what would diffuse during normal steady state
17	operation out to the gap, to the plenum region. It
18	doesn't take into account any gas that would be
19	released during the transient. So we've identified
20	there's two separate mechanisms. The first one, as I
21	mentioned, was the thermal-driven diffusion of the
22	fission products inventory during time and temperature
23	during normal operation. And, secondly, during the
24	transient, the pellet fragments and there's grain
25	boundary separation which results in an additional
I	I

(202) 234-4433

155 1 mechanism to release fission gas. And the amount of 2 fission gas, I'll go back, is correlatable to the 3 increase in enthalpy of the fuel during the transient. 4 DR. KRESS: Is there a hidden parameter 5 here that's the burn-up? 6 MR. CLIFFORD: We looked into the burn-up, 7 and we would have expected to see more burn-up 8 behavior, because you've got to imagine --9 DR. KRESS: You would have thought during 10 burn-up it increases --Right. 11 mR. CLIFFORD: 12 DR. If there's no burn-up, WALLIS: there's no fission gas release. So you've got one 13 14 point. DR. ARMIJO: No, I think Tom's question 15 16 was in a high burn-up rod we have even more --17 DR. WALLIS: Yes, that's what I mean. I mean, it's obviously --18 19 CHAIRMAN SHACK: He's just giving you the 20 limit of no burn-up, no gas. 21 DR. ARMIJO: Okay. 22 This is a percent of MR. CLIFFORD: 23 fission gases available. This isn't an absolute 24 percentage, so low burn-up pellet is going to have 25 less fission gas available for release than a high

> NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433

	156
1	burn-up pellet. It's just the percentage.
2	DR. WALLIS: So you're proposing a new
3	CHAIRMAN SHACK: We've got to move on
4	guys, so let's
5	DR. KRESS: Well, let me ask one more
6	question. Is this strictly fission gas, or are yo
7	including some solids in there?
8	MR. CLIFFORD: This is strictly fission
9	gas.
10	DR. KRESS: Okay.
11	MR. CLIFFORD: It's Krypton, Xenons, and
12	Iodines.
13	DR. KRESS: Yes, but you're not including
14	any solids that might come out.
15	MR. CLIFFORD: That is correct. So what
16	we're recommending is that the licensees consider both
17	contributions, the steady state fission gas which
18	would be roughly the 10 percent that would be there
19	during normal operation. And then this additional
20	mechanism which is the transient fission gas release.
21	DR. WALLIS: And that's a percentage.
22	MR. CLIFFORD: That is percentage.
23	DR. ARMIJO: We're going to have to zip
24	through this.
25	MR. CLIFFORD: Okay. The next part is
I	I

(202) 234-4433

	157
1	entirely different. We've been talking about doses,
2	fuel failure, source terms, now we're getting into
3	GDC-28, which is coolability and maintaining reactor
4	vessel integrity.
5	(Off the record comments.)
6	MR. CLIFFORD: We're all familiar with the
7	phenomena at play as far as the potential for
8	expelling fuel particles, either molten or non-molten,
9	and the interaction with reactor coolant which result
10	in a steam generation and pressure pulse. And there's
11	also potential for flow blockage and fuel rod
12	ballooning.
13	The regulations right now are based on
14	GDC-28. The current criteria in Reg Guide 177 provide
15	details on how to meet the overarching requirements of
16	GDC0-28. And right now they state that as long as you
17	maintain a radial average enthalpy less than 280
18	calories per gram in any node, you'll be okay. And
19	your reactor vessel pressure needs to be less than
20	Service Level C. Service Level C is not in question.
21	We're maintaining that.
22	The problem with the current criteria is
23	that we've known since 1980 that the 280 calories per
24	gram is non-conservative, and fuel rods at PBF that
25	experience 280 calories per gram, which is acceptance

(202) 234-4433

158 criteria, exhibited a loss of rod type geometry, and 1 2 did not meet the requirements. Further, there was a conclusion that had 3 4 you reported the acceptance criteria in different 5 units, that 230 would have been the more appropriate In other words, there was a misinterpretation 6 limit. 7 of the results from the tests. And, also, the current 8 criteria does not address fuel fragmentation and 9 dispersal, and the current criteria does not address fuel rod ballooning. 10 DR. BANERJEE: But it was -- MacDonald's 11 experiments didn't show an effective burn-up. Right? 12 MacDonald, yes. 13 MR. CLIFFORD: Start tree 14 and PBF had mostly low burn-up. I believe there was 15 two or three rods that were up in the mid to high 20s 16 in burn-up. There were a couple of data points. 17 DR. CORRADINI: I was going to say PBF -I thought the fifth test. 18 19 DR. BONACA: All the vendors self-impose 20 themselves some limit, like 250 calories per gram, 21 230. 22 MR. CLIFFORD: Not all vendors and all 23 licensees have imposed stricter limits. DR. ARMIJO: But this will do that. 24 25 DR. BANERJEE: So at the moment, I mean,

> NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433

	159
1	if you use this, it would be flat 230?
2	MR. CLIFFORD: Right now it would be 230
3	going straight across for all burn-up. Correct.
4	Well, I'm sorry, today we have 280, which is
5	DR. BANERJEE: Today it would be 280.
6	MR. CLIFFORD: It's 280. That's what's in
7	the regulations, the Reg Guides. The empirical data
8	as shown, as I mentioned, there has been experimental
9	evidence of loss of rod geometry and molten fuel
10	coolant interaction reported at SPERT PBF, There's
11	also been fuel fragmentation dispersal reported in
12	various RAI test programs. It has also been reported
13	pressure pulses at various RAI test programs.
14	DR. BANERJEE: Are you going to show us
15	any data, or is that only the subcommittee meeting?
16	DR. CORRADINI: It's proprietary at the
17	subcommittee only. I think that's what the Chairman
18	is saying.
19	DR. BANERJEE: But isn't that I mean,
20	the data seems to show that some fuel dispersal occurs
21	at fairly low fuel enthalpies.
22	MR. CLIFFORD: Yes.
23	DR. BANERJEE: And, furthermore, it
24	depends also a little bit on pulse width, or not?
25	MR. CLIFFORD: Yes. Absolutely depend on
	1

(202) 234-4433

	160
1	pulse width. We're not going to define a numerical
2	limit to address fuel dispersal. That is something
3	that the we're just going to provide a criteria
4	that the industry will then need to demonstrate that
5	they can meet.
6	In other words, the first two criteria up
7	here are going to be hard and fast calculated limits,
8	which is something that's quantified. The next two
9	limits, which I'll get to in the next few slides, are
10	more qualitative, where the industry is going to need
11	to present data.
12	DR. WALLIS: Could you explain what you
13	mean by no loss of coolable geometry due to fuel
14	pellet and cladding fragmentation?
15	DR. CORRADINI: Graham, I don't think he's
16	going to get there yet.
17	DR. WALLIS: We're never going to get
18	there?
19	(Simultaneous speech.)
20	DR. ARMIJO: Just a matter for the
21	Chairman, I'd like to add. We've got if we're
22	going to close at 12:15
23	CHAIRMAN SHACK: We're not going to close
24	it. We're going to run until 12:30, and everybody is
25	going to grab a very fast thing so we can get back to
	I

(202) 234-4433

	161
1	the interviews.
2	DR. ARMIJO: It wouldn't be fair to
3	DR. WALLIS: If you want the committee to
4	make a decision, the committee has to understand what
5	it's deciding about.
б	DR. ARMIJO: But I think we obviously made
7	an error in not scheduling enough time for this
8	subject. And I'm just asking that maybe take that
9	into account, or we'll go as long as we can. We're in
10	a bind, so we'll just
11	DR. BANERJEE: We have a lot of time to
12	prepare our letters this time.
13	DR. ARMIJO: Maybe we should put more time
14	into these Full Committee reviews on such a big topic,
15	and we just didn't schedule enough time for this
16	thing. That's a problem, and I just apologize for
17	that.
18	DR. ABDEL-KHALIK: Mr. Chairman, is there
19	any problem with continuing the discussion following
20	the lunch break?
21	CHAIRMAN SHACK: We're just discussing
22	that. Let's just see how far we can get before we
23	bump the rest of the schedule.
24	DR. ABDEL-KHALIK: Thank you.
25	MR. CLIFFORD: Okay. This slide here
I	1

(202) 234-4433

shows, to address the first two criteria, which is right now we currently have 280 calories per gram in the Reg Guide. MacDonald determined looking at SPERT, Tree, and PBF that 230 was a more appropriate limit. We concur with MacDonald's conclusion, so we're going to maintain the 230, so at no time can you exceed 230 calories per gram. And that protects the rod

9 IN addition, there is a requirement that you can't achieve fuel melt temperatures, and the 10 11 reason for that is that once you achieve fuel melt, 12 then you have potential of expanding, and breaking, and having molten fuel to coolant interaction. 13 So to 14 avoid molten fuel coolant interaction, we avoid 15 temperatures. And here is just two melting The calculation of fuel temperatures is 16 calculations. 17 very design-specific. The thickness of the pellet, the thickness of the cladding or the moderator, so 18 19 we're not dictating a specific limit. We're just 20 saying that use approved methods and demonstrate that 21 your fuel temperatures remain below melt. So here's 22 just two examples of a particular fuel design. This 23 is provided by EPRI.

24DR. WALLIS: So after 27 years, you're25decidingeventuallytoacceptMacDonald's

NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433

1

2

3

4

5

6

7

8

geometry.

(202) 234-4433

162

	163
1	recommendation?
2	DR. CORRADINI: He's a difficult man to
3	work with. You have to
4	(Laughter.)
5	DR. WALLIS: It's taken a whole new
6	generation of people.
7	DR. CORRADINI: (Laughing.) I'm sorry.
8	I apologize.
9	DR. BANERJEE: Is he still around?
10	DR. CORRADINI: Yes.
11	DR. ARMIJO: Gentlemen, let's keep going
12	here. The point is here is a no
13	DR. CORRADINI: Let's not dump on fuel.
14	Right.
15	DR. WALLIS: Well, this is very strange.
16	Why now?
17	MR. CLIFFORD: Well
18	CHAIRMAN SHACK: We can do it without a
19	backfit. Okay. Let's move on.
20	DR. WALLIS: You can do that without a
21	backfit. That's why. Right?
22	DR. BANERJEE: When you said approved
23	methods for T melt calculations, what did you mean?
24	I mean, there was a huge discussion on what is an
25	accepted method, and an approved method in one of the
I	I

(202) 234-4433

164 1 subcommittee meetings a few months ago. Do you really 2 approved method, because that mean means that 3 everything has to be validated, and all that sort of 4 stuff. 5 MR. CLIFFORD: Correct. 6 DR. BANERJEE: Not just an accepted 7 method. 8 MR. CLIFFORD: It would be approved. Ιt would be submitted, reviewed, and approved. 9 10 DR. BANERJEE: And are there codes which actually do that? 11 12 CLIFFORD: I believe there are MR. approved suite of codes that do that right now. 13 Of 14 course, some of them are 2D or 1D, so they're very 15 conservative. DR. BANERJEE: So they could be very 16 17 conservative. MR. CLIFFORD: Correct. But when they 18 19 revise their methodology so that they don't get -- so 20 they could limit their clad failure during PCMI, 21 they're going to be introducing 3D kinetics and when 22 you introduce 3D kinetics, that's also going to help 23 you out here in the fuel temperatures, also affect 24 reactivity. 25 DR. ARMIJO: Okay.

> NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433

	165
1	MR. CLIFFORD: Okay. So the acceptance
2	criteria for one and two essentially would be the
3	lower of these lines. It would be the lower of your
4	fuel temperature calculation, which is strongly
5	dependent on burn-up, and it would be the MacDonald
6	limit up here.
7	DR. WALLIS: Why would you ever do this
8	when all the other criteria ask for lower fuel
9	enthalpies? Why would you ever worry about this one
10	at all?
11	MR. CLIFFORD: You can exceed the previous
12	limits, because that defines when clad fails. These
13	are the upper limit that can't be exceeded.
14	DR. WALLIS: Oh, I see. For any of the
15	fuel.
16	MR. CLIFFORD: Any fuel, not one fuel.
17	DR. ARMIJO: See, as long as the doses are
18	okay.
19	DR. ABDEL-KHALIK: Am I missing something
20	here? Why set it at the blue line, rather than a line
21	depending on the pulse width, which may be 10 or 20
22	milliseconds?
23	DR. CORRADINI: But I think, Said, that's
24	the second criteria. It's the lower of the two.
25	MR. CLIFFORD: The second criteria would
ļ	

(202) 234-4433

	166
1	specifically account for the pulse width
2	DR. CORRADINI: Pulse width.
3	MR. CLIFFORD: Because reactor-specific
4	fuel rod design specific, where you would take that
5	into account and calculate
6	DR. CORRADINI: The way I read this is the
7	blue line is operative at low burn-up, and depending
8	upon what the ejection is, the green line is operative
9	at high burn-up.
10	DR. BANERJEE: Maybe, depending on the
11	fuel.
12	DR. CORRADINI: Yes.
13	MR. CLIFFORD: Well, fuel temperatures do
14	decrease I mean, fuel conductivity decreases with
15	burn-up, you get pellet edge peaking due to Plutonium
16	build-up in a rim formation. And, also, you get
17	extremely high localized burn-up in the rim region,
18	all of which result in out here melting in the rim
19	region or melting in the periphery, and this would
20	occur at a pretty low enthalpy.
21	Okay. The first two, as I mentioned, were
22	very quantitative. The next two are very qualitative,
23	in the sense that we understand that there's no
24	criteria now to address this phenomenon, and there
25	needs to be an established line in the sand, say, for
Į	1

(202) 234-4433

	167
1	determining whether or not you get a significant
2	pressure pulse from the interaction of non-molten
3	fuel, small fuel particles which are ejected into the
4	coolant. And it's effect on the integrity of the
5	evaluation of the reactor vessel pressure integrity.
б	DR. WALLIS: You're telling us this is
7	something you don't understand how to evaluate?
8	MR. CLIFFORD: All we're doing is telling
9	we're providing guidance to the reviewers that say
10	the licensee coming in needs to include an evaluation
11	of the interaction of the fuel and the coolant in
12	determining the pressure pulse, and determining
13	whether or not the reactor vessel
14	DR. WALLIS: Is there a technology for
15	doing that?
16	MR. CLIFFORD: There is a limited database
17	of mechanical interaction, mostly from severe accident
18	space that has been done.
19	DR. WALLIS: How will you evaluate
20	something if you don't know what the basis for it is?
21	MR. CLIFFORD: Well, there needs to be a
22	conversion of the energy to fuel to steam, and there
23	is data available, and there's data presented in the
24	EPRI topical report.
25	DR. KRESS: You first have to know how
	1

(202) 234-4433

	168
1	much non-molten fuel gets ejected. That you're going
2	to have to measure. There's no other way to do that.
3	Then you can bound it, the energetics of that, if you
4	know how much is ejected, because you don't know how
5	much energy it has, convert it all.
6	MR. CLIFFORD: Right. And the amount of
7	energy is not just the amount of fuel, it's the size
8	of the particle, and the shape of the particle.
9	DR. KRESS: That would be a refinement.
10	But then you'd have to know a lot more about the
11	ejected fuel.
12	MR. CLIFFORD: I'm not dispositioning
13	this. All I'm saying for the staff is, this is
14	something that the applicant needs to address, as
15	opposed to now they just have a blind eye to it.
16	DR. KRESS: Well, that's tough. You would
17	have to take a piece of fuel at different burn-up
18	levels, eject it to these pulses, and measure how much
19	stuff gets ejected. That's not an easy test to do.
20	And I guess they're saying we have to leave that up to
21	the applicant.
22	DR. ARMIJO: Figure out a way to avoid
23	that situation, in the design of your plant, the
24	operation of your plant, design of your fuel.
25	DR. KRESS: Of course, even this goes away
ļ	I construction of the second se

(202) 234-4433

	169
1	if you use 3D kinetics.
2	DR. ARMIJO: Right. That's the other way.
3	DR. KRESS: That's the solution to all of
4	this.
5	MR. CLIFFORD: Also, as was mentioned,
б	there is a very strong burn-up dependence on the
7	amount of fuel that could be dispersed, whether
8	there's a rim region or not, so maybe you could if
9	you could show for instance, as an example, that you
10	don't fail any cladding above a burn-up that
11	corresponds to having no rim formation yet, then there
12	would be very low
13	DR. WALLIS: Well, this sort of reminds me
14	of the sumps. I mean, you have some guidance which
15	says that sump screens should not clog. But until you
16	know what makes them clog and how to evaluate it,
17	that's sort of a useless statement. Is this one of
18	those things that they've got to evaluate something,
19	but no one knows how to do it?
20	DR. BANERJEE: Or they can try to design
21	around it, I guess.
22	MR. CLIFFORD: They can prevent fuel
23	coolant interaction by design, or by analytical tools,
24	or a combination thereof.
25	DR. CORRADINI: So this is I'm still
l	1

(202) 234-4433

170 1 trying to read into this. This is above, this is if 2 you lie above 1 and 2, or this is even below 1 and 2? DR. BANERJEE: No, below, below. 3 4 DR. WALLIS: Below 1 and 2. MR. CLIFFORD: This is below. You can't 5 6 7 DR. BANERJEE: One and two you can't 8 exceed. 9 DR. WALLIS: Even then, you've got to do 10 something more. DR. ABDEL-KHALIK: I guess I'm concerned 11 12 about conceptually, moving from we're one uncomfortable 13 current position to another 14 uncomfortable future position. The current position 15 is uncomfortable because we're saying the methods used are conservative, even though the limits currently 16 17 imposed are non-conservative, and that's why we feel comfortable, albeit, deep down we are uncomfortable 18 19 because we're doing all this work. And now you're 20 essentially forcing people to go to detailed 3D 21 methods, and yet you're not giving them adequate 22 limits that are commensurate with the level of detail in which these methods will be used. So I'm not sure 23 24 what we're gaining by doing this. 25 DR. CORRADINI: Well, first of all --

> NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433

	171
1	DR. BANERJEE: Well, one and two are
2	clear, I think we've gained something there.
3	DR. MAYNARD: If we do nothing, we're
4	stuck with the old criteria, which may be just as bad
5	for the future, not ready to go to the ultimate
6	answer, so this is an interim step that is more
7	conservative than what's on the books right now.
8	DR. CORRADINI: I don't understand if I
9	was an applicant what I'd do I mean, I think sites
10	I'm just like
11	DR. ARMIJO: I would do everything I could
12	to avoid getting into that situation.
13	DR. CORRADINI: Right. But that's what I
14	guess I'm getting at quantitatively. I understand how
15	I would avoid getting into one and two. I don't
16	understand three and four. You're saying that any
17	reactivity insertion at all, you must show three and
18	four.
19	MR. CLIFFORD: Correct. If you have clad
20	failure, you have to show three and four.
21	DR. CORRADINI: If you have clad failure,
22	you must show three and four.
23	MR. CLIFFORD: Yes.
24	DR. BANERJEE: I understand your conduct.
25	We're making
I	

```
(202) 234-4433
```

	172
1	mR. CLIFFORD: If you don't have clad
2	failure, then three and four go away.
3	R.C.: How do you show non-clad failure?
4	How do you show that the clad doesn't fail?
5	DR. CORRADINI: Stay below the red line.
6	That's the only according to
7	R.C.: I think this is
8	mR. CLIFFORD: It's not out of the
9	question. This is what was presented in RIL0401.
10	They said with modern physics codes you would not have
11	clad failure. This isn't something we're making up.
12	It's well documented.
13	DR. ARMIJO: It would be unfortunate,
14	though, if with modern physics codes, and all the
15	tools you had at your command, fuel design and
16	everything else, and you still had fuel failure, and
17	then we force the licensees into a situation to
18	analyze something that nobody knows how to do, we'd
19	all be in a mess. So we have to be pretty confident
20	that there is a way to address this thing, and close
21	it to the staff's satisfaction.
22	CHAIRMAN SHACK: But, I mean, if you don't
23	like this answer, you have to come up with a different
24	you can make a risk-informed argument. There are
25	various things, but if you get clad failure and you
I	I

(202) 234-4433

	173
1	have this possibility, then you have to address it.
2	That's all they're saying. Now they can avoid clad
3	failure, we can come back for a different argument,
4	but if you have clad failure, and if this happens,
5	then you have to address it.
6	DR. WALLIS: Is it a problem? Do we know
7	if it's a problem or not? If you have this clad
8	failure, does it lead to a pressure pulse which will
9	challenge the reactor, the vessel?
10	MR. CLIFFORD: There's empirical data out
11	there shows the mechanical energy conversion of non-
12	molten fuel significantly less than that of molten
13	fuel. And by Criteria One and Two, we have a comfort
14	level that mechanical energy is going to be a lot
15	lower because we're precluding fuel melt. But at the
16	same time, we can't say you don't have to address it.
17	There's going to be some mechanical interaction. It's
18	probably a lot less, but to what extent, we don't
19	know.
20	DR. BONACA: Although, the old presumption
21	was that if you were below 280 calories per gram, you
22	wouldn't have to do anything else. It was assurance
23	that you would have no pressure pulse.
24	DR. WALLIS: How about leading to further
25	
	I

(202) 234-4433

	174
1	mR. CLIFFORD: That was on fresh fuel, so
2	you didn't get the pellet didn't break apart, as it
3	would in higher burn-up. Fuel pellets didn't
4	disperse.
5	CHAIRMAN SHACK: We're just going to have
6	to close this off. Can we go to the last slide, and
7	we're
8	DR. WALLIS: Damage to neighboring pellet,
9	neighboring fuel elements?
10	MR. CLIFFORD: That's why we didn't say
11	that has to be addressed with respect to fuel
12	DR. WALLIS: But you don't know how to
13	address it. We don't know how to predict how many
14	fuel elements will be damaged if one of them fails, do
15	we, by energetic - we don't know that, don't know how
16	to do that. Is that true?
17	DR. CORRADINI: Yes, I think that's quite
18	true. If you want to have a deterministic knowledge
19	of it
20	DR. WALLIS: Even probabilistics ought to
21	be based on some physics.
22	DR. CORRADINI: Well, I wouldn't even try
23	that. If I can't even calculate it for a set
24	experiment, I doubt if I'd know what to do to put
25	curves on it, and spreads, and stuff.
	I

(202) 234-4433

	175
1	DR. WALLIS: This is somewhat
2	extraordinary, it seems to me.
3	CHAIRMAN SHACK: Let's move on. Let's
4	move on. We'll come back to this in our discussions.
5	DR. WALLIS: If we're already in the
6	quicksand, how can we move on?
7	DR. CORRADINI: He's throwing us a life
8	line, the Chairman is throwing us
9	mR. CLIFFORD: Implementation. The
10	interim criterion guides, as we discussed, will be
11	applied to the new applicants, the COL applications.
12	DR. WALLIS: Poor fellows.
13	MR. CLIFFORD: Over the next 18 months or
14	so, we'll complete further evaluation, taking in new
15	data that's become available, and we'll finalize the
16	criteria, and advise Reg Guides on the SRP again. And
17	during this period, the purpose of the RIS is to
18	communicate to the industry that here you have a
19	target that you should aim for. You should start
20	looking into developing a strategy for dealing with
21	long-term cooling, you should develop methodology for
22	dealing with short-term clad failure PCMI failures,
23	and get that license reviewed because in 18 months
24	when we issue the final criteria, then we'll have to
25	address backfit of the current fleet.
ļ	

(202) 234-4433

	176
1	DR. ABDEL-KHALIK: Would you be really
2	ready to issue final criteria in 18 months based on
3	what you presented today?
4	MR. CLIFFORD: We will be doing our own
5	assessments, but the industry is also preparing
6	further information to provide the staff for
7	evaluating, or determining the final criteria. So we
8	believe we will be in a position within 18 months to
9	massage it. That doesn't mean that the more
10	qualitative arguments for three and four can be
11	thoroughly dispositioned.
12	DR. BANERJEE: What does
13	mR. CLIFFORD: Those are gray areas, but
14	as far as fine tuning when you get PCMI and when you
15	don't, we'll have enough information.
16	DR. BANERJEE: What comments have you
17	had interactions with industry about points three and
18	four?
19	MR. CLIFFORD: We had two public workshops
20	that were very well attended.
21	CHAIRMAN SHACK: We're going to have a
22	presentation by industry after lunch, so it was
23	supposed to be before lunch.
24	DR. ABDEL-KHALIK: We did get extra time.
25	CHAIRMAN SHACK: Yes, we have extra time.
I	1

(202) 234-4433

	177
1	DR. ABDEL-KHALIK: I'd like to thank
2	DR. BONACA: I mean, the only way you're
3	going to get values like this in a PWR is to assume
4	zero power, all the rods are in, and you're ejecting
5	a rod from that location. Okay? That's how you get
6	these values.
7	MR. CLIFFORD: It's actually worse than
8	that. Generally, you assume Xenon oscillation such
9	that your ASI is the worst it could ever be, and then
10	you eject a rod through
11	DR. BONACA: Exactly. And then
12	physically, you wonder where you're going to eject it,
13	or whatever. I don't try right now tightening so much
14	the criteria.
15	DR. KRESS: You're using a risk-informed
16	approach.
17	DR. BONACA: If I went to risk-informed
18	approach, this problem most likely would go away.
19	CHAIRMAN SHACK: I mean, that's also part
20	of the original continuing justification for future
21	of operation. I mean, with the results of the 3D
22	neutronics and the realization that this was a
23	relatively infrequent event.
24	We're going to adjourn now for lunch.
25	Everybody knows we have interviews here starting in
I	I

(202) 234-4433

	178
1	two minutes, and we'll be back here at 1:45, which
2	we're going to have an industry presentation on the
3	RIA stuff.
4	(Whereupon, the proceedings went off the
5	record at 12:26 p.m., and went back on the record at
6	1:44 p.m.)
7	CHAIRMAN SHACK: On the record. Those of
8	you are excited to hear about risk management
9	technical specifications, Initiative 4B, we're running
10	a little late from this morning and so we'll be
11	starting in about 15 or 20 minutes.
12	(Off the record comments.)
13	DR. ARMIJO: You'll hear some very
14	interesting stuff.
15	CHAIRMAN SHACK: Yes.
16	DR. ARMIJO: About what?
17	DR. POWERS: We're about to insert some
18	reactivity.
19	DR. ARMIJO: Right. So the balance of the
20	presentation will be given
21	DR. POWERS: We've been pretty reactive so
22	far, but we're going to look some new criteria for our
23	reactivity insertion.
24	CHAIRMAN SHACK: All right. Dr. Ozer from
25	EPRI will be speaking with backup by Rob Montgomery of
	I

	179
1	Anatech and discuss industry's position on SRP 4.2,
2	specifically the RIA criteria.
3	MR. OZER: Thank you very much. I would
4	like to thank very much the Committee for giving us
5	this opportunity to present the industry perspective.
6	This presentation has been put together with
7	considerable input from a working group of the
8	industry that consists of U.S. nuclear utilities, a
9	large number of overseas utilities, all the major fuel
10	vendors as well as our sister organization, NEI.
11	This is the outline of the presentation.
12	I was originally planning on saying a few words about
13	SRP 4.2 in general, then focus really on the Appendix
14	B criteria and then finish with a couple of
15	conclusions and recommendations. However, since we
16	are so far behind, I will skip the discussion of the
17	overall SRP 4.2 other than saying that we did identify
18	a number of areas where we wanted to give you feedback
19	to the NRC and that was presented two days ago at the
20	subcommittee meeting and we'll be presenting them also
21	in a letter to the NRC staff in the near future.
22	Then I would like to focus on the interim
23	RIA criteria, our perspective on Appendix B. I'd like
24	to reiterate that the evidence shows that the current
25	RIA criteria, we agree that they are inappropriate at
I	I

(202) 234-4433

1 high burnups. They are okay at low burnups, but high 2 burnup conditions, they need to be changed. NRC has 3 stated that these criteria need to be changed, but 4 there is no safety concern due to conservative 5 methods. We agree with that and also would like to add that the risk is very low. 6 This is a very low 7 probability event and our evaluation of what would 8 happen is also rather contained. 9 So our position on the interim criteria is 10 that we consider them to be appropriate for new plants. 11 12 Keep going please. DR. APOSTOLAKIS: 13 MR. OZER: I'm sorry. 14 DR. APOSTOLAKIS: No. No problem. Okay. 15 That's better. 16 MR. OZER: Sure. No problem. We 17 considered the criteria to be appropriate. We had an opportunity to interact with the NRR staff in these 18 19 couple of workshops that were mentioned before and I 20 think some of our key concerns have been addressed. 21 The key concerns that we had were really the ability 22 to treat coolability separate from fuel failures. You 23 failures, fuel but you cannot exceed the can 24 coolability limit. That's the limit that is really 25 the major limit.

> NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433

(202) 234-4433

180

	181
1	We feel that, and I hesitate to say that
2	after listening to all the difficulties that the
3	previous speaker was put to, there are some excessive
4	conservatisms in the criteria, the interim criteria.
5	We feel that there is room for improvement,
б	particularly in the failure thresholds and there is
7	excessive work that needs to be done to address the
8	coolability issue and we look forward to work with the
9	NRC for the development of these final criteria that
10	
11	VICE CHAIR WALLIS: Is this conservatism
12	in the failure threshold?
13	MR. OZER: Yes.
14	VICE CHAIR WALLIS: Can you give us a
15	MR. OZER: I'll be coming to that. Yes,
16	definitely.
17	We feel that we We were concerned about
18	this issue when it first appeared in the early 1990s
19	and since then, we've invested a considerable amount
20	of effort, resources, into trying to understand what's
21	going on and we have now a pretty good understanding
22	of what's going on and we developed a mechanistic
23	approach, a methodology for analysis and of the
24	experiments that were carried out.
25	But we're not trying to develop a failure
I	I

(202) 234-4433

	182
1	line for experiments. We're trying to develop a
2	failure line for fuel in a reactor. So the
3	experimental results have to be translated to how fuel
4	would respond in a reactor and that's why we feel that
5	we need to come from first principles. We have to
6	know what's happening to that fuel during the
7	experiments. The approach that we used is really
8	based on that.
9	This is really sort of a bird's-eye view
10	of our approach. We use a mechanistic code that
11	follows the thermal mechanical changes that happen in
12	a fuel rod as it's being hit by a power pulse and we
13	have What happens, for example, during an RIA
14	simulation test is we have a power pulse, an energy
15	input, and the question is how will the pellet respond
16	to that.
17	Now here is a graph of what we estimate is
18	going to be the pellet response. What we have there
19	is the cladding and over here from here on is the
20	pellet. This is the pellet periphery and that's the
21	pellet center. So you have to assume that's half of
22	a symmetric diagram and what happens is initially as
23	the pulse is starting you have the first response.
24	This is high burnup fuel we're looking at.
25	The first response to appear at the pellet
	I

(202) 234-4433

1 periphery, the pellet rim, which has this plutonium-2 rich region and it's a very narrow region and that's -- We're plodding here the 3 where the first 4 temperature. The temperature of the rim is going up 5 very quickly. By the time we reach the peak of the pulse, the rim temperature is way up here. The pellet 6 7 center tries to follow, but it follows at a slower 8 rate and eventually --9 VICE CHAIR WALLIS: And this is due to the 10 plutonium enrichment on the outside. MR. OZER: Yes, sir. But eventually, of 11 course, this peak disappears and gets lower and we end 12 up with the usual parabolic distribution way after the 13 14 It's kind of interesting to see what happens pulse. 15 to the cladding. You see the cladding temperature initially when the pulse first starts, the cladding is 16 17 still at the ambient temperature because so early on it's still an adiabatic process. 18 The cladding has not 19 had a chance to heat up. 20 But as we hit the high peak in the rim, 21 the cladding starts to heat up and the inside is 22 getting reasonably hot, but the outside is still cold. 23 So it's really a question -- It's a race really 24 whether the cladding has enough time to warm up so 25 that its ductility will improve to respond to this

> NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433

(202) 234-4433

183

	184
1	challenge without fracturing.
2	DR. ARMIJO: Just out of the record, are
3	these number prototypical? In other words, are they
4	consistent when you say a peak temperature of roughly
5	2500 Kelvin at 112 calories per gram?
6	MR. OZER: This is what we calculate for
7	the tests that were carried out and it agrees with all
8	the measurements. But there are no direct
9	measurements of the temperature while this is
10	happening.
11	DR. ARMIJO: No. I just wanted to make
12	sure that these numbers are consistent.
13	MR. OZER: But we can only deduce. Yes.
14	DR. ARMIJO: Okay.
15	MR. OZER: And let me It's a good
16	question to say "Well okay. So are you calculating
17	this or what?" And really the proof of the pudding is
18	can we predict what's happening in these tests and
19	what we have in these tests at the end is the strain,
20	the residual strain, and that can be measured and
21	these are the measurements and this is our calculation
22	of the residual strain. So we feel that all our
23	results are consistent with what has been observed.
24	We can explain mostly the non-failed, all the non-
25	failed cases.

(202) 234-4433

	185
1	DR. ARMIJO: So this is an unfailed rod
2	and you have measured versus predicted strain.
3	MR. OZER: Yes sir.
4	DR. ARMIJO: Okay.
5	VICE CHAIR WALLIS: It bulges our 5 mm, in
6	other words, 5 X $10^{-2}$ . Okay. I see that. I didn't
7	see that.
8	DR. ARMIJO: I wish it was that ductile.
9	We wouldn't be here if it was that ductile.
10	MR. OZER: So we felt confident that we
11	understand what's happening in these tests and then we
12	used this methodology to determine what kind of a
13	pulse one would need in a reactor situation to fail
14	the fuel. We also developed a measure of when fuel
15	would fail and we based that on a metric which we
16	called the strain energy density or critical strain
17	energy density. It's when the fuel is expected to
18	fail.
19	On this basis, we proposed modifications
20	to current criteria. This would be essentially our
21	view of the current criteria. This is the range where
22	Paul was saying that you don't have PCMI really. PCMI
23	concerns really start at the higher burnup. At the
24	lower burnup, you have ductility so that you have to
25	go to really high enough enthalpies to melt the

(202) 234-4433

	186
1	cladding. But at the higher enthalpies you start have
2	the PCMI interaction and then the question is does the
3	cladding have enough ductility to survive.
4	VICE CHAIR WALLIS: So what happens to
5	have the curve change direction at around 36?
6	MR. OZER: Yes. At that point, the gap is
7	closed. You start having the possibility of PCMI and
8	as you go to higher burnups, you start losing
9	ductility because of the hydrogen content in the
10	cladding starts heating up.
11	VICE CHAIR WALLIS: Where does it level
12	off? When it gets up 80?
13	MR. OZER: I'm sorry. When it levels off
14	up here?
15	DR. ARMIJO: Yes. Why doesn't it just
16	keep going down?
17	MR. OZER: Yes. It's because you need a
18	certain amount of enthalpy just to close the gap and
19	get over the elastic capability of the cladding. So
20	the cladding will fail once it enters into plastic
21	regime if it has no ductility whatsoever. So you
22	still have enough room for deforming the cladding,
23	closing the gap and deforming the cladding.
24	We were When we submitted this, NRC
25	Research independently proposed a much more
	I

(202) 234-4433

1 conservative approach and they used a completely 2 different concept. They said rather than going 3 through the first principles approach, we'll just take 4 the experiments and recognizing that the experiments 5 differ, the environment of the experiments differs, from the end reactor situation, we'll try to make some 6 7 adjustments to do it and also there was some question about how we addressed uncertainties in the material 8 9 properties and there were questions about our use of 10 strain energy metric.

first of all that 11 Our response was 12 different approaches, independent approaches, if they come from first principles and even if they use a 13 14 different metric like maybe total plastic elongation 15 of total plastic strain as they measure when you start breaking the cladding you will end up with similar 16 This was really justified or supported later 17 results. on when there was a paper presented by the Swedish 18 19 industry. The lead author here was from the Swedish 20 Nuclear Power Inspectorate.

21 So we took this slide originally from 22 them. It's a little complicated slide, but let me 23 explain what we have here. First of all, this is 24 their slide. So this is their estimate using a 25 different code and using a different metric of where

> NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433

1 they think the failure limit ought to be at the higher 2 burnups and that's why this is referred to as a It is a present study for the Swedish 3 present study. 4 paper and they're comparing it to what we proposed 5 which is this red line which goes like this and it flattens off here and also they compared it to a study 6 7 conducted by Battelle Northwest using FRAPTRAN and 8 also a different metric and we see that, yes, there is 9 some difference but generally there is agreement as compared to the NRC research curve which would lie 10 That's why we believe that there is a lot 11 down here. of -- That's why there is a disagreement. 12 The interim criteria gives us some room up 13 14 to these intermediate burnups and then they start 15 dropping down. The reason I don't have a single line here but just a region is because the abscessa here is 16 burnup whereas the interim criteria are defined in 17 terms of corrosion ratio. So we need to translate 18 19 those into burnup space and in doing that, there is 20 some uncertainty that comes in. So we think that the 21 curve is going to lie somewhere in here. 22 DR. ARMIJO: But this is exclusively for 23 PWR, right? 24 MR. OZER: This is exclusively for PWR. 25 That's correct. For hot temperature.

> NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433

(202) 234-4433

188

	189
1	DR. ABDEL-KHALIK: Your answer to the
2	previous question regarding the asymptotic value at
3	high burnup implies that there is a mechanistic basis
4	for deriving that asymptotic valve.
5	MR. OZER: Yes, I think so.
6	DR. ABDEL-KHALIK: Now if that is the
7	case, people can evaluate mechanistic models. Why
8	couldn't you present that?
9	MR. OZER: I think that we thought there
10	was some more room above that, but I think that's
11	That would be our bottom line.
12	DR. CORRADINI: But can I ask Said's
13	question differently? You get to an asymptotic value.
14	So does your calculation decompose to essentially a
15	model that gets you to a constant new enthalpy?
16	(Off the record discussion.)
17	MR. MONTGOMERY: Can I answer that?
18	MR. OZER: Yes, please do.
19	MR. MONTGOMERY: Robert Montgomery from
20	Anatech. The asymptotic behavior of the line here is
21	a combination of several factors and they basically
22	are some of the assumptions that went into the
23	analysis. The analysis is a combination of a best
24	estimate methodology combined with some treatment of
25	uncertainties through a deterministic way, not really
ļ	I

(202) 234-4433

a statistical way, and the saturation has to do with two primary parameters. One is the burnup dependency of the gap or the PCMI loading. That pretty much saturates after awhile. You don't really close the gap anymore. There's always a finite amount of gap that's pretty saturated after a burnup of about 45,000 or 50,000.

The second part comes in as we made the 8 9 assumption that the material properties reached the 10 worst possible state and stay there. They don't get any worst and that's based on the data we have at 11 12 these burnup levels, that it doesn't reach a very low Improvements in cladding, material properties, 13 state. 14 will stay basically unchanged beyond a certain burnup. 15 They won't continue to fall. That's where you get the 16 asymptotic behavior primarily.

DR. ARMIJO: If the hydrogen content keeps growing with burnup, why don't the properties keep degrading?

20 MR. MONTGOMERY: What we assumed in this 21 calculation here is that there will be a license limit 22 on how high the hydrogen content can go and we took a 23 bounding value and assumed that you reached it at 24 about 45,000 gigawatt-days and you didn't exceed that 25 anymore because there's a limit to envelope the number

> NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433

1

2

3

4

5

6

7

	191
1	or the variation of hydrogen with burnup or really we
2	did it with oxide data, but it would be the same.
3	DR. ABDEL-KHALIK: I guess we're talking
4	maybe of different asymptotes.
5	MR. MONTGOMERY: This one here you're
6	talking about.
7	DR. ABDEL-KHALIK: Yes, the flattening.
8	MR. MONTGOMERY: Right. So what happens
9	in this range is there are two factors. One is you're
10	reaching the maximum amount of cladding mechanical
11	property degradation because we've reached the limit
12	based on hydrogen. The hydrogen content is limited.
13	We limited it to something like 800 ppm and said
14	that's as far as we wanted to go in our model because
15	it didn't make sense to allow it continue to go up
16	beyond where we ever expected to go. So that's one
17	factor going into contributing to why this is becoming
18	asymptotic. The second is the role of burnup on the
19	loading process, the PCMI loading process. That's
20	saturated with burnup. So both of those come together
21	to contribute to that asymptotic behavior.
22	DR. ABDEL-KHALIK: What's different about
23	the PNNL model that it keeps going down?
24	MR. MONTGOMERY: This one here?
25	DR. ABDEL-KHALIK: Yes.
I	1

(202) 234-4433

	192
1	MR. MONTGOMERY: I believe primarily
2	that's due to the mechanical properties that they
3	used. They did not set a limit or saturated it. They
4	allowed it to go down.
5	DR. ARMIJO: So their hydrogen kept going
6	up and their ductility went down.
7	MR. MONTGOMERY: Kept going up. But I
8	can't speak to that in detail because I did not do
9	those calculations. That would be my estimation.
10	DR. CORRADINI: So one of the questions
11	just since you have a graph up, did you put the data
12	that NRC is using on that graph and it all lies above
13	any of your lines or does it span the lines of your
14	calculation?
15	MR. OZER: We used that same
16	DR. CORRADINI: I'm sorry.
17	MR. MONTGOMERY: But it's going to be in
18	a different space. What I can tell you is that in the
19	data that was shown earlier, that's basically from RIA
20	test from around the world. Some will fall below this
21	line. Some will fall above that line and Dr. Ozer
22	here will explain to you why some fall below and some
23	fall above.
24	MEMBER CORRADINI: Fine. Thanks. I'll
25	wait.
	1

(202) 234-4433

	193
1	MR. OZER: So in view of this, our
2	perspective on the interim criteria is that they are
3	an improvement over our RIL401 but there are still
4	areas of excessive conservatisms in there that seem to
5	us to be unjustified. We feel that for the final
б	criteria we need a strong technical basis that must
7	exist. We need to improve, not only analytically, the
8	assumptions that were made for the interim criteria
9	but also need to incorporate additional experimental
10	data. You have to keep in mind that again the
11	Japanese NSRR data is at room temperature, ambient
12	pressure, extremely narrow pulses, whereas the CABRI
13	is somewhat more representative but it's in a sodium
14	environment. The coolant is sodium and both of these
15	will be the CABRI facility is being converted to a
16	water loop and the NSRR facility will start having
17	tests under pressure and representative temperatures.
18	We feel that that has to be looked at and we also feel
19	that there are some considerations for the BWRs that
20	need to be address as well.
21	CHAIRMAN SHACK: Odelli, I would like if
22	you could finish up in ten minutes.
23	MR. OZER: Okay. What I would like to say
24	here is that we really wait until the data becomes
25	available please, that the schedule should not be
I	

(202) 234-4433

(202) 234-4433

194 1 driven by calendar but really by the availability of 2 data. 3 Now the reason we felt that the interim 4 criteria need to be improved is because they still use 5 a subjective lower bound to adjusted RIA simulation tests and we feel that the adjustments really were not 6 7 sufficient and there were some assumptions that were 8 made that we don't agree with, assumptions such as  $UO_2$ 9 and MOX fuel pellet responses identical or the same or 10 there is no difference between  $UO_2$  and MOX. Assumption that room temperature and hot 11 12 zero product ductility is the same and the assumption is that cladding that has high corrosion will behave 13 14 the same whether it's spalled or unspalled if it has 15 high blisters or has uniform distribution of hydrides. 16 You disagree with that and we think that we need to 17 address those. The impact of this is to result in a lower than necessary criteria. 18 19 address these issues. Let me The difference between UO<sub>2</sub> and MOX fuel pellets is that in 20 a UO<sub>2</sub> pellet you have a rim formation at high burnups 21 and it's really as we saw in the graphs earlier. 22 It's 23 the rim that's driving the stresses on the cladding 24 primarily. In MOX pellet, there is no rim in the same

sense as in  $UO_2$ . MOX you have plutonium oxide grains

NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433

25

embedded in a matrix and you have rims developing throughout around each one of these grains. So when you have a challenge like the pulse that is experienced during an RIA, more of the pellets inside contributes to expanding the cladding. So given the same enthalpy input, MOX fuel responds much more strongly than UO<sub>2</sub>. Next slide please.

This is further demonstrated in this 8 9 slide. Here what we have is the sodium that is displaced during the experiment during the initial 10 phase at the same enthalpy level. When you insert 70 11 12 calories per gram enthalpy, how much sodium was dispersed by three different uranium rods? And this 13 14 is the displacement at this point which is primarily 15 due to just the expansion of the cladding. This is uranium. This is the same thing for three plutonium 16 rods and there's a significant change. 17

Going to our next argument that there is no improvement in ductility, these are burst tests that were conducted under the NFIR program. We see going from room temperature to operating temperatures a factor of 3 improvement in total plastic elongation. Next.

24 So what is our objection to the 25 adjustments? This is the dataset that was used to fit

> NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433

1

2

3

4

5

6

7

	196
1	the interim criteria. The interim criteria, next,
2	this is the line. Now the round points are NSRR
3	experiments that failed. The hollow ones are NSRR
4	experiments that did not fail. These are CABRI
5	experiments that did not fail and CABRI experiments
6	that did fail.
7	VICE CHAIR WALLIS: And you've taken out
8	the very low ones.
9	MR. OZER: Yes, we did take out the very
10	low one. I mean, we did not take out the very low
11	one. There was a committee that was set up by NRC to
12	evaluate whether the lowest experiment was defective
13	or not and we published a two volume report on that.
14	VICE CHAIR WALLIS: That one but not the
15	one above it.
16	MR. OZER: No, just that one.
17	VICE CHAIR WALLIS: It's below the line.
18	MR. OZER: That was the very first
19	experiment. It was conditioned differently than the
20	other experiments and the NRC's consultant's opinion
21	was that that contributed to its premature failure.
22	But we did not remove the other ones. But what we
23	noticed was that all the failures, these failures,
24	these had something special about them and I'll
25	address that later on.

(202) 234-4433

	197
1	Again, I remind you that there was no
2	adjustment for the improvement in ductility due to
3	temperature. Next. If we do that adjustment, this is
4	what will happen. Those points that were done here
5	are now up here, will move up here.
6	Now the reason we ware complaining so much
7	about the use of MOX is because this is the one MOX
8	point that is really driving down the curve. The only
9	reason why the curve is so low at this point. If we
10	take into consideration that MOX is a different beast
11	and try to estimate how much enthalpy we'd need to
12	insert into a ${ m UO}_2$ rod to produce the same effect we
13	would see that this point would move up here and then
14	if we do our fit, the fit will be over here.
15	VICE CHAIR WALLIS: Up to that one that's
16	over there that didn't move.
17	MR. OZER: This one is really up here.
18	VICE CHAIR WALLIS: Over that, that
19	purpley sort of
20	MR. OZER: These two?
21	VICE CHAIR WALLIS: The bottom of the red.
22	DR. ARMIJO: Right at that.
23	MR. OZER: This?
24	VICE CHAIR WALLIS: That one. Shouldn't
25	that move too?
I	I

	198
1	MR. OZER: This. No. The diamonds. I'm
2	sorry. Oh, this is the only MOX rod that
3	VICE CHAIR WALLIS: No. What about the
4	other one that hasn't moved at all?
5	DR. ARMIJO: That was tested at high
б	temperature.
7	VICE CHAIR WALLIS: It was tested at high
8	temperature. Okay.
9	MR. OZER: These are all high temperature,
10	yes. So far the only corrections we made was for
11	temperature and for MOX.
12	VICE CHAIR WALLIS: Okay.
13	DR. ABDEL-KHALIK: Now if I go back to
14	that graph that you showed earlier with your
15	asymptotic model, the asymptotic value in your model
16	is 125 and if I draw that asymptotic value a lot of
17	the data on the right beyond 0.12 would fall below
18	that line.
19	MR. OZER: Yes.
20	DR. ABDEL-KHALIK: So what does that mean?
21	Your model is not conservative.
22	MR. OZER: Okay. These points would fall
23	below it. These points survived. These points would
24	fall below it.
25	DR. ABDEL-KHALIK: So would the two to the

(202) 234-4433

	199
1	left of those that you just corrected?
2	MR. OZER: These?
3	DR. ABDEL-KHALIK: Yes.
4	DR. ARMIJO: There are about 100, right?
5	One hundred and ten? Something?
6	MR. OZER: Yes, I think that would be
7	fairly close.
8	MR. MONTGOMERY: I should just point out
9	one thing. The Y axis on this plot has changed from
10	what we were showing before which was total enthalpy.
11	This is non-enthalpy change. So there is about 15 to
12	20 calories per gram difference. These are going to
13	be about 20 calories per gram lower than the other
14	ones. So just note that. These are a little lower.
15	So 125 is actually about 100 on this plot or 105.
16	CHAIRMAN SHACK: So they're close.
17	MR. OZER: But the question about these
18	points, I think, is real easy to measure and
19	unfortunately for time sake, I took out that the size
20	that I had, in other words, these. These are rods
21	that were highly spalled and here what we're doing is
22	we're trying to develop a fit that will include a
23	population of rods that are spalled. If we can claim
24	that there is no spallation that, that the probability
25	for spallation is negligible, then we What
I	

(202) 234-4433

	200
1	happened?
2	MR. MONTGOMERY: Sorry.
3	MR. OZER: Then we end up with this curve.
4	Now these Keep in mind that spallation has only
5	been observed in Zirc-4 so far. The advanced
6	plottings, you're going to have high burnup, high
7	corrosion levels, which have not indicated an
8	spallation to the point where you have blisters or any
9	spallation even when pushed beyond their design limits
10	like in the rods that were used for testing which were
11	irradiated for one extra cycle at very high duty in
12	Spain and still they had very high corrosion but no
13	spallation.
14	And keep in mind also that today in our
15	inventory of all the U.S. plants 80 percent of the
16	fuel is advanced cladding, M5 or ZIRLO. The 20
17	percent that you still use That slide is Back
18	up.
19	DR. ARMIJO: Just leave that slide there
20	while you're talking about I want one question later.
21	Go ahead and finish that one.
22	MR. OZER: That's okay. That's 26. This
23	is the distribution in today's population and what we
24	see is that these two, this is M5, this is ZIRLO, 80
25	percent the Zirc-4. The Zircaloy-4 is 20 percent.
ļ	I

(202) 234-4433

(202) 234-4433

	201
1	Also the plants that keep using Zirc-4 are the lower
2	duty plants where the Zirc-4 is not likely to be
3	challenged to the same extent that it is in the higher
4	plants that have to use advanced claddings.
5	DR. ARMIJO: Okay. Now there's one of
6	your red points that didn't move at all and that was
7	right at about 150 and 0.05 or something.
8	MR. OZER: 0.05.
9	DR. ARMIJO: Keep going.
10	MR. OZER: This one.
11	DR. ARMIJO: That one didn't move at all
12	with your temperature correction or
13	MR. MONTGOMERY: That's correct.
14	DR. ARMIJO: Why didn't that move if it
15	was a low temperature test?
16	MR. MONTGOMERY: We haven't completed all
17	these assessments yet. So this is just kind of an
18	illustration. That would move up, I bet, but we don't
19	know exactly how much at this point.
20	DR. ARMIJO: Okay.
21	MR. MONTGOMERY: This slide primarily
22	MR. OZER: This is primarily for
23	illustration purposes.
24	MR. MONTGOMERY: Yes. We haven't done it
25	yet.
I	I

```
(202) 234-4433
```

	202
1	CHAIRMAN SHACK: Odelli, can we hit Slide
2	17 and then your final slide?
3	MR. OZER: Sure.
4	CHAIRMAN SHACK: We'll give you a shot on
5	the BWR and then a conclusion slide.
6	MR. OZER: Okay. For the case of BWRs,
7	yes, there was a discussion. There were lots of
8	questions about these points. We feel that even here
9	there's room for improvement. First of all, there was
10	a lot of concern about how much hydrogen can we expect
11	in operation. I would like to point out that these
12	tests were carried out on high burnup on the rods that
13	were discharged from a BWR at high burnup. So the
14	hydrogen content for these is typical for end of life.
15	We may have some higher but I don't think that will be
16	going much higher than maybe 300.
17	DR. ARMIJO: What was the burnup level for
18	those rods?
19	MR. OZER: Do you remember?
20	MR. MONTGOMERY: Yes, those are 61. The
21	solid black ones are 61.
22	MR. OZER: And also there was a
23	MR. MONTGOMERY: Gigawatt-days.
24	MR. OZER: There was a question why dumb
25	bells are not The reason why we have dumb bells
ļ	I

(202) 234-4433

203 1 here is because there is some uncertainty in how much 2 hydrogen in that rod that was actually tested. So the hydrogen information is coming from the adjacent 3 4 regions both above and below. So we have a range for 5 that. We expect that actually the point will be in 6 between. 7 Now we think that if we adjust the PWR data there is also an equivalent adjustment that 8 9 should be made to the BWR. The adjustment is that this data has been obtained with a four millisecond 10 pulse. In BWRs, the minimum pulse you can have is 30 11 milliseconds. So if you take that into consideration, 12 these points will move up. 13 14 VICE CHAIR WALLIS: Now look. You have 15 five points of failure and one point of no failure. 16 MR. OZER: Yes. 17 VICE CHAIR WALLIS: And you've drawn a red line or someone has drawn a red line and if you just 18 19 look at it statistically, I mean, you haven't gotten 20 very much information out of those six points and two 21 of them are in conflict. So I would find it difficult 22 to know where to draw that red line, such a small 23 dataset there. 24 MR. OZER: It is a very small dataset, but 25 you have to keep in mind that RIA simulation tests are

> NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433

	204
1	extremely expensive. The ones at CABRI are about \$1
2	million a piece. So one point to add a couple of
3	points.
4	VICE CHAIR WALLIS: But expense is not the
5	point. The point is what sort of probabilities are
6	doing. If we drew the line more to be conservative,
7	you would draw it with lower than that, wouldn't you?
8	MR. OZER: Yes, if you want to be
9	conservative, you would draw it there.
10	VICE CHAIR WALLIS: But why not? If
11	you're uncertain, you would be conservative.
12	MR. OZER: But first of all, you would
13	need to adjust the data for the pulse width because
14	again let me remind you. We're not drawing criteria
15	for RIA simulation tests. We're drawing criteria for
16	BWRs and in BWRs, the pulse is going to be much wider
17	and we have to take that into consideration.
18	DR. ARMIJO: Is there an acceptable
19	methodology for correcting for pulse width and does
20	the staff recognize
21	MR. OZER: I don't think there is an
22	accepted methodology, but I don't think it's rocket
23	science either. I mean we can discuss it with the
24	staff and we can either convince them that our methods
25	are good or work with them so that FRAPTRAN can be
ļ	I

(202) 234-4433

	205
1	used to adjust for this.
2	DR. ARMIJO: But you haven't done that
3	yet.
4	MR. OZER: No.
5	DR. ARMIJO: Okay.
6	MR. OZER: No, it's just an observation.
7	CHAIRMAN SHACK: Conclusion please.
8	MR. OZER: Conclusion. Okay. For
9	conclusion, yes, we agree that RIA criteria should
10	change but just the fact that a change is needed
11	doesn't mean that we have a safety issue on our hands.
12	We support the application of the interim criteria to
13	new plants, we feel that the interim criteria
14	conservative with room for improvement. We feel that
15	final criteria should be technically well founded.
16	VICE CHAIR WALLIS: Does that mean that
17	the interim criteria are not?
18	MR. OZER: I think that's the point.
19	Well, the point that I was making is that there is
20	still room for improvement there. They had to produce
21	something quickly for the new plants to be designed,
22	but we feel uncomfortable with those criteria if they
23	were to be applied to current points because they are
24	really conservative. The new plants can design so
25	that they can bypass. They can not enter into a
l	I

(202) 234-4433

	206
1	situation where this would be a problem.
2	But when we are to apply the criteria to
3	operating plants, we need to consider the benefits
4	versus costs. There are some hidden costs to this,
5	not costs, but hidden results that are unexpected. If
6	you try to design a course that you will never have a
7	failure, you end up with flattening your flux to the
8	point that now fluence on the pressure vessel starts
9	to increase. You start using more and more assemblies
10	less efficiently so you have storage problems.
11	So there are all these things that have to
12	be taken into consideration. What is the benefit that
13	we are gaining from requiring overly conservative
14	criteria? Is it a smart thing to do? And again, the
15	sales job will work gladly within NRC to reach a
16	consensus.
17	DR. ARMIJO: I think that's all the time
18	we have. Appreciate it. Thank you very much.
19	MR. OZER: Okay. Thank you.
20	DR. ARMIJO: It's all yours, Mr. Chairman.
21	I failed again.
22	CHAIRMAN SHACK: We'll take up our next
23	topic which is our Risk Management Technical
24	Specification Initiative 4b, Flexible Completion Times
25	and that's brings us back to George who is very good
	I

(202) 234-4433

	207
1	at staying on schedule. Right, George, so we can make
2	up some time?
3	DR. APOSTOLAKIS: I have 45 minutes left.
4	DR. CORRADINI: Yes, that's what I told
5	him. Forty-five minutes.
6	DR. APOSTOLAKIS: So we'll start right
7	away.
8	CHAIRMAN SHACK: Yes.
9	DR. APOSTOLAKIS: Okay. As we know, 10
10	CFR 50.65(A)(4) requires the assessment and management
11	of the risk from maintenance activities and the
12	industry has developed a report, the NEI 06-09 rev. 0.
13	And the staff has reviewed it. We received the safety
14	evaluation report recently and essentially this
15	initiative 4b allows the extension of completion times
16	of selected limiting conditions for operation
17	following certain rules that are based on risk
18	assessment and provided, of course, that there are
19	also some actions that are called risk management
20	actions. So this is the subject of today's meeting
21	and who is starting the meeting?
22	MR. TJADER: Dr. Apostolakis, Dr. Shack,
23	ACRS Committee Members, thank you for inviting us here
24	to present Risk Management Tech Spec Initiative 4b,
25	Risk Informed Completion Times. We will be presenting
	I

(202) 234-4433

the NEI 06-09 as Dr. Apostolakis said, the guidance document and its associated safety evaluation. The 3 guidance document includes the process, the limits, 4 the requirements, the quidance associated with implementing Initiative 4b, Risk Informed Completion Times. 6

7 As suggested by the subcommittee meeting which we were before on March 23<sup>rd</sup>, we will focus on 8 providing an overview of Initiative 4b for the benefit 9 of those who have not yet be introduced to it. 10 We will highlight the benefits. We will discuss issues 11 12 related to cumulative risk and other issues that we discussed and time permitting if we can discuss the 13 14 one that was mentioned at the end of the meeting, operability versus functionality and we'll discuss PRA 15 adequacy. And then, of course, we seek a letter to 16 the Commission supporting this initiative. 17

18 Ouickly, the purpose of the risk 19 management tech spec initiatives in general and this 20 one in particular is to align the tech specs with the 21 Commission's 1995 policy statement on the use of PRA 22 which encourages the use of PRA in decision making. 23 The purpose is to make the tech specs consistent with the maintenance rule and other established guidance 24 25 such as the regulatory guidance 1174, 1177 and the

> **NEAL R. GROSS** COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433

1

2

5

	209
1	NUMARC guidance 9301 which is endorsed by NUMARC 182.
2	The purpose is to enhance safety. Current
3	tech specs are in general legalistic, prescriptive,
4	rather rigid. They focus on single systems. Risk
5	management tech specs would be flexible. They would
6	be process oriented. They take into account the
7	integrated plant considerations, integrated plant
8	risk.
9	VICE CHAIR WALLIS: Do you have an
10	estimate of the enhanced safety on some metric?
11	MR. TJADER: The metrics are included in
12	the guidance document.
13	VICE CHAIR WALLIS: Do you have an
14	estimate of how much safety will be enhanced or is
15	this just an empty statement?
16	MR. TJADER: I don't believe it will be an
17	empty statement, but we don't have anything quantified
18	if that's what you mean.
19	VICE CHAIR WALLIS: Just a hope that it
20	might have happen.
21	MR. TJADER: Yes. It's a hope. It's a
22	MR. RUBIN: This is Mark Rubin from the
23	staff. Let me give a perspective of that though I'll
24	have to add that it indeed is a hope, but in this
25	case, it's a more informed hope than the current tech
I	I

(202) 234-4433

	210
1	specs would allow you to actually achieve. Because as
2	everyone is well aware, the current specs with single
3	AOT times would allow you to reenter them.
4	VICE CHAIR WALLIS: But there's an
5	opportunity to enhance them.
6	MR. RUBIN: Yes sir.
7	VICE CHAIR WALLIS: But you might also
8	decrease safety if you mismanage it.
9	MR. RUBIN: If you mismanage it, the
10	potential would be there, but the control in place
11	would hopefully prevent that. In fact, the
12	opportunity here is a much more rigorous analytical
13	method that would allow you to achieve the safety
14	benefit if properly implemented.
15	MR. TJADER: Yes, we assume that it will
16	be implemented properly and that it will not be abused
17	to the extent that hopefully it cannot be abused.
18	Initiative 4b, Risk Informed Completion Times, it uses
19	configuration risk management assessment of the
20	configuration of the plant to calculate a real time
21	completion time, tech spec completion time, to restore
22	systems to operable status based upon plant
23	configuration and associated quantified risk
24	assessment. It extends the completion time from the
25	existing completion times of the tech specs which we
ļ	

(202) 234-4433

	211
1	call frontstops up to a risk-informed completion time
2	not to exceed 30 days which ever is less.
3	The status, the guidance document is
4	currently complete. The safety evaluation is complete
5	and we expect it to be issued at the end of April.
6	The South Texas pilot plant, its license amendment has
7	been reviewed. It's been in-house for a couple of
8	years. We expect to issue it this summer and the
9	second pilot, Fort Calhoun, shortly thereafter.
10	The benefits, it's risk-informed. It's
11	based upon the risk associated with plant
12	configurations. It's real time. It allows for real
13	time decision making. The benefits include enhancing
14	safety and improving effectiveness. It focuses on the
15	correct course of action to take. It focuses on
16	repair of equipment, returning systems, operability
17	and not necessarily on shutting down and thereby
18	avoiding unnecessary plant transients such as
19	shutting. It can avoid NOEDs in the future.
20	It takes into account integrated plant
21	risk. It focuses on plant risks and as Mark Rubin
22	just alluded to it manages the configuration. It
23	manages multiple SSC component inoperabilities and
24	while the current specs focus on single system
25	inoperabilities, it takes into account once you're in

(202) 234-4433

	212
1	a risk-informed completion time both tech spec systems
2	and non tech spec systems that are addressed by the
3	PRA.
4	DR. ABDEL-KHALIK: But depending on the
5	level of detail of the PRA, the applicant can sort of
6	pick and choose which ones to apply this methodology
7	to while retaining the current prescriptive method in
8	tech specs to other tech spec limits.
9	MR. TJADER: It can only apply it to the
10	ones in which the PRA has been audited, certified to
11	appropriate, acceptable to assume that.
12	DR. ABDEL-KHALIK: Right.
13	MR. TJADER: Yes, they can. It's a
14	voluntary entry into a risk-informed completion time.
15	DR. ABDEL-KHALIK: Right. So the fact
16	that someone can sort of pick and choose which tech
17	spec limit to apply this methodology to rather than
18	applying it in total to all tech spec limits raises in
19	my own mind some concerns because the interaction
20	between various tech spec limits might not be captured
21	by this methodology.
22	MR. HOWE: Let me address that, Bob.
23	MR. TJADER: Sure.
24	MR. HOWE: Even if you only apply it to a
25	certain subset of tech specs, the other systems that
I	I

(202) 234-4433

	213
1	are still part of your PRA model, if they are
2	unavailable, they're still considered as part of the
3	risk calculation for risk-informed completion time
4	whether they could operate under risk-informed
5	completion time or not.
6	For example, the site wanted to apply it
7	to For example, Fort Calhoun, our single system
8	pilot for ECCS, their auxiliary feedwater would not be
9	part of the risk-informed tech specs that they're
10	proposing to apply this to, but if they were in an
11	ECCS outage and they also had problems with auxiliary
12	feedwater, that would have to be factored into the
13	risk-informed completion time with ECCS. So even if
14	you opt out certain systems for whatever reason and
15	they are part of your PRA model, they still factor
16	into the risk-informed completion times for the other
17	systems are subject to risk-informed completion time.
18	MR. TJADER: In a sense, it's conservative
19	not to apply it to everything that it could be applied
20	to. It's only being We're extending
21	DR. ABDEL-KHALIK: But that's what's not
22	clear in my own mind that it is really conservative
23	that you can look at a subset.
24	MR. TJADER: Well, as Andrew said, all of
25	the systems that are in the PRA have to be considered
	I

(202) 234-4433

in the calculation of the risk-informed completion time for the specs that it applies to. But by not allowing it to apply to certain systems that perhaps you don't think that the PRA would be conservative in in applying it to that one, then you are excluding it from that one being extended. In other words, you are limited to being within just that --

8 MR. RUBIN: This is Mark Rubin again. 9 Perhaps I could give you an example or two. As Andy mentioned, regardless of which systems they plan to 10 extend the completion time, all of 11 the system 12 interactions and the impact in a risk model are assessed when you look at extending a risk-informed 13 14 completion time. What perhaps should be looked at in 15 considering the benefits or even the negative attributes of this program, but I think that there are 16 17 definitely benefits, is that the current tech specifications are not risk-based or risk-informed at 18 19 They've come from historical precedent. all.

We've tried to level the playing field over a number of years by looking at the risk contribution of single AOTs, but they're definitely not risk-informed and by moving in that direction, we're certainly moving in what I think is a positive direction. So even if you just start extending some

> NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433

1

2

3

4

5

6

7

	215
1	of the systems in a risk-informed manner, you still
2	will consider all of the systems impacts vis à vis
3	their unavailability in that risk model when you
4	consider the changes to the systems that come under
5	4b.
б	DR. MAYNARD: And as I understand the
7	process, an applicant for this application, they have
8	to demonstrate that their PRA for those that they're
9	applying this to does take the rest of that into
10	account and that gets reviewed as part of the audit
11	and the inspection and everything by the NRC. So they
12	have to demonstrate that they do take the other
13	factors into account, those things that they don't
14	risk inform.
15	MR. HOWE: Two important things is they
16	have, for the systems that they want to apply it to,
17	to demonstrate that their PRA model actively reflects
18	the design of the licensing basis whether it's
19	conservative or whatever justifications. We also look
20	at the scope of everything in their CRMP configuration
21	risk management program looking for just those types
22	of interactions when you're not dealing with a full
23	scope on it, absolutely.
24	DR. ABDEL-KHALIK: Thank you.
25	MR. TJADER: Next slide. The guidance
I	

(202) 234-4433

document as I previously said, it includes the methodology, the decision making process. It includes requirements guidance. It includes requirements for PRA technical adequacy and configuration risk It includes metrics monitoring tool requirements. that are limits for quantified configuration and cumulative risk, documentation and training requirements.

The risk management guidance document, the 9 word "quidance" is perhaps somewhat of a misnomer, but 10 11 it is that the title is Risk Management Tech Spec 12 Guidance NEI 06-09. It will be incorporated into the tech specs, the administrative control section of the 13 14 tech specs. It will referenced by revision number 15 That makes the requirements that are and/or date. quidance in the document and 16 listed in the particularly in section two will make them tech spec 17 requirements. I will require a license amendment to 18 19 change the version of that guidance document that may 20 be applied.

21 Now for an example, a couple of examples, 22 the completion time, the frontstop is the current 23 completion time as I mentioned. The risk-informed 24 completion time is the configuration risk management 25 program quantified as faced configuration completion

> NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433

1

2

3

4

5

6

7

8

(202) 234-4433

216

	217
1	time and the backstop is 30 days.
2	Let's go to the next slide to take a look
3	at tech spec. A current tech spec would be B.1.
4	Condition B, the system is inoperable. B.1, restore
5	the system to operable status within 72 hours. The
6	procedures B.2 are the required actions. B.2 are what
7	would be added by the Initiative 4b. That is if a
8	licensee determines within the existing completion
9	time that they cannot restore a system to operable
10	status and that they wish to apply, they voluntarily
11	apply a risk-informed completion time, they would
12	perform a quantified risk assessment within that
13	existing 73 hours and determine whether an appropriate
14	risk-informed completion time would be up to a max of
15	30 days. That completion time, that risk-informed
16	completion time, then would apply until the status of
17	the plant changed or until they exited the required
18	actions. They had restored the system to operable
19	status.
20	DR. ARMIJO: So they could do this while
21	the plant is running. Something becomes inoperable
22	and then step in and do this analysis.
23	MR. TJADER: Yes.
24	DR. ARMIJO: For how many systems could
25	they do it?
l	I

(202) 234-4433

	218
1	MR. TJADER: For every As I said for
2	every configuration, once you're in a risk-informed
3	completion time, you establish the time that in
4	essence is the time to restore the system, the entire
5	plant, to a completely operable status. That time is
6	associated with a configuration. When that
7	configuration of the plant changes
8	DR. ARMIJO: Another piece of equipment
9	becomes
10	MR. TJADER: Becomes inoperable. You must
11	recalculate that risk-informed completion time and
12	apply the new risk-informed completion time. We have
13	a couple examples right after this which will get in
14	and shows you how that applies. If things are
15	restored, that completion time then could be extended.
16	DR. BONACA: The question I have is this,
17	however, I didn't ask that question on the
18	subcommittee, assume that you have calculated an
19	acceptable RICT of 20 days and less than 30, but
20	really to restore the piece of equipment, all you need
21	is five days.
22	MR. TJADER: I think the motivation for
23	restoring it at an appropriate time would be that they
24	would minimize the accumulated risk that the plant
25	would be exposed to. I don't see any benefit for them

(202) 234-4433

	219
1	being in an inoperable status any longer than they
2	would have to be.
3	DR. MAYNARD: The licensee has a lot of
4	motivation to minimize the time that the safety
5	systems are out of service.
6	DR. BONACA: I know that.
7	DR. MAYNARD: You have performance
8	indicators. There are a number of things that rely on
9	that.
10	CHAIRMAN SHACK: He's also going to be
11	rolling up an accumulated risk.
12	DR. MAYNARD: You bet. Yes.
13	CHAIRMAN SHACK: That he has to track.
14	DR. BONACA: I'm trying to understand,
15	however Okay.
16	DR. MAYNARD: But now they can take it out
17	for the 72 hours and restore it to service, take it
18	back out for another 72 hours.
19	MR. RUBIN: That's correct and you
20	accumulate risk, of course, as you do that as well.
21	DR. MAYNARD: Yes.
22	DR. APOSTOLAKIS: If you have lost one
23	train of, say, high pressure injection and you still
24	have the others, you go through this. If during the
25	time that you have determined, the new completion
I	1

```
(202) 234-4433
```

	220
1	time, the second train fails, so the same system, so
2	you have lost the system completely, you still
3	continue and you have a new risk now.
4	MR. TJADER: If you have lost function.
5	DR. APOSTOLAKIS: "Function" means what?
6	MR. TJADER: If you've lost your specified
7	safety function, your design First of all, there
8	are a couple things you have to consider. You have to
9	If there is an existing condition that addresses
10	both trains inoperable, then you can consider
11	extending that completion time. If there is not
12	condition that addresses both trains inoperable, you
13	cannot.
14	DR. APOSTOLAKIS: "Existing condition"
15	means what?
16	MR. TJADER: In other words, there's a
17	condition. Two trains of the system are inoperable.
18	Restore one train within four hours.
19	DR. APOSTOLAKIS: Right.
20	MR. TJADER: If that condition exists, you
21	can apply a risk-informed completion time to that if
22	you have not lost total function, safety function.
23	DR. APOSTOLAKIS: And "safety function" is
24	considered the function of that system because a
25	function may be

(202) 234-4433

	221
1	MR. TJADER: No. A system can have
2	multiple functions, but the function we're talking
3	about is the specified safety function required by
4	tech specs that is encompassed by operability, the
5	definition of operability.
6	DR. APOSTOLAKIS: Let's say the function
7	is injection of water under high pressure.
8	MR. TJADER: And if the second train is
9	inoperable because it cannot inject the specified
10	required amount of flow into the loop, you cannot
11	apply a risk-informed completion time.
12	DR. APOSTOLAKIS: Okay.
13	MR. TJADER: If it is inoperable because
14	you've suddenly found out First of all, if it's
15	inoperable and there is a condition that addresses
16	both trains inoperable, you can apply it, let's say,
17	if the reason for inoperability is not really because
18	you've lost that specified safety function, that in
19	addition, the PRA can address. You can apply this
20	risk. You can apply it if you've not lost function.
21	If the PRA accurately reflects the degree that
22	functionality is retained, then you can apply it to
23	extent the completion time. If you've lost function
24	or the PRA does not address that capability even if
25	you think you've retained that function, the PRA can't
	I

(202) 234-4433

	222
1	identify down to that level of detail, then you cannot
2	apply that risk-informed completion time and all that
3	is specified in the guidance document.
4	Let's go to the next slide here. These
5	are the metrics, the limits. There are two times that
6	we go to. One is called the risk management action
7	time and that is when in a risk-informed completion
8	time we've accumulated an ICDP or an ILERP of up to
9	$10^{-6}$ or $10^{-7}$ .
10	VICE CHAIR WALLIS: What does an ICDP
11	mean?
12	MR. TJADER: Incremental.
13	DR. APOSTOLAKIS: Incremental CDP.
14	MR. TJADER: Incremental core damage
15	probability and incremental
16	VICE CHAIR WALLIS: Is that based on the
17	yearly average or the instantaneous state or what?
18	MR. RUBIN: Instantaneous integrated over
19	time.
20	VICE CHAIR WALLIS: Instantaneous
21	integrated over the whole year.
22	MR. RUBIN: No, for the period in
23	question.
24	VICE CHAIR WALLIS: Only an anticipated
25	period.
I	1

(202) 234-4433

	223
1	MR. RUBIN: Yes.
2	VICE CHAIR WALLIS: Okay.
3	MR. TJADER: It's the configuration
4	specific risk since the component is inoperable.
5	VICE CHAIR WALLIS: So you could have $1E^3$
6	for one day.
7	MR. TJADER: That's instantaneous.
8	VICE CHAIR WALLIS: That's instantaneous.
9	MR. TJADER: That's a different one. That
10	is another metric specified in the guidance document.
11	And then there is the risk-informed completion time
12	calculated to the $10^{-5}$ ICDP, $10^{-6}$ ILERF not to exceed
13	30 days and not exceed instantaneous CDP of $10^{-3}$ or
14	LERF of $10^{-4}$ .
15	DR. APOSTOLAKIS: But that's something
16	that the industry voluntarily has imposed.
17	MR. TJADER: That's right by adopting the
18	guidance document. That's correct.
19	DR. POWERS: This just strikes me as very
20	stringent numbers.
21	MR. TJADER: We believe it to be
22	conservative.
23	VICE CHAIR WALLIS: Conservative?
24	MR. TJADER: The ICDP calculation.
25	VICE CHAIR WALLIS: Conservative to what?
I	I

(202) 234-4433

	224
1	DR. BONACA: Depending on risk.
2	DR. POWERS: Yes. Had they asked me off
3	the top of my head to set those numbers I would have
4	set them all higher. I mean I just did it while you
5	were talking and your numbers surprised me.
6	MR. HOWE: Fundamentally, they were set to
7	be consistent with the Maintenance Rule limits that
8	were endorsed by Reg. Guide 1.182 and NUMARC 93.01.
9	MR. RUBIN: This is Mark Rubin. I could
10	give a little historical insight that relates to those
11	numbers. Back before the Maintenance Rule was even
12	envisioned, we did some studies of maintenance logs
13	and we looked at instantaneous plant risk just to get
14	an idea of where we were and people were rather
15	startled to see some plants in $10^{-2}$ CDF space for some
16	periods of time. So I think it was felt to be prudent
17	that that's maybe not a good number to target for.
18	But you're right analytically
19	DR. POWERS: 10 $^{-2}$ for three days is 10 $^{-4}$
20	for a year.
21	MR. RUBIN: Yes sir.
22	DR. POWERS: I find this just interesting.
23	I'm delighted to see you capping that. I think that's
24	
25	CHAIRMAN SHACK: You made that statement,

(202) 234-4433

	225
1	but you're not the one that introduced the cap. The
2	industry did. In your own reg. guides, you have no
3	cap.
4	MR. RUBIN: The cap was also identified in
5	an industry PRA guides document. Biff, what's the
6	name of that thing? The EPRI
7	MR. BRADLEY: PRA PSA outlooks.
8	MR. RUBIN: Yes, and the staff
9	specifically did not endorse that number. It's just
10	an operating guidance, guideline, that the industry
11	uses and we don't have a hard knife-edge determinator.
12	VICE CHAIR WALLIS: So these good future
13	plans that claim to have CDF $1E^{-6}$ will have
14	essentially the CDF governed by these risk management
15	actions.
16	MR. RUBIN: Yes.
17	VICE CHAIR WALLIS: Which will overwhelm
18	the
19	DR. POWERS: Yes, exactly so.
20	DR. ABDEL-KHALIK: But if you have an
21	action that would take a few hours, that means during
22	that few hour period if you apply this criterion, the
23	instantaneous value of the risk can be very high.
24	Shouldn't there be a limit then on the instantaneous
25	value of the risk?
	I

(202) 234-4433

	226
1	(Several "There is.")
2	VICE CHAIR WALLIS: That's the $1E^{-3}$ .
3	MR. TJADER: That's the $10^{-3}$ CDF and $10^{-4}$ .
4	DR. ABDEL-KHALIK: Okay. Thank you.
5	DR. APOSTOLAKIS: Now is that
6	instantaneous?
7	VICE CHAIR WALLIS: Yes. That's what he
8	means.
9	MR. HOWE: Configuration-specific core
10	damage frequency.
11	DR. APOSTOLAKIS: If it were
12	MR. HOWE: It stayed the entirety. It's
13	from our pilot plants and from a proposed pilot plant
14	we don't feel that those limits are going to be
15	encroached upon very frequently especially for our
16	South Texas pilot.
17	MR. RUBIN: Also, Mark Rubin again, if I
18	could add the thought that when you put yourself in a
19	very high instantaneous risk configuration even for
20	short periods of time your assuming recovery. You're
21	assuming that you'll get out of that state in a short
22	period of time. What happens if what you're doing if
23	you open a maintenance pack to restore a valve or a
24	solenoid actuator and you find out the O-ring is
25	missing? I can't restore that component for seven
ļ	I

(202) 234-4433

	227
1	days.
2	VICE CHAIR WALLIS: Is there a cumulative
3	limit? I mean, can you do this 20 times or something?
4	MR. TJADER: That's the last We're
5	going to talk about that.
6	VICE CHAIR WALLIS: You're getting to
7	that.
8	MR. TJADER: There is a periodic
9	assessment of the cumulative risk in
10	DR. APOSTOLAKIS: I'm just curious.
11	MR. TJADER: in accordance with that
12	and we will address subsequent.
13	DR. APOSTOLAKIS: Is it possible that you
14	can have the current completion, the frontstop, and
15	let's say that's a week. But you don't do any
16	calculations now, right, because now it's regulations
17	and you know that for this component you have a week.
18	Is it possible that five days into the week your ICDP
19	and ILERF exceed these limits?
20	MR. HOWE: Possible? Yes. Likely? No.
21	DR. APOSTOLAKIS: And why would that be
22	acceptable? What?
23	MR. HOWE: Possibly? Yes. Likely? No.
24	DR. APOSTOLAKIS: How do you know? I
25	don't think we've ever done it. Biff.
I	I

(202) 234-4433

	228
1	MR. BRADLEY: Bradley NEI. I just wanted
2	to mention that's why A4 of the Maintenance Rule was
3	developed and issued was to address your situation and
4	A4 applies to all plants so even within the frontstop.
5	DR. APOSTOLAKIS: No, but if I planned to
6	stay with the existing completion time I don't have to
7	do any calculations.
8	MR. BRADLEY: Yes, you have to do the A4
9	calculation. The same approach that's given here and
10	the same metrics apply for the Maintenance Rule A4.
11	MR. RUBIN: You have to assess and manage
12	risk according to A4, sir.
13	MR. BRADLEY: Yes.
14	DR. APOSTOLAKIS: No matter what?
15	MR. BRADLEY: Yes.
16	MR. RUBIN: No matter what but there is
17	not a hard and fast numerical criteria. This is
18	different. This establishes actual guidelines,
19	numerical guidelines.
20	MR. BRADLEY: Part of this initiative is
21	to establish consistency between the tech specs and
22	A4.
23	DR. APOSTOLAKIS: I don't want to be risk
24	informed at all. I follow the completion times that
25	are in the regulations. You can't force me to do
ļ	I

(202) 234-4433

	229
1	this.
2	MR. RUBIN: The regulation requires it,
3	sir. Maintenance Rule.
4	DR. KRESS: It's the Maintenance Rule.
5	MR. RUBIN: But it doesn't give you a
6	definitive number to say yes or no. It's up to the
7	individual plants and the utility guidance. NEI set
8	up some guidance to help them.
9	DR. APOSTOLAKIS: If they find that it's
10	greater than these limits.
11	MR. RUBIN: As long as they can claim that
12	they're managing it appropriately they skate the rule.
13	DR. MAYNARD: That's the key. You don't
14	have to shut down, but you have to manage the risk.
15	It means you maybe have to put some additional
16	oversight, additional compensatory measures, in place.
17	MR. RUBIN: Yes, let me give you an
18	example.
19	DR. APOSTOLAKIS: What if they don't even
20	have a good PRA because they are not entering their
21	risk-informed They have to do it.
22	MR. RUBIN: Everyone had a baseline
23	inspection for employing the Maintenance Rule. Some
24	had good PRAs. Some did. You're absolutely right.
25	Some used precalculated charts. Some used a living
1	

(202) 234-4433

	230
1	top of entry faulty model to rerun their PRA every
2	day. South Texas, St. Onofree, have very capable
3	online risk monitors and a number of other plants do
4	as well. But the thing to keep in mind is that they
5	do have to assess it and manage it and besides
6	compensatory measure, managing might be work three
7	shifts instead of one shift to get it back into
8	service.
9	DR. ABDEL-KHALIK: If we go back to my
10	original question about allowing someone to pick and
11	choose, by allowing people to pick and choose you're
12	not really forcing them to go back and evaluate the
13	appropriateness of that frontstop.
14	MR. TJADER: A couple things. A plant
15	that will have adopted this Initiative 4B if they are
16	within their frontstops they still have to prior to
17	performance of maintenance have to assess and manage
18	risk in accordance with A4. Furthermore, we expect
19	and it's written in the guidance document that it is
20	expected the licensee is implementing risk management
21	tech spec 4B will use the same PRA models and risk
22	assessment tools for assessing risk and for
23	implementing initial 4B RMTS and for implementing A4.
24	So if a plant is within the frontstops of multiple
25	specs then we don't expect them to put on blinders and
ļ	I

(202) 234-4433

	231
1	not do an appropriate risk assessment using the tools
2	that are available to them, i.e., the configuration
3	risk management tool that is developed to support
4	initiative 4B. We expect them to utilize that and
5	take appropriate action accordingly.
б	VICE CHAIR WALLIS: Can we go back to your
7	
8	MR. HOWE: I can only speak
9	hypothetically, but as a reviewer if a licensee came
10	in and said I would like to apply 4B to these six or
11	seven subsystems, one of my questions is going to be
12	why aren't you interested in these others and if it
13	came out that I can get some benefit for these but the
14	other ones it would kill me because I'm not
15	conservative whether we have the authority to change
16	things that would be another question. But it's not
17	something that's going to be just slipping past me as
18	a reviewer. I wouldn't expect any reviewer just to
19	blindly ignore what the scope of the
20	VICE CHAIR WALLIS: Aren't you enhancing
21	safety? I mean, it seems to me that you have
22	something which previously you had to do in three days
23	and now you can look at it and say I don't really have
24	to do it in three days. I can take two weeks because
25	I can now make it It's not very significantly until
ļ	I

(202) 234-4433

	232
1	two weeks. So you're letting them take longer to take
2	the action which would seem to put it in a risky state
3	for longer. Therefore, you're not enhancing safety.
4	You're decreasing it.
5	MR. HOWE: If that's the way it was
6	applied, you would be correct. That would not be
7	enhancing safety. That's not what we
8	VICE CHAIR WALLIS: You said you were
9	enhancing safety with this rule.
10	DR. POWERS: I think you're looking at it
11	maybe in the wrong way, Graham. Here's the situation
12	that they're trying to avoid and we have encountered
13	this many times is people will start to repair
14	something that's down. They will get into a situation
15	where they said they realized they cannot meet the 72
16	hour. They cobbled the thing back together, get it
17	operational and then take it back down again and that
18	cannot be a safer system than taking the extra ten
19	hours that it would have taken to fix it.
20	MR. TJADER: Or they may come in and
21	request a notice of enforcement discretion where we
22	would have to quickly evaluate that and more often
23	than not, we will grant them an extension of time.
24	VICE CHAIR WALLIS: That's true where they
25	get into the situation where they can't fix it in the

(202) 234-4433

	233
1	time available. But where they just don't want to fix
2	it they just let it drag on and they say it's not risk
3	significant. That is a possibility and that is not
4	enhancing safety.
5	DR. MAYNARD: I really don't think that's
6	
7	MR. TJADER: Let me address that. If you
8	go back to slide 20, one of the things that we are
9	going to be developing is we're going to engage the
10	resident inspectors of each plant to provide oversight
11	for the implementation of Initiative 4B. But some of
12	the things that must be documented that are required
13	by the guidance document that will be incorporated in
14	the tech specs that will be tech spec requirements is
15	that they will have to document, log in, the date and
16	time of entry into a risk-informed completion, the
17	thing at exiting the risk-informed, PRA functionality
18	assessment, i.e., it's inoperable however we're going
19	to utilize its functionality capability in determining
20	a risk-informed completion time, documenting that,
21	configuration of risk specific data, what are you
22	basing your quantified assessment on, what is the
23	configuration of the plant so that we can perhaps
24	reconstruct it if need be.
25	Risk management actions implemented if
I	1

(202) 234-4433

	234
1	they get to $10^{-4}$ ICDP. Emerging condition assessment
2	additional systems become inoperable. What
3	assessments then are taken. And accumulated ICDP and
4	ILERF that is accumulated during that time. These are
5	the things that are documented that we can
6	subsequently go back and review and audit if need be
7	and if hopefully it is being abused, in other words,
8	they are lazy and don't want to restore the system for
9	some unknown reason, then perhaps we can take
10	subsequent action. I don't think they'll apply it
11	like that. I think that
12	DR. BONACA: The question wasn't about
13	being lazy. What about the fact that there are
14	components that either may come out. Okay. So
15	therefore you may reschedule one system. You delay
16	the other one, etc., because you have a window. Maybe
17	you end up with several components that you're
18	managing in the other service. Now
19	MR. TJADER: It permits you to manage
20	DR. BONACA: I understand that.
21	MR. TJADER: And keep in mind that the
22	transitioning down through modes and shutting down
23	there is some risk inherent in that.
24	DR. APOSTOLAKIS: But I think to evaluate
25	Graham's, you've answered that. You really would have
I	1

(202) 234-4433

	235
1	to look at the decision options inherent and calculate
2	the risk of each one which includes in the case of
3	complying with the frontstop shutting down what risk
4	you entail there and take the whole thing.
5	VICE CHAIR WALLIS: If you have to shut
6	down.
7	DR. APOSTOLAKIS: And what they are
8	saying, the staff is saying, is that they haven't done
9	the calculation but they believe that the benefit is
10	
11	VICE CHAIR WALLIS: I'm sure with the
12	other plant which has a good management that pays
13	attention to all these things, things will work out.
14	But you do get some plants that let things slide.
15	MR. BRADLEY: Could I make a statement?
16	DR. APOSTOLAKIS: Yes please.
17	MR. BRADLEY: I just wanted to note that
18	outside of tech specs there are a number of regulatory
19	incentives to minimize unavailability of safety
20	systems. It would be a very bad decision to
21	arbitrarily extend an AOT. You're going to take a hit
22	on the reactor oversight process. If it's a
23	mitigating system, that's MSPI. The Maintenance Rule
24	requires you to track and balance unavailability and
25	unreliability. There are a whole number of other
	I

(202) 234-4433

regulatory regimes that preclude someone from misusing this capability to extend the AOT. It would be a very poor decision to do that.

4 DR. MAYNARD: There is essentially no 5 incentive for a licensee to just arbitrarily extend and take longer than necessary on the safety system. 6 7 There are all kinds of incentives for them to get it restored just as soon as they can and if somebody were 8 9 to do that, they could also just take a system out, put it back and take it back out again. 10 I believe this is ultimately a much better way of handling these 11 12 Otherwise, they're going to have to come situations. back for notice of enforcement discretion or like Dana 13 14 said, they're going to cobble the system back together 15 or you're going to live with the --

DR. BONACA: There is no doubt in my mind 16 17 it's a better thing. But what we're looking for is are there any flaws in the process that is being 18 19 licensed. That's the issue. So I'm not saying that 20 comprehensively, as I said during the subcommittee, 21 I'm extremely supportive of this. I'm only testing to 22 see if the process that's being implemented has any 23 pitfalls and you're convincing me that probably there 24 isn't.

DR. APOSTOLAKIS: So shall we go back to

NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433

25

1

2

3

	237
1	the example?
2	MR. TJADER: Okay. The next would be
3	slide 11, but I think we've discussed the process.
4	DR. APOSTOLAKIS: Yes.
5	MR. TJADER: This is basically for the
6	If we go to slides 12 and 3, gee whiz. Twelve and
7	three go together. Twelve and 13 go together.
8	(Off the record comments.)
9	MR. TJADER: If you take a look at this,
10	a plant is operating from time zero to 20, zero
11	maintenance state. There are no inoperabilities and
12	you're not in a risk-informed completion time. This
13	first example takes the situation in which you are not
14	exceeding your frontstop. Okay. At time 20, there's
15	a planned maintenance activity which you're entering
16	and the planned maintenance activity is expected to be
17	100 hours.
18	DR. APOSTOLAKIS: I think it's important
19	though here, Bob, to point out that before you enter
20	it you see the CDF is zero. Right? It's not the
21	average CDP that the PRA calculates. It's a CDF with
22	what? No maintenance. You explained it last night.
23	MR. TJADER: What this really represents
24	is the delta CDF above the zero maintenance core
25	damage frequency. In other words, there is some
Į	1

(202) 234-4433

	238
1	baseline risk.
2	DR. APOSTOLAKIS: Okay.
3	MR. TJADER: Even if everything has been
4	serviced just from random failure. This is really
5	riding on top of that if that helps.
6	DR. APOSTOLAKIS: So when you say zero,
7	you mean there is no delta.
8	MR. TJADER: Delta.
9	DR. APOSTOLAKIS: Go ahead.
10	MR. TJADER: Okay. The planned
11	maintenance activity is expected to be 100 hours. You
12	take a train or the component out and you enter your
13	tech spec condition and the completion time is to
14	restore it within seven days. At this point, you
15	enter a tech spec time zero.
16	At time 40, you have an emergent failure.
17	You have another system fail that is reflected in the
18	PRA and you calculate then the new risk management
19	action times and the risk-informed completion times at
20	time 40. Your risk management action time which is
21	reflected by the purple bar, you would cross that
22	threshold where you were required to take risk
23	management actions, i.e., compensatory type measures
24	at 47 hours and if you draw the line out, your risk-
25	informed completion time would be 17 days. That is
I	I

(202) 234-4433

	239
1	beyond the frontstop of seven days. So the frontstop
2	of seven days, if you needed it, you could utilize the
3	risk-informed completion time of seven days. But at
4	time 70, you restore the emergent failure and then the
5	CDF decreases instantaneous and the graph changes.
6	VICE CHAIR WALLIS: But it doesn't go down
7	on 120. It stays up to where it was and you don't
8	suddenly remove the ICDP and you
9	MR. TJADER: The ICDP, the cumulative risk
10	is
11	VICE CHAIR WALLIS: It's cumulated. It
12	doesn't suddenly disappear.
13	MR. TJADER: Right.
14	VICE CHAIR WALLIS: It stays up there.
15	MR. TJADER: Right, but the instantaneous
16	goes down.
17	VICE CHAIR WALLIS: It's not as if it
18	disappears after you've done the action. It's still
19	there. You've still incurred it.
20	MR. HOWE: That's a valid point. The way
21	we've set this program up is risk accumulates, but
22	even after you restore components to service, you
23	don't get to drop that
24	VICE CHAIR WALLIS: Again, you don't know.
25	You had to keep that.
Į	I

	240
1	MR. HOWE: Right. If you have an emergent
2	failure that puts you in a particularly high risk
3	condition and you accumulate risk very rapidly up
4	towards the $10^{-5}$ ICDP limit, even if you restored it
5	before getting to $10^{-5}$ but you were almost there, you
6	may not have much time left because of the amount of
7	risk you had accumulated.
8	DR. APOSTOLAKIS: But how many of these
9	you're going to have will be taken care of later by
10	comparing with the 1.174 criteria.
11	MR. HOWE: Which we're going to address in
12	just a minute.
13	DR. BONACA: One thing that's interesting,
14	I mean, clearly you're going to have a daily risk
15	resulting from or weekly or whatever. But for the
16	experience I had when I was supporting operation,
17	every month we would look back and see what kind of
18	curve we had for unavailability because life is not
19	the way you plan it. Things happen in addition to
20	with every other service. Is there any consideration
21	of that in this? There isn't because this is just for
22	a tech specs and I wonder if it's being done at the
23	plants.
24	MR. HOWE: Are you talking about a look-
25	back?
	I

(202) 234-4433

241 1 DR. BONACA: A look-back, yes, because 2 you're projecting forward a certain risk profile that 3 is affected by components out of service for 4 maintenance, some tech spec actions taken from this. 5 But in reality, you have other things happening there and when you look back, you find that in addition to 6 7 the curve that you had, you have now additional components and you have a different kind of profile 8 9 and a notice --10 DR. APOSTOLAKIS: How can you have those? MR. HOWE: If I understand what you said, 11 12 the assumption is that they know what the specific configuration is as they occurred. If you're in a 13 14 risk-informed completion time and you're managing it 15 appropriately and then you exited it, then at some time through some of the program, you realize that 16 wait a minute. Something else was broken that I 17 didn't realize that would have changed my decision, 18 19 that's not really part of this program. That would be 20 part of the corrective action program --21 DR. BONACA: No, in fact, I'm not 22 expecting that this would have that element. I'm 23 talking about in the aggregate. We have been 24 reviewing a number of changes to regulation that 25 allows risk-informed information to take components at

> NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433

	242
1	the surface either for maintenance or because of
2	through tech specs. And I'm wondering if the industry
3	at large out there if it's looking back and seeing
4	really what happened and trying to learn the lessons
5	of events that they have no plan. Things happen that
6	they didn't plan.
7	MR. HOWE: I don't know. I don't have an
8	answer for that.
9	MR. TJADER: We have a slide that covers
10	that.
11	MR. HOWE: South Texas will address that.
12	DR. BONACA: Okay. Great.
13	MR. TJADER: The second example is one in
14	which the frontstop will be exceeded and slides 14 and
15	15 apply to that. At time zero, a tech spec system
16	becomes inoperable and the risk management action time
17	is calculated at seven days as reflected by the slope
18	of the graph and the risk-informed completion time is
19	projected to be greater than 30 days. The point at
20	which the slope would exceed the $10^{-5}$ . So in
21	entering, if utilizing a risk-informed completion
22	time, the backstop in this case would apply.
23	At time five, a second component becomes
24	inoperable. They are required to recalculate the risk
25	management action times and the risk-informed
	I

(202) 234-4433

completion times. It turns out that the risk management action time is relatively soon in the order of probably an hour or two and the risk-informed completion time recalculated would be 27 days, less than the backstop. So if entering a risk-informed completion time, it then would be 27 days and not the backstop of 30.

And this example here at Day 20, the 8 9 second system is restored. You recalculate the 10 completion time. It ends up being greater than 30 Thirty days would apply. You would then exit 11 days. 12 the risk-informed completion time. You would take actions to exit it either at 30 days or getting out of 13 14 the mode of taking the appropriate tech spec actions 15 that would apply if you exceeded the completion time as currently exist. You would get out of the mode of 16 applicability of the spec or you would exit the risk-17 informed completion time by restoring the system or 18 19 systems to operable status.

20 VICE CHAIR WALLIS: Now you're assuming 21 you all can do the second in 15 days. You did do the 22 second. B you would fix in 15 days, right? 23 MR. TJADER: That's the assumption in the 24 example.

> NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

VICE CHAIR WALLIS: But it may be that it

(202) 234-4433

25

1

2

3

4

5

6

7

	244
1	takes you longer. Suppose that you find that it's
2	going to take 25 days to fix it. Then you're out of
3	compliance there.
4	MR. TJADER: If they attempt to not follow
5	required procedures, tech spec required actions of 30
6	days, exiting
7	VICE CHAIR WALLIS: Maybe you can't do it.
8	You can't get the shaft or whatever you need to
9	replace something.
10	MR. TJADER: Then you have to get out of
11	the mode applicability as you would now. You have to
12	shut down.
13	VICE CHAIR WALLIS: You have to shut down.
14	Okay.
15	MR. TJADER: Yes, you have to shut down.
16	DR. APOSTOLAKIS: I'm still troubled by
17	delta CDF. I believe the point of reference
18	because you know this is real time. It's not PRA on
19	the average. You know what is out of service. So I
20	think the zero is when everything is working.
21	MR. HOWE: Yes.
22	DR. APOSTOLAKIS: If I'm doing regular
23	maintenance and I have removed something from service,
24	then I will be a little higher than that. Right?
25	MR. HOWE: The zero in these graphs
I	

(202) 234-4433

245 1 represent the configuration of a plant where every PRA 2 component is --3 DR. APOSTOLAKIS: Working. 4 MR. HOWE: -- working and believed to be 5 \_ \_ DR. APOSTOLAKIS: So it's not a delta from 6 7 the average CDF. 8 MR. HOWE: No. 9 DR. APOSTOLAKIS: Not here and this is 10 real time. Okay. Because that was a little -- So even if I'm doing line maintenance, then I have to 11 enter risk, right, even though it's scheduled and 12 everything and I know that I have to take this train 13 14 out and work on it for a few days. Then I'm entering 15 like what you have there 0.5. 16 MR. HOWE: If you're going to exceed the 17 current frontstop completion time, yes. 18 DR. APOSTOLAKIS: Yes, if you --19 MR. HOWE: You have to do these 20 calculations. DR. APOSTOLAKIS: But that's where you 21 22 enter and you say I'm going to complete it by the 23 given CT that's fine. 24 MR. HOWE: You can finish, if you want to, 25 the existing tech specs and you would never have to do

> NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

```
(202) 234-4433
```

	246
1	any of these calculations. However, if you were going
2	to exceed it, you have to.
3	DR. APOSTOLAKIS: I was told you have to
4	to manage risk.
5	MR. HOWE: For managed I'm sorry. I'm
6	talking tech specs. From a tech spec point of view,
7	you do not have to do any of this. From a Maintenance
8	Rule A4
9	DR. APOSTOLAKIS: You have to do
10	something.
11	MR. HOWE: you'll do exactly the same
12	calculations of CDF and LERF and you'll manage that
13	risk, but you wouldn't have tech spec limits
14	associated with it.
15	DR. APOSTOLAKIS: Okay. Now it makes
16	sense. I don't know why regulations have to be so
17	complicated. There must be a reason. You have
18	exceeded your time, Bob.
19	MR. TJADER: Fortunately, I'm done and the
20	only thing that's left for backup slides that I need
21	not go into unless you wish to discuss them.
22	DR. APOSTOLAKIS: I don't think we need
23	them. So the next presentation
24	MR. TJADER: Andrew was going to discuss
25	the items that were suggested, PRA.
	I

(202) 234-4433

	247
1	DR. APOSTOLAKIS: Adequacy and
2	uncertainty.
3	MR. TJADER: Adequacy and the Reg. Guide
4	1.174.
5	DR. APOSTOLAKIS: of 4B. Class STP
6	examples. Okay. Is that what you're going to do,
7	Andrew?
8	MR. HOWE: No, I was going to wing it.
9	DR. APOSTOLAKIS: Okay.
10	MR. RUBIN: Does the Committee need that
11	presentation? I mean we have so much on PRA quality
12	and scope that has been presented on other venues.
13	DR. APOSTOLAKIS: To tell you the truth,
14	I don't think we need it, but I don't know if any
15	members
16	MR. HOWE: It's very brief, but I'm happy
17	to
18	DR. APOSTOLAKIS: I would rather spend
19	time on your examples and then the presentation from
20	STP because this is really what's relevant to this.
21	MR. HOWE: I don't really That
22	DR. APOSTOLAKIS: Okay. So we know this.
23	Next.
24	(Off the record comments.)
25	DR. APOSTOLAKIS: You have examples?
I	I

(202) 234-4433

	248
1	MR. HOWE: No, I do not have examples.
2	DR. APOSTOLAKIS: It was just quality.
3	MR. HOWE: There was a slide from this
4	presentation that got left in here.
5	DR. APOSTOLAKIS: No, but I am curious
6	though how uncertainties are handled in these cases.
7	Do you have a slide on that?
8	MR. HOWE: We can talk generalities about
9	what the guidance document requires. I was going to
10	present that.
11	DR. APOSTOLAKIS: Well, the guidance, the
12	SER at least, says that they are expected to do some
13	sensitivity analysis. I mean, who is going to do that
14	in real time?
15	MR. HOWE: They're not going to in real
16	time. Let me I might as well go through this real
17	quick since it sounds like you have a couple of
18	questions.
19	DR. APOSTOLAKIS: If you can enlighten.
20	Okay. That we know.
21	MR. HOWE: Right. That's the PRA.
22	DR. APOSTOLAKIS: Uncertainty analysis.
23	MR. HOWE: I'll talk a little bit on
24	uncertainty analysis.
25	DR. APOSTOLAKIS: Yes.
Į	

	249
1	MR. HOWE: This is from our visit at South
2	Texas. This was their plans as we discussed with
3	them. Fundamentally, they're going to identify key
4	uncertainties using industry guidance documents that
5	EPRI has developed. They will take those key
б	uncertainties for their PRA and look at the impact on
7	the configurations in their plant where they have less
8	than a 30-day completion. If they had configurations
9	that were way beyond 30 days, it was assumed that any
10	uncertainties in the PRA probably wouldn't
11	significantly affect that decision and that seemed
12	reasonable to us.
13	For those where the key uncertainties
14	could affect configurations that were already less
15	than 30 days, they planned to do sensitivity studies
16	to see within the bounds of what we know about that
17	uncertainty how could it affect the decision. Will 30
18	days become 28 days or 15 days? What was the
19	importance of it?
20	And then in accordance with NEI 609, they
21	propose any appropriate program restrictions or comp
22	measures for those configurations that would be
23	affected by the uncertainties. That's what South
24	Texas presented to us when we did our site visit. The
25	NRC team made some recommendations from additional
	1

(202) 234-4433

	250
1	areas to be considered. But the overall approach we
2	felt was very reasonable for addressing uncertainty
3	and is consistent with the NEI 609.
4	DR. APOSTOLAKIS: Now this is based on
5	their assumption that all this will be precalculated,
6	right? That there will be a library of states of
7	MR. HOWE: It is for South Texas but not
8	necessarily a requirement for another licensee. But
9	it identified that this would be done as part of the
10	license application process to use 4B for certain
11	specs.
12	DR. APOSTOLAKIS: My point is that I can
13	see how someone who develops this library like South
14	Texas did can do this because they do it in their
15	offices, no pressure and so on. If you haven't done
16	that and if you're supposed now to do the analysis in
17	real time, I'm not sure how they're going to take care
18	of the uncertainties. I think it most likely will be
19	something that will be the judgment of people as they
20	go along. Why don't you ask people to do these things
21	in advance and have them like South Texas? Have a pre
22	You can't do that.
23	MR. HOWE: It could be done. I guess we
24	could.
25	DR. APOSTOLAKIS: Wouldn't that make much
l	1

(202) 234-4433

	251
1	more sense to have an analysis, a rigorous analysis,
2	done in an air-conditioned office without pressure,
3	you understand what's going on, rather than wait until
4	I have a picture like the one Bob showed where now I
5	have to calculate in real time what's going on? I
6	think that would probably not be a very good idea.
7	But the second question that I would have
8	is we keep talking about uncertainties in the context
9	of PRA, but this is now real time decision making.
10	I'm trying to figure out what uncertainties are we
11	talking about here. Are we talking about the
12	uncertainty in the estimate of completion? But then
13	again, that doesn't really matter because I look at
14	the clock. What else? Does it matter that I have
15	uncertainties in the failure rates? Why would that
16	matter?
17	MR. HOWE: The biggest thing that we're
18	looking at and I'll ask Dr. Perry to chime in if I
19	misspeak is really the modeling that you choose to
20	build your PRA would be something that you make in
21	your PRA. The exemption is the success criteria, not
22	
23	DR. APOSTOLAKIS: Andrew, I just don't see
24	how anyone can take those into account in real time.
25	I can see them doing it in advance but not in real
	I

(202) 234-4433

(202) 234-4433

	252
1	time.
2	MR. HOWE: No, we don't ask them to do
3	that. What we're asking for is for them to identify
4	what the key uncertainties are and provide an
5	assessment of how those uncertainties can affect the
6	completion times for those systems that are subject to
7	RITS, do the appropriate sensitivity studies to see
8	what the effect is and if necessary put programmatic
9	restrictions on it.
10	DR. APOSTOLAKIS: And I think that should
11	be done in advance.
12	MR. TJADER: It is being done.
13	MR. HARRISON: This is Donnie Harrison
14	from the PRA branch. The key thing that Andy
15	mentioned and may have been glossed over a few minutes
16	ago was all of this uncertainty analysis is occurring
17	at the application phase when the applicant, the
18	licensee comes in, and submits the application to do
19	this. They must address all the tech specs that
20	they're going to implement at that point, do these
21	sensitivity studies at that time, not before they
22	actually implement it.
23	DR. APOSTOLAKIS: You mean they're going
24	to tell you actually for this component and this
25	system, this is the analysis we would
ļ	

(202) 234-4433

	253
1	MR. HARRISON: Here's the model
2	uncertainty or here is the issues that affect the key
3	uncertainties that affect this PRA that would affect
4	those tech specs and then all run sensitivity cases on
5	those at the application if I'm understanding what you
6	
7	DR. APOSTOLAKIS: But this is how South
8	Texas has done that.
9	MR. HARRISON: And again, South Texas has
10	the advantage of they already have their pretty solved
11	models, pretty solved results as well.
12	MR. HOWE: But I don't think the process
13	is any different at this point for pretty solved
14	versus simply solve the cases that you need to explore
15	the impact of these uncertainties on the results you
16	would get.
17	DR. APOSTOLAKIS: So you are pre-solving
18	them. What is the difference? I'm missing the
19	difference. You're saying they did it and they also
20	pre-solved cases. The other guy is going to do what?
21	MR. HOWE: Everybody will identify what
22	they consider to be the key modeling uncertainties
23	that could affect this program. Every plant will
24	identify a linkage between those uncertainties and the
25	LCOs and the systems that it will apply to it. So
	I

(202) 234-4433

254 1 that's no different whether I pre-solve it or not for 2 my CRMP. 3 At that point, we need sensitivity studies 4 that say given this uncertainty how do I 5 quantitatively bound it and how would it affect those 6 systems that I link to that. If you're pre-solved, 7 you're going to simply look at the pre-solved cases. 8 If you're not, you're simply going to run the new 9 cases that you need to explore those sensitivities at that point and then you'll see what the impacts are 10 and implement appropriate program restrictions. 11 The 12 only difference is once a plant has done this, we've reviewed it, we accepted whatever conclusions they've 13 14 drawn, when they actually go to implement their 15 configuration risk management program for this tech spec, we would have a pre-solved case with a number on 16 it or they would simply exercise their PRA model in 17 real time and generate that number. 18 19 DR. APOSTOLAKIS: It seems to me it would 20 be cleaner to have the pre-solved cases. 21 I don't disagree with that. MR. HOWE: 22 It's easier because you review it ahead of time. 23 DR. APOSTOLAKIS: Yes. 24 DR. MAYNARD: But I'm not sure that you 25 can pre-solve every potential case ahead of time. Ι

> NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433

	255
1	think you do the most likely and large number of them.
2	But you also have to have the capability of if you end
3	up in a condition that you had not anticipated
4	MR. HOWE: You have to generate the case
5	
6	DR. APOSTOLAKIS: I don't have a problem
7	with that. Biff.
8	(Off the record comments.)
9	MR. BRADLEY: That was the point I was
10	going to make because the CRMP tool just looking at
11	the scope of tech specs it's for the entire plant and
12	all the components in the plant in the PRA and it's
13	really impossible to pre-quantify all the
14	uncertainties for all those combinations. So we're
15	looking at the key ones in advance as Andy said and I
16	think that's the difference. You can't on the fly do
17	an uncertainty calculation for every configuration
18	that could come up. There are too many permutations
19	to do that. So we just look at the key components.
20	MR. TJADER: In the safety evaluation at
21	the end, we've listed 13 things that at a minimum we
22	expect to see in the license amendment request that a
23	license proposes and No. 10 addresses this to some
24	degree. It says, "The request will provide a
25	discussion of how the key assumptions and the sources
Į	I

(202) 234-4433

256 1 of uncertainty were identified and how their impact on 2 the risk management tech spec Initiative 4B was 3 assessed and dispositioned." So it has to be 4 addressed in the license. 5 DR. ABDEL-KHALIK: Let me ask a slightly different question. Let's say somebody is going to 6 7 embark on doing this and is going to do pre-canned 8 scenarios and a lot of these pre-canned scenarios 9 involve just one malfunctioning component, the first 10 one, and then the others would follow and they can analyze those scenarios as well. Can they come to you 11 and use these pre-canned scenarios to modify the 12 frontstop in their tech spec? 13 14 MR. HOWE: The frontstop? Right. 15 DR. ABDEL-KHALIK: Can they? They come in with a 16 MR. HOWE: 17 separate license amendment to say we think this frontstop needs to be changed and here's our risk 18 19 basis. 20 That's similar to current MR. RUBIN: You could just have a risk-informed tech 21 processes. 22 spec change. 23 DR. APOSTOLAKIS: They've done it already 24 DR. MAYNARD: Yes, there's a current 25 process in place for doing that and the guidance is

> NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433

	257
1	4B.
2	MR. HOWE: Guidance 1.177. But the risk
3	managed tech spec program that we're presenting today
4	has no impact on frontstops.
5	DR. MAYNARD: Okay.
6	MR. HOWE: The operation before the
7	frontstop is unchanged. It's only if they want to go
8	beyond.
9	DR. MAYNARD: Beyond that. Okay.
10	DR. APOSTOLAKIS: If they want to change
11	the frontstop, then they would have to go to
12	regulatory guide 1.174. Right?
13	MR. HOWE: 1.177.
14	DR. APOSTOLAKIS: Okay. The next
15	presentation then. Is that what it is?
16	MR. HOWE: That was what I had to say on
17	uncertainty. Where the There must be another one.
18	Did you want the reg. Guide 1.174 limitations?
19	DR. APOSTOLAKIS: Yes, I think that's
20	important.
21	CHAIRMAN SHACK: George, we're
22	MR. HOWE: It's there somewhere.
23	CHAIRMAN SHACK: We're 3:45 p.m. here.
24	VICE CHAIR WALLIS: We have an industry
25	presentation too.
ļ	I

	258
1	CHAIRMAN SHACK: Yes.
2	DR. APOSTOLAKIS: We'll move onto that
3	one. What they do is there is an interesting Let
4	me talk about it and If you do this too much over
5	the year and you calculate your average CDF, then you
6	may end up with a delta CDF above your baseline which
7	violated 1.174.
8	MR. HOWE: If it's significantly
9	DR. APOSTOLAKIS: What?
10	MR. HOWE: If it's above the
11	DR. APOSTOLAKIS: If it's above, yes. So
12	they have this extra criteria that says look back over
13	the year. How many times did you do this? How many
14	triangles did you have? Do your arithmetic and find
15	out. It's a very interesting application of 1.174
16	because here 1.174 is used after the fact. Right?
17	MR. HOWE: At least the first one we tried
18	to do.
19	DR. APOSTOLAKIS: Yes, it's after the
20	fact. Usually you have it in advance. You say if I
21	want to make this change
22	VICE CHAIR WALLIS: But don't you have to
23	keep track of this cumulative thing throughout the
24	year?
25	DR. APOSTOLAKIS: Yes.

(202) 234-4433

	259
1	VICE CHAIR WALLIS: Not just for backup at
2	the end?
3	DR. APOSTOLAKIS: Yes, and at the end of
4	the year, you go and say my average delta CDF now was
5	acceptable according to 1.174. I just want to
6	sensitize the Committee. This is a different use of
7	that.
8	VICE CHAIR WALLIS: Suppose it was not
9	acceptable.
10	DR. APOSTOLAKIS: It's after the fact, but
11	it's not permanent.
12	VICE CHAIR WALLIS: Is it really after the
13	fact, George? Don't you have to anticipate what
14	you're going to get?
15	DR. APOSTOLAKIS: No, they don't
16	anticipate. During the year, they
17	VICE CHAIR WALLIS: You may have used up
18	your delta CDF already at half a year.
19	DR. APOSTOLAKIS: During the year, they
20	use the incremental ones.
21	VICE CHAIR WALLIS: But halfway through
22	the year, you may have violated 1.174.
23	DR. APOSTOLAKIS: At the end of the year,
24	they look at the average and you make a violation.
25	VICE CHAIR WALLIS: But you may have
	I

(202) 234-4433

	260
1	violated it halfway through the year.
2	DR. APOSTOLAKIS: Oh, I see what you mean.
3	I don't think they do, but I'm sure if there is a case
4	like that, somebody will stand up and say "Hey guys.
5	What's going on here?"
6	VICE CHAIR WALLIS: I think you have to
7	look at it all the way through as you go along.
8	DR. APOSTOLAKIS: I mean if six months
9	into the year you have done it so many times that you
10	have violated
11	DR. MAYNARD: You would have had a lot of
12	attention for that.
13	DR. APOSTOLAKIS: somebody is going to
14	pay attention to that.
15	DR. ABDEL-KHALIK: Could you get around
16	that problem by doing a running average?
17	VICE CHAIR WALLIS: Yes, do a running.
18	DR. APOSTOLAKIS: Do a running average?
19	MR. HOWE: I'm going to show what our
20	expectation is and we'll get the Committee's input.
21	DR. APOSTOLAKIS: Good.
22	VICE CHAIR WALLIS: Yes, I think you
23	should do a running average.
24	DR. APOSTOLAKIS: I think the expectation
25	is that this is not going to lead you to that. Right?
	I

(202) 234-4433

	261
1	MR. HOWE: Fundamentally, when this was
2	presented to the staff for review, it was said that it
3	would comply with Reg. Guide 1.174. It should result
4	in no more than a small increase in risk. The
5	question came up "Well, how given that any one entry
6	into this is limited to 10 $^{-5}$ ICDP and a small risk
7	increase in Reg. Guide 1.1174 is $10^{-5}$ per year?" It
8	would seem like that's out of balance.
9	DR. APOSTOLAKIS: You have to have too
10	many of these. As Otto said, somebody will pay
11	attention.
12	MR. HOWE: So what we asked the licensees
13	to do or excuse me, NEI, is to put in a program app.
14	requirement for a periodic assessment of this program,
15	its implementation, not just an individual LCO
16	extension which is very clearly addressed and has
17	limits and tech spec enforcement, but look at once
18	you've put this in place, how has it affected the way
19	you actually operate your plant and your risk profile.
20	So hopefully this isn't too simplistic because I've
21	tried numerous ways to present this and this seemed to
22	be the best way. I apologize for the readability, but
23	basically if this is time
24	DR. APOSTOLAKIS: No. You can't do that.
25	MR. HOWE: I can't stand up. Okay.
I	I

(202) 234-4433

	262
1	DR. APOSTOLAKIS: Unless we wire you. Can
2	you wire him?
3	MR. HOWE: Wait a minute. Don't do that.
4	I have a pointer right here. This is core damage
5	frequency on the Y axis with time going on the X axis.
б	So a plant is operating with nothing out of service.
7	It still accumulates a baseline of risk, the zero
8	maintenance risk we talked about.
9	DR. APOSTOLAKIS: Right.
10	MR. HOWE: And over about a one year
11	period, the area in the curve represented in red would
12	be the core damage frequency that year. So even if
13	they did no maintenance, they would accumulate this
14	amount of this core damage risk that year and if they
15	did that year after year the same, that would be their
16	average core damage frequency zero maintenance.
17	Of course, we know in reality plants do
18	maintenance and they have some average CDF which again
19	
20	VICE CHAIR WALLIS: When we see a CDF
21	quoted for a plant, it includes this increase.
22	MR. HOWE: It includes the contribution
23	for maintenance and it's smeared out over the years,
24	the average CDF. We know in reality
25	VICE CHAIR WALLIS: It zigzags around.
I	1

(202) 234-4433

	263
1	MR. HOWE: typically they're at zero.
2	They take things out. It goes up. They bounce
3	around. But theoretically, the area of each of these
4	green rectangles which is accumulating an amount of
5	risk would average out to the average annual CDF.
6	VICE CHAIR WALLIS: But if it's more than
7	that
8	MR. HOWE: It could be more than that. If
9	they do a little bit more maintenance that year, then
10	their CDF would trend up. If they start doing less
11	maintenance or better maintenance, it will swing down.
12	So what are we asking for or what is going to happen
13	to a plant in RMTS phase when they implement extension
14	of the LCO? So now these LCOs may be extended as
15	permitted by tech specs.
16	VICE CHAIR WALLIS: So you're increasing
17	the risk.
18	MR. HOWE: Possibly.
19	VICE CHAIR WALLIS: You're increasing
20	MR. HOWE: That's what we want to see to
21	make sure we have programmatic controls in place to
22	cover this. So what happens is a plant may extend the
23	risk of one or more of these LCOs and as a result, the
24	amount of green that you have here which is affecting
25	your change above the zero maintenance may increase
I	I

(202) 234-4433

264 1 with time. So basically what we're asking them to do 2 to look at their programmatic use of is RMTS, 3 basically to look for these, times when they extend 4 the LCOs and how much risk did they accumulate which 5 they would otherwise not be permitted to accumulate 6 and to assess what that change is every two years on 7 an average per year basis. 8 VICE CHAIR WALLIS: So you're not 9 enhancing safety, are you? 10 MR. HOWE: If the only thing that happened when a plant implementing RMTS was to do this, plant 11 12 risk would go up on average. VICE CHAIR WALLIS: 13 Right. 14 MR. HOWE: What we've been told is and we 15 believe is that that's not going to be the only 16 impact. What might happen is you may extend this LCO 17 and do extra maintenance. VICE CHAIR WALLIS: That helps you to 18 19 avoid having --20 MR. HOWE: And then maybe you don't have to do this outage over here. 21 22 VICE CHAIR WALLIS: Good. Yes. There has 23 to be a payoff. 24 MR. HOWE: Or maybe you have two or three 25 planned maintenance outages on the diesel generator

> NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

```
(202) 234-4433
```

	265
1	here and now you're combining the one and you don't
2	have the time taking out and restoring three times.
3	You do it once.
4	VICE CHAIR WALLIS: Is there a reward for
5	that?
6	DR. APOSTOLAKIS: increasing risk with
7	that.
8	VICE CHAIR WALLIS: There should be a
9	reward for that.
10	MR. HOWE: Maybe we'll get into the
11	regulations here. But fundamentally, the licensees
12	need to assess these increases in risk if they exist
13	and compare them to the Reg. Guide 1.174 limits and
14	assure that they're below the $10^{-5}$ . If they find that
15	they are not, they are increasing risk, they need to
16	address that through the corrective action programs.
17	DR. APOSTOLAKIS: Do we ever given any
18	rewards to the licensees?
19	MR. HOWE: Mark, you know the history.
20	Have we ever given rewards to licensees?
21	MR. RUBIN: Have we ever given rewards?
22	MR. HOWE: For good performance.
23	MR. RUBIN: Oh, yeah. We don't cite them
24	for violations.
25	(Off the record comments.)
Į	

	266
1	DR. APOSTOLAKIS: Okay. Maybe STP is
2	next. That was very good.
3	(Off the record comments.)
4	DR. MAYNARD: While they're coming up
5	here, on the last topic we discussed, you do have to
6	be careful in what's done with these results because
7	the fact that you've used it it may have been an
8	increase in risk. It may have actually been a
9	reduction in risk. So I think you have to do some
10	qualitative looking at the stuff because you're not
11	seeing a total change in risk associated with that.
12	I think it's a good exercise, something to do, but you
13	need to be a little careful in how the results are
14	handled there.
15	DR. APOSTOLAKIS: Okay. So we have our
16	usual visitors from South Texas, fairly new to the PRA
17	business. Please.
18	MR. HEAD: Okay. We'll start. My name is
19	Scott Head. I'm the Manager of Licensing at the South
20	Texas project and with me is Rick Grantom, the Manager
21	of the Risk Analysis Group of South Texas Project.
22	For the subcommittee, you gentlemen are normally used
23	to seeing Jay Phelps, one of our operations managers,
24	who is here. He's on night shift right now helping
25	run our outage. I would note also that Rick Grantom
ļ	I

(202) 234-4433

267 1 is on night shift right now and is here basically off 2 the night shift. I'm mentioning that because some of the 3 4 answers I'm going to give if we're asked those 5 questions are -- Jay Phelps as an operations manager would give you a very emphatic answer. 6 I'm going to 7 try to replicate those because there is an operation's 8 perspective to the answers of some of the questions 9 that have been asked. 10 This is pretty much an implementation overview of what we're about to do at South Texas if 11 12 the license amendment is approved and we're get through very quickly and answer any questions that you 13 14 all have. So the overview, we are the pilot for the 15 risk-informed tech specs using the configuration 16 mismanagement process. It's a (a)(4) approach and we 17 will apply like was mentioned before. We state that we will implement the quidance of 0609 NEI and that's 18 19 embedded in technical specifications. 20 As a part of this process, we were also 21 one of the pilots for the Reg. Guide 1.200 assessment 22 process. Very important for an operation's 23 perspective as Jay would say is we keep the current 24 tech specs the way they are. We don't make exotic 25 changes to the technical specifications. This is an

> NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433

	268
1	option that we can use periodically if we need to, but
2	the frontstops and the way the tech specs look for the
3	operators right now are the same.
4	We've added some additional actions to
5	take, but the tech spec fundamentally looks the same
б	and we mention in the next bullet here that it allows
7	us the option to use this if we need to and it imposes
8	a backstop time limit to return applicable equipment
9	to services. I'm going to stop right here and give you
10	the licensee's perspective on the 30 days because we
11	got real close to it in the previous discussion.
12	VICE CHAIR WALLIS: Can I ask you
13	something?
14	MR. HEAD: Sure.
15	VICE CHAIR WALLIS: If you really followed
16	this through and you allowed the operators to use risk
17	management options for everything, maybe you don't
18	need the tech specs in quite the form they are now.
19	Maybe you can relax the tech specs themselves if
20	you're from day to day looking at your risk
21	management.
22	MR. HEAD: That's a possibility.
23	DR. APOSTOLAKIS: You need to eliminate a
24	frontstop?
25	VICE CHAIR WALLIS: Maybe you can cut back
	1

(202) 234-4433

	269
1	on the tech specs.
2	MR. HEAD: Take it out of the tech specs.
3	That's a possibility and we think those thoughts.
4	This was the initiative we elected to go after first.
5	VICE CHAIR WALLIS: Get some things out of
6	the tech specs, right?
7	MR. GRANTOM: I think them more than Scott
8	does. But yes.
9	VICE CHAIR WALLIS: You're thinking of
10	doing or
11	MR. HEAD: We are but that would be
12	something that's further down the line.
13	VICE CHAIR WALLIS: But it's a
14	possibility.
15	MR. HEAD: It's a possibility
16	Containment spray is one that often gets some interest
17	in that area, but that's not what we'll be doing with
18	this one.
19	With respect to the backstop, my
20	perspective on the backstop is, and operations would
21	say also, that having something out of service for 30
22	days would just be unacceptable. There are some
23	regulatory requirements between MSPI and the oversight
24	process and even if you could say this new safety
25	culture initiative. If utility embarked upon that

(202) 234-4433

270 1 sort of process, I think they would run into a number 2 regulatory impacts that would make it an of unacceptable place to be. 3 4 From a licensing manager's perspective 5 what 30 days allows me which we have in fact done at South Texas, if you're near maintenance and you're 6 7 working on a pump and you find out that the shaft is 8 destroyed and the shaft is 60 days away from being 9 built for your site, that 30 days allows me to go get 10 an emergency tech spec change from the NRC to allow us to operate that 60 days. So it's a regulatory window 11 that we can re-engage the NRC if we need some other 12 sort of relief via the tech spec route as opposed to 13 14 even the notice of enforcement discretion route. 15 Like I say, we've done that before at South Texas with one of our diesels where we had a 16 17 significant moment with it. So the 30 days I would say from my perspective is more of something we would 18 19 exercise if there was some significant damage to a 20 component. 21 The next slide, this is the scope of the 22 stuff that we currently have in our tech specs with

the tech spec amendment that we have in the NRC for review. You can see it's very encompassing. It's a number of different components, a number of different

> NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433

1 systems, and I'd say we have visions, something along 2 what you were talking about before, to include other 3 stuff in here in the future once they're in the mode, 4 once they're firmly entrenched in the model. Then we might go back and submit another tech spec change to 5 include more components in there. But right now, this 6 7 is the scope of what's in the model and within the 8 amendment we have with the NRC. 9 To the question that was asked earlier, the next slide, one of the reasons we're doing this is 10 that we have been doing it for many, many years. 11 This is how we've tracked risk at South Texas project for 12

many, many years and it's our (a)(4) assessment that we do in the work week and the slide, the graphs, look a whole like what we're doing in tech spec space.

But to the question of do people go back 16 and look and see how they did, here, this was one of 17 our work weeks. The straight line is what we had 18 19 planned to work which includes some aux feedwater work 20 and a power operator relief valve work. The dotted 21 line ends up is what actually happened that week. The 22 week after this week takes place. The word group gets 23 together and says what happened. Why did this happen? 24 What do we need to do? How would we do that week 25 differently next time? Quite often at South Texas,

> NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433

13

14

15

the line in fact is below what we had originally planned and that's obviously good. But if we have situations like this, we go back and look at it and assess that week in terms of work processes or other things, planning or otherwise. With respect to the year, I'll let Rick talk about what we do with respect to monitoring the risk over the year.

8 MR. GRANTOM: This is kept. We keep a 9 record of all these and you can see on the actual times over here these are based on down to a minute of 10 when operations returns something to service at that 11 12 So what we do is we collect these over point in time. 52 weeks and we contiguously place these together and 13 14 we have what's called a rolling 52 week average. So six months into the year it looks back at the previous 15 16 52 weeks and determines what the weekly average was 17 and you see this and I could have actually shown this plot right here, the rolling 52 week average, and you 18 19 can see where the average core damage frequency as 20 Andy had shown on the previous graph and you can see 21 where the actual configuration risk is occurring for 22 both units.

23 DR. BONACA: On a weekly basis you can see 24 what components caused the curve to --

> **NEAL R. GROSS** COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

There is an incredible MR. GRANTOM:

(202) 234-4433

25

1

2

3

4

5

6

7

amount of ticking and tacking and accounting that can
be done. You can see what maintenance state you were
in the most. What were the maintenance states that
contributed to most of the risk? What was the down
time? All of this stuff feeds to the Maintenance Rule
at STP also.
DR. BONACA: This is valuable information
for the operators if you could show them what happened
there. So I'm sure that you communicate somehow the
important components of that and availability to them,
right?
MR. GRANTOM: I can give you an important
point in history right now. When we had first started
doing I would say we have done this right at a
decade right now we've been performing this. When we
first started doing planned and actual risk everybody
had the good plan. But when we started showing the
actual risk and what was really occurring, we used to
come to the threshold which is 1E-6. We would come to
border that quite often. It got people a lot nervous.
They started looking at it and we started looking at
it and our scheduling is done along the lines of what
we call functional equipment groups.
So we started looking at the functional
equipment groups with this and it turns out that they

(202) 234-4433

б

(202) 234-4433

1 were taking things out in series. They would take 2 essential cooling water out which makes the diesel 3 generator inoperable. Later in the week, they took 4 the diesel generator out which makes the diesel 5 generator inoperable. So they were taking these double hits on risk. But once they could see it, then 6 7 they worked the functional equipment groups where they started essential cooling water diesels on the same 8 9 day and work those. The risk just came down. Now 10 that was not the risk group doing that. That was work window coordinators being able to do exactly what you 11 said, seeing the impact and realizing there was a way 12 that they could risk manage this. 13 14 DR. BONACA: The reason I was asking was because it's true that he makes the decision. 15 But you make it visible to him. For example, you show me this 16 17 curve here, it's an -- curve. There is a limitation to the amount of information it gives me. If you have 18 19 it on a daily basis of what components you have out, 20 I'm sure you have that kind of information and provide 21 that. 22 And this is a plant tool now. MR. HEAD: 23 This is not just the risk group. The plant generates 24 this. The plant looks at it. Operations reviews it 25 real time before we've embarked upon that work week

> NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433

(202) 234-4433

and after. So Operations is involved with all of this.

3 MR. GRANTOM: It's important to note that 4 the risk management group, the PRA group, of South 5 Texas is not making these plots. Operations and Work Control are making these plots and you're correct. 6 7 This opens up a whole new field of evaluation to be able to look at what the impact of removing equipment 8 9 from service, what the impact of making decisions on configurations. It's an incredible -- The opportunity 10 for management to build risk management actions for 11 12 certain specific conditions, we've opened this up before which in previous tech specs you had no clue 13 14 what configuration you were in to even apply these 15 kinds of risk management treatments. So it's a really 16 dynamic process that seems to work good.

17 MR. HEAD: That was an attempt to answer 18 question and it's also to qive you your the 19 perspective that we've been doing what we're talking in many ways for a long period of time. 20 about 21 Although at the same time this was happening, 22 obviously tech specs was there also and so --23 See this right here is MR. GRANTOM:

24 something that they do as part of the actual risk too 25 that Scott alluded to a minute ago. The ability now

> NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433

1

2

to go take a look at this and see where we were 1 2 relative to the plan and if it gets too far off 3 they'll write condition reports to try to determine 4 what happened in there.

MR. HEAD: Okay. And the other slide, the other graph over here, is what we do with the trip 6 risk and it's just our way of assessing the secondary 8 side of the plant to see if we take a feedwater pump 9 or something what sort of trip risk we've out accumulated.

The next slide is with respect to the 11 12 culture at STP and we have robust PRA obviously that meets the technical adequacy requirements as one of 13 14 the reasons that we believe in the pilot. We have 15 processes and procedures and I've showed you an example of that that effectively communicate the risk 16 thresholds and identify the main actions to take when 17 thresholds are reached. We have trained operators. 18 19 We've talked about we've doing this for a decade. 20 What we're about to do with this new tech spec is not 21 that big a change from the operation's perspective. 22 You'll see the new program that we're going to use. 23 But using the risk insights, taking risk management 24 actions, is something that we've done a lot of at 25 South Texas Project and we have a management team that

> **NEAL R. GROSS** COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433

5

7

10

(202) 234-4433

277 1 has supported this process, that understands the 2 process and using this as a decision-making tool. 3 If and when this is approved for South 4 Texas, we expect to implement it in a timely manner. 5 In essence, all of the procedures that we need to implement this are built. There are some last 6 7 adjustments that we're going to make based on the 8 safety evaluation report. There are some 9 recommendations in there for some risk management actions and we're making sure those will be in the 10 procedures that we have. 11 12 Starting last summer, we've been training on risk management tech specs for three years at least 13 14 with the senior reactor operators during requal. 15 Starting last summer, we got into -- Okay. This is going to happen. You need to really understand the 16 17 process, what's going to happen, the computers, how the process will work. So we've been training almost 18 19 since last summer. We believe the operators are ready 20 for this. 21 As I mentioned, the procedures are in 22 essence approved, ready to go, or not approved, but 23 they are ready to go. We have already had the pilot 24 class to introduce this to management. Rick and I 25 taught a four hour pilot class that introduced this to

> NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433

1 the management level above Operations, but including 2 Maintenance and Work Control. Supervisors all the way 3 up to Joe Sheppard, our Chief Nuclear Officer, will 4 have this training because we recognize that this is 5 a significant cultural moment for a station to adopt something like this with respect to tech spec. 6 So 7 it's not just a licensed operator kind of thing. 8 Everyone needs to understand it. Everyone needs to 9 understand the basis for it. Everyone needs to understand the limitations of 10 the PRA and the importance of risk management actions and like I say, 11 there's a wide body of people that do but all the way 12 People in the decision making chain 13 up to the top. 14 need to understand that. We've had a couple of meetings with the 15

region and a number of discussions with the residents 16 to make sure that they understand what this is going 17 to look like, what actions we'll take on the station. 18 19 I've had some interesting discussions with a senior 20 resident along the -- I guess, the topic that we 21 alluded to earlier about abuse. What could a station 22 do with this that would be inappropriate or not what 23 was expected by the regulator when it was approved and 24 like I said, we agreed that between the oversight 25 process, the safety culture initiative, MSPI, that

> NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433

(202) 234-4433

5 And I think what's very interesting about this particular tech spec change is to invoke it the 6 7 senior resident will immediately know or he'll know 8 the next day when he comes to the morning meeting or 9 he'll know when he goes to the control room. It will 10 be in the log and at that point in time he can engage into whatever level he wants to. So it's something 11 that the NRC will have real time involvement. 12 From perspective, it's clearly 13 that transparent as 14 something we can obviously engage on real time.

15 DR. BONACA: I wouldn't worry so much in 16 intentional abuse because it's just simply that as you 17 proliferate the use of Reg. Guide 1.174 to get 18 relaxation through specs, through tech online 19 maintenance, through so many different means and 20 applications, you have to be concerned about the fact 21 that each one of them even in a small way provides or 22 has an increasing risk and therefore you may not see the interference for that -- if that's --23 24 MR. HEAD: And I think speaking of that

the assessment that we're going to be required to do

NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433

25

(202) 234-4433

	280
1	every two years that's embedded within the guidance,
2	that's an important thing. Right now, there's no
3	official way to share that with the NRC. We will
4	certainly share it with the senior resident, if
5	nothing else, because they'll want to look at it from
6	a corrective action standpoint. Here was a couple of
7	interesting things that have happened. Have you taken
8	the appropriate corrective actions with respect to
9	those incidents that occurred? So it's something that
10	we will share with the regulator. We will expect the
11	region to review it as we go forward and implement
12	this.
13	Crucial to how we're going to be doing
14	work we've alluded to it before, the precalculated set
15	of calculations, is that we're going to have what we
16	call a RICT calculator and this is based on STP's
17	existing configuration risk management tool, the thing
18	that you saw earlier that generated the curves for
19	years. We've taken that tool now and put it more or
20	less in a tech spec environment. It meets the
21	guidelines. It's based on greater than 20,000
22	configurations or maintenance states that have been
23	already pre-quantified and it will be using CDF and
24	LERF as its pre-quantified limits.
25	It's user interface. It's a friendly
	1

(202) 234-4433

(202) 234-4433

281

questions and puts it in a format that they can use and we'll show it to you in a second. To be used by Operations real time is if something becomes inoperable that's outside of the planned work week but maintenance will be using it to plan the work week.

It's our vision that we don't challenge 9 the South Texas  $10^{-6}$  very often and we would not 10 expect that the change would with risk-informed tech 11 12 specs because one of the things that we do in almost all nuclear plants is the work week is how you do your 13 14 work and to schedule something past the work week more 15 or less, it really impacts the rest of the work schedule. So the maintenance people or the 16 17 maintenance planners are important to understand what's going to happen that work week and if we're 18 19 going to be using risk managed tech specs as part of 20 that work week, there will be opportunities for 21 management and others to get involved and go, is that 22 the work week we want to plan and if it is, then we'll 23 go forth and do what's required. It comes with risk-24 managed tech specs.

Periodically, what happens is they'll

NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433

25

1

2

3

4

5

6

7

8

282 encounter a configuration that does not exist within the database and when that happens, it could happen two ways. One is we're planning a configuration for a work week that does not exist and before that work week happens, the risk management, the risk individuals, get involved, calculate that work week or calculate that configuration and that's now available to the risk planners or the maintenance planners. What could happen also though is that a non-calculated configuration could exist during the work week? What will happen now if it involves tech

10 11 specs equipment is that we will have to go back and 12 recalculate that and within the guidelines, there's a 13 14 requirement that that happens within 12 hours. We're 15 set up at South Texas, we believe, to be able to do that quite easily within 12 hours to make sure that we 16 17 understand the consequences of that configuration had it not been precalculated. Anything to add to that, 18 19 Rick?

20 Yes, just a couple of quick MR. GRANTOM: 21 Scott is right. The work planners, the things. 22 maintenance planners, take a look and they'll have a 23 risk profile planned for the week. That has to go up 24 through management and gets approved by the plant 25 manager at T-2 is what we call it, two weeks prior to

> NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433

1

2

3

4

5

6

7

8

9

283 the work week and this gives you an opportunity to find out where the risk significant window is during that work and they have the opportunity now to start doing other risk management compensatory measures. It may be as simple as some pre-job briefs or some other areas. But it gives you the opportunity to go and post that ahead of time. It's an important facet of that.

9 The other part of that is the database of 10 the 20,000 maintenance states, just an interesting datapoint that we know of is that only about 500 11 12 maintenance states have actually occurred in either Most of these maintenance states occurred as 13 unit. 14 Scott said due to planning. They think they're going 15 to do something and then all of a sudden we calculate a whole bunch of maintenance states and we'll add a 16 17 bunch of maintenance states to go calculate. Just things will overlap and flip and they won't quite come 18 19 out the way they exactly planned to do that. But it 20 is an interesting kind of thing when we see that you 21 500 maintenance states have that have actually 22 occurred over the 20,000 that you have. I like to 23 think of it somewhat as margin in that regard. 24 MR. HEAD: Okay. And just real quick, 25 this is the tool that we developed. What you see here

> NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433

1

2

3

4

5

6

7

8

	284
1	is this is where the operators would go in and based
2	on the declaration time when their equipment was
3	rendered inoperable, they would enter the time that it
4	was inoperable. This is safety injection train A
5	common. This is taking out the whole safety injection
б	train A. Here is when they took out a central cooling
7	water. Here's when they took out chilled water and
8	here's when the diesel went out. Now, in fact, the
9	diesel became inoperable when the DW went out.
10	So let's go to the next slide. This is
11	So once they've entered that, here's what they'll be
12	looking at and I'll ask you to look at the work week.
13	That's the first four items on here because they're
14	all train A. And this example what happened is during
15	the rounds, these hypothetical rounds, we discovered
16	something wrong with diesel generator C. Right now at
17	South Texas, this would be as 303 and if whatever we
18	found would render it inoperable, that would be a 303
19	situation.
20	What we would do now is we would enter
21	that configuration's time in and we would now
22	calculate the new risk completion time. What we would
23	find is that within an hour and 12 minutes we're going
24	to cross $E^{-6}$ and so we basically need to immediately
25	start implementing risk management actions because now
l	I

(202) 234-4433

(202) 234-4433

we're going to be crossing this threshold and we now have 174 hours to get us out of this configuration before we cross E<sup>-5</sup>.
There are many ways to do that. We can get out of this train work week quickly or we can get out of whatever is causing the diesel generator C to

7 become inoperable. But this would be now his tech spec moment and this configuration is I have this 8 9 diesel generator C is now inoperable. I have to start taking risk management actions because of this number 10 11 which is very, very short. And here is my new risk-12 informed completion time in this configuration if we were to stay in that configuration for that whole 13 14 time.

15 As stuff started becoming -- If we got safety injection or background information in that 16 case, if the chiller became operable, if you got it 17 operable, then the curve that you saw before would 18 19 The slope would decrease. Once EW became decrease. 20 operable, the slope would decrease again and then all 21 that would be left at that point in time is the diesel 22 and the clock is starting back though from when we 23 first took safety injection out of service. 24

24 MR. GRANTOM: A couple of things to maybe 25 just -- You have to keep in mind. This is an operator

> NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433

1 in the control room entering these components and 2 entering these times in or out of service. The other 3 point over here too to look at is when they calculate 4 the risk-informed completion time you can see that it 5 will calculate the 30-day backstop and it also has the risk-informed backstop that will pick 6 the most 7 limiting item out of that configuration. So this would be the tool they would use to be able to apply 8 9 a risk-informed completion time. This would be This would be available to be retrieved 10 documented. by the regulator, whatever, for evaluating these 11 conditions. 12 And then as Scott indicated, there are 13 14 several different ways that one could get out this. I mean, this diesel generator may be really broken, 15 functionally broken, or it could have just a small 16 problem possibly with something, some calculation or 17 some other item that makes it indeterminate in the 18 19 definition of what operability is. So this tool works well. 20 This was 21 designed by both planners and by the operating crews. 22 This screen is made because that's the way they wanted 23 the screen to look. 24 DR. MAYNARD: But if you end up in a 25 configuration that had not been pre-analyzed.

> NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433

(202) 234-4433

	287
1	MR. GRANTOM: Right here.
2	MR. HEAD: If that happens, then you get
3	warned in the previous screen. You would have seen
4	it. In another one, you would have seen an email is
5	immediately sent to risk management. In this
6	configuration if that were to happen, then they would
7	be called.
8	DR. APOSTOLAKIS: That's why they're on
9	night shift now.
10	MR. HEAD: That's why we're on night
11	shift.
12	MR. GRANTOM: No. Really, in fact, he
13	managing the circ water structure on night shift right
14	now. But we have people available 24 hours. They're
15	on call to do something like this and fortunately,
16	this sort of activity all happened during the work
17	week because we only do this sort of work during an
18	actually Monday through
19	It's a typical process. The way it works
20	is there's a duty-risk engineer always on call.
21	They'll get the page. They know their own duty. They
22	have the capability even at their own homes to be able
23	to calculate that. We've made that tool available to
24	them and we can usually turn these things around
25	literally within an hour or two hours and then what
	1

(202) 234-4433

1       happens is we upload the new information, the new         2       maintenance state, to the database and then the         3       database is read over the station's LAN and then it's         4       available to the operators then at that point in time         5       available to the operators then at that point in time         6       works.         7       DR. ABDEL-KHALIK: Now the 4.62 X 10 <sup>-4</sup> 8       number, that's the instantaneous value of the risk?         9       MR. HEAD: Yes. For that state.         10       DR. ABDEL-KHALIK: So that's how you keep         11       track of the 1 X 10 <sup>-3</sup> .         12       MR. HEAD: Right. And what we expect to         13       do there is that screen is going to turn red if it         14       goes over E <sup>-3</sup> is what we think the operators are going         15       to want. We don't have a annunciator for it. We're         16       just going to have that one turn red if it goes past         17       and the procedures all will be for what you do, how         18       VICE CHAIR WALLIS: Shouldn't one of those         20       column be ILERF instead of         21       MR. HEAD: Right here, LERF.         22       VICE CHAIR WALLIS: No, over there. The         23       MR. HEAD: Yeah.		288
<ul> <li>database is read over the station's LAN and then it's</li> <li>available to the operators then at that point in time</li> <li>and we've contacted them. That's pretty simply how it</li> <li>works.</li> <li>DR. AEDEL-KHALIK: Now the 4.62 X 10 <sup>-4</sup></li> <li>number, that's the instantaneous value of the risk?</li> <li>MR. HEAD: Yes. For that state.</li> <li>DR. AEDEL-KHALIK: So that's how you keep</li> <li>track of the 1 X 10<sup>-3</sup>.</li> <li>MR. HEAD: Right. And what we expect to</li> <li>do there is that screen is going to turn red if it</li> <li>goes over E<sup>-3</sup> is what we think the operators are going</li> <li>to want. We don't have a annunciator for it. We're</li> <li>just going to have that one turn red if it goes past</li> <li>and the procedures all will be for what you do, how</li> <li>you react to that.</li> <li>VICE CHAIR WALLIS: Shouldn't one of those</li> <li>column be ILERF instead of</li> <li>MR. HEAD: Right here, LERF.</li> <li>VICE CHAIR WALLIS: No, over there. The</li> <li>two LERF columns.</li> <li>MR. HEAD: Yeah.</li> </ul>	1	happens is we upload the new information, the new
<ul> <li>available to the operators then at that point in time</li> <li>and we've contacted them. That's pretty simply how it</li> <li>works.</li> <li>DR. AEDEL-KHALIK: Now the 4.62 X 10 <sup>-4</sup></li> <li>number, that's the instantaneous value of the risk?</li> <li>MR. HEAD: Yes. For that state.</li> <li>DR. AEDEL-KHALIK: So that's how you keep</li> <li>track of the 1 X 10<sup>-3</sup>.</li> <li>MR. HEAD: Right. And what we expect to</li> <li>do there is that screen is going to turn red if it</li> <li>goes over E<sup>-3</sup> is what we think the operators are going</li> <li>to want. We don't have a annunciator for it. We're</li> <li>just going to have that one turn red if it goes past</li> <li>and the procedures all will be for what you do, how</li> <li>you react to that.</li> <li>VICE CHAIR WALLIS: Shouldn't one of those</li> <li>column be ILERF instead of</li> <li>MR. HEAD: Right here, LERF.</li> <li>VICE CHAIR WALLIS: No, over there. The</li> <li>two LERF columns.</li> <li>MR. HEAD: Yeah.</li> </ul>	2	maintenance state, to the database and then the
5       and we've contacted them. That's pretty simply how it         6       works.         7       DR. ABDEL-KHALIK: Now the 4.62 X 10 <sup>-4</sup> 8       number, that's the instantaneous value of the risk?         9       MR. HEAD: Yes. For that state.         10       DR. ABDEL-KHALIK: So that's how you keep         11       track of the 1 X 10 <sup>-3</sup> .         12       MR. HEAD: Right. And what we expect to         13       do there is that screen is going to turn red if it         14       goes over E <sup>-3</sup> is what we think the operators are going         15       to want. We don't have a annunciator for it. We're         16       just going to have that one turn red if it goes past         17       and the procedures all will be for what you do, how         18       you react to that.         19       VICE CHAIR WALLIS: Shouldn't one of those         20       column be ILERF instead of         21       MR. HEAD: Right here, LERF.         22       VICE CHAIR WALLIS: No, over there. The         23       two LERF columns.         24       MR. HEAD: Yeah.	3	database is read over the station's LAN and then it's
6       works.         7       DR. ABDEL-KHALIK: Now the 4.62 X 10 <sup>-4</sup> 8       number, that's the instantaneous value of the risk?         9       MR. HEAD: Yes. For that state.         10       DR. ABDEL-KHALIK: So that's how you keep         11       track of the 1 X 10 <sup>-3</sup> .         12       MR. HEAD: Right. And what we expect to         13       do there is that screen is going to turn red if it         14       goes over E <sup>-3</sup> is what we think the operators are going         15       to want. We don't have a annunciator for it. We're         16       just going to have that one turn red if it goes past         17       and the procedures all will be for what you do, how         18       you react to that.         19       VICE CHAIR WALLIS: Shouldn't one of those         20       column be ILERF instead of         21       MR. HEAD: Right here, LERF.         22       VICE CHAIR WALLIS: No, over there. The         23       two LERF columns.         24       MR. HEAD: Yeah.	4	available to the operators then at that point in time
7DR. ABDEL-KHALIK: Now the 4.62 X 10-48number, that's the instantaneous value of the risk?9MR. HEAD: Yes. For that state.10DR. ABDEL-KHALIK: So that's how you keep11track of the 1 X 10 <sup>-3</sup> .12MR. HEAD: Right. And what we expect to13do there is that screen is going to turn red if it14goes over E <sup>-3</sup> is what we think the operators are going15to want. We don't have a annunciator for it. We're16just going to have that one turn red if it goes past17and the procedures all will be for what you do, how18you react to that.19VICE CHAIR WALLIS: Shouldn't one of those20column be ILERF instead of21MR. HEAD: Right here, LERF.22VICE CHAIR WALLIS: No, over there. The23two LERF columns.24MR. HEAD: Yeah.	5	and we've contacted them. That's pretty simply how it
7       DR. ABDEL-MALIK: Now the 4.62 X 10         8       number, that's the instantaneous value of the risk?         9       MR. HEAD: Yes. For that state.         10       DR. ABDEL-KHALIK: So that's how you keep         11       track of the 1 X 10 <sup>-3</sup> .         12       MR. HEAD: Right. And what we expect to         13       do there is that screen is going to turn red if it         14       goes over E <sup>-3</sup> is what we think the operators are going         15       to want. We don't have a annunciator for it. We're         16       just going to have that one turn red if it goes past         17       and the procedures all will be for what you do, how         18       you react to that.         19       VICE CHAIR WALLIS: Shouldn't one of those         20       column be ILERF instead of         21       MR. HEAD: Right here, LERF.         22       VICE CHAIR WALLIS: No, over there. The         23       two LERF columns.         24       MR. HEAD: Yeah.	6	works.
9MR. HEAD: Yes. For that state.10DR. ABDEL-KHALIK: So that's how you keep11track of the 1 x 10 <sup>-3</sup> .12MR. HEAD: Right. And what we expect to13do there is that screen is going to turn red if it14goes over E <sup>-3</sup> is what we think the operators are going15to want. We don't have a annunciator for it. We're16just going to have that one turn red if it goes past17and the procedures all will be for what you do, how18you react to that.19VICE CHAIR WALLIS: Shouldn't one of those20column be ILERF instead of21MR. HEAD: Right here, LERF.22VICE CHAIR WALLIS: No, over there. The23two LERF columns.24MR. HEAD: Yeah.	7	DR. ABDEL-KHALIK: Now the 4.62 X 10 $^{-4}$
10DR. ABDEL-KHALIK: So that's how you keep11track of the 1 X 10 <sup>-3</sup> .12MR. HEAD: Right. And what we expect to13do there is that screen is going to turn red if it14goes over E <sup>-3</sup> is what we think the operators are going15to want. We don't have a annunciator for it. We're16just going to have that one turn red if it goes past17and the procedures all will be for what you do, how18you react to that.19VICE CHAIR WALLIS: Shouldn't one of those20column be ILERF instead of21MR. HEAD: Right here, LERF.22VICE CHAIR WALLIS: No, over there. The23two LERF columns.24MR. HEAD: Yeah.	8	number, that's the instantaneous value of the risk?
11track of the 1 X 10 <sup>-3</sup> .12MR. HEAD: Right. And what we expect to13do there is that screen is going to turn red if it14goes over E <sup>-3</sup> is what we think the operators are going15to want. We don't have a annunciator for it. We're16just going to have that one turn red if it goes past17and the procedures all will be for what you do, how18you react to that.19VICE CHAIR WALLIS: Shouldn't one of those20column be ILERF instead of21MR. HEAD: Right here, LERF.22VICE CHAIR WALLIS: No, over there. The23two LERF columns.24MR. HEAD: Yeah.	9	MR. HEAD: Yes. For that state.
12MR. HEAD: Right. And what we expect to13do there is that screen is going to turn red if it14goes over E <sup>-3</sup> is what we think the operators are going15to want. We don't have a annunciator for it. We're16just going to have that one turn red if it goes past17and the procedures all will be for what you do, how18you react to that.19VICE CHAIR WALLIS: Shouldn't one of those20column be ILERF instead of21MR. HEAD: Right here, LERF.22VICE CHAIR WALLIS: No, over there. The23two LERF columns.24MR. HEAD: Yeah.	10	DR. ABDEL-KHALIK: So that's how you keep
13do there is that screen is going to turn red if it14goes over E <sup>-3</sup> is what we think the operators are going15to want. We don't have a annunciator for it. We're16just going to have that one turn red if it goes past17and the procedures all will be for what you do, how18you react to that.19VICE CHAIR WALLIS: Shouldn't one of those20column be ILERF instead of21MR. HEAD: Right here, LERF.22VICE CHAIR WALLIS: No, over there. The23two LERF columns.24MR. HEAD: Yeah.	11	track of the 1 X $10^{-3}$ .
14goes over E <sup>-3</sup> is what we think the operators are going15to want. We don't have a annunciator for it. We're16just going to have that one turn red if it goes past17and the procedures all will be for what you do, how18you react to that.19VICE CHAIR WALLIS: Shouldn't one of those20column be ILERF instead of21MR. HEAD: Right here, LERF.22VICE CHAIR WALLIS: No, over there. The23two LERF columns.24MR. HEAD: Yeah.	12	MR. HEAD: Right. And what we expect to
15 to want. We don't have a annunciator for it. We're just going to have that one turn red if it goes past and the procedures all will be for what you do, how you react to that. 19 VICE CHAIR WALLIS: Shouldn't one of those column be ILERF instead of 21 MR. HEAD: Right here, LERF. 22 VICE CHAIR WALLIS: No, over there. The 23 two LERF columns. 24 MR. HEAD: Yeah.	13	do there is that screen is going to turn red if it
<pre>16 just going to have that one turn red if it goes past 17 and the procedures all will be for what you do, how 18 you react to that. 19 VICE CHAIR WALLIS: Shouldn't one of those 20 column be ILERF instead of 21 MR. HEAD: Right here, LERF. 22 VICE CHAIR WALLIS: No, over there. The 23 two LERF columns. 24 MR. HEAD: Yeah.</pre>	14	goes over $E^{-3}$ is what we think the operators are going
17 and the procedures all will be for what you do, how you react to that. 19 VICE CHAIR WALLIS: Shouldn't one of those column be ILERF instead of 21 MR. HEAD: Right here, LERF. 22 VICE CHAIR WALLIS: No, over there. The 23 two LERF columns. 24 MR. HEAD: Yeah.	15	to want. We don't have a annunciator for it. We're
<pre>18 you react to that. 19 VICE CHAIR WALLIS: Shouldn't one of those 20 column be ILERF instead of 21 MR. HEAD: Right here, LERF. 22 VICE CHAIR WALLIS: No, over there. The 23 two LERF columns. 24 MR. HEAD: Yeah.</pre>	16	just going to have that one turn red if it goes past
<ul> <li>19 VICE CHAIR WALLIS: Shouldn't one of those</li> <li>20 column be ILERF instead of</li> <li>21 MR. HEAD: Right here, LERF.</li> <li>22 VICE CHAIR WALLIS: No, over there. The</li> <li>23 two LERF columns.</li> <li>24 MR. HEAD: Yeah.</li> </ul>	17	and the procedures all will be for what you do, how
<pre>20 column be ILERF instead of 21 MR. HEAD: Right here, LERF. 22 VICE CHAIR WALLIS: No, over there. The 23 two LERF columns. 24 MR. HEAD: Yeah.</pre>	18	you react to that.
21 MR. HEAD: Right here, LERF. 22 VICE CHAIR WALLIS: No, over there. The 23 two LERF columns. 24 MR. HEAD: Yeah.	19	VICE CHAIR WALLIS: Shouldn't one of those
<ul> <li>VICE CHAIR WALLIS: No, over there. The</li> <li>two LERF columns.</li> <li>MR. HEAD: Yeah.</li> </ul>	20	column be ILERF instead of
<pre>23 two LERF columns. 24 MR. HEAD: Yeah.</pre>	21	MR. HEAD: Right here, LERF.
24 MR. HEAD: Yeah.	22	VICE CHAIR WALLIS: No, over there. The
	23	two LERF columns.
25 VICE CHAIR WALLIS: One is ILERF, isn't	24	MR. HEAD: Yeah.
	25	VICE CHAIR WALLIS: One is ILERF, isn't

	289
1	it?
2	MR. HEAD: This is still going through
3	some beta testing right now. We just recently changed
4	these. Yes, that should have been an "I" in there.
5	DR. APOSTOLAKIS: Can we wrap up now?
6	MR. HEAD: Conclusions are we're poised to
7	implement the tech spec
8	DR. BONACA: You do have a QA problem,
9	right?
10	MR. HEAD: Yes sir.
11	DR. BONACA: You, for example, have an
12	independent review of the calculation being done by
13	MR. GRANTOM: Yes, the process for
14	uploading the maintenance states is we go What we
15	do is we do it through a sampling. We made the
16	maintenance state changes and we do a review and a
17	verification of those and then we can sample the other
18	ones and see if we're getting expected changes the way
19	we expected to. Obviously with 20,000 we can't check
20	every one of them. But they are all archived. All
21	the calculations are archived there and all of the
22	software that you've seen obviously goes through a
23	software quality assurance program for the software
24	itself.
25	MR. HEAD: Which is stipulated in the
I	I

(202) 234-4433

	290
1	guidance document on how you do that.
2	Like I said, I summarized what I've said
3	before. The model is ready. The procedures were
4	reviewed. Operations is trained. Station management
5	is very much aware of this and will be trained before
б	we implement it and we do believe it is a significant
7	industry milestone we
8	VICE CHAIR WALLIS: The second bullet
9	here. When it's all over, are you going to
10	demonstrate having done this over the two years on
11	what you're doing that you have actually gotten a
12	significant improvement in safety?
13	MR. HEAD: What we're going to do is
14	continue to monitor the 52 week average.
15	VICE CHAIR WALLIS: You will. So you
16	intend to demonstrate that there is a significant
17	improvement in safety.
18	MR. GRANTOM: I would tell you that, yes,
19	we are going to demonstrate that there is an
20	improvement in safety because there's an improvement
21	in measuring safety.
22	VICE CHAIR WALLIS: Otherwise, it's an
23	empty statement. This is a pilot plant. You're
24	running an experiment. You're going to show it as an
25	improvement in safety.
ļ	I

(202) 234-4433

	291
1	MR. RUBIN: I'd like to put it this way.
2	Apparently right now, you don't know where you are.
3	VICE CHAIR WALLIS: So why are you making
4	this statement?
5	MR. MONTGOMERY: Say. Excuse me. I mean,
6	you've been operating with this in parallel with tech
7	specs for ten years.
8	MR. GRANTOM: Right.
9	MR. MONTGOMERY: You can go back and show
10	that after Year 2 and Year 3 after having implemented
11	that you have realized an improvement in safety.
12	MR. GRANTOM: If you were to take a look
13	at our relative 52 week average versus what our
14	average CDF and we'll have to make the assumption that
15	the average CDF calculation is truly an average, what
16	we find is that the average of the configurations that
17	we've been in since we've been able to measure this
18	and see it has always been lower than the average CDF.
19	MR. RUBIN: However, let me add from the
20	staff's perspective that the staff criteria for this
21	program is not a reduction in risk. It's not a
22	necessary criteria. It's an expectation.
23	VICE CHAIR WALLIS: What's it for?
24	DR. BONACA: I would like to add that just
25	one avoided shutdown, it's a big reduction in risk.
Į	I

(202) 234-4433

	292
1	MR. RUBIN: It's a smarter way of
2	operating the plant, smarter way of controlling
3	DR. BONACA: The current tech specs may
4	force you to shut down, but this will allow you not to
5	have.
6	MR. HEAD: I don't know that we'll
7	demonstrate it, if I could, quantitatively because we
8	don't know what shutdowns we would have had or missed
9	if we had this. But it is such a much better way of
10	running the plant in avoiding those shutdowns that we
11	believe that is an improvement
12	VICE CHAIR WALLIS: I like the idea. I
13	think it's a great idea. But I think if you're going
14	to do the pilot, you're going to have some measure of
15	success when you run the pilot compared with what you
16	would have done if you hadn't run the pilot and it
17	should really be presumably improving safety, one of
18	the measures, or cost or something.
19	DR. KRESS: Plant economics and not
20	affecting and not reducing.
21	DR. MAYNARD: But there are other benefits
22	and a lot of it is to the NRC staff too. Because a
23	typical process now is if you find yourself in a
24	situation, something happens in the middle and you're
25	not going to be able to get it done, typically you
I	I

(202) 234-4433

	293
1	will go for enforcement discretion which means you're
2	on the phone at night making a call and putting
3	together a lot of information and the staff having to
4	take that information and decide whether they believe
5	that it is safe enough to go ahead and extend that.
6	This goes ahead and puts it in more of a pre-approved
7	decision making process on when it's appropriate to
8	extend an LCO versus when it's not. So it has
9	benefits to the staff and to the decision making
10	process on when it is safe or not safe.
11	DR. ABDEL-KHALIK: Do you have enough
12	historical data that would allow you to quantify the
13	running average of the risk under the current tech
14	specs prior to implementation of this like for the
15	five years prior to starting and then you can see how
16	the running average changed over time?
17	MR. GRANTOM: Yes, we do. It's based on
18	Maintenance Rule though which is based on
19	functionality. But, yes, you can definitely see that
20	once we've been able to start to manage it, there's
21	been a reduction in that. Plus the other factor of
22	this, one of the other safety benefits and I haven't
23	really heard anybody say this yet, in each of these
24	quantifications, there's non tech spec equipment and
25	even some non safety-related equipment that's being
Į	I

(202) 234-4433

	294
1	calculated in the risk-informed completion time time
2	frame here. That's currently not done at all under
3	tech specs for that and just that by itself to me in
4	my way of thinking is a safety improvement.
5	MR. BRADLEY: There's another safety
6	improvement we haven't discussed and that is that this
7	program provides an incentive to have a better, higher
8	quality, greater scope PRA model that you will not
9	only be using for this, but you'll be using for all
10	your other risk-informed decisions including (a)(4)
11	and that is a definite benefit to this effort.
12	MR. HEAD: That's the way I was going to
13	answer. Biff, I'm glad you did. This is a global
14	statement. It's for the industry is the way this was
15	oriented.
16	MR. TJADER: As far as the pilot question
17	goes though, you are a pilot plant and the staff will
18	go out in a year, probably not even two years. We'll
19	go out sooner and observe and actually we'll be
20	observing on a continuous basis through the resident
21	inspectors how it's being implemented.
22	VICE CHAIR WALLIS: It would help a great
23	deal if you had measures of improvement because
24	there's a significant fraction of the public out there
25	that believes that risk-informing is simply going
ļ	I

(202) 234-4433

	295
1	easier on industry and there is no benefit to the
2	public. If you could show that there is a real safety
3	benefit from using this risk-informed regulation, I
4	think you would do a tremendous amount of good.
5	MR. RUBIN: I think in actuality there's
б	a potential here for the type of improvement you're
7	talking about. But from the staff's perspective, the
8	criteria guidelines we're using is no more than a
9	small increase in risk that's fully in line with Reg.
10	Guide 174, the Commission's guidance
11	VICE CHAIR WALLIS: But that's an
12	increase.
13	MR. RUBIN: and the ACRS guidance.
14	VICE CHAIR WALLIS: That's an increase in
15	risk.
16	(Off the record comments.)
17	MR. RUBIN: At the worst, no more than a
18	small increase in risk. The reality is you'll be
19	operating the plant in a much smarter way and the
20	potential for reducing risk is very apparent and very
21	doable because the analytical methods are going to be
22	applied here.
23	MR. MONTGOMERY: The point I wanted to
24	make previously is that early on, and in fact you just
25	alluded to it, Rick, is where you said that when we
	I

(202) 234-4433

	296
1	started implementing this we realized that we were
2	doing things in series and that we have higher
3	accumulated risk before we implemented this in
4	parallel. We now have significantly reduced through
5	the application of this program through actually doing
б	it though not being required to do it in parallel with
7	tech specs. Basically, they've had the existing
8	completion times, operating with those, and in
9	conjunction operating with a risk-informed completion
10	time and observing the appropriate, voluntarily
11	observing, the implications of that on their own.
12	They have already realized a reduction of risk. Is
13	that correct, Rick?
14	MR. GRANTOM: Yes, the point I was trying
15	to get to is the fact that currently you don't know
16	where you are.
17	(Laughter.)
18	CHAIRMAN SHACK: We're going to call it
19	quits.
20	DR. APOSTOLAKIS: The best statement was
21	by Improving the quality of PRA by itself improves
22	safety.
23	CHAIRMAN SHACK: It's an end in itself.
24	Right, George?
25	DR. APOSTOLAKIS: And that's the end.

(202) 234-4433

	297
1	VICE CHAIR WALLIS: An end in itself.
2	DR. APOSTOLAKIS: Thank you very much. It
3	was really very helpful.
4	CHAIRMAN SHACK: Time for a break, a 20
5	minute break. Off the record.
6	(Whereupon, at 4:04 p.m., the above-
7	entitled matter recessed.)
8	
9	
10	
11	
12	
13	
14	
15	
16	
17	
18	
19	
20	
21	
22	
23	
24	
25	
Į	I