## Official Transcript of Proceedings NUCLEAR REGULATORY COMMISSION

Title: Advisory Committee on Reactor Safeguards

Subcommittee on Fire Protection

Docket Number: (not applicable)

Location: Rockville, Maryland

Date: Tuesday, May 17, 2005

Work Order No.: NRC-385 Pages 1-192

NEAL R. GROSS AND CO., INC. Court Reporters and Transcribers 1323 Rhode Island Avenue, N.W. Washington, D.C. 20005 (202) 234-4433

	1
1	UNITED STATES OF AMERICA
2	NUCLEAR REGULATORY COMMISSION
3	+ + + +
4	ADVISORY COMMITTEE ON REACTOR SAFEGUARDS (ACRS)
5	+ + + +
6	SUBCOMMITTEE ON FIRE PROTECTION
7	+ + + +
8	TUESDAY,
9	MAY 17, 2005
10	+ + + +
11	ROCKVILLE, MARYLAND
12	+ + + +
13	The subcommittee met at the Nuclear
14	Regulatory Commission, Two White Flint North, Room T-
15	2B3, 11545 Rockville Pike, at 8:30 a.m., Stephen L.
16	Rosen, Chairman, presiding.
17	COMMITTEE MEMBERS:
18	STEPHEN L. ROSEN, Chairman
19	GEORGE E. APOSTOLAKIS, Member
20	MARIO V. BONACA, Member
21	RICHARD S. DENNING, Member
22	DANA A. POWERS, Member
23	GRAHAM B. WALLIS, Member
24	
25	

		2
1	ACRS/ACNW STAFF:	
2	HOSSEIN P. NOURBAKHSH, Designated Federal	
3	Official	
4	JOHN G. LAMB	
5	PANELISTS:	
6	JEFF ERTMAN, Progress Energy	
7	ELIZABETH KLEINSORG, Kleinsorg Group Risk	
8	Services, LLC	
9	ALEX MARION, NEI	
10	NRC STAFF:	
11	RICHARD A. DIPERT, NRR	
12	RAY GALLUCCI, NRR	
13	JOHN HANNON, NRR	
14	PETER KOLTAY, NRR	
15	PAUL W. LAIN, NRR	
16	ROBERT F. RADLINSKI, NRR	
17	SUNIL D. WEERAKKODY, NRR	
18		
19		
20		
21		
22		
23		
24		
25		

		3
1	I-N-D-E-X	
2	Pag	9
3	Opening Remarks	
4	by Stephen L. Rosen, Chairman	4
5	Introductory Remarks by John Hannon	
6	and Sunil D. Weerakkody, NRR	5
7	Programmatic Overview by Paul Lain, NRR	7
8	NFPA 805 Regulatory Guide by	
9	Robert F. Radlinski, NRR	0
10	NEI 04-02 Implementation Guide introductory	
11	Remarks By Alex Marion, NEI	1
12	NEI-04-02 by Elizabeth Kleinsorg,	
13	Kleinsort Group Risk Services 7	7
14	NFPA 805 Inspection Procedure	
15	by Richard A. Dipert, NRR 15	3
16	NFPA 805 Transition Pilot Program	
17	by Paul Lain, NRR	1
18	Adjournment	2
19		
20		
21		
22		
23		
24		
25		

1 P-R-O-C-E-E-D-I-N-G-S 2 (8:31 a.m.)The meeting will now come 3 CHAIRMAN ROSEN: 4 to order. Good morning. This is a meeting of the ACRS Subcommittee on Fire Protection. I am Steve 5 Rosen, Chairman of the Subcommittee. 6 Members in 7 attendance are George Apostolakis, Rich Denning, Graham Wallis, Dana Powers, and Mario Bonaca. 8 The purpose of this meeting is to discuss 9 the draft Final Regulatory Guide, Risk-Informed, 10 11 Performance-Based Fire Protection for Existing Light-12 Water Nuclear Power Plants. The Subcommittee will gather information, analyze relevant issues and facts, 13 14 and formulate proposed positions and actions as 15 appropriate for deliberation by the Full Committee. Dr. Hossein Nourbakhsh is the designated 16 federal official for this meeting. Also, Mr. John 17 Lamb, of the ACRS staff, is in attendance to provide 18 19 technical support. The rules for participation in today's 20 21 meeting have been announced as part of a Notice of 22 this meeting previously published in The Federal 23 Register on May 4, 2005. A transcript of the meeting is being kept 24

A transcript of the meeting is being kept and will be made available as stated in the The

Federal Register Notice. It is requested that the speakers first identify themselves, use one of the many microphones, and speak with sufficient clarity and volume so that they can be readily heard.

We have received no written comments or requests for time to make oral statements from members of the public today regarding today's meeting.

We will now proceed with the meeting. I call upon Sunil Weerakkody of the Office of Nuclear Reactor Regulation to begin.

MR. WEERAKKODY: My name is Sunil
Weerakkody. I am the Section Chief of Fire Protection
in NRR. Our Region Director is out today and my boss,
John Hannon, will join us shortly.

It has been a while, I think, more than about. six months since we last briefed Subcommittee. Today's briefing is solely focused on NFPA 805, which call the Risk-Informed, we Performance-Based Rule. We have a number of presentations from the staff. The focus of the discussion is the Reg. Guide, however, we will have a presentation to you on the Inspection Guide. message we want to convey to you, and that is under the endorsement we will be seeking, is that you would see that we have taken a number of steps to avoid the

1

2

3

4

5

6

7

8

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

kind of errors or the kind of confusions that got us into the Appendix R. For example, the Appendix R Reg. Guide was developed only about three years ago even though Appendix R was issued in 1981. As compared to that, in comparison, the Rule was issued in July of last year and by July of this year, we hope to get the endorsement of all stakeholders and have a finalized Reg. Guide in place.

In addition, we are planning to have an Inspection Procedure that will work with 805 in place by the end of the year, available for the regions, even though it will be used for the first time in about two and a half years from now. So we are taking all the steps to address any uncertainties in the implementation of this new Risk-Informed Rule.

With that, I would like to introduce the next speaker. Sitting here on my right is Paul Lain. He is the Project Manager for NFPA 805. He has been playing that role for the last three years, taking care of all issues basically associated with 805.

Bob Radlinski here is in my staff. He is the key responsible person for the Reg. Guide. He is going to give you a presentation on the Reg. Guide. Sitting in the back is Rick Dipert. He is going to provide you with a presentation on the Inspection Plan

1 because he is the Chairman of the Working Group that 2 we have put together to prepare the Inspection Guide. 3 With that, Paul, why don't you go ahead 4 and start? 5 MR. LAIN: Okay. As you said, my name is I am a Fire Protection Engineer in Sunil's 6 Paul Lain. 7 staff. I have a Master's in Fire Protection 8 Engineering from Worcester Polytech. And today we are 9 oOhere to talk about the Regulatory Guide and seek 10 your endorsement. Here's a brief outline of what I plan to 11 12 discuss today. I will start with the main purpose for the meeting, review a short history of the 805 Rule, 13 14 fill in the Subcommittee on the various 805 activities 15 that are ongoing, review the Reg. Guide Schedule, touch on industry's interests so far, and then add 16 17 some insight on a new standard for advanced reactors. So the main purpose of the meeting today 18 19 is, as Sunil said, we are looking for ACRS endorsement 20 to publish the NUREG Guide. The ACRS gave us a 21 deferral on the review of the draft until the public 22 comments period was over and we've addressed those 23 public comments and are hoping for your endorsement. 24 Here is a short history of the Risk-

Informed Rule. NFPA 805 was born out of a few -- out

of a number of issues. In the `90's, the Commission embraced Risk-Informed, Performance-Based Regulation and the reduction of regulatory burden. In addition, some thought Appendix R was too deterministic with hundreds of exemptions. A Thermo-Lag problem heightened the need for the methodology to quantify the risk, which could have minimized the resolution impact. In '98, the staff formally proposed to the Commission to work with NFPA to develop a Risk-Informed, Performance-Based Consensus Standard and, if acceptable, the staff would request the Commission to endorse the rulemaking. In 2000, the staff had confidence that the Standard would be acceptable and requested the Commission approve the Rulemaking Plan and adopt 805. In 2001, NFPA issued 805 and in 2002, the Rule was published -- the proposed Rule was published, and in 2004, the Final Rule was approved.

So here are some items that are left to do with the 805. We will discuss the first four bullets in more detail today, in the next couple of briefings. The fifth bullet, the Subcommittee heard from Research and EPRI earlier this month, NRR has been monitoring these efforts and providing comments on the drafts. Once the new Regs have been finalized, NRR will review the limitations and address, you know, how to

1

2

3

4

5

6

7

8

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

implement those in the next revision of the Reg. Guide. So Revision Zero will not -- has placeholders and discussions of those products, but not full endorsement of those products until those products are complete.

Finally, the last bullet there is the Standard Review Plan. It may need to be updated for review of the 805 License Amendment Process. allowing licensees to transition in a graded approach. If they have a clean licensing basis and follow the Reg. Guides, it should be an administrative matter to transition, but if they have gray issues within their licensing basis, they can submit those issues to NRC Review. One of our goals here is to have the 805 transitions bring clarity to the licensing basis, so we are allowing them to submit extra license amendment items that can be reviewed and approved through the NSER Process so that they will have -- they will bring their licensing basis up to proper clarity. something industry wanted to do and we're allowing that through this process.

We will also be reviewing the SRP during the Product Program and any updates or any updates that are needed.

Here is a short -- back to the main reason

1

2

3

4

5

6

7

8

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

why we are here today is that the Reg. Guide's
schedule we want the Reg. Guide published. This is
our current schedule. It has taken some time, but it
was expected since we have been working with NEI to
develop a consensus on their implementation guidance,
NEI 04-02, we will hear a little bit more about that
today. Bob Radlinski of NEI will be discussing these
documents further and, hopefully, we can get the
Committee's endorsement by the end of June and meet
our July publishing date.
MR. APOSTOLAKIS: When will you get the
CRGR Review?
MR. LAIN: We are meeting with them next
Tuesday.
MR. APOSTOLAKIS: So the document we are
reviewing then may not be the final document?
MR. LAIN: We are hoping it will be very
close to the final document, yes.
We don't see the CRGR pretty much gave
a pass on the Rule since the Rule is voluntary. We
don't see a lot of back-dated issues with this Rule,
and so we discussed, and we got a deferral from them
on the Reg. Guide, but they also said they wanted to
take a look at the Reg. Guide before the Reg. Guide
went out. So, yes, sir.

б

1	MR. APOSTOLAKIS: Okay.
2	MR. LAIN: I have added this slide because
3	the Subcommittee, in the past, has shown some interest
4	on who may adopt this new Rule.
5	CHAIRMAN ROSEN: What is that LOI?
6	MR. LAIN: It is a Letter of Intent and we
7	will be discussing that a little bit later. I
8	probably shouldn't throw in acronyms there at the
9	beginning of the presentation.
LO	As I've heard it said before, Duke has
L1	volunteered to be the first penguin off the ice. I
L2	think Dennis has said that. And Duke has sent us a
L3	Letter of Intent in February
L4	DR. POWERS: Who uses an analogy for a
L5	Fire Protection Rule?
L6	(LAUGHTER.)
L7	MR. LAIN: They've indicated their intent
L8	to transition all seven of their units.
L9	MR. APOSTOLAKIS: But why would they do
20	that? It's a little bit of a mystery to me. I mean,
21	we've been hearing over the years that they have
22	invested tremendous amounts of money and effort to
23	implement Appendix R. Why would they change now?
24	MR. WEERAKKODY: Let me try to answer that
25	using some of the material that Drew Barron, he's the

1 Chief Nuclear Officer of Duke, came to the RIC and he 2 gave a presentation on 805 and gave a number of 3 reasons --4 CHAIRMAN ROSEN: You said he came to the? 5 MR. WEERAKKODY: The RIC, Regulatory Information Conference 2005, and he provided a 6 7 presentation as to why he decided to go this way, 8 granted there is a mystery to the Appendix R, but at 9 same year-to-year basis, the time, on а 10 Inspection Basis, they are having to deal with a large 11 number of mostly lower significant issues that are 12 non-compliances. They like -- you know, he is driven by the need to go to a stable regulatory environment 13 14 through 805. That is his high-level intent. He also 15 sees that in addition to being able to focus his attention to the risk significant issues in what are 16 the necessary modifications, he also sees as a way of 17 not having to do unnecessary modifications that does 18 19 not advocate --20 MR. APOSTOLAKIS: So let me understand 21 this. Appendix RR has been around for 20 --22 Twenty-four years. MR. WEERAKKODY: 23 APOSTOLAKIS: -- for twenty-four MR. 24 And some facilities still have a problem 25 complying with Appendix R?

1	MR. WEERAKKODY: Yes, there is in Fire
2	Protection, what you see, Dr. Apostolakis
3	MR. APOSTOLAKIS: George, George is fine.
4	MR. WEERAKKODY: is a large number of
5	non-compliances, very few, a small fraction of them
6	greater than green, okay? Like, when I involved
7	research, all these findings since ROP began, only
8	five percent are greater than green, but we have like
9	70-some odd findings. So, you know, one would say all
10	those green findings that meet the Defense Index and
11	Safety Margin are non-issues. But as a regulator, we
12	can't tell the licensee, hey, you know, we know it's
13	a non-compliance.
14	MR. APOSTOLAKIS: But the green though, is
15	determined using risk arguments?
16	MR. WEERAKKODY: Yes.
17	MR. APOSTOLAKIS: So there is an
18	inconsistency then between the ROP finding, which is
19	based on the risk, and the compliance with Appendix R?
20	MR. WEERAKKODY: Yes, but
21	MR. APOSTOLAKIS: Is that what you're
22	saying?
23	MR. WEERAKKODY: No, I'm what I'm
24	saying is if you go to Appendix R, the compliance
25	expectations are not really aligned with ROP. So the
I	

1	Inspectors go they find issues that are non-
2	compliances, yet not important safety issues.
3	MR. APOSTOLAKIS: That is what they just
4	said?
5	MR. WEERAKKODY: Yes.
6	MR. APOSTOLAKIS: That there is an
7	inconsistency?
8	MR. WEERAKKODY: Yes. Yes, that is
9	correct. But in answer to your question, when a
10	licensee goes to 805
11	MR. APOSTOLAKIS: Maybe you would address
12	that later, but exactly does it mean to transition to
13	a Risk Informed Fire Protection Program? What does it
14	mean? What
15	MR. PARTICIPANT: We will go into that in
16	more detail later.
17	MR. APOSTOLAKIS: Okay, fine. Fine.
18	So Duke is interested in this and Progress
19	Energy, right?
20	MR. WEERAKKODY: Yes.
21	CHAIRMAN ROSEN: What is a tentative
22	Letter of Intent? I'm not clear.
23	MR. WEERAKKODY: It is an intent of some
24	meeting on Federal intent.
25	MR. LAIN: Yes. Yes. I'll move on to

well, let me finish up with Duke. Duke is, due to
expertise availability, they have chosen to overlap
their series and finish up with Catawba in 2009. With
Progress Energy, we have been in some conversations
with Progress, they're planning on coming and briefing
us this afternoon. They have indicated that they'll
send us Letter of Intent by the end of the month.
Their first plant, I think, they plan to transition
is Harris. They have shown interest, I guess, in
transitioning all five of their sites. So we've also
heard through the grapevine there's other sites
evaluating the 805 option, but these two sites have
really indicated that they've that they are
probably going to go.
DR. DENNING: Do all of those units have
existing fire PRAs?
MR. LAIN: Do all sites have?
DR. DENNING: Do all of those units have
fire PRAs?
MR. LAIN: Duke from what I know, Duke
is developing. They're going through a lot of cable
tracing, they're reconstituting their Appendix RR
licensing basis and then developing the fire PRAs.
MR. WEERAKKODY: The Rule does not requir
that they have a fire PRA, but in answer to your

б

1	question, the Oconee does have and we are telling all
2	licensees that if you are adopting 805, you really
3	need a fire PRA to do it right.
4	DR. DENNING: Yeah, I'd like to pursue
5	that just a little bit further because that's the
6	one of the things that has me concerned is the
7	rational by which you would go to Risk Informed
8	Regulation when you don't have a fire PRA for a unit.
9	What's the basis on which you can really determine the
LO	risk significance of changes?
L1	MR. WEERAKKODY: Okay, what the Rule
L2	requires is if for a change, for a change you
L3	Are using risk analysis and all changes do require
L4	some level of risk analysis, you need to have a risk
L5	analysis that can properly capture the scope and
L6	nature of the change. So there is a requirement
L7	there. Now, whether or not the licensee has a fire
L8	PRA is not tied into the Rule itself.
L9	MR. APOSTOLAKIS: Are you saying that, in
20	effect, they would have to have one?
21	MR. WEERAKODY: Yes.
22	MR. APOSTOLAKIS: But the Guide, though
23	and we are going to pursue this a little bit from Page
24	4 says, "transition to an NFPA 805 based fire
25	protection program does not require licensees to use

1	a fire Probabilistic Risk Assessment model; however,
2	without a fire PRA, licensees may not realize the full
3	safety and cost benefits of transitioning to NFPA
4	805." Now, a statement like that is so confusing.
5	You want to have a Risk Informed Fire Protection
6	Program that says it does not require, but you can
7	have benefits. How can you have I mean, it seems
8	like you can't do it at all if you don't have a Fire
9	Protection
10	MR. WEERAKODY: You could transition,
11	George. You could transition to an 805 licensee
12	basis. What you cannot do is, after you transition,
13	when you perform a change, you come to a point where
14	you have to demonstrate that to yourself and to
15	NFPA, if necessary, that the change you're making is
16	not very significant.
17	MR. APOSTOLAKIS: How do you transition
18	I mean, that's my confusion what does it mean to
19	transition?
20	MR. WEERAKKODY: Could we yes, because
21	I think that's most of your questions are going to
22	be answered by 04-02.
23	MR. APOSTOLAKIS: Okay.
24	MR. WEERAKKODY: But in summary, you look
25	at each of your fire areas and you make a

1	determination as to whether you're meeting your
2	current deterministic rules and then you might
3	concentrate in some of those areas under the currently
4	demonstrated requirements for that area, but then in
5	certain other areas, you may decide that you're going
6	to use a performance based method to transition. So
7	really, when you transition, what you're saying to the
8	Agency is that from now on, I am operating under a new
9	set of rules.
10	MR. APOSTOLAKIS: And you said those rules
11	are based is based on risk?
12	MR. WEERAKKODY: Yes.
13	MR. APOSTOLAKIS: But, still, I don't need
14	the risk assessment? I mean that's where the
15	confusion is.
16	MR. LAIN: Well, within 805, there is a
17	parallel there's a deterministic side and a
18	MR. APOSTOLAKIS: Yes.
19	MR. LAIN: So they could fall on the
20	deterministic side of go down the performance based
21	side, selectively as they need as they wanted to
22	make changes. But for economics, it would be it's
23	definitely more economical to have the fire PRA.
24	MR. APOSTOLAKIS: So the two parallel
25	paths, I remember. It's not one or the other? You

can mix?

1

2

3

4

5

6

7

8

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

25

MR. LAIN: You can combine them, yes.

MR. POSTOLAKIS: It's still confusing. I mean, with the Regulatory Guide titled Risk-Informed, Performance-Based that no risk tools may be used for it.

DR. BONACA: It's too confusing.

This is John Hannon, Plant MR. HANNON: Systems Branch. Let me try to help with this because I understand the confounding nature of this and we've talked a lot about it and had a number of discussions with these licensees. And it's true that you can transition to an 805 regime, regulatory scheme, without having a full fire PRA, but at the time -- at the point where, for any one particular fire area, you might want to make a change to that area for cost beneficial reasons -- let's say you want to remove some fire barriers or something. You do need to do at least a mini-PRA for that change. It doesn't -- you don't need a full-blown fire PRA. You can do a limited scope risk assessment just for that change. would be consistent with the 805 Rule. What the staff is trying to suggest, though, is that -- that if you do have a full-fledged fire PRA when you make the transition to 805, it equips you to be able to move

into that regime much more effectively because you have the tools available to you at that point.

So what we've seen so far with these utilities that are expressing the interest here is they are developing a full-fledged fire PRA for their facilities.

DR. BONACA: Yeah, well my main concern about the ambiguity, I mean, whether or not they're needed or not is tied mostly to the -- to an expectation of standards for whatever is being used. I mean, if you say that there is a requirement for risk analysis in the Rule, then we know expectations you have for a solid risk analysis that would support that. If you have no definition of that, you're talking about a mini-PRA or whatever, you know, you have no standards to judge what you're doing I mean, I don't know how a reviewer in the there. staff would be comfortable about approving something

MR. APOSTOLAKIS: Not only that, but it's made explicit in the NEI document, at least, that any changes that are risk informed or risk based will be governed by Regulatory Guide 1.174, which now says that not only do you need the fire PRA, you need the internal event PRA, too, because for the zone to

1

2

3

4

5

6

7

8

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

1 access, it's a total CDF. So how can you do a 2 meaningful PRA and go to the Regulatory Guide? 3 CHAIRMAN ROSEN: I don't know how you do 4 a fire PRA without an internal events PRA, to begin 5 with, but let's drill down for a minute and --MR. APOSTOLAKIS: But the Regulatory Guide 6 7 has explicit requirements. It says the total CDF is on the horizontal line, so if you don't have that --8 9 CHAIRMAN ROSEN: Yes, I understand. 10 MR. APOSTOLAKIS: -- you cannot go there. You can calculate the depth of CDF using a small PRA, 11 12 but for the total, I don't know, unless it doesn't I mean, we have these flat lines there. 13 14 MR. LAIN: But if you envision a typical 15 case, George, where a licensee takes a fire area and says he wants to do a mini-PRA for that fire area, he 16 17 goes into that fire area, he finds equipment and cables, many cables presumably in some fire areas, and 18 19 now you have to ask yourself the question, "To what 20 equipment do these cables go?" and "Where does that 21 equipment show up in the PRA, in what sequences?" 22 so pretty soon, you're into a full PRA anyway. 23 don't know how you can do it without that. 24 So it seems like, although you can say the 25 words, in practice, for implementation, if someone

tried that and tried to present it to a knowledgeable person or group, it wouldn't pass. It might not -- it most likely wouldn't pass unless the area was very simple.

MR. WEERAKKODY: Well, let me try to answer the question a different way. Let me think of 805 plan, you know, a plan that has fully transitioned. What we are saying is if they had an area with, say, ten barrels of oil and they want to bring one more barrel of oil and then place it in that Say, the Turban Building. Now, if you do a area. fire modeling calculation and you show that any of the potential targets cannot be affected because of that Delta chain, with a high degree of certainty, okay? You shouldn't have to have a full fire PRA to say, from a risk assessment, you know, you basically go through the Risk Assessment Methods to say that the risk assessment is negligible. So what we are trying to avoid or what the Rule is trying to avoid was to impose undue requirements like that. But I do agree with the Committee, all of you, that, -- and, in fact, when licensees come for an 805 transition, one of the messages I communicate with them is even though the Rule doesn't require, you cannot -- it's almost difficult -- any substantial changes, you are going to

1

2

3

4

5

6

7

8

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

1	need a fire PRA to support that.
2	MR. APOSTOLAKIS: But the example you gave
3	us, wouldn't that be handled under 5059? I don't need
4	the FPA 805 at all. I mean, I can show that by adding
5	the extra barrel of oil, I don't affect the initiating
6	event frequencies, I don't affect any sequences, go
7	through the list, you know, the 5059 requirements, and
8	then say I don't even have to go to the NRC.
9	MR. WEERAKKODY: The elements that affect
10	the Fire Protection Program, George, 5059, has no
11	rule. It was it is done under a separate program.
12	MR. APOSTOLAKIS: But this seems to me to
13	be an extreme case, and to have such statements just
14	because of these previous situations maybe the
15	statement should be that you should have a fire PRA,
16	but there are some cases where you probably don't need
17	it. That would have been a more appropriate
18	statement.
19	DR. DENNING: Or there could have been the
20	position that it's mandatory that you have a fire PRA
21	before you go into this. I mean, that seems to me the
22	logical thing, and that that fire PRA has to meet
23	certain criteria.
24	MR. APOSTOLAKIS: I mean a Risk Informed
25	Performance Base without a PRA is kind of and

1	what's worse, since we're at it, it says there two or
2	three times in the NEI document quantitative
3	evaluations can be a more complex qualitative
4	evaluation. What does that mean? Maybe we're jumping
5	ahead, but it will be there, even later. So it's
6	on Page 46, Footnote 10, "The quantitative evaluation
7	can be a more detailed qualitative evaluation." What
8	on earth does that mean? It's a general attitude
9	we've seen in the past, too, stay away from numbers as
10	much as you can, you know. And I don't like that.
11	And then that's repeated later. I don't remember
12	where.
13	MR. LAIN: Anyway
14	MR. APOSTOLAKIS: Why don't we come out
15	and say, "If you want a Risk Informed System, you have
16	to have risk information." I mean, that stands to
17	reason. It's very simple. It's too simply.
18	DR. WALLIS: It's not only reasonable;
19	it's very logical.
20	MR. APOSTOLAKIS: Maybe that's the problem
21	with it. Okay, why don't we go on
22	DR. WALLIS: It's not his fault, but
23	could I ask a question?
24	CHAIRMAN ROSEN: Graham, a question?
25	DR. WALLIS: You've told us a bit about

1	what this is. Now, why is this industry interested?
2	Is it because they don't comply with the Regulations
3	now, but they could if they used this Guide, or are
4	they interested because they want to make significant
5	changes in the Plan?
6	MR. WEERAKKODY: I'll be speculating, Dr.
7	Wallis, if I what I know is that most of the the
8	two utilities that have come forward are confronted
9	with a number of non-compliances.
10	DR. WALLIS: And they want to comply by
11	doing it a different way, I guess.
12	MR. WEERAKKODY: Yes, exactly.
13	CHAIRMAN ROSEN: Non-compliances, don't
14	they that they agree are non-compliances, but they
15	think are not risk significant?
16	MR. WEERAKKODY: Exactly. Not only them,
17	we also know that.
18	CHAIRMAN ROSEN: And you agree they are
19	not risk significant?
20	MR. WEERAKKODY: Yes.
21	DR. WALLIS: And you've essentially
22	allowed these non-compliances, so nothing significant
23	would change except they will now sort of come under
24	the umbrella of the law if they go with this new
25	method.

1	MR. WEERAKKODY: Yes.
2	DR. WALLIS: So that's a very different
3	thing from are they going to make significant changes
4	in the PRA. If they are going to make significant
5	changes in the PRA, you might be a little weary of
6	that.
7	MR. WEERAKKODY: I've heard that concern.
8	One of the things that's not common knowledge, but is
9	that even the licensees who adopt 805 have to meet the
10	5048(a). Okay, that doesn't go away. And what 5048(a)
11	refers to is the old general design criteria 53. So
12	just because a licensee adopts 805, they can't go
13	report the suppression systems, you know, there are
14	measures against that. But where they can benefit is
15	where they have non-compliances you know, in fire
16	protection you find a lot of situations where when
17	they build the plans, things are not exactly according
18	to some quota out there. So you have a lot of stuff
19	out there which are non-compliance. Now, that kind of
20	stuff would go away.
21	CHAIRMAN ROSEN: Perhaps we should
22	continue.
23	MR. WEERAKKODY: Yes.
24	MR. LAIN: Well, I've included this extra
25	information here. It doesn't we're not talking

necessarily about the Reg. Guide, but we're talking
about something our group is working with that I
thought the Subcommittee might be interested in and
that is what we are doing with NFPA. Shortly after
805 was issued, DSSA requested NFPA to start working
on developing a Risk-Informed, Performance-Based
Standard for advanced reactors. 804 was the current
deterministic standard for advanced reactors and 805
was limited to existing light-water reactors. So we
noted the gap there and we requested NFPA to
MR. APOSTOLAKIS: Now, advanced reactors
are Gen 4, Generation 4?
MR. LAIN: Yes.
MR. APOSTOLAKIS: Now, these are still
trying to prove feasibility, selecting materials, and
so on, and it seems to me that for a fire PRA, you
really need some idea of how the plant will be laid
out.
MR. LAIN: Well, I think what we're also
talking about could have been used for the AP 1000 and
could have been used for the
MR. APOSTOLAKIS: Gen 3?
MR. LAIN: Yes, the ESBWR.
CHAIRMAN ROSEN: So let me be clear. This
is for AP 1000, the slide we're looking at now?

б

1	MR. LAIN: Well, AP 1000 has already been
2	reviewed to 804.
3	CHAIRMAN ROSEN: Okay. So it's not for AP
4	1000?
5	MR. LAIN: Right. It could have been used
6	if
7	CHAIRMAN ROSEN: If it were available?
8	MR. LAIN: if it was available. So the
9	Technical Committee is wrestling with that. Is it
10	the, you know, the revolutionary plants versus the
11	evolutionary plants. We're trying to, I think,
12	MR. APOSTOLAKIS: I think if somebody
13	decides to build an AP 1000, there is nothing to stop
14	them from using 805. Is there?
15	MR. LAIN: Except
16	MR. APOSTOLAKIS: It is a light-water
17	reactor.
18	MR. LAIN: Yes, except it's part of the
19	Applicability Statement within it. It says "existing"
20	light-water reactors. So it would, you know, it would
21	have to be right now, we're taking it on a case-by-
22	case basis. And so, you know, the NRC would have to
23	review what they did and decide whether it would be
24	applicable to use it.
25	CHAIRMAN ROSEN: Is there some technical

1	issue you know about now for AP 1000 and other
2	MR. APOSTOLAKIS: ESBWR.
3	CHAIRMAN ROSEN: ESBWR, any other light
4	water reactor that's existing?
5	MR. LAIN: No, but what we're doing with
6	that standard is we are raising the bar. The
7	Commission, at some point, said, you know, with the
8	new reactors, with new built, we shouldn't allow
9	twenty-foot separations. So in the Nuclear Safety of
10	Safe Shut-down Systems, we've raised the bar and
11	eliminated the twenty-foot separation between cables
12	with no limits.
13	CHAIRMAN ROSEN: So there is some
14	technical issue
15	MR. APOSTOLAKIS: We shouldn't allow it.
16	We should not require it.
17	MR. LAIN: We I think it's it should
18	not allow it.
19	CHAIRMAN ROSEN: Right now, a twenty-foot
20	separation is enough to separate two redundant plants?
21	MR. LAIN: Two redundant, yes.
22	CHAIRMAN ROSEN: And what you're saying is
23	it won't be enough in huge plants?
24	MR. LAIN: Right.
25	CHAIRMAN ROSEN: Just pure separation of
I	I

that amount wouldn't be adequate?

1

2

3

4

5

6

7

8

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

25

MR. LAIN: Yes. So this gives a short We've -- the Technical Committee for Nuclear Facilities established subcommittees last summer and a rough draft has been assembled this past And we'll see. We'll continue to work on this draft and it will be issued for public comments next May and comments will be reviewed and, hopefully, we'll have something in 2008. And NRR also needs it. We need to start working on a plan on how we're going implement this standard, but to new don't necessarily have anything in the works right now to look at, you know, are we going to do rule-making or just still use it on a case-by-case basis. That is something our group needs to look at. We'll put it on our list of things -- items to work on in the future.

CHAIRMAN ROSEN: Okay, are you finished?

I guess that's your last slide.

MR. LAIN: Yes, I'm done and I'll hand it over to Mr. Radlinski here.

MR. RADLINSKI: Okay. My name is Bob
Radlinski. I'm a licensed Fire Protection Engineer
working in Sunil's group and I'm going to talk about
the Regulatory Guide for the NFPA Fire Protection
Program.

The Reg. Guide has two basic purposes. One, of course, is to provide specific guidance that is acceptable to the NRC for the implementation of a Risk-Informed, Performance-Based Fire Protection The other is to provide licensees with a the potential basis for assessing impact transitioning to an 805 program so they can adequately assess whether they want to make the transition or not.

To achieve those purposes, Number One, the Reg. Guide endorses two industry guidance documents. The first is NEI 04-02, which provides -- it's about a 200-page document that provides rather detailed guidance on the implementation of an 805 program. other is NEI 00-01, which provides guidance for doing post-fire safe shutdown circuit analysis. Guide avoids repeating the information that's in these quidance documents, but we do include emphasis in the area that we consider E-guidance issues. It addresses exceptions to NEI 04-02 and there may not be any at the rate we're going. We're getting pretty close to reaching full agreement. One that has to remain as a -- there is a section in NEI 04-02 on the use of Performance- Based methods for plants that do not transition to 805 and that is not something that we're

1

2

3

4

5

6

7

8

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

1 addressing. It's not addressed in the Reg. Guide. 2 It's not addressed in the Rules. So that's sort of an administrative exception, but other than that we're 3 4 pretty close to a hundred percent agreement on the 5 interpretation of this. CHAIRMAN ROSEN: Well why would -- why 6 7 would NEI leave it in there if you've decided not to 8 allow that? 9 MR. RADLINSKI: Well, it's not that we 10 don't allow it. It's an acceptable use of the 11 methods. A licensee can choose not to transition, making full transition to an 805 license basis, but 12 yet, they can use methods. But they would have to use 13 them as the basis for an exemption request. 14 15 Oh, I see. CHAIRMAN ROSEN: Their License Amendment 16 MR. RADLINSKI: 17 Request. They couldn't just use it without any type of -- without going through NRC approval. 18 It also provides high-level guidance on 19 20 the License Amendment Requests, the transition from 21 the current license basis to an 805 license basis, 22 enforcement discretion and quidance on 23 documentation that the licensee must have, both during 24 the transition and post-transition for maintaining

this program.

It identifies suggested fire models that can be used and also provides high-level guidance on fire PRAs. There was, I believe, a presentation earlier this month on both fire models and the PRAs.

And lastly, it describes the staff position on 805, the 805 Appendices, which 805 does not necessarily endorse nor does the Rule endorse, however, there is useful information, useful guidance in the Appendices, so we include that -- some guidance in the Reg. Guide as to which aspects of those Appendices we consider to be acceptable.

DR. DENNING: Could I address the next to the last bullet there? "Clarifies acceptable fire models and fire PRAs." When we heard earlier this month, I guess, the status of some RES activities, it certainly looked like, as far fire concerned, that the work that's ongoing is very important that the current state of fire models -fire PRA -- I'm sorry -- is certainly not at the level of Level One PRA internal events. And as we look at fire models and the V&V of those fire models, there's lot of work still required towards determining acceptable -- what's acceptable for V&V are those models. And I have grave concerns about what the standards are for V&V fire models. I have concern

1

2

3

4

5

6

7

8

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

that we'll go through certain validation exercises and even though the uncertainties are extremely large, they will now be recognized in the validation and will bless a certain model and say, "It's now V&V." the applicant -- not the applicant, but the utility has the ability to use a V&V model without a lot of regulatory oversight, as I see it, as to whether they're truly recognizing the very broad uncertainties that exist in those models. So the question is how do we go forward with the Regulatory Guide at this point when the state-of-the-art is limited and why wouldn't we wait two years or whatever is required to -- for the state-of-the-art to catch up? Because I think that the current state of V&V of the models in here is inadequate. So that's my question.

MR. WEERAKODY: I'll take that. Dr.

Denning, I saw the preliminary wording of the same document. Now I'm speaking about the fire models where the office of Research as we read four of the five, completed four of the five fire models and provided answers on a number of key parameters on the five models. I walked away with a totally different conclusion than -- from the same data. And I'll tell you why. I think the information that Research has put together is sufficient for us to not just do risk

1

2

3

4

5

6

7

8

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

assessment, but a good grip on the uncertainties and
safety margins. And if you bear with me for this long
answer, let me bring a separate example from a
different agency that I was in charge of heavy loads.
Okay, you have cranes that are good for a hundred tons
and sometimes we'd get questions from licensee because
they have to lift loads higher than a hundred, a
hundred ten tons. Consequently, I talked to my, you
know, guy who's responsible and I said, "How much
safety factors are there?" He said, "Oh, five, ten."
So, in other words, my point is to put things in
context, no matter what data you go to, you find those
same kinds of uncertainties. So, to me, when I see
the V&V documents, not only do I know I have these
five models, but I know my range of uncertainty. And
I believe, in some of those models, with some
parameters, if the answer is one, they would say it
may be as high as ten. And in a number of other
things like C-fast (phonetic), the answer is one, then
range could be .9 to .7. Now, the reason I am very
optimistic about those things is if you look at how
plants have been in an 805, not only do they have to
meet CDF, they have to meet something called the
Safety Margin. And if you read the verbiage in Reg.
Guide 1.174 for Safety Margin, one of the things that

they mention is calculation of uncertainty. is -- I'm sort of thinking ahead into the Inspection So if I tell an Inspector, "Look, has that area now. licensee properly used the models?" the first question the Inspector would ask is, "Did you or NRC do a V&V of this model?" And if the Inspector is doing that evaluation of the safety margin, I have the perfect Research has provided me the perfect tool to make an assessment on that because my other counter point in terms of waiting is that as with any other highly complex areas, we will never be there to that level of perfection, but I think right now we have enough of a perfect tool to move forward. -- I know it was a long answer, but I think this is something that I have been struggling with. know whether --

MR. HANNON: This is John Hannon again.

Let me just supplement what you said, Sunil, because I don't -- I don't want anyone to get the impression that we don't have any Regulatory Oversight here. We will, and you'll hear more about that later when Rich Dipert talks about our Inspection Program. As Sunil mentioned, we are going to be looking at the use of these fire models during our Inspection Program, so it's not like the licensees are out operating without

1

2

3

4

5

6

7

8

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

any oversight at all. And we will have the opportunity to come in and check what they're doing and make sure it's reasonable. So there is Regulatory Oversight being provided in the program. We'll hear more about that later when Rich talks.

MR. RADLINSKI: The next few slides are going to talk about is some of the key issues and the basis for an issue. A key issue is that we weren't necessarily in alignment with NEI on these issues and we discussed them and we have now come to agreement for the most part.

The first one is what constitutes NRC approval to get existing program elements. The Reg. Guide identifies two types of documentation that we clearly represent or constitute NRC approval, one of which, of course, is SER and the other would be approved Exemption Requests and Deviation Requests. It also identifies a couple of types of documentation that we do not consider to constitute NRC approval, and those are the Inspection Reports and Meeting Minutes.

The 04-02 document lists a number of other documents that they consider to constitute NRC approval and we're taking the position that those need to be addressed or evaluated on a case-by-case basis

1 before we can say that they are actually basis for NRC 2 We continue to work with OGC on this and increase the list of documents 3 4 considered from concept through approval. 5 CHAIRMAN ROSEN: And this is important because licensees have relied on those kinds of 6 7 documents that exist on their dockets for making decisions in their current fire protection programs? 8 9 MR. RADLINSKI: That is correct. And some 10 consider their fire protection design documents as being the basis for -- their license 11 12 basis and that they don't require NRC approval, that they have essentially been accepted as the basis for 13 14 their design. 15 I would also like to point out that if we aren't able to achieve a hundred percent alignment 16 17 with NEI on this issue, that we expect that during the Pilot Programs we'll be able to identify other samples 18 19 or types of documentation that we would consider to be That will be addressed in a future 20 acceptable. 21 addition or revision to the Reg. Guide. 22 Well, I'm just thinking, CHAIRMAN ROSEN: 23 wondering how a licensee could think that a document 24 is acceptable to you if you haven't reviewed it.

instance, an internal document of any kind, whatever

its position in the document hierarchy. It seems obvious, but that is not always the case.

MR. RADLINSKI: The other issue is how to address plant changes and, when I say "plant changes," that includes both modifications of the plant -- and that obviously is the changes -- but also identify deviations, a licensee or an Inspector, identify something that deviates from Regulatory requirements. It can either be corrected, of course, by the licensee or it can be addressed as part of a plant change evaluation using their procedure.

high-level The Guide provides Req. screening of changes that we would on consider not to be really plant changes that don't be addressed need to as a plant change, inconsequential changes that have no impact on the Fire Protection Program. We're still working with NEI They have some examples in their on this issue. They have some criteria. We are not in documents. full alignment for either of those, but we hope to be before we issue our respective documents.

DR. DENNING: Excuse me. Can we get a little more specific about Delta CDFs and Delta LERFs and all that kind of stuff that are in Section 5 of the NEI 04-02 and what your position is on those? I

1

2

3

4

5

6

7

8

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

noticed that on Page 52, they talk about the ability
to make changes that are fire related, but without a
fire PRA. And then there are Delta CDFs and Delta
LERFs that are discussed there. It isn't clear to me
how you make that how you really know that you can
allow a positive increase in CDF if it's an internal
events. I mean, I'm interpreting it based on this as
being because they didn't have a fire PRA, that their
Delta CDF is an internal events change. And I agree,
it's small, but I have no idea how the what the
implications are to the true overall CDF. I'm talking
right now in that second paragraph on Page 52. It
says
MR. WEERAKKODY: The paragraph that starts
with "The PRA CDF"?
DR. DENNING: Yeah, yeah, that's right.
MR. RADLINSKI: Well, first of all, let me
just say high level. When you're in to this level
of evaluation, you're into the plant change process.
DR. DENNING: Yes.
MR. RADLINSKI: This is not something that
we screen out as not being a change and doesn't have
to be evaluated. So if you're looking at CDF, you're
in the plant change process.
DR. DENNING: Yes.

б

1 MR. RADLINSKI: CDF is not a basis for 2 screening anything out of the process. 3 DR. DENNING: Right, but you're -- but you 4 would allow, without review by the staff, 5 understand here, they could then make an assessment that they could make a plant change, right? 6 7 MR. RADLINSKI: Correct. It has fire implications and 8 DR. DENNING: 9 there are some criteria here that relate to, it looks 10 to me like, internal events PRA changes, and without specifically looking at what the Delta CDF is, as it 11 12 relates to fire, they could make a change that increases risk. I don't quite understand what the 13 14 rationale is by which we would allow that. 15 MR. WEERAKKODY: The question is how can 16 you say something is related and then if ten to the 17 minus seven --Well, they're saying --18 CHAIRMAN ROSEN: 19 MR. WEERAKKODY: -- they are not going to 20 ten to the minus seven unless we have done a 21 quantification. 22 Yeah. Well, it sounds to CHAIRMAN ROSEN: 23 me like the only basis they have for saying it is less 24 than ten to the minus seven is that the impact of that 25 change on internal events is less than ten to the

1	minus seven. But that doesn't give me any
2	understanding of what it is with regards to total
3	risk, which would include the fire risks. And these
4	are fire risk related changes.
5	MR. APOSTOLAKIS: I think we have answered
6	it, so can we proceed with the presentation?
7	CHAIRMAN ROSEN: You can proceed with the
8	presentation.
9	DR. DENING: The ten to the minus seven
LO	for Delta CDF, if you look at Figure 5-2 on the
L1	preceding page, is even lower than what the staff
L2	approved for Region 3. Right? It is an order of
L3	magnitude lower? So maybe somebody thought that if
L4	you have such a low Delta CDF, it doesn't really
L5	matter what the CDF is. And that was their
L6	supplemental, Regulatory Guide 1.174.
L7	CHAIRMAN ROSEN: They're saying you could
L8	add fire risk if you're very, very low. You can add
L9	some fire risk without knowing how much.
20	MR. APOSTOLAKIS: Without knowing how
21	much?
22	CHAIRMAN ROSEN: Well, it looks like
23	DR. DENNING: You don't have a fire PRA.
24	CHAIRMAN ROSEN: if you don't have a
25	fire PRA, the way you would assess it, presumably, is
I	I and the second

just on the basis of a change in internal events, but that may not be the case. I think it -- there is a lot of interpretation.

MR. APOSTOLAKIS: No, it's not on the basis of internal events; it's on the basis of, you know, this limited PRA. You are doing a fire related small PRA and, you know, if everything else drops out, then you are calculating a Delta CDF. You don't need the specific PRA to do that. I mean, you don't need the whole plant PRA because the common elements drop out when you go to the Delta.

CHAIRMAN ROSEN: But if you read that paragraph, George, the last sentence says, "If an existing fire PRA or IPEEE is available, it should be used to obtain a Fire Induced CDF and level of contribution for the plant." Implying that there is no quantification.

MR. APOSTOLAKIS: So how do they get the ten to the minus seven? No, you're -- I think it comes back to your comment about the small, you know, you're changing, say, -- let's say you are removing a fire barrier between two divisions. Okay? And you're doing the calculations there, by how much would the frequency of fire, common cause fire, go up by the removal of that thing. Okay? And then you manage to

go all the way to core damage frequency from there.

You see, the Delta CDF is this. But I don't know what
the total CDF is. I can do a sequence calculation,
but I'm not doing the full plant. So I can calculate
Delta CDF, but the point is by then they are putting
an uncertainty requirement that it should be even
lower than what the staff allows for the Region 3.

Right? That's what they are doing.

And the next question is, I mean, we keep
talking about all those huge uncertainties we have,

And the next question is, I mean, we keep talking about all those huge uncertainties we have, can you really trust the number that is ten to the minus seven in this field?

I don't know what it means, but again, this general philosophy of trying to do things without the necessary infrastructure, where your PRA or -- it's really very disturbing after awhile. I mean, I can see how one can stretch things and do things, but to call this a Risk-Informed, Performance-Based approach and then say if you have a fire PRA, wow! So what kind of a Risk-Informed, Performance-Based approach is this? And how many -- I mean, all these plants that you mentioned earlier that may submit a Letter of Intent to do this, do they have fire PRAs?

MR. APOSTOLAKIS: Yes, what you mentioned

The plants that are?

MR. WEERAKKODY:

	43
1	earlier.
2	CHAIRMAN ROSEN: The Progress Energy
3	Plants.
4	MR. WEERAKKODY: Yes, they
5	MR. APOSTOLAKIS: What do they do?
6	MR. WEERAKKODY: Yes, this is from
7	MR. MARION: Alex Marion, NEI. If I might
8	respond to that question. The two utilities that have
9	announced tentatively or permanently their intentions
10	to make the transition plan to develop a fire PRA.
11	MR. APOSTOLAKIS: But they must have done
12	an IPEEE.
13	MR. MARION: Yes, as a minimum. And we'd
14	recommend
15	MR. APOSTOLAKIS: So you will update those
16	studies
17	MR. MARION: Yes. We'd recommend it to
18	utilities that if they're going to move forward with
19	this transition that a fire PRA is practically
20	mandatory because you can't do the quantification
21	without it.
22	MR. APOSTOLAKIS: But again, listen to
23	what this says. " if an existing fire PRA or IPEEE
24	is available" We have all agreed for a long time
25	the IPEEE is not good enough.

1 MR. WEERAKKODY: Yeah, Page 12 of the Reg. 2 Guide specifically refers to IPEEE. So evidently, the 3 whole --4 MR. APOSTOLAKIS: I mean, as a matter of 5 fact, I mean, they will have to do a fire PRA because otherwise you can't communicate with the stuff. 6 7 this idea of -- no, you don't put it on paper. do all this without the risk assessment. I don't know 8 9 why we have to fight this all the time. 10 gives a false impression that the fire PRA and the 11 IPEEE are equivalent because it says if one or the 12 other is available. Maybe we can extrapolate and you can do localities 13 14 without similar hydraulic models. 15 MR. WEERAKKODY: We got the message. 16 I think, as you've heard, we got the message, but 17 there are a couple of other things there that bear in here. As you know, the Req. Guide can't go out of the 18 19 envelope of the Rule itself. It couldn't use a Reg. 20 Guide for refinements. So it -- as Alex Marion said, 21 and we have said in every public forum that it doesn't 22 make sense to go to an 805 without a fire PRA. 23 MR. APOSTOLAKIS: Okay, you are in a very 24 awkward position. You cannot impose new requirements, 25 On the other hand, you cannot really that is true.

1	put statements together that are not true. And we all
2	know that the fire PRA and the IPEEE are not the same
3	thing.
4	CHAIRMAN ROSEN: No, if it is conveying
5	that, we agree it is not.
6	MR. APOSTOLAKIS: Well, if an existing
7	fire PRA or the IPEEE is available, it should be used
8	to obtain
9	CHAIRMAN ROSEN: Remember, these are not
10	the staff's words, but you are endorsing them.
11	MR. WEERAKKODY: Oh, yes, yes. We are
12	endorsing it, so we are not saying it is NEI and then
13	no.
14	DR. BONACA: I mean if you are
15	MR. APOSTOLAKIS: If you adopt this,
16	that's it.
17	DR. BONACA: The Reg. Guide is a regular,
18	you know, it's NRC and is specifically here on Page 4,
19	refers to IPEEE.
20	CHAIRMAN ROSEN: It does.
21	MR. APOSTOLAKIS: Let me ask what
22	endorsement means. Suppose I'm a licensee. And I'm
23	doing my thing and then I come to you with an IPEEE.
24	Okay, and I request whatever change. And you come
25	back and you say, "Well, gee, your IPEEE needs to be

1 updated and all that. " And I say, "No, no, it 2 doesn't." It says, "... if an existing fire PRA or 3 IPEEE is available..." You have to accept --4 MR. WEERAKKODY: They couldn't do that. 5 They couldn't do that. 6 MR. APOSTOLAKIS: Why not? 7 MR. WEERAKKODY: That's because --8 MR. APOSTOLAKIS: That's what it says 9 here. 10 MR. WEERAKKODY: The Rule requirement --DR. GALLUCCI: This is Ray Gallucci from 11 12 Sunil's staff. That statement does not say that the fire -- that an existing IPEEE or even an existing 13 14 fire PRA is adequate. All that statement is implying 15 is that you use that as a building block for the next You could take the information that's in there. 16 17 It doesn't say that you can just take an internal events calculation and superimpose a couple of fire 18 19 frequencies on it and use that. Although that tends 20 to be conservative, it's not always conservative 21 because the internal events does not necessarily 22 credit some of the systems; it may not include some of 23 the multiple spurious actuations. So I think that 24 statement -- maybe it's not clear enough, but

doesn't say that you use the fire IPEEE or even an

existing fire PSA as a substitute. You use that as a 1 2 starting point. 3 MR. APOSTOLAKIS: Well, it doesn't say it 4 explicitly. 5 DR. GALLUCCI: No, it doesn't, but that's the implication. 6 7 MR. APOSTOLAKIS: Well, your endorsement says clearly though, "The transition to an NFPA 805 8 9 based IPEEE does not require licensees to use a fire 10 probabilistic risk assessment model. However, without 11 the fire PRA, licensees may not realize the full 12 safety and first benefits of transitioning to NFPA So it is a matter of benefits. This is a 13 14 loaded statement actually, isn't it? 15 CHAIRMAN ROSEN: Well, I think it sends 16 the message. Was that its intent? To send a message 17 to the industry that without a fire PRA, you may not achieve the full benefits, which is to say the staff 18 19 may be less than over-awed by your lack -- by your 20 presentation. 21 MR. WEERAKKODY: Yes, it is intended to 22 send a message because we recognize that the Rule 23 necessarily doesn't require a fire PRA. But we want 24 the plants to know without that, any time they want to 25 make a significant change -- I'm not talking about

	50
1	bringing a barrel of oil and adding two hundred
2	barrels, but anything more progressive than that, the
3	staff and the licensee couldn't come to an agreement
4	on the risk there without a fire PRA. So you are
5	correct, Steve.
6	CHAIRMAN ROSEN: I think we've beaten that
7	one to death.
8	MR. WEERAKKODY: Yes. Can I say one
9	thing, please? I was looking for the applicable
10	Section 805 Rule. One of the things and I was
11	looking for the paragraph here reads says, "The
12	risk assessment should be based on the as-built
13	plant." In other words
14	CHAIRMAN ROSEN: Where does it say that?
15	MR. WEERAKKODY: I have to find it and
16	point to the paragraph. The Rule itself I point to
17	this as the Rule because the Rule in this 805 there
18	is language here that tells practically you can't pull
19	out a IPEEE or likely to pull it and use that as the
20	basis for a good risk calculation. I'll find the
21	exact words and point to it.
22	MR. APOSTOLAKIS: But this ten to the
23	minus seven, I mean, it's thrown out there without any
24	warning. I mean, you really have to look at the go

back to the figure and realize that it's an inordinate

amount lower than the Regulatory Guides limit. Why? Why such a silent thing? And then for LERF, it's the same thing. If you compare it with 5-3, Figure 5-3, the implication here, which may be true, is that if you are so low, if your CDF is so low, it really doesn't matter what your CDF is. I tend to agree with that. It really doesn't. You can be anywhere you want on the horizontal axis. The question is, of course, how credible is the ten to the minus seven we calculated, but that's a separate question.

MR. WEERAKKODY: Yes, very quick add to what I said, lowering the number -- one number magnitude below what's in the 1.174, you know, when you do a change evaluation, you are looking at one change. So obviously, anyone has a concern, okay, you know, if it's a one circuit issue, you know, you've got to hold individual issues to a higher threshold than if cumulative. But if you want to -- because I know you work with NEI.

DR. GALLUCCI: Well, remember that the risk number by itself is not -- is necessary, but not sufficient for a plant change. There is also the defense-in-depth and safety margin and if one wants to think of those in quantitative terms, essentially you're talking about the uncertainty which can serve

1	as the surrogate for the defense-in-depth and safety
2	margin. So if you're going to make a plant change and
3	you crunch out a ten at the minus seven, you also need
4	to satisfy the Reg. Guide 1.174 Defense-in-Depth and
5	Safety Margin, which, to me, implies that if you were
6	to do a purely quantitatively, you would have already
7	calculated that the uncertainty on that ten to the
8	minus seven is going to be small enough or tiny enough
9	that you feel that you're and certainly below ten
10	to the minus six, even with a reasonable uncertainty.
11	So, again, the plant change process, you always have
12	to go through that step that says Defense-in-Depth and
13	Safety Margin. The risk number by itself is
14	necessary, but not sufficient.
15	MR. APOSTOLAKIS: Well, I can't imagine
16	that a calculation that shows that you have a Delta
17	CDF of ten to the minus seven will be rejected on the
18	basis of safety margins. I mean, ten to a minus seven
19	is ten to a minus seven.
20	MR. WEERAKKODY: I if I
21	MR. APOSTOLAKIS: By the way, there is an
22	excellent discussion of safety margins in this. That
23	was very good. There are some good elements in this.
24	MR. WEERAKKODY: George, I and I have
25	a slightly different opinion there because I think

the DID is there, and especially with things like the fire models where, like, Dr. Denning pointed out, things are not perfect; we have a lot of uncertainties, so obviously if somebody came in in the minus seven, we would look at differences.

MR. APOSTOLAKIS: I know you would, but I'm saying the chances are that the Defense-in-Depth and Safety Margins have not been affected significantly.

MR. WEERAKKODY: Oh, yes. Yes, we agree.

MR. APOSTOLAKIS: Because, my God, the ten to the minus seven is so low, so low. It's like your extra barrel of oil, you know.

MR. WEERAKKODY: Yes.

MR. APOSTOLAKIS: But I guess, you know, you can argue about some serious points here, but what really bothers me is this constant -- the attitude that, you know, you really don't need to do much; you can use this; don't worry about the underlining thing, and I don't understand that. When everybody included in this just says that, in practice, yeah, you would have to have the fire PRA, so why then write it this way? To satisfy whom? Who is scared so much -- I mean, if they don't want to do it, don't do it. But to say this is a Risk-Informed approach and then have

1	statements, " if a fire PRA is available" so
2	what kind of a Risk-Informed approach is this?
3	MR. WEERAKKODY: We look at both I
4	understand where you're coming from. We look at both,
5	I think. First off, Section 2.433
6	MR. APOSTOLAKIS: Of what?
7	MR. WEERAKKODY: This is you were
8	asking how or why a licensee can
9	MR. APOSTOLAKIS: 2.2 of what?
10	MR. WEERAKKODY: This
11	MR. PARTICIPANT: The NFPA Reg.
12	MR. APOSTOLAKIS: The NFPA.
13	MR. WEERAKKODY: And what it says is, with
14	respect to the PSA approach let me just read, "The
15	PSA approach methods and data shall be acceptable to
16	the 8J.
17	MR. APOSTOLAKIS: 2.2-what?
18	MR. WEERAKKODY: It is Page 805-11,
19	Section 2.433.
20	CHAIRMAN ROSEN: You don't have 805, do
21	you?
22	MR. WEERAKKODY: Oh
23	MR. PARTICIPANT: This is an 805.
24	MR. APOSTOLAKIS: Oh, 805?
25	MR. WEERAKKODY: Yeah because that you

1	have words there under Section 2.433 that tells you
2	that you can't you know, what you model in your PSA
3	has to be what's in that plant. So that's the Rule
4	and that overrides anything that the Reg. Guide or
5	anything I have.
6	MR. APOSTOLAKIS: See, I asked the
7	question earlier. Maybe we will talk about it later
8	what exactly does it mean to transition to 805?
9	CHAIRMAN ROSEN: Well, we're going to
10	we're going to get to that.
11	MR. APOSTOLAKIS: Some other time?
12	CHAIRMAN ROSEN: Yes, we're going to talk
13	about that.
14	MR. APOSTOLAKIS: Okay. So let's discuss
15	then
16	MR. RADLINSKI: Right after the break, I
17	think, we're going to talk about that.
18	MR. APOSTOLAKIS: Okay. So why don't you
19	go ahead then?
20	MR. RADLINSKI: Okay. Alright, we're on
21	the second bullet with respect to plant changes again.
22	The Reg. Guide also emphasizes the need to perform the
23	integrated assessment of risk, Defense-in-Depth and
24	Safety Margin for all Fire Protection Program changes.
25	Okay. The key issue there or question was with

regards to whether or not a risk assessment or risk evaluation had to be done for all types of changes. There's a little bit of grayness in the way it's written in 805, but the position that the NRC is taking is that this is a Risk-Informed Fire Protection Program, so any changes to it must be evaluated for the impact on overall risk. We emphasize that.

The Reg. Guide also endorses NEI 04-02 guidance with respect to the various methods of evaluating changes, which include the deterministic approach, the fire model, risk assessment, and any combination of these to evaluate changes.

Another key issue, of course, is circuit analyses. As I noted earlier, the Req. Guide endorses NEI 00-01, which is the industry guidance document for performing post-fire safe shutdown circuit analyses. It also -- the Reg. Guide also advocates addressing spurious actuations using a Risk-Informed Performance-Based approach. And it emphasizes that Information Notice 92-18 type failures should be considered. Those failure -- fire-induced failures are protective circuits of motor operated valves to the extent that the valve can be over-torqued and you could damage the valve and then it would not be functional after the fire.

1

2

3

4

5

6

7

8

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

1 Finally, it provides guidance for addressing the cumulative effects of changes, plant 2 3 changes involving circuits. 4 CHAIRMAN ROSEN: See, when you use the 5 word "advocates," in the second bullet, I'm puzzled. Because I would have expected you to say "requires 6 7 addressing spurious actuation." Why is it that when 8 a licensee comes in and wants to make a change, and 9 says that it's going to be Risk-Informed, that he 10 wouldn't use the most modern way of looking at things which is available, rather than not consider spurious 11 12 actuations? All you say is, "We think you ought to do that." 13 14 MR. WEERAKKODY: Okay. That's -- do you 15 want to answer that? MR. RADLINSKI: No, that's a policy issue. 16 17 MR. WEERAKKODY: In fact, this is intentional, the use of the word, "advocate" rather 18 19 than "requires." If you look at the two areas which 20 has main fire protection legacy confusing, and those 21 two are circuits and the associated manual actions, 22 okay? 23 CHAIRMAN ROSEN: Right. 24 MR. WEERAKKODY: If you go to the manual 25 action rulemaking, the Agency has -- the whole Agency,

including OGC, we have taken a common stock position
which says, "III.G.2 manual actions not allowed
without prior staff approval." and the Commission
agreed. So it's very clear what the expectations
there are and we use the word "require" there. So if
a plant transitions from, you know, the licensing
basis to 805, you basically say, "Hey, those things
are non-compliances and, therefore, if you want to
come back into compliance, you are required to do
this. The word "advocate" for circuit, is if you look
at a circuit area and I don't want to go to a whole
history of the circuit plan, but one of the drivers
there is the confusions, the multiple interpretations,
of the circuit issues. You know, how many what
should you populate? We have approved License
Amendments that said only one, but now we have data
that says, "No, more than one," and those need to be
addressed. But, Steve, I think we are in a sort of a
state of flux there, legally speaking. Again, we are
in the realm where legally we are in a volatile area,
but we know that if a licensee wants to go to a
regulatory stability, they should look at things from
a Risk-Informed manner, using the current data.
CHAIRMAN ROSEN: I'll come back to
George's point then. If the licensee doesn't want to

1 do this thing, then he doesn't have to. 2 But if he does want to do it, then you voluntary. should -- it seems to me you should require the 3 4 consideration of spurious actuation. I'm not just 5 jawboning. 6 MR. WEERAKKODY: Okay. What we -- we have 7 something this is tied to. We have a generic letter 8 in the works that would do that. Okay. What we can do 9 is we can preempt the intentions of the generic letter 10 where we would tell the licensees, look, it's true that we have approved the single spurious in the past, 11 but we have new data that says multiple can happen 12 and, therefore, you should consider and address that. 13 14 So that is in the works. 15 CHAIRMAN ROSEN: That's in a new generic letter coming out? 16 17 MR. WEERAKKODY: Yes. Yes, sir. 18 CHAIRMAN ROSEN: So that would change this 19 "advocates" to "requires" once that is --20 Yes, now if that generic MR. WEERAKKODY: 21 letter was issued, then I would say I am more inclined 22 to use the word "requires." I think -- but I think, 23 you know, for your information, like, for example, 24 Oconee, if you look at the Oconee's Letter of Intent, 25 they specifically say in their Letter of Intent that

1	they are going to use risk-informed multiple spurious
2	as their new licensing basis. And Progress Energy, I
3	don't object, but at a later time, you'll have to
4	comment on that. But the licensees just like
5	these, just like the fire PRAs, it doesn't make sense
6	for licensees to invest in the transition.
7	MR. RADLINSKI: Also, I mention in the
8	next slide, under Recovery Actions or Operator Manual
9	Actions, NFPA requires any circuit analyses that rely
10	on Operator Manual Actions to be done using
11	performance-based methods. So if your spurious
12	actuations are mitigated using by crediting
13	Operator Manual Actions, the NFPA requires that you
14	use the performance-based methods.
15	CHAIRMAN ROSEN: Well, that's helpful, but
16	it doesn't mean you have to identify it.
17	MR. RADLINSKI: It on the prior slide
18	now it says if you don't address spurious
19	actuations, you don't identify them, then you
20	MR. PARTICIPANT: You have to identify
21	them. That's in 804.
22	CHAIRMAN ROSEN: You know, I come back to
23	the same thing. We're dancing around it. It's all
24	there. Every time we ask a question, you say it's
25	there; you have to do it. But we don't come out and

say it. So it looks like the fire PRA discussion we had a moment ago.

MR. WEERAKKODY: You're right. I think you could put it that way, we are dancing around it, but I think again, what we need to recognize is we are trying to transition from the confusing legacy to the clear expectation. So even for the Appendix R Plant, Steve, they are going to have to deal with multiple spurious actuations, and so does 805. But to say, when we use the word "require," we look at and look for clear Regulatory expectations in the circuits that is not there with the Commission consensus. So if I use the word "require" with the licensee, I make sure that the Commission has agreed with me.

CHAIRMAN ROSEN: I don't know what else needs to be said.

MR. RADLINSKI: Okay. What we refer to as "Operator Manual Actions" are referred to in 805 as "Recovery Actions," which includes and encompasses both Operator Manual Actions and repairs. We don't say a whole lot in the Reg. Guide about them. We do mention that an unapproved Operator Manual Action, credited in a III.G.2 area must be evaluated as a plant change. And, again, per 805, it has to be done on a performance-based approach.

1	MR. APOSTOLAKIS: What does that mean,
2	using "Performance-Based methods?"
3	MR. RADLINSKI: As opposed to the
4	deterministic approach. You'd have to go into the
5	plant change process and evaluate it based on risk,
6	fire modeling, a combination of the two.
7	MR. APOSTOLAKIS: Oh. So, Delta CPF and
8	all that stuff?
9	MR. RADLINSKI: Sure.
10	MR. APOSTOLAKIS: This is considered
11	"Performance-Based?"
12	MR. RADLINSKI: Right.
13	MR. APOSTOLAKIS: Oh, I see.
14	CHAIRMAN ROSEN: And you have to use the
15	appropriate HRA methods?
16	MR. WEERAKKODY: Yes.
17	CHAIRMAN ROSEN: Considering all the
18	factors, the performance-shaping factors?
19	MR. APOSTOLAKIS: Which HRA method would
20	you use?
21	CHAIRMAN ROSEN: Well, considering
22	performance-shaping factors for the actions that are
23	being analyzed.
24	MR. APOSTOLAKIS: Yeah, but, I mean, I'm
25	serious. Which method do you have in mind?

1	CHAIRMAN ROSEN: I
2	MR. APOSTOLAKIS: ATHENA?
3	MR. WEERAKKODY: No, I
4	MR. APOSTOLAKIS: No? No, he says and he
5	laughs.
6	DR. GALLUCCI: It's Ray Gallucci again.
7	The licensee is free to use the one he chooses. You
8	don't have to
9	MR. APOSTOLAKIS: How can you know that
10	that method is good enough?
11	DR. GALLUCCI: You test it out and you
12	check it with sensitivities and you see how robust it
13	is, but there's no advocated method. No one has ever
14	come up and said this is the perfect method. There
15	obviously, there is some aspects that work better for
16	some techniques than others, but there's no there's
17	no approved Regulatory HRA method and there may never
18	be.
19	MR. APOSTOLAKIS: Well, we've been
20	investigating this topic now for more than ten years.
21	And we still don't have it.
22	MR. WEERAKKODY: Well, we have I would
23	say that where we have used with consensus agreement,
24	like when I was in the Office of Research for the
25	accident sequence, because of the program, we used

1 something called "ASCP." Again, no matter which HRA -- like Ray said, no matter which HRA method you take, 2 3 there's going to be uncertainties and so we deal with 4 that through the requiring of the Defense-in-Depth and 5 the Safety Module. MR. RADLINSKI: Okay, that's it for the 6 7 key issues. I'm going to address in the Reg. Guide this one last slide here before the Conclusion with 8 9 respect to the burden on licensees. Again, this is a voluntary rule so the Req. Guide provides guidance for 10 implementation of the rule. It does not cause any 11 12 undue burden to the licensees. On the other hand, there will be an Impact 13 14 Report on licensees who perform the transition and to 15 maintain the program. The Reg. Guide provides quidance or provides a basis for a licensee to assess 16 what that impact would be. 17 So, in conclusion, the Req. Guide does 18 19 licensees with specific guidance 20 implementation of an 805 Fire Protection Program. The 21 Req. Guide also does not cause any undue burden to 22 it provides suitable quidance licensees and 23 licensees to assess the impact of adopting a Risk-24 Informed, Performance-Based Fire Protection Program.

MR. APOSTOLAKIS: So "Performance-Based"

1	means using those figures?
2	MR. RADLINSKI: Yes.
3	MR. APOSTOLAKIS: So why would there be a
4	"Risk-Informed" program without it being Performance-
5	Based? Is there such a thing as "Risk-Informed"
6	without "Performance"?
7	MR. WEERAKKODY: The Maintenance Rule was
8	
9	MR. APOSTOLAKIS: Oh, that's an
10	interesting point because if he finds the targets for
11	the unavailability without redoing anything in Delta
12	CDF?
13	MR. WEERAKKODY: Yes, there are some
14	parallels, you know, even if you go back to the
15	Maintenance Rule again, it's been a while I'm
16	not sure Maintenance would have required a PRA, but
17	internally, you know, we had PRAs support the meeting.
18	And then Dr. Gallucci, Ray Gallucci, who is a Senior
19	Fire PRA Expert, if he was here, he would basically
20	one hundred percent agree with me and say fire PRAs
21	should be mandated for all plants.
22	MR. APOSTOLAKIS: If he was where?
23	MR. WEERAKKODY: If he was here.
24	MR. APOSTOLAKIS: I think he is there.
25	MR. WEERAKKODY: He would still say it.

MR. APOSTOLAKIS: Oh.

2 DR. GALLUCCI: I can say it from here,

 $3 \parallel \text{yes.}$ 

1

4

5

6

7

8

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

25

(LAUGHTER.)

CHAIRMAN ROSEN: Well, on that note --

MR. APOSTOLAKIS: Can you explain to me --

I'm really perplexed now. Why this argument? I mean,

every step of the way, you know, let's make sure that

9 we don't demand the PRA.

MR. WEERAKKODY: Well, let me answer this, Dr. Apostolakis. I know I've come here and I'm not going to change your opinion on this, but -- that's a compliment, okay? But when we put the Reg. Guide out, our initial version said all changes will require risk And one of the public comments that we assessment. got from the industry is that, hey, you know, we don't think so because they will pull out the same document and they went to a different page and said we don't think every change requires risk assessment. one hand, we dug into their differences and said, you know, where are they coming from, and then we did some of our own research and we concluded, no, you do require risk assessment. But at the same time, we understood what was driving them, you know, because when you say a change, and then you go and say, you

know, what is the change. Anything could be a change out there, so they were worried that down the line, you know, five years from now, after their transition to 805, you may have an Inspector who walks in with an extremely different interpretation of what that is, and basically for the smallest difference in the PRA, require a full-blown risk assessment. So that was a valid concern. The duplicity that you see, or the lack of clarity you see there, you are not saying you need fire PRAs and you need fire PRAs and a full-blown risk assessment for every change is somewhat due to that. And your asking Steve why we cannot satisfy it, and I would say it is straightforward, honest answer, you have to satisfy the licensees.

APOSTOLAKIS: Okay. But if the MR. licensee calculates a Delta CDF, that goes way beyond an Inspector walking around and saying something. The guy's calculating a Delta CDF and he wants to do that without a PRA. You know, and then the next thing is what? He's going to calculate it without a PRA? No, that would be, you know, completely black magic. is gray now, but -- so this is the problem. least, we stayed away from Delta CDF, I can understand your point. We are doing certain things and we don't always need a PRA. The moment you start saying I'm

1

2

3

4

5

6

7

8

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

calculating Delta CDF and in the same paragraph it says, now if you have a fire PRA, your life would be easier. I have already calculated a Delta CDF. And then, of course, it goes below even the smallest allowed change in the Regulatory Guide. So, I mean, we are really amending the Regulatory Guide here, 1.174.

CHAIRMAN ROSEN: Well, I --

MR. APOSTOLAKIS: Well, yeah. If you go to 1.174, nowhere in there does it say that if it's ten to the minus seven, you don't need a risk assessment. And 1.174 is also a Regulatory Guide, which has been approved.

CHAIRMAN ROSEN: Well, I don't understand how you can say if it's 1.174, you don't need a risk assessment because you -- the fact that it's saying 1.174 means you have a risk assessment. How do you know it's less than ten minus seven without a risk assessment?

MR. APOSTOLAKIS: I can see someone doing a calculation with one sequence in one room and saying the change is this. Somehow that can be done. You don't need a full PRA to do that. But then when you go and say that if that is less then ten to the minus seven, that's okay even without the CDF, this is now

Τ	a very new and innovative use of the Regulatory Guide
2	1.174. It was not intended, anyway.
3	MR. WEERAKKODY: When you say, "The
4	amended 1" is that because of the lower
5	threshold?
6	MR. APOSTOLAKIS: Yeah, that's what I'm
7	saying. It doesn't say that if you are below ten to
8	the minus seven, you don't need to worry about the
9	CDF. It says that the CDF is always there and if you
10	enter a CDF and Delta CDF and if you are here, you do
11	this. And if you are there, you do that. And now you
12	guys are saying, "No, no, no, no. If Delta CDF is
13	even lower than what the Guide says, we really don't
14	care about CDF." Now if 1.174 said that, then you
15	would be okay, but it doesn't say that. Now, it
16	doesn't preclude it either.
17	MR. WEERAKKODY: When you
18	MR. APOSTOLAKIS: I don't know what to
19	say. I mean
20	MR. WEERAKKODY: No, we cannot and
21	shouldn't be contradicting 1.174. I'm trying to
22	understand
23	MR. APOSTOLAKIS: You are not
24	contradicting it exactly. You are expanding it.
25	MR. WEERAKKODY: Let me say we are

building another layer of concern or something, or is 1 2 that --3 MR. APOSTOLAKIS: It is not a concern; it 4 is just a novel application. 5 DR. BONACA: I appreciate any concern that you may have that you would force using the cannon to 6 7 do any minute changes. That is a concern that I have 8 to have, but I am saying even if you put additional 9 clarity on the need for risk information, you can still deal with the issue without having this kind of 10 confusion. It seems to me that, you know, you claimed 11 12 before with regard to the statement that advocates addressing spurious actuations that these are the 13 14 Guides that provide nuclear education. There is much 15 more to it. Well, it does and does 16 CHAIRMAN ROSEN: 17 not. DR. BONACA: I mean there is still this 18 19 confusion on, you know, how do you use the risk tools 20 and what sort of risk information do you use. It makes 21 reference to the IPEEEs. This advocates addressing 22 I totally agree with Mr. Rosen spurious actuations. 23 here that there should be clarity there and if there 24 is spurious actuation, you have to deal with it. So, 25 it's -- you know, again, I appreciate the concern of

1 the industry that you would be forcing them to use 2 your full-fledged evaluations for any minor exemption. 3 Common sense has to help there. 4 CHAIRMAN ROSEN: Okay. 5 MR. APOSTOLAKIS: Let's take a break. CHAIRMAN ROSEN: Yeah, I think we'll take 6 7 a break now until 10:15 a.m. 8 (Off the record at 10:00 a.m.) 9 (On the record at 10:17 a.m.) 10 CHAIRMAN ROSEN: We're back on the record. Alex, I'll turn it over to you. 11 MR. MARION: Good morning. 12 My name is Alex Marion. I'm the Senior Director of Engineering 13 14 at NEI and I appreciate the opportunity for the industry to provide an overview of the Guidance 15 document that we've developed for implementing the 16 17 NFPA 805 Rulemaking. industry, through NEI, 18 The has been 19 the application of Risk-Informed supporting 20 Performance-Based approaches for a number of years. 21 The basic objective is to apply those methodologies so 22 that we can better focus resources on the part of the 23 industry as well as the NRC on matters that are 24 extremely important in terms of plant safety, and in 25 this particular case, in terms of fire risk.

1	Let me just offer a perspective on fire
2	protection, historically, if you will. Despite the
3	best efforts of NRC and the industry to establish a
4	stable and consistent Regulatory Process, if you look
5	back over time, we keep raising or identifying these
6	issues related to compliance and we all recognize that
7	there are alternatives that are effective in terms of
8	dealing with the fire risk, although you still have
9	the compliance issue. And that's a fundamental
10	Regulatory challenge that you always have to deal
11	with, whether we're talking about fire protection or
12	any other Regulations. But more importantly, you've
13	had a continuing and diverse set of expectations and
14	interpretations in the Regulations over the years and
15	different processes involved. Let me just cite an
16	example with regard to manual actions. There have
17	been two processes that have been used in the industry
18	that deal with NRC review and approval or acceptance
19	of manual actions. One has been formal through the
20	Exemption Request Process and the other has been less
21	formal through documented information and Safety
22	Evaluation Reports Satisfaction Reports. Whether we
23	like it or not, that has been the accepted practice
24	over the past twenty-five/thirty years. Now, we're
25	trying to apply some stability and the Commission has

decided that, okay, going forward, you will use the Exemption Process or you will use this new Regulation that's currently in the process of being developed, which is fine, but we need to recognize that as we move forward with the new Regulatory construct, whether it be Manual Actions or whether it be this particular Rulemaking, we don't want to lose sight of the fundamental objective. The fundamental objective is to have a consistent, stable process that allows us to continually focus on safety and demonstrate to internal stakeholders and anyone, external stakeholders, that the plants are safe and the programs we have in place are assuring that level of safety over the longer term. We have an opportunity with the NFPA to apply Rulemaking to do that. that is the best opportunity we've had since Appendix R and 50.48 were issued.

There were some questions raised this morning about why the utilities are making the transition from a deterministic philosophy, if you will, under 50.48 Appendix R, with all these interpretations that allow alternative methods, but deterministic framework nonetheless, to one that's risk-informed and performance-based. The point was raised about don't you need a fire PRA as a benchmark

1

2

3

4

5

6

7

8

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

1	or foundation to make this transition. We absolutely
2	agree that a fire PRA is necessary. And the two
3	utilities that are one has officially announced
4	that they are going to make the transition for their
5	plants and another one is going to make the
6	announcement this afternoon plan to develop a fire
7	PRA. So they can optimize or maximize the benefit
8	with this transition.
9	CHAIRMAN ROSEN: I presume they're going
10	to use the new Guidance that just came out in the NRC,
11	as a result of the NRC and EPRI work on fire PRA?
12	MR. MARION: The vulnerability assessment?
13	CHAIRMAN ROSEN: No, the
14	MS. KLEINSORG: Re-quantification.
15	CHAIRMAN ROSEN: re-quantification. Is
16	that a good assumption?
17	MR. MARION: Yes. Yes.
18	DR. WALLIS: That's also why the Agency
19	doesn't require it. Usually the Agency elects to
20	require things that you guys have some good reason why
21	you shouldn't, but if you guys want all industry to
22	have the PRA, what's the inhibition the Agency has
23	about requiring it?
24	MR. MARION: Well, the challenge to the
25	Agency is to demonstrate that there is a safety

1	benefit in requiring PRAs and they have to go through
2	the back fit analysis, the Regulatory analysis to
3	demonstrate that the cost associated with
4	implementation of that requirement is commensurate
5	with the safety improvement.
6	DR. WALLIS: There seems to be a sine qua
7	non requirement. If you're going to use risk-informed
8	methods, you've got to have a PRA.
9	MR. MARION: Right. From an industry
LO	perspective, we don't need the NRC to require us to
L1	apply PRA.
L2	MR. WEERAKKODY: But we are
L3	MR. MARION: We are doing that in a number
L4	of areas already.
L5	DR. WALLIS: With regards to the
L6	implementation of this, and the Regulatory Guide,
L7	would the industry object then if it said having a
L8	fire PRA was a prerequisite to this risk-based, risk-
L9	informed rather, approach?
20	MR. MARION: On a matter of principle, we
21	would.
22	DR. WALLIS: We're not saying you have to
23	have it, but
24	MR. MARION: Because we don't
25	DR. WALLIS: but if you wanted to use

1	this.
2	MR. MARION: I understand, yes. We are
3	communicating that to the utilities, so I don't see
4	any value of NRC weighing in on that at this
5	particular point in time. It's being done.
6	DR. WALLIS: What was the matter of
7	principle?
8	MR. MARION: The fact that we don't need
9	the NRC to make that kind of statement in the
10	Regulatory Guide. It's not necessary. Because we are
11	doing it anyway. And the NRC weigh-in on this, in any
12	way, shape or form, brings into the process additional
13	trappings because it's an opinion, an interpretation,
14	an expectation, if you will, of the Regulator without
15	the discipline process of capturing a new Regulatory
16	position and all the trappings associated with it.
17	DR. WALLIS: One thing I'm concerned
18	MR. MARION: I hate to get legalistic, but
19	that's one of the
20	DR. WALLIS: about is the Agency doing
21	something that appears illogical, which is saying
22	we're going to have a risk-informed without having a
23	PRA as part of it. That seems so illogical.
24	MR. MARION: Well, I don't think that's

what the NRC is really saying, okay.

Anyway, I'd like to move on because we do have some material I would like to cover. want to offer one more point and I would ask you to think about it during the presentation. There were comments made about compliance. What I would ask you to think about is, what is it; what does it mean; how is it established; how is it verified; and how is it maintained. It sounds like a very straightforward respond to those questions, but if you look back over the history of fire protection under 50.48 and Appendix R and you look at all the interpretations and expectations, compliance isn't what you think it is. I would just leave that thought with you, and I would like to introduce Liz Kleinsorg who is the Managing Partner with Kleinsorg Group Risk Services. She's our contractor who's been devoted to developing the Guidance document that we've put together for implementation of NFPA 805 Rulemaking. With that, Liz? Hi, I'm Liz Kleinsorg and MS. KLEINSORG: before we get started, I would like to talk a little bit about my partners that helped develop this. the team lead, but I had assembled a group of

individuals who are very well known and very excellent

We had Andy Ratchford and myself

in their fields.

1

2

3

4

5

6

7

8

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

worked mostly on the programmatic aspects of NEI 04-02, the transition of the traditional Appendix R information into the new Risk-Informed, Performance-Based Rulemaking. We had Sheldon Trubatch as our legal counsel and we had Kiang Zee who did our PRA from Aaron Engineering. So, with that, I would like to talk a little bit about -- I'm going to talk about the transition process in a great amount of detail, and talk to you a little bit about how the transition process we see working. And it might add -- actually shed a little bit of light as to why a -- how you can transition into a PRA. So whereas a PRA, you can see from the two utilities that are going to be doing the transition, or considering the transition, they will be embarking on developing new fire PRAs. But from a transition perspective, and a timing perspective, it's not required to start the transition process. you'll be able to see a little bit about that.

I'm mostly going to talk to you about the change process. These are two real fundamental backbones of the new NFPA 805 Regulation, and they are the -- there are a few issues associated with that that Bob touched on -- Radlinski -- touched on that are still outstanding as far as we're concerned with how we're going to finish up the NEI 04-02 document.

1

2

3

4

5

6

7

8

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

Okay, let's go with the first slide. I apologize for the blue background.

This is a big picture of what transition process is all about and it's more of a "What kind of documents do you put together?" "What kind of phases does a utility go through?" You notice there are three phases to the transition. This big picture now. Each phase ending with documentation. So the preliminary assessment is, "Well, should I go to NFPA 805?" And a utility makes those decisions for lots of reasons. Duke has already sent in their Letter of Intent. The Letter of Intent triggers the enforcement discretion. So that's the end of Phase One.

Progress Energy, who's here today also in the back, they're also considering -- that's Jeff Ertman from Progress -- they're also considering the transition to 805.

The next phase is actually starting to do the transition and it is required -- is a required engineering analysis, the transition of your technical documentation and your program documentation. Duke has started with the project plan. I've been helping them put together the project plan and the schedule. It is about a year and a half to two years, I think

1

2

3

4

5

6

7

8

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

2 them in in order. So -- sequential order. 3 What the second phase will end with will 4 be the License Amendment Request itself and it will 5 also end with the transition report. Now because Duke is a pilot, we'll be going through a number of checks 6 7 -- the Pilot Assessment, I think you guys are going to 8 talk about that a little later today -- and we hope to 9 fine tune the NEI 04-02 process during that because we 10 do think that once we get real "into the process," there might be some fine tuning associated with 11 12 previously approved some οf the and change evaluations. And I'll talk a little bit more about 13 14 that. 15 BONACA: And you said that the DR. Statement of Intent --16 17 MS. KLEINSORG: Yes? DR. BONACA: -- triggers the enforcement 18 19 discretion? 20 MS. KLEINSORG: That's correct. DR. BONACA: In what sense are you --21 22 what's the need at this stage? 23 MS. KLEINSORG: At this stage -- first of 24 all, enforcement discretion has got two sides to it. 25 It's the stuff that is known going in. So, for

they've got, for each plant because they want to put

1	instance, Duke and both Duke and Progress Energy
2	have some known issues. So, if they haven't already
3	been colored up, they won't be put into the ROP
4	process, so that's part of it. And then, as we
5	DR. BONACA: There is a statement that the
6	resolution of those issues will come as a result of
7	implementation of enforcement discretion?
8	MS. KLEINSORG: That's correct, and
9	anything else we dig up as we do the transition will
10	also as long as it doesn't meet the trigger
11	requirements, will be under enforcement discretion.
12	DR. BONACA: Thank you.
13	MS. KLEINSORG: Okay
14	CHAIRMAN ROSEN: How long does that last?
15	MR. KLEINSORG: The enforcement discretion
16	is two years, I think, although it could be longer
17	than that depending upon individual utility requests.
18	Correct, Sunil?
19	MR. WEERAKKODY: Can be.
20	MS. KLEINSORG: Oh, sorry.
21	CHAIRMAN ROSEN: From the date of the
22	Letter of Intent?
23	MS. KLEINSORG: I think that's our
24	intention. It's a little gray right now, but I don't
25	know how you guys handled the Duke letter, so the

1	Duke letter did request enforcement discretion.
2	CHAIRMAN ROSEN: Okay.
3	MS. KLEINSORG: Okay. So that's kind of
4	the big picture. Then Phase Two, when the License
5	Amendment Request goes in and the Transition Report is
6	submitted to the staff, the utility will continue to
7	work on the transition because there's going to be
8	program documents that have to change, processes that
9	will have to be changed, and have to be pre-stage, new
10	training that will have to be done to transition the
11	program. So the utility would start to do those kinds
12	of things, maybe even work on some modifications that
13	they intend to put in as part of this Risk-Informed,
14	Performance-Based Transition.
15	And then the last phase would end with the
16	actual License Amendment Request being granted.
17	So that's the big picture transition. I'm
18	going to talk a little bit about the technical details
19	of transition next. Next slide.
20	I added this because of all the
21	discussions that happened about transition while I was
22	with the NRC, I had the luxury of stuffing another
23	slide in. So I'm going to back up a little.
24	There really
25	MR. APOSTOLAKIS: We don't have it.
ļ	I control of the second of the

1	MS. KLEINSORG: You don't have it, but I
2	can get you a handout. But I thought it was really
3	important because of all the questions you guys were
4	asking.
5	MR. APOSTOLAKIS: So you drew it this
6	morning?
7	MS. KLEINSORG: I did. I just whipped it
8	right up. I'm the queen of Visio.
9	(LAUGHTER.)
10	MR. MARION: She is that good.
11	MS. KLEINSORG: Yeah. We're going to talk
12	a little bit about Chapter 3 requirements of NFPA 805
13	and Chapter 4 requirements. These are, again, things
14	that we talked about and everybody around our group
15	knows what we're talking about. But Chapter 3
16	requirements are fundamental elements of a Fire
17	Protection Program and our minimum design
18	requirements. So they are the classical Fire
19	Protection Program aspects. Those get transitioned and
20	I'll talk a little bit about that.
21	The other side is Chapter 4, which you can
22	liken to the existing Appendix R requirements, the
23	protection of nuclear safety.
24	So what a utility will do is, as they
25	transition, is they will take their program, their

existing Fire Protection Program and compare it to the fundamental elements and minimum design requirements in Chapter 3. That's the left-hand side.

We're going to talk a little bit more about that because there is a -- Chapter 3 requires License Amendments. Changes from Chapter 3 are -- anomalies from Chapter 3, if you don't meet Chapter 3, you're required to get a License Amendment with the NRC and we'll talk a little bit about that in both discussion of previously approved and discussion of the change evaluation.

So the utility will go ahead and do that. We have provided information in NEI 04-02 that takes the old branch technical positions and compares them to an FPA 805, Chapter 3, and allows the utility to document how they're transitioning.

The other major aspect of the transition is the transition on Nuclear Safety requirements and that's the old Appendix R stuff. And that is -- does not have the same requirement for the demonstration of previous approval for a License Amendment Request issue that the Chapter 3 requirements have. And I'll show you a little bit more about that.

There are also two new aspects of 805 that aren't in the current Regulation and that's

radioactive release assessment and the assessment for non-power operational modes. Currently Appendix R goes from power operations to shutdown. It does not -- cold shutdown -- it does not look at what we do during outages. And this will add another aspect of the program.

So that's what the utility does during transition. They true-up their fundamental elements; they compare it; they see if they have any outliers; they see if they have got previous approval. If they don't have previous approval, they submit it to the NRC for a License Amendment Request during the transition process.

They also do the same thing on Nuclear Safety. They go through each fire area; they go -- actually, they go through their methodology; true it up against NEI 00-01's methodology; identify outliers; justify those to the NRC; and then they do a fire area by fire area comparison.

And Alex pointed out, and I want to reemphasize, that one of the reasons -- one of the underlying reasons people are going to 805 is to clean up twenty-five years of licensing, to make it clearer. So it doesn't do a utility any good to go gray today, gray tomorrow. Our big thing is safe today, safe

tomorrow. It does a utility no good not to clarify their license and basis as they go forward. And we've made that clear also in NEI 04-02 in the latest revision, about things that are topical and subject to confusion should be clarified in the documentation submitted to the NRC.

In the programmatic aspects down at the bottom, monitoring programs have to be established if you're going to use Risk-Informed, Performance-Based change evaluations and solutions. You have to monitor the basic assumptions that go into that or the basic premise that go into that to make sure that the underlying assumptions don't change during the life of the plant. We currently don't think that's a big deal because we have monitoring programs; they're just old -- they're more less risk-informed and they will be more risk-informed going forward. A great example is, from a monitoring perspective, is combustible loading. Utilities now have these combustible loading tracking programs and they are allowed to bring so many BTUs into a fire area. Going forward, if you're using risk-information and performance-based information -as I like to say, all BTUs aren't created equal -it's no longer important how many BTUs, but what the field package is and where it's placed, so that you're

1

2

3

4

5

6

7

8

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

1 monitoring a different aspect of the program going 2 forward. So that's how the programmatic functions will change. 3 4 We'll confirm adequate documentation and 5 quality control. We have a Guidance portion in Appendix -- I think it's "Charlie" of the document, as 6 7 to what the documentation would look like going forward for an 805 plant and then the Regulatory 8 9 submittal and approval. So that's kind of transition in a big 10 picture perspective. Any questions so far? 11 12 (NO RESPONSE.) Okay. Next slide, please. Okay, this is 13 14 a batch of handouts. 15 One of the big sticking issues with the staff in the industry in the completion of NEI 04-02 16 and its endorsement in the Reg. Guide is the issue 17 about previous approval. This plays importantly into 18 19 Chapter 3 because if you can show that you don't meet 20 a Chapter 3 requirement, but you have previous 21 approval, as documented in the -- in SERs or Exemption 22 Requests, then you don't have to meet the Chapter 3 23 If you can't meet the burden of previous requirement. 24 approval, then it requires a License Amendment

Request.

One of the big discussion points we had
with the staff was, well, in 1978, '81, '85, whenever
we got our SER, we had a program defined. Then we
adopted the Standard License Condition, which allows
us to make changes without previous approval from the
NRC. So, for instance, if I had told the NRC I had
two fire pumps and I had an SER, so I had two fire
pumps probably not a good example, but bear with me
and over the life of the plant, I made some change
and I did my 50.59 process which shells out to the
Fire Protection Regulatory Review Process and it said,
oh, I can make this change without prior Regulatory
approval. That new change may no longer meet Chapter
3. So, whereas, we can claim we're in compliance with
our current licensing basis and our current program,
we can't claim previous approval if it no longer meets
the Chapter 3 requirement. And I think we've actually
come to agreement on that portion. So we can claim
we're still in compliance with our program, but we
cannot claim that it meets Chapter 3's previous
approval test. That was a huge sticking point for us.
Because, you know, we have changed the plants over the
years, quite a bit. We're allowed to by our
Regulatory basis. So I think we've come to terms on
that

Any questions on that part of it?
MR. MARION: Yeah, if I might add, that's
one key aspect of maintaining the licensing basis that
we feel, from a process point of view, carries over
and should carry forward.
MS. KLEINSORG: Right.
DR. BONACA: The question I have is, you
know, looking at the previous slide that you had,
there was an emphasis on non-compliances and clearly,
you go to the engineering analysis, you come through,
and you go through a performance change evaluation if
needed, and clearly clean up all of these basis with
whatever non-compliance you may have had.
MR. KLEINSORG: Right.
DR. BONACA: But if you do have a full
risk analysis, assume you have other insights that do
not have anything to do with compliances or not, okay,
but it says you should have a different kind of
approach to fire protection, would you would the
licensee have an option to implement those or an
obligation to implement those changes?
MS. KLEINSORG: A non-risk informed change
is
DR. BONACA: No, no, risk-informed. I'm
saying, out of respect you know, I mean, one

1	portion, which is probably a minor portion, we address
2	non-compliances. But an expected fire PRA would bring
3	insights that tell you that maybe the fire protection
4	should be developed in a different way.
5	MR. MARION: Right, absolutely. The fire
6	PRA will identify vulnerabilities that a licensee will
7	have to evaluate against the requirements of the
8	Regulation and enhance their fire protection program
9	based upon that specific vulnerability.
10	MS. KLEINSORG: And we've actually seen
11	that in demonstration.
12	DR. BONACA: Other than the process, what
13	do you do have a hybrid between the Appendix R
14	Regulation and whatever comes out of your risk-
15	informed approach?
16	MS. KLEINSORG: Right. Actually the next
17	slide exactly goes to that.
18	DR. BONACA: Okay.
19	CHAIRMAN ROSEN: I hate to interrupt
20	Mario's train of thought, but I really wanted you to
21	track your example through this slide. In the example
22	where you had two pumps and you
23	MS. KLEINSORG: Right, right.
24	CHAIRMAN ROSEN: But where do you end up
25	on this slide?
J	I and the second

1	MS. KLEINSORG: Where I end up, and it's
2	hard to see. I can't bring it in and it's really
3	hard to see if I had let's say I had previous
4	approval of my two pumps. Bad example, but we'll work
5	through it. And it was a previously approved
6	alternative and the answer was yes, but NFPA 803
7	805, excuse me requires two pumps. I had two
8	pumps, but during the life of the plant, I made a
9	change and now I can no longer claim that it's
10	previously approved because the NRC
11	CHAIRMAN ROSEN: It's compliant, but
12	MS. KLEINSORG: It's compliant, but it's
13	not previously approved. So we have given up on that
14	and we will submit those as part of the Licensing
15	Amendment.
16	CHAIRMAN ROSEN: So you go down to this
17	bottom "no,"
18	MS. KLEINSORG: The bottom part will be
19	"no" because and I should have
20	CHAIRMAN ROSEN: and you then go to the
21	one that says "prepare and submit License Amendment?"
22	MS. KLEINSORG: License Amendment, that is
23	correct. Now, we're going to talk a little bit more
24	about that in the Change Evaluation Process because we
25	can see ourselves we think we're in agreement with

the NRC in -- how do I put this? -- in spirit, we are in agreement that not all changes need to have License Amendment Requests, I think. How we're going to go about implementing that right now is where we're at. We still haven't come to resolution on that and I have real specific examples of things of that nature when we talk about the Change Evaluation.

During the original transition, again, the majority of Chapter 3, for those of you who've looked at NFPA 805, a lot of it is programmatic. A lot of stuff is really high-level, good programmatic guidance and that you wouldn't end up ever undoing those kinds However, it does get into specifics regarding compliance with NFPA Codes for suppression and detection where we on a -- not a daily basis, but probably, you know, every month somebody something where we're not truly Code compliant with one little issue. The implication is, now do we require a License Amendment for that little thing we found two years down the road? So we want to talk about that a little bit more because that will become burdensome and I don't think either this staff or the industry really wants to do it. How we resolve that remains to be seen as far as we're concerned.

Okay, back to the hybrid. It's not cherry

1

2

3

4

5

6

7

8

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

picking. When a plant transitions to 805, they transition to 805, but not every fire area will risk-informed. Some of them will transition transition as deterministic. So let's go through this. Every plant has an Appendix R analysis right They have compliance on a fire area by fire area As they transition, they're going to -- they can take a look at their fire areas and say, "Okay, does this meet Appendix R. Yes, they do." We have a whole series of questions they have to go through and documentation as to transition that licensing basis. But if you had one-hour wrap with suppression and detection, and it still exists, you can transition that fire area over just like that into the 805 space. So this plays into, "Why don't I need a

fire PRA right away?" Well, if I have -- let's say my plant's perfect and I don't have any manual action issues and I don't have any circuit issues. There is no reason why I can't transition my plant over all in the deterministic bucket until I find a change that I want to be able to evaluate later on using risk.

So the timing issue -- whereas, we all agree that having a fire PRA provides a lot more value and a lot more insight into having the process, when you have it, you know, might vary depending on how

1

2

3

4

5

6

7

8

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

1	your plant's current licensing situation is.
2	CHAIRMAN ROSEN: In your example, you
3	assume the plant is perfect and you've done the
4	multiple spurious calculations and all that.
5	MS. KLEINSORG: Right, we know nobody's
6	like that.
7	MR. APOSTOLAKIS: The discussion earlier
8	was not really on that topic. I mean nobody objects,
9	or nobody would demand a fire PRA for the first three
LO	boxes there.
L1	MS. KLEINSORG: Right.
L2	MR. APOSTOLAKIS: But when people start
L3	producing Delta CDF without a fire PRA, I mean, that's
L4	really pushing it. That's really where the concern
L5	was.
L6	MS. KLEINSORG: Yes.
L7	MR. APOSTOLAKIS: But it's perfectly all
L8	right if to say, you know, I meet the deterministic
L9	requirements of the 805 standard. Well, more power to
20	you.
21	MS. KLEINSORG: Right.
22	MR. APOSTOLAKIS: So that's where the
23	language is a little bit provocative. You know, when
24	you actually start calculating Delta CDFs
25	DR. BONACA: Well, in a sense, the

1 confusion between meeting this NFPA method and the 2 risk-informed part of it, as long as you meet the 3 deterministic requirements, that's okay. 4 MR. APOSTOLAKIS: That's okay. 5 DR. BONACA: It shouldn't be a part of this discussion on the Reg. Guide at all. 6 7 MR. APOSTOLAKIS: Well, the Reg. Guide --8 no, no, no, because the Reg. Guide talks about the --9 CHAIRMAN ROSEN: Yeah, but NFPA has two 10 branches. DR. BONACA: Yeah, but it is out of 11 12 essentially risk-informed respect, however, that information is used to deal with low compliances or 13 14 low conformances, okay, but I'm saying that there is 15 no obligation on the part of the licensee to change anything about his compliance portion and so there may 16 17 not be benefits really gained from the application of fire analysis in the sense that you may know that you 18 19 get some benefit, but you don't need to do it, so you 20 don't do it. MS. KLEINSORG: Well, we've run a couple 21 22 of pilots using the change, the change process, which 23 is really what we come down to with this risk-informed 24 process. And what we found is once you open a fire

area back up, you can't just focus on the one non-

compliance; you have to look at the fire area in total. So you'll find things that you -- you'll find things where the fire protection was okay for the non-compliance you were looking at, but it wasn't so okay on the other side of the area. So once you open a fire area up, you open the whole area back up again. You have to look at it in context.

MR. APOSTOLAKIS: Now, this sends the message that in the transition, the preference is really to go to the deterministic branch of NFPA of 805? And that when you find that you can't do it, then you go reluctantly to the risk-informed part to try to justify it. That's the message I'm getting from this picture, which may be, you know, for whatever reason, the reasonable thing to do.

How about the situation though where a fire PRA would, in fact, identify some issues that are not covered by the first three boxes? Now if the licensee doesn't have to do a fire PRA, then these would never be discovered. In other words, the fire PRA or the risk approach is used only to justify certain things that are not compliant with the deterministic requirements of 805?

DR. BONACA: Yeah, but it was an open vulnerability.

1	MR. APOSTOLAKIS: What?
2	DR. BONACA: If it was a clear
3	vulnerability, I think you would have to address it.
4	MR. APOSTOLAKIS: If founded, yeah, I'm
5	sure people will have to do something about it, but
6	you are not really going after vulnerabilities.
7	DR. BONACA: That's right.
8	MR. APOSTOLAKIS: Because you're not doing
9	the fire PRA.
10	DR. BONACA: Absolutely.
11	MR. APOSTOLAKIS: And yet, it would be a
12	risk-informed system. So that that is
13	CHAIRMAN ROSEN: Yeah, that's very
14	troubling. I think it's a good point, George, because
15	we always used to say, maybe less now than we used to,
16	but doing PRA, internal events was a good thing to do
17	because it reveals vulnerabilities.
18	MR. APOSTOLAKIS: Sure. And in this case,
19	I mean, you know.
20	CHAIRMAN ROSEN: Anyway, let's go on.
21	MR. MARION: No, let me just offer that
22	that is a good point and we intend to work with the
23	two licensees and as we go through that piloting
24	exercise, because our interest in this is to make sure
25	that the process is efficient, effective, transparent,

and does satisfy what the industry wants as well as
what the NRC wants. And after that effort is
completed, we may likely revise this document. It's
hard to say what areas will be changed, but we are
going to make this a living document for a period of
several years, at least, until we get the first couple
of utilities through the process. Because there are
several utilities that are waiting in the wings to see
how this plays out with Duke and Progress. And then
based upon how successful they are, they may decide to
weigh in on this and go forward with the transition,
so we want to make sure that we have this guidance
document to a point where it is relevant not only to
the two pilots, but also subsequent utilities in the
future.
MR. APOSTOLAKIS: Now, the two branches of
that diagram and it's been a while since I've seen
it but, as I recall, one can choose is it one or
the other, or both?
CHAIRMAN ROSEN: It's one or the other.
MR. APOSTOLAKIS: One or the other. So I
can be completely risk, which is not what we're doing

here. Here, we're not using one or the other; here

we're going to deterministic and if we can't, we're

invoking risk arguments to justify that.

б

1	CHAIRMAN ROSEN: On a fire area by fire
2	area basis.
3	MR. APOSTOLAKIS: Fire area, yes.
4	Whereas, in the 805 document, you either go this way
5	or that way, deterministic or risk-informed, in which
6	case, the issue we raised earlier of identifying
7	vulnerabilities wouldn't exist because if you go risk-
8	informed, you are going to do the PRA and identify the
9	vulnerabilities.
10	MR. MARION: Yeah, that's that's fine.
11	MR. APOSTOLAKIS: So that's something that
12	needs to be clarified, in my view.
13	MR. MARION: Yeah. Hindsight being 20/20,
14	et cetera
15	MS. KLEINSORG: I have a copy.
16	MR. MARION: We're trying to work within
17	the framework of 805
18	MR. APOSTOLAKIS: The Government can
19	afford that.
20	MS. KLEINSORG: Okay.
21	MR. APOSTOLAKIS: I'm sorry, Alex.
22	MR. MARION: Yeah, we're doing our best to
23	work within the framework of 805 and we're already
24	identified areas where it can be improved. I think
25	there's a Writing Committee right now looking at a
	I .

1	revision to it.
2	MS. KLEINSORG: We have revised it. I'm
3	on the Committee.
4	MR. MARION: And so any input that we
5	gather as we go through this process that would
6	suggest changes to 805, we'll make that available to
7	the Writing Committee. But it's the best document on
8	the street we have right now to work with.
9	MR. APOSTOLAKIS: What is, FPA 805?
10	MR. MARION: Yeah.
11	MS. KLEINSORG: All right.
12	MR. ERTMAN: Can I make a, I guess a
13	comment, just to answer something you said a little
14	earlier. I'm Jeff Ertman with Progress Energy. And,
15	as stated earlier and Alex stated, yes, we understand
16	you will want to make some risk-informed change
17	evaluations and we are going forward with the full
18	fire PRA. We do understand that there could be
19	vulnerabilities identified and we would address those
20	vulnerabilities. That's just something that we would
21	do as part of our corrective action.
22	DR. DENNING: But to clarify something
23	that George said, there's no Regulatory requirement to
24	address those vulnerabilities, correct? I mean, if

you do a fire PRA, you identify vulnerabilities,

1	chances are good you're going to address the most
2	critical ones.
3	MR. ERTMAN: Yes.
4	DR. DENNING: But even if it came out ten
5	to the minus three per year, ten to the minus two per
6	year, there is nothing that would require
7	MR. ERTMAN: Oh, no, no
8	MR. APOSTOLAKIS: No, remember what
9	happened when Quad Cities found
10	MR. MARION: Yeah, but you don't need a
11	Regulatory requirement to
12	DR. DENNING: And you don't have and
13	I'm not saying that it wouldn't happen, and
14	particularly you'd be handcuffed here as far as being
15	able to make you know, if you have a ten to the
16	minus
17	MR. APOSTOLAKIS: If you find anything
18	that's above ten to the minus three, it becomes an
19	issue of
20	CHAIRMAN ROSEN: I think the thing that
21	you have to keep in mind is this area is very
22	carefully reviewed through the insurance arm of the
23	industry and that if such a finding was on the books
24	of a company, and they had done nothing about it, then
25	they had had a fire, a serious fire, I mean, there

1	would likely be some questions about that.
2	MR. APOSTOLAKIS: No, no, no, we'd
3	have the precedent. I mean the moment the word came
4	down that Quad Cities had what the first amendment
5	was nine, ten to the minus three.
6	CHAIRMAN ROSEN: Right.
7	MR. APOSTOLAKIS: That was a bunch of NRC
8	guys flying over there immediately.
9	MR. MARION: I understand all that, but
10	I'm saying that it doesn't take just that. I mean,
11	there's another whole process going on that we don't
12	see a whole lot of.
13	MR. APOSTOLAKIS: Yeah, there are the EO
14	and ANI
15	CHAIRMAN ROSEN: The insurance process
16	which highly deals with inspections and standards and
17	all the rest. So, the company would expose itself to
18	a significant financial risk if it found such a thing
19	and took no action.
20	MR. MARION: But I assure you that there's
21	a significant level of attention and focus on
22	evaluating the insights that come out of PRA methods,
23	insights whether it's a reduction or whether it's an
24	increase or an enhancement. They're not people

don't go through a picking and choosing scenario and

determine what they're going to implement and what they're not going to implement. It's going to identify vulnerabilities that need to be addressed and they'll be incorporated in the Corrective Action Program and dispositioned accordingly. It may result in a programmatic change or it may result in a modification of the plant. But they will do something.

MR. WEERAKKODY: There are two --

DR. BONACA: And I appreciate that. think it is really a profit thing. That's why, however, you know, I was thinking back about the concern of not having a requirement for a full PRA model. We discussed it before. It's almost like setting minimum requirements at the level where somebody could say, okay, I'm not doing a full-blown PRA but I'm just dealing with non-compliances and then I want to look at the rest that a coming down and resolve them to some minor risk considerations. probably most of them are such non-compliances that you can't affect it, I mean, a concern by a simple risk analysis. And so in that case, I think we would lose the benefit of application risk information to the general, you know, fire issue which I think is a much superior way of going about it.

1

2

3

4

5

6

7

8

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

1 MR. APOSTOLAKIS: Would you see any 2 licensee going the other way, saying I'm going to do a risk thing and then maybe look at some deterministic 3 4 evaluations where the risk -- the risk analysis may 5 indicate some vulnerability some place and I'm going to use a computer code, a deterministic calculation to 6 7 In other words, show that this is not an issue? reverse the attitude as opposed to trying to be as 8 9 deterministic as you can and if you can't, go to risk. I don't know. 10 MS.KLEINSORG: I don't know The way Dukes' Project Plan is coming out right 11 yet. 12 now, is they're going to be going down dual paths, doing a fire PRA at the same time we're truing up the 13 14 transition of the old Appendix R over. So I think 15 they'll merge at some point. One can't -- we can't be finished until both are done. We will not submit our 16 17 Licensing Amendment Request until both are done. shouldn't say "ours," "theirs" -- I feel a part of it. 18 19 But I don't know if it'll just -- if the PRA bus will 20 end up ahead of the deterministic transition. I don't 21 know. 22 MR. APOSTOLAKIS: Why is there a -- do we 23 have to issue this Regulatory Guide before the pilot 24 programs take place? 25 MR. WEERAKKODY: Yes.

1 MR. APOSTOLAKIS: Don't we have this thing 2 of trial use? We've done it in the past. 3 MR. WEERAKKODY: We won't issue the 4 Regulatory Guide -- we won't issue the Regulatory 5 Guide --MR. APOSTOLAKIS: Why not? I mean, there 6 7 are all these issues that would be resolved after Duke 8 does its job. MR. WEERAKKODY: Duke is familiar with the 9 10 details because they were from Day One -- not Day One, 11 for a while was interested, but the Regulatory Guide is not just for Duke and Progress. 12 It's for all the other players as well. 13 14 MR. APOSTOLAKIS: Well, I understand that, 15 but it appears that we're going to learn a lot from this particular obligation. We're really going to 16 17 learn a lot. DR. BONACA: I mean it is complex as an 18 19 issue because I'm sure as you do a fire PRA, Appendix 20 K is already invented in the design of the plan. So 21 therefore, you're reflecting commitments in it and 22 some of them are positive this report will be the 23 results and some of them will be sufficient. 24 have, you know, a hybrid system already in place.

so I think there is a lot to be learned from the first

application, to see what comes out of it.

MR. MARION: Yeah, that's an excellent point. It is a hybrid system. And it will be until we work through the details with a couple of pilots. But, you know, from an industry perspective, the Reg. Guide would be beneficial because it captures endorsement of some of the fundamental documents here and the utilities like to move forward with some level of confidence that NRS finds some of these documents to be acceptable.

So, you know, there is benefit to them issuing the Reg. Guide now, but also -- I don't want to speak for the staff -- it seems to me that they will reevaluate the Reg. Guide after we go through the pilots and determine if additional changes are necessary.

MR. APOSTOLAKIS: There was this -- what was it, a couple of years ago -- that Ms. Mary Drouin was here arguing why a particular Regulatory Guide had to be issued on a try and use basis because then it would be easier to change it as we went along and all that. We could do the same thing here, couldn't we?

MR. WEERAKKODY: We could, but you know,

listening to all the questions though, if I look at what we know versus what we don't, today to issue a

1	Reg. Guide, we understand there's a concern with the
2	requirement for approved PRA, but I think we know a
3	lot about Reg. Guides so that there is some certainty
4	on the part of the licensees who want to make a
5	decision. In fact, you know, for example, D. C. Cook
6	was up here and one of the things they are doing right
7	now, although they haven't sent a Letter of Intent, is
8	they are taking the things like the Reg. Guide and
9	doing an evaluation to decide whether they want to
10	update 805. So I think the Reg. Guide should be out
11	in the street.
12	I'm not refuting that we won't learn
13	during the pilots, and we will modify the Reg. Guide
14	and I know NEI will modify 04-02 as appropriate,
15	there's not such little uncertainty that we can
16	assure it.
17	MR. APOSTOLAKIS: But again, isn't this
18	picture here inconsistent with 805? No?
19	MR. WEERAKKODY: No, I don't think so.
20	MR.LAIN: No, I think the consensus the
21	Committee wrote it in this way for ease of transition,
22	I think. If they required all the fire areas to go
23	through the Performance-Based method, that you would
24	end up being the cost burden would be too much for
25	people to volunteer to actually transition over. In

1	some areas, you don't have problems and they're safe
2	today, they meet the deterministic requirement, they
3	have lots of safety margin, that, you know, it's
4	considered to move on and address the non-compliances
5	in the areas and as changes are done, they are going
6	to have to work with the as-built condition, so they
7	are going to have to evaluate the whole area as they
8	make
9	MR. APOSTOLAKIS: So what you're saying is
10	that the deterministic versus performance-based
11	approach is to apply to each area, not to the plant?
12	MR. LAIN: Correct. They'll march through
13	the fire area by fire area and decide, you know, does
14	this meet the deterministic
15	MR. APOSTOLAKIS: This time I'm going to
16	do it using the deterministic method; this other one
17	I'm going to do
18	MR. LAIN: Right. This other one, I have
19	non-compliances that don't meet the deterministic,
20	then I have to go through this, you know, this other
21	method to establish that it meets the risk
22	requirements.
23	MS. KLEINSORG: And that's consistent with
24	Section 2.2 and the NFPA 805, I think. The
25	methodology.

1	MR. DIPERT: After your transition, and
2	then you want to make a change in the plant, you can
3	do that on a risk basis regardless of how you got that
4	area?
5	MS. KLEINSORG: The transition out of
6	there, that's correct. That's correct. And, you
7	know, if you look at the deterministic side, you if
8	you find an anomaly in a plant post-transition, you
9	are either going to bring yourself back into
10	compliance with your transition licensing basis, you
11	could pick an NFPA 805 deterministic, which is more
12	stringent than your transition licensing basis, or
13	more than likely, you'll do some sort of Risk-
14	Informed, Performance-Based evaluation of either the
15	adequacy of the as-found condition or the
16	justification for what change what is the most
17	bang-for-your-buck from a change perspective.
18	CHAIRMAN ROSEN: Well, that answer
19	confused me a little bit. I think what Rich was
20	saying was that after you make the transition
21	MS. KLEINSORG: Right.
22	CHAIRMAN ROSEN: but you haven't
23	transitioned every area, maybe you've only
24	transitioned
25	MS. KLEINSORG: No, you transition every
	I and the second

1 You transition every fire area, you transition 2 it either a deterministic or risk-informed. 3 CHAIRMAN ROSEN: Okay. Thank you for that 4 clarification. You've transitioned every area, but 5 many of them have stayed deterministic, say ninety 6 percent. 7 MS. KLEINSORG: Correct. 8 CHAIRMAN ROSEN: Now you have a change --9 then sometime subsequent to that you find a problem in 10 one of the deterministic areas. Can you then treat that as a risk-informed area by doing a --11 12 MS. KLEINSORG: A change evaluation. CHAIRMAN ROSEN: -- a change evaluation, 13 14 a risk-informed change evaluation? KLEINSORG: A Risk-Informed, 15 MS. 16 Performance-Based change evaluation. You would go 17 through the whole change process for that area. 18 MR. MARION: Unfortunately, it would 19 really be nice if you could make a distinctive, clean 20 separation from deterministic and make a transition in 21 the risk-informed. But when you're dealing with 22 licensing basis and the framework of the documents we 23 have to work with now, you have to evaluate the 24 deterministic and make a judgment as to what carries 25 So we're into a blended scenario. forward.

Hopefully, as we go through this exercise, with a couple of plants and utilities, maybe we can get to the point where we can make a clean transition and say this is a new risk-informed environment, Regulatory environment for dealing with fire protection going forward. But right now, it's very difficult to do that because you can't turn your back on the current licensing basis, unfortunately, and that's the practical reality of the process that we're trying to work through.

MS. KLEINSORG: Any other questions on Before we go to the next slide, I just this slide? wanted to make one point. You notice that there is no previously approved question mark box on this slide. That's very important. And that's important because we will have a previously approved -- we have an approved Fire Protection Program, and approved Appendix R Analysis, fire area by fire area. been, under the Standard License Condition, allowed to make changes without prior NRC approval if we met the test of not adversely affecting ability to achieve and maintain safe shutdown. We consider, the industry considers those evaluations, if done correctly, and there will be a process of reviewing those to make sure that they are basis for acceptability are still

1

2

3

4

5

6

7

8

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

true, we consider those part of our current licensing basis moving forward, and that we do not need to go back and ask NRC permission for those changes that we've made over the years to this compliance strategy, nor does NFPA 805 require that previous approval determination, as it does for Chapter 3 requirements and then triggers us into the License Amendment Request. So there is a -- it's subtle, but it's real to us in the industry, that change. And I think that is the way the Reg. Guide is -- not the Reg. Guide -- that's the way NEI 04-02 is written currently.

Any questions on that?

(NO RESPONSE.)

MS. KLEINSORG: Okay, let's go to the next slide.

So this has been a real -- I just wanted to lead off with this. There's been great progress made and great -- a great working environment trying to make NEI 04-02 work, and meet both -- all stakeholders' needs for it, the industry and the Regulatory bodies. And I think we have reached a lot of agreement. I think we've reached agreement on how we're going to handle the transition for Chapter 3 as far as previous approved. If we've changed a previously approved -- if, you know, had a firm pump

and now we have two, and now we have one, or we add three and now we have two, and we change it, and NFPA 805 required, you know, a certain amount and Chapter 3 required a certain amount, and we don't meet the exact word of that and we cannot find exact previous approval of that, then we will ask for the License Amendment in Chapter 3. So we have come to terms with that.

Next slide. In Chapter 4, we believe that if we had told the NRC that we had one-hour wrap and suppression detection in a fire area and now we've changed it to three-hour wrap and we're no longer crediting suppression detection in a fire area, we meet Appendix R, we can move forward without their approval of that. So that's kind of a subtle difference with how we see the transition of Chapter 3 requirements versus Chapter 4.

We've also provided tabular information and templates for how a licensee would transition that. So it would be very clear to the Inspectors going forward as to exactly what section of Appendix R and NFPA 805 we have transitioned by fire and how we meet it.

Okay. These are the aspects that I think will get tested during the pilot, that I think will

1	probably require some tweaking of 04-02, and that is
2	the determination of previous approval. You know, how
3	clear does it have to be? If it's really clear in our
4	submittal to the NRC, but not really clear in the SER,
5	you know, how previously approved are we? So those
6	are the kinds of things we're going to be testing.
7	And, as all of you who know, who's looked at an SER,
8	sometimes the SERs say exactly what we said in the
9	submittal and sometimes they don't, although the
LO	submittal may be very, very clear.
L1	So we're going to we're going to see a
L2	few of those, I think, once we start testing the
L3	transition.
L4	MR. APOSTOLAKIS: So somebody has
L5	transitioned.
L6	MS.KLEINSORG: Yes.
L7	MR. APOSTOLAKIS: So somebody has
L8	transitioned, okay.
L9	MS. KLEINSORG: Right.
20	MR. APOSTOLAKIS: Okay, and they have gone
21	through the boxes that you mentioned earlier, and all
22	that and everything's fine now. Six months later,
23	they want to change something. That would have to be
24	risk-informed?
25	MS. KLEINSORG: Yes.

1	MR. APOSTOLAKIS: So they will have to
2	calculate Delta CDF and so on?
3	MS. KLEINSORG: It could be qualitative.
4	MR. MARION: Ohhhh.
5	MS. KLEINSORG: I shouldn't have said
6	that?
7	MR. MARION: You shouldn't have said that.
8	Can we withdraw that comment?
9	MS. KLEINSORG: We can and maybe Ray
10	can help me out because we've spent hours talking
11	about this with his staff, but I have a slide
12	MR. APOSTOLAKIS: Well, the point is that
13	it would have to be risk-informed.
14	MS. KLEINSORG: It has to be risk-
15	informed.
16	MR. APOSTOLAKIS: There is no such thing
17	anymore that a monistic space, therefore, you know,
18	I'll wave my arms.
19	MS. KLEINSORG: Right. Every change
20	MR. APOSTOLAKIS: Which means they will
21	have to have a fire PRA then on that point. There is
22	no way they can avoid that.
23	DR. GALLUCCI: They could compare their
24	they could say that we did without doing a detailed
25	analysis, this is no more likely than the impact of a

1	meteor and since that's known to be ten to the minus
2	thirteen, they don't have to have a detailed
3	calculation.
4	MR. APOSTOLAKIS: These are the
5	exceptions, guys, these are the exceptions.
6	DR. GALLUCCI: That's what that is meant
7	to that's what that's meant to address, is those
8	exception cases. When you do plant changes
9	MR. APOSTOLAKIS: But for a more
10	substantive change, you would have to calculate Delta
11	CDF and Delta LERF and do the whole works.
12	MR. MARION: You will not be able to use
13	those tables, 5-2 and 5-3, without having such a PRA.
14	MR. APOSTOLAKIS: Right.
15	MR. MARION: For a substantive change.
16	You're absolutely correct.
17	MR. WEERAKKODY: Yes, I again, yes, you
18	can do a lot of things there, any substantive change,
19	you would have to have a fire PRA. But what we are
20	trying to say is that if the rule required the full
21	fire PRA at transition, rather than what the rules
22	does now, which is you've got to have a risk
23	assessment that captures the scope and the nature of
24	the change, it's too different. Because if the rule
25	requires a full fire DRA any additional requirements

that are laid on the fire PRA, for example, if the Agency says not only should you have a full fire PRA, but it should be a Level III, that is going to affect any 805 plant. But the way the rule -- when I say "the rule," not the Reg. Guide, stops it now, the essential element of risk analysis is required and the -- but we are not adding unnecessary burden unnecessary requirements. That's what the difference is. MS. KLEINSORG: Okay. Let's talk about

the change process a little.

DR. BONACA: I just had one little comment I would like to make.

> MS. KLEINSORG: Okay.

I'm still troubled by the DR. BONACA: fact that the focus seems to be using some risk analysis, whatever can work, to eliminate compliances. Risk analysis is not being used to look for weaknesses in the current Appendix R and that's a pretty unique approach, because, I mean, if I remember when we did the IPEEE, that particular -- the first intent was to look for vulnerabilities and we took care of that and then we said, okay, now let's look at Regulatory burden and we took care of that. And we're taking of that right now. In this particular case, it

1

2

3

4

5

6

7

8

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

1 is a very selective process that is being used to 2 eliminate non-compliances and I agree that it is very powerful because most of these compliances are pretty 3 4 irrelevant. I mean, they are not -- but it just 5 simply troubles me that here we have the risk-informed Regulatory Guide, you know, performance-based, and 6 7 to eliminate it's so focused on using it 8 compliances. That's a statement. 9 Well, you raise an MR. MARION: 10 interesting point because the industry and the NRC had, you know, came to a crossroads and one path was 11 12 do we apply risk-informed approaches and restructure all of the Regulations and look at that level of 13 14 effort, and the difficulty and challenges with that, 15 and the second path is do we look at the applications of the Regulations and apply risk-informed approaches 16 17 to the applications, and whether there is a right or wrong thing to do, that's the path that we've chosen. 18 19 DR. BONACA: Yeah, I understand. CHAIRMAN ROSEN: And you're saying by 20 21 analogy, this is the same thing? 22 Yes, but it's more of MR. MARION: Yes. 23 a hybrid because we don't have that clean separation 24 between deterministic and risk. But it's an

improvement over the Regulatory framework we currently

1 have. 2 CHAIRMAN ROSEN: Well, then this is the 3 opportunity to do it, Mario, and what George has been 4 suggesting is to find the vulnerability. 5 DR. BONACA: Right. CHAIRMAN ROSEN: Until the plant decides 6 7 to do a full scope fire PRA, and then they fall out of 8 the process. 9 MR. MARION: Yes. 10 MR. APOSTOLAKIS: This is just the 11 transition. 12 I know, I know, but just CHAIRMAN ROSEN: following on Alex's point, that you don't get the 13 14 benefits that you are seeking until, in this process, 15 but at some point, the plant says well, to do this process, I've got a lot of fire areas I want to 16 address; I'm worried about multiple spurious and I'm 17 worrying about interactions; I might just as well bite 18 19 the bullet and do a good fire PRA; we've got the 20 guidance now from the re-quantification effort. 21 some plants, I understand they are doing just that. 22 And they accrue the benefits of finding their own 23 vulnerabilities and so does the public. 24 MR. APOSTOLAKIS: But, again, at the same

what benefit would the plant have if

time,

1	identified vulnerabilities using PRA?
2	
3	CHAIRMAN ROSEN: Benefit?
4	MR. APOSTOLAKIS: Yes. Would the NRC say,
5	"Boy, you guys are great; therefore, we'll do this for
6	you," or are they just inviting trouble?
7	CHAIRMAN ROSEN: I don't think they're
8	inviting trouble. I think that finding
9	vulnerabilities is an important part of running an
10	enterprise.
11	MR. APOSTOLAKIS: They are inviting
12	trouble.
13	DR. BONACA: No, because, I mean, when
14	they when you identify a problem, they are self-
15	identified, especially if you have an aggressive way
16	to look at it, and the NRC and TPRA recognizes that
17	and they support you. I mean, it is not going to be
18	the question is when you don't find the problems
19	because you're not looking for them.
20	CHAIRMAN ROSEN: That's right. When
21	they're self-revealing, or found by the Agency, that's
22	a different story.
23	MR. APOSTOLAKIS: That's a different
24	story.
25	But the Agency is not looking because the Agency is
	T .

1	not doing risk assessments either.
2	CHAIRMAN ROSEN: That's right.
3	DR. BONACA: Well, but an Inspector can
4	walk around and find the other problem, or the, you
5	know, NRC may have sent a number of communications
6	regarding the plant, et cetera, and the licensee has
7	not responded.
8	MR. APOSTOLAKIS: Now, this NEI 04-02 is
9	not just for the transition period, right?
10	MS.KLEINSORG: No, it's the whole most
11	of it a lot of it deals with the transition, but it
12	does deal with price transition also.
13	MR. WEERAKKODY: Liz, can I interrupt and
14	say something
15	MS. KLEINSORG: Yes.
16	MR. WEERAKKODY: Because you are talking
17	about the vulnerabilities. I know of three reasons
18	why the vulnerability screening or that whole aspect
19	is fully addressed within the Agency. First, as
20	you'll know, the IPEEE, if you look at Addenda 80, 20
21	and Sub 21 (phonetic), the responses to that came to
22	the Agency and those are commitments on the part of
23	the licensee. So that still holds because, you know,
24	we have been we have hardly none 805 plants,

meaning that there is a number of plants -- that there

1	are more plants out there and they have no intention
2	about 805. So the second thing is the back approval.
3	As we all know, 5109 if anything that, you know, is
4	found by the licensee or the industry will be
5	challenged for adequate safety, then the Regulatory
6	requirements is there. And the third thing, you are
7	right, we don't normally go and look more than the
8	tri-annual and the annual and the quarterly kind of
9	inspections, but if there's reasons to inspect, you
10	know, for example, in the multiple spurious, we target
11	some of these and I send my best PRA folks to look.
12	Dr. Ray Gallucci just visited one of the plants that
13	we think may have issues that they may not have
14	identified, and he came back and told me no, they have
15	done the analysis.
16	So we sometimes, you know, go beyond as a
17	Regulator in the requirements to look at it it is
18	out there. I just want to make that clear.
19	MS. KLEINSORG: Okay. Change Process.
20	This is the other fundamental process that we have
21	developed in NEI 04-02 and an important attribute of
22	this change process is that all changes are required
23	to be risk-informed.
24	MR. APOSTOLAKIS: After you transition.
25	MS. KLEINSORG: After you transition, that

is correct. The process that we've set up is very similar to the current 5059 screening, which is now the Fire Protection Regulatory Review Process 9607, NEI document that was endorsed by the staff. There is a number of checklists that have been added to NEI 04-02 and a number of screening criteria.

We do have one remaining issue that we're discussing with the staff and that is the ability to perform equivalency evaluations on Chapter 3 requirements. And I thought I'd take you through the change classes and kind of talk a little bit about then and now going forward.

This is one of our favorite diagrams in NEI 04-02. This is the Change Process and it's laid out in Chapter 3 of the 04-02 document. I think a couple of -- well, the key point that I want to bring up here is you come down, you define the change, identify whether it's a Chapter 3 requirement or not -- a Chapter 3 requirement, can you do an engineering equivalency evaluation, and we've given some examples, and I actually go through some of those examples in the last two slides.

We believe that there are certain things where equivalency evaluations can still be done and should be allowed. Otherwise, I think the staff will

1	be over-burdened by License Amendment Requests. But
2	we're working on that.
3	Even if it doesn't require a License
4	Amendment Request, it still goes through the risk
5	check. Everything goes through the risk check.
6	MR. APOSTOLAKIS: What are you working on?
7	The staff has agreed to this?
8	MS. KLEINSORG: No.
9	MR. APOSTOLAKIS: No?
10	MS.KLEINSORG: I don't think I think
11	that's one of the last things the differences
12	between 04-02 right now. Right?
13	MR. WEERAKKODY: This is probably the only
14	thing I'm cognizant of.
15	MS. KLEINSORG: I think it is now.
16	MR. WEERAKKODY: We are working on the
17	details, yes.
18	MR. APOSTOLAKIS: Where does it in the
19	Regulatory Guide say you are in disagreement?
20	MS. KLEINSORG: It
21	MR. APOSTOLAKIS: You're only excluding
22	Chapter 6.
23	MS. KLEINSORG: You brought that up, Bob,
24	right?
25	MR. RADLINSKI: Yeah, the Rule requires
	I

1	that you deviate from Chapter 3 that the NFPA
2	identified, that you have to submit a License
3	Amendment, right?
4	MR. APOSTOLAKIS: Can you point me to the
5	actual Regulatory Guide where you say this?
6	MR. RADLINSKI: 3.1.4. Page 9 of the Reg.
7	Guide.
8	MR. APOSTOLAKIS: Page 9.
9	MR. RADLINSKI: It's a deviation from
10	Chapter 3, unless it's been previously approved,
11	documented as being previously approved by the NRC,
12	then it has to be submitted.
13	MR. APOSTOLAKIS: Alright.
14	MS. KLEINSORG: Is the language you're
15	writing, NFPA Code, still in the draft Reg. Guide?
16	Regarding whether the authority having jurisdiction
17	needed to look at equivalency evaluations?
18	MR. RADLINSKI: I'm sorry.
19	MS.KLEINSORG: There is a section in the
20	draft Reg. Guide that talked about NFPA Code
21	specifically requiring AHJ approval.
22	MR. RADLINSKI: You mean earlier?
23	MS. KLEINSORG: Oh, there we go. Right.
24	MR. RADLINSKI: Tentative records?
25	MS. KLEINSORG: Yes.

1 MR. RADLINSKI: Yes, that's still in 2 there. MS. KLEINSORG: 3 That's still in there. 4 Right. It's in 3.1.4. Page 9. 5 CHAIRMAN ROSEN: So I've lost the track Now if you do an engineering equivalency 6 7 evaluation, that has to be approved by the AHJ? Yeah, that's the NRC's 8 MS. KLEINSORG: 9 And our position is we do them now. example would be a block sprinkler head. 10 11 suppression and -- well, there's two different ways of 12 looking at it. Chapter 3 requires that if you -- if Chapter 4 -- let me take a big step back. If Chapter 13 14 4 requires a suppression system, and Chapter 3 15 requires that suppression system be installed with the 16 appropriate NFPA Code. It's our position, the 17 industry's position is that the NFPA Code doesn't tell you where to put the suppression system and fire area. 18 19 It tells you how to ensure that it's adequate for the 20 -- if it's installed, where it should be. 21 always been allowed to do engineering evaluations that 22 say, you know, the fire area is this big, but we only 23 need to put the suppression system over here. 24 always been able to do partial suppression detection 25 evaluations and we considered -- we would consider

1	those the types of engineering equivalency evaluations
2	that we should still be allowed to do because they're
3	more meeting Chapter 4 requirements than Chapter 3
4	requirements. That's a very key point. Utilities
5	have to be able to assess a block sprinkler head and
6	say, oh, it's still adequate for the hazard. Because
7	I don't think the NRC wants License Amendment Requests
8	for every one of those we find going forward.
9	DR. WALLIS: Is this where the
LO	performance- based comes in?
L1	MS. KLEINSORG: Pardon me?
L2	DR. WALLIS: Is this where the
L3	performance- based part comes in?
L4	MS. KLEINSORG: Yes.
L5	MR. APOSTOLAKIS: No.
L6	MS. KLEINSORG: Yes, this is performance-
L7	based.
L8	MR. APOSTOLAKIS: If you are allowed to do
L9	it now, why can't you be allowed to do it in the
20	future?
21	MS. KLEINSORG: Because Chapter 3 requires
22	that deviations from NFPA Codes require approval of
23	MR. APOSTOLAKIS: Chapter 3 of what?
24	MS. KLEINSORG: NFPA 805. We just want
25	clarification on that going forward.

1	MR. APOSTOLAKIS: Right.
2	MR. MARION: And we have not sent the
3	staff the final draft of our Guidance document, but in
4	that draft, we've identified examples of what requires
5	a License Amendment Request and what does not. And
6	we're hoping that we can get their concurrence on that
7	and I plan to submit that to them tomorrow.
8	MR. APOSTOLAKIS: One other question for
9	you.
10	CHAIRMAN ROSEN: But we're being asked to
11	bless the Reg. Guide without that knowledge, without
12	that final piece understood.
13	MR. WEERAKKODY: We are.
14	CHAIRMAN ROSEN: So in time for the June
15	meeting, we will need it.
16	MR. MARION: Okay.
17	CHAIRMAN ROSEN: Well, I don't know how we
18	could endorse the Reg. Guide with a piece of it still
19	under discussion between your team, the staff and NEI.
20	MR. WEERAKKODY: We are having the next
21	meeting June 2 <sup>nd</sup> , right? We will have it ready by
22	then, yes.
23	MR. APOSTOLAKIS: Yeah, but, I mean, we
24	have to read it.
25	MR. WEERAKKODY: Okay.

1	DR. WALLIS: No matter which way you go,
2	you end up in front of the
3	MR. WEERAKKODY: What we will do is
4	what we will do
5	MR. APOSTOLAKIS: Draft letters are like
6	Rules. They don't change easily.
7	(LAUGHTER.)
8	DR. WALLIS: Now, we've spent an hour and
9	twenty minutes and we've not yet talked about risk and
10	I'm interested in getting to this risk part of this
11	whole thing.
12	MR. APOSTOLAKIS: Yeah.
13	DR. WALLIS: Well, I think I'm going to go
14	because no matter what you do, you end up doing the
15	risk screening.
16	MS. KLEINSORG: That's correct.
17	MR. MARION: Yes, it changes.
18	MS. KLEINSORG: No matter what change you
19	do, you must do a risk screening.
20	DR. WALLIS: How do you know that the risk
21	is how do you know that change impacts the risk
22	non-negligibly?
23	MS. KLEINSORG: You'd have to do the
24	evaluation. The checklist takes you through the
25	evaluation. For PRAs

1	MR. APOSTOLAKIS: There's always a problem
2	with this kind of question.
3	CHAIRMAN ROSEN: What's your question?
4	MR. APOSTOLAKIS: There are three
5	categories as I recall: negligible, very small
6	MS. KLEINSORG: No, it's we've actually
7	made them I think there's two: negligible and non-
8	negligible.
9	MR. APOSTOLAKIS: You borrowed them from
10	the new language of 5059, right?
11	MS. KLEINSORG: Right. Small and
12	MR. APOSTOLAKIS: So negligible
13	MS. KLEINSORG: Greater than small or very
14	
15	MR. APOSTOLAKIS: Negligible, negligible
16	square, and negligible cubed.
17	MS. KLEINSORG: Really, really negligible.
18	MR. APOSTOLAKIS: Yeah, really, really
19	negligible.
20	DR. WALLIS: One over
21	
22	MR. APOSTOLAKIS: Yeah, I guess the only
23	thing there is that you have to convince the staff
24	that it's negligible square. And if it is not, then
25	you go on to the numbers, right?
ı	I and the second

	191
1	MS. KLEINSORG: That's how it's set up.
2	MR. APOSTOLAKIS: Yeah. And the reason is
3	what Sunil said earlier, that 5059 itself does not
4	apply here?
5	MR. WEERAKKODY: That's correct.
6	MS. KLEINSORG: That's correct.
7	MR. APOSTOLAKIS: So you are creating the
8	equivalent of a 5059?
9	MR. WEERAKKODY: Yes, similar, yes.
10	MR. APOSTOLAKIS: That's what you're
11	doing.
12	MR. WEERAKKODY: Yes. Yes.
13	MR. APOSTOLAKIS: Oh, but then if they
14	find something that's negligible, they don't have to
15	justify it to you?
16	MS. KLEINSORG: We have to maintain
17	MR. APOSTOLAKIS: Unless you guys ask.
18	MR. WEERAKKODY: If it's
19	MR. APOSTOLAKIS: Unless you ask.
20	MR. WEERAKKODY: That's correct, yes.
21	MR. APOSTOLAKIS: Because that's what 5059
22	does.
23	MR. WEERAKKODY: Yes.
24	MR. APOSTOLAKIS: It gives you the freedom
25	to

1	MR. WEERAKKODY: It does.
2	MS. KLEINSORG: And the Change Process
3	that we've set up makes the licensee document, the
4	conclusion as to why something has been screened as
5	negligible and that's retained for the life of the
6	plant. Just like 5059.
7	CHAIRMAN ROSEN: I think that the
8	utilities would believe there is a very high
9	likelihood that those changes will be reviewed by the
10	staff in the field.
11	MR. APOSTOLAKIS: At least
12	CHAIRMAN ROSEN: Pardon me?
13	MR. APOSTOLAKIS: At least in the
14	beginning.
15	Yeah, I don't see why they should be, frankly. A lot
16	of changes are negligible.
17	CHAIRMAN ROSEN: Well, that's why they're
18	being reviewed, to make sure that the Inspector
19	generally agrees that there's nothing in a pile of
20	changes that catches his eye.
21	MR. APOSTOLAKIS: Okay, but when you move
22	to the quantitative risk evaluation and you have this
23	footnote that says that this is a more complex
24	qualitative evaluation, you really lose me completely.
25	DR. GALLUCCI: Let me handle it. Those

are my words in there.

1

2

3

4

5

6

7

8

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

25

MR. APOSTOLAKIS: Oh.

MS. KLEINSORG: Thank you, Ray.

DR. GALLUCCI: In an earlier version of NEI 04-02, there was a distinction made that the simple -- the upper level in that diagram would be qualitative and the lower level would be quantitative. I don't like that distinction, that simple equal qualitative; complex equals quantitative, So I asked them to re-word it so that automatically. they would include that you could have -- a simple analysis can be qualitative and most likely will be qualitative, but can be quantitative, typically, on an order of magnitude type of thing. Maybe some of the early steps you would see in the Fire Protection SDP, might consider sort of hybrid qualitative and quantitative. Now while I don't necessarily envision such a thing as detail qualitative analysis off the top of my head, I can conceive that there may be such things and possible examples would be if you go to Step 2.8 of the Fire Protection SDP, the HRA tables that choose the Gamma, Beta and Alpha factors, the Gareth Parry type table, one could consider that a detail, but still more of a qualitative type of evaluation. So that's one area

1 that might fit into that definition. 2 Another area might be what's done at 3 plants during outage management where they identify, 4 maybe seven or eight, safety functions that have to be 5 maintained while they're reconfiguring the plant for the various outage strategies, and they do sort of a 6 7 redundancy order of magnitude calculation where you calculate just how many trains of a certain system are 8 9 left, and there are some sort of formulas that enable 10 you to determine whether you're overall pseudo risk 11 level is green, yellow, orange or red. Again, one can 12 argue that that is not really quantitative, but it is a detailed, well-based type of technique that all 13 14 plants use. So that's another thing that I would 15 consider, probably something -- what I would call a 16 detail qualitative. So it's kind of a catch-all 17 phrase. DR. WALLIS: You said you had numbers in 18 19 it, so it must be --20 DR. GALLUCCI: Yeah, numbers like one and 21 two. 22 But they are bounding or WALLIS: 23 something, they're guiding?

It's not where you calculate it and come up with

DR. GALLUCCI: It's quasi-quantitative.

24

1	probabilities.
2	MR. APOSTOLAKIS: But why not? Why not
3	actually calculate probabilities? At which point are
4	you saying do a fire risk assessment? No. Maybe that
5	thing we're using trains, we'll do that here, too.
6	Why not say, "Quantitative risk evaluation requires a
7	fire risk assessment. Thank you very much."
8	DR. WALIS: Well, to be quantitative is
9	sort of making excuses, and detailed quantitative is
10	making many excuses.
11	MR. APOSTOLAKIS: Yeah, it's all excuses.
12	DR. WALLIS: That doesn't necessarily make
13	it better.
14	DR. GALLUCCI: Because NFPA 805 will not
15	allow us to come out and say you have to do risk
16	assessment. Until it's amended, you're stuck with
17	what NFPA 805 is.
18	MR. APOSTOLAKIS: Wait a minute, now.
19	Even if it says "quantitative risk evaluation," you
20	cannot require a risk assessment?
21	DR. GALLUCCI: Correct.
22	MR. APOSTOLAKIS: Well, why don't you
23	require risk assessment? They come to you with stuff
24	that we just mentioned, then you are going to review

it and you may find it acceptable. Define what "risk

1	assessment" is.
2	DR. GALLUCCI: I require risk assessment,
3	but I'm not the only reviewer.
4	MR. APOSTOLAKIS: But wait a minute now.
5	"Risk assessment" means a lot of things. Okay. So
6	you say you are doing quantitative risk evaluation;
7	you have to have a risk assessment. Now if a guy
8	comes in with an extended qualitative semi-
9	quantitative analysis, you might say that, in this
10	particular application, this is good, but you don't go
11	out of your way to explain that this is the way to do
12	it.
13	Anyways, I mean, this is a perennial I
14	mean consistent theme here.
15	CHAIRMAN ROSEN: Yes, so that I think
16	we're
17	MR. APOSTOLAKIS: We're trying to stay
18	away from risk assessment.
19	CHAIRMAN ROSEN: going to be very much
20	late getting to lunch unless we move forward.
21	MR. APOSTOLAKIS: Some of us have planes
22	to catch. So we can't be too late.
23	CHAIRMAN ROSEN: Well, I'm not trying to
24	encourage the movement
25	MS. KLEINSORG: Okay.

1	MR. APOSTOLAKIS: Yeah, we understand.
2	MS. KLEINSORG: So I just wanted to finish
3	up the Change Process evaluation. Did Bob want to
4	did you want to make one point or not?
5	MR. RADLINSKI: Well, I missed your
6	example and that's fine.
7	MS. KLEINSORG: Okay, we'll go through the
8	examples again. Alright.
9	MR. RADLINSKI: Well, from what I've heard
10	of it, it may not be a difference of opinion.
11	MS. KLEINSORG: I haven't seen the latest
12	version of the Reg. Guides I mean the
13	DR. WALLIS: Well actually maybe I should
14	say something.
15	MS. KLEINSORG: Okay.
16	DR. WALLIS: When you get down to the
17	bottom here, you have "DID" and "SM." Now, "SM," you
18	have some definitions which are useful. "DID"
19	contains your here on Page 53 of this thing.
20	There's a lot of quantitative statements, which again,
21	very qualitative
22	MR. APOSTOLAKIS: Which page are you on?
23	DR. WALLIS: liable to a wide range of
24	interpretations.
25	MS. KLEINSORG: Defense-in-Depth.

	138
1	DR. WALLIS: DID is defined in terms of
2	qualitative statements which I suspect different
3	reviewers would assess differently.
4	MR. APOSTOLAKIS: Actually, the
5	description of safety margins is much superior to
6	DR. WALLIS: That's what I said. They do
7	a good job on safety margins. It's the DID part.
8	MR. APOSTOLAKIS: So we are in agreement?
9	DR. WALLIS: Yeah. The DID part, where
10	it's the bottom step here, and I think there are
11	qualitative statements, liable to a range of
12	interpretation, while we're on the issue of
13	qualitative thinking. Since you flipped very quickly
14	out of the guts of the whole process here.
15	MS. KLEINSORG: Let's talk a little bit
16	more about the guts of the process in the next few
17	slides. The Change Process, I just wanted to kind of
18	give you a juxtaposition of what we can currently do
19	versus what we're going to be doing going forward with
20	805. The acceptance criteria changes from the ability
21	to achieve and maintain safe shutdowns has not been
22	adversely affected to Defense-in-Depth Safety Margin
23	in the Reg. Guide 1.174 criteria, essentially, for the
24	change evaluation that the utilities now will be using

to make those changes. Their license condition will

actually be changed and I think that's in the Reg.

Guide.

Okay, next slide. Currently we can make

any change to our Fire Protection Program without prior NRC approval as long as we meet the standard license condition and have not violated -- or not undoing an approved Exemption Request.

Going forward under 5048, Charlie, we are not going to be allowed to make changes to Chapter 3 requirements that are performance-based unless we get a License Amendment Request. Now, we provided some screening criteria for Chapter 3 changes and I think that's what we were talking about where we have to come to terms with the NRC, and I'll go through some examples of those. We might be actually in violent agreement at this point, but I haven't seen the last Reg. Guide yet.

And then all that under Chapter 4.

Currently Chapter 4 is just very similar to our standard license condition now.

Okay. Examples. These are examples that we had in the NEI 04-02 document of changes that we would not consider requiring a License Amendment:

Replacing a fire-rated component with another fire-rated component. Still has a rating. It meets some

1	sort of rating criteria and, therefore, it's a change
2	to a Chapter 3 requirement, but it's it's an
3	equivalency change. An equivalent change. Change in
4	frequency of a fire protection feature based on a new
5	NFPA standard. As long as the underlying basis for
6	the standard is consistent with the underlying basis
7	for how we maintain our systems.
8	DR. POWERS: Let me ask you a question.
9	MS. KLEINSORG: Sure.
10	DR. POWERS: The material when it's fire-
11	rated. If a company comes out and says that they have
12	a fire-rated material that has a 3-hour rating
13	
14	MS. KLEINSORG: Yes.
15	DR. POWERS: and it is easily it
16	will take my fire rating material one hour and I can
17	slap this on and it's three hours, so I do it. Is
18	that okay?
19	MS. KLEINSORG: Well, it would be okay if
20	it met all the criteria of the NFPA standard it was
21	judge against and the testing criteria. I would
22	assume if it's a new system
23	DR. POWERS: It says it does.
24	MS. KLEINSORG: Oh, I would have to check
25	it. And if it does if I do check it and I make the

	141
1	same conclusion during my change evaluation process,
2	then that would be okay. I mean, but you would still
3	it would have to meet if it's a new material, it
4	would have to meet Generic Letter 8610, Supplement 1
5	criteria for
6	DR. POWERS: He says it does.
7	MS. KLEINSORG: He says it does.
8	MR. MARION: Well, the utility will
9	evaluate it
10	MS. KLEINSORG: Evaluate it.
11	MR. MARION: to confirm it.
12	MS. KLEINSORG: Right. One would hope.
13	MR. ERTMAN: This is Jeff Ertman, Progress
14	Energy. We would have to have that proved to us, our
15	evaluation that they did do the testing and it does
16	meet the standards.
17	MR. MARION: Without belaboring the point,
18	the challenge has been, over the years, the conduct of
19	tests has evolved and we've gotten a lot smarter. And
20	we will continue to improve and evolve as we go
21	forward. And anyone who brings a new product to
22	market and claims that he's tested it to the latest
23	requirements, the utilities are expected to evaluate
24	it and confirm that that is, indeed, the case.

Whatever the latest requirements and expectations may

1	be.
2	DR. POWERS: I mean the problem is, Alex,
3	as you well know, we've had people come forward and
4	say they've tested and they've gotten all sorts of
5	testimony swearing that it was the greatest test ever,
6	and we have all been burned by relying solely on what
7	is advertised.
8	MR. MARION: Yeah.
9	DR. POWERS: I would hope that we would
10	learn from those lessons.
11	MR. MARION: I think we will.
12	DR. POWERS: I certainly hope so. We
13	can't afford not to.
14	MR. MARION: After that, I don't think
15	so.
16	DR. POWERS: Well
17	(LAUGHTER.)
18	MR. MARION: There's a lifetime.
19	MS. KLEINSORG: There's a cycle.
20	MR. POWERS: Well, that's true. That's
21	true.
22	MS. KLEINSORG: And last, of course, there
23	is a corollary to everything where you will not
24	require a License Amendment and we do believe that

there are things where we would require a License

1	Amendment if it was a change to Chapter 3. Reducing
2	the number of fire brigade members to below five, it
3	clearly says you have to have five. There's no way
4	around it.
5	DR. POWERS: Can you do that and not run
6	afoul of the OSHA rules?
7	MS. KLEINSORG: Pardon me?
8	DR. POWERS: Can you do that an not run
9	afoul of OSHA rules?
10	MS. KLEINSORG: Two men in two in, two
11	out? Yeah. You two in, two out, it's only four.
12	So I don't think you could go below, much below five
13	and still meet OSHA Regulations, although I'm not an
14	expert.
15	DR. POWERS: Yeah, I think you'd run into
16	problems somewhere.
17	MS. KLEINSORG: Right, right.
18	DR. POWERS: In OSHA Regulations.
19	MS. KLEINSORG: Just in the safety
20	yeah.
21	MR. APOSTOLAKIS: The risk, for example,
22	would be sensitive. I don't see how you can get a
23	Delta CDF by going to 4.
24	MS. KLEINSORG: Right. So that and
25	that was the purpose of that was actually the

1 purpose, the underlying purpose of some of Chapter 3 2 and NFPA 805. There were things that the NRC and the held sacred 3 industry kind of that couldn't 4 evaluated away necessarily. I mean, there are a lot 5 of programmatic issues, which would be very difficult to assess from a risk perspective, I think. 6 7 DR. GALLUCCI: You could -- you could do something though by varying the manual suppression 8 9 probabilities. You could increase the manual suppression probabilities, assuming you have less fire 10 brigade members, and you could do some sensitivities. 11 12 MS. KLEINSORG: Right. DR. POWERS: It seems to me that if you 13 14 cold not do the two in, two out, you would just have 15 to say that there is not going to be any manual fire 16 plan. 17 MR. APOSTOLAKIS: What's two in, two out? DR. POWERS: It's an OSHA Rule on confined 18 19 Fire fighting -- you put two men -- if you're 20 going to put two people in there, you've got to have 21 two people outside to rescue those two if they get in 22 trouble is the basic thing. And it's -- it is my 23 perception that our fire plans still have not 24 completely accommodated that rule. My perception.

don't know that for a fact.

1	CHAIRMAN ROSEN: Okay.
2	MS. KLEINSORG: That was the end of my
3	presentation.
4	MR. RADLINSKI: Liz?
5	MS. KLEINSORG: Bob?
6	MR. RADLINSKI: Bob Radlinski.
7	DR. WALLIS: Are you going to say it?
8	MR. RADLINSKI: I'm sorry?
9	CHAIRMAN ROSEN: Go ahead, Dr. Wallis.
10	DR. WALLIS: I'm baffled by this whole
11	process. I thought we were going to hear about how
12	you use risk information in this whole process of fire
13	protection. You seem to be getting tied up with this
14	endless discussion of processes which don't use risk
15	at all. So I'm not quite sure what we're hearing. I
16	mean, it doesn't seem to be here I don't seem to be
17	hearing what I came here to hear. So I'm befuddled by
18	this whole thing. Maybe I'm the only one.
19	DR. GALLUCCI: I think the risk it's
20	Ray Gallucci. I think the risk processes would
21	encompass what you heard a couple weeks ago from the
22	Research people, things from the Fire Risk Re-quad
23	Study, aspects of the Fire Protection SDP on a more
24	scooping nature
25	DR. WALLIS: I came here with great

1	enthusiasm to hear about how you're going to
2	revolutionize things by using by being risk-
3	informed. I haven't really heard it. Again, maybe I
4	have the wrong assumption.
5	MR. APOSTOLAKIS: Well, they key slide
6	that explains why you didn't hear it is Slide 10.
7	CHAIRMAN ROSEN: Yeah, the block under
8	"quantitative risk evaluation" on Slide 10. We just
9	jumped over that. Because everybody knows what you're
10	going to do
11	MR. APOSTOLAKIS: No, it was not the
12	Chapter slide. It was this other one. The Info Slide
13	5.
14	DR. WALLIS: You do the best you can with
15	
16	MR. APOSTOLAKIS: That says that everybody
17	wants to be deterministic and, as a last resort
18	DR. WALLIS: That is impossible to do
19	deterministically, and then you this last resort
20	MR. APOSTOLAKIS: As a last resort, you go
21	to risk, yeah.
22	DR. WALLIS: As a last resort, you go to
23	risk. That's very strange.
24	MR. APOSTOLAKIS: That's why you haven't
25	heard more about it.
I	I control of the cont

1	DR. WALLIS: Very peculiar.
2	MR. APOSTOLAKIS: Because the problem is
3	that fire protection engineers are trained to be
4	awfully deterministic.
5	DR. WALLIS: Another thing. While we're
6	talking about NEI 04-02 I guess we're talking about
7	that, are we?
8	MS. KLEINSORG: Yes.
9	DR. WALLIS: I thought the best part of
10	the whole thing was Appendix D.
11	MR. MARION: Thank you.
12	DR. WALLIS: It was very good, a very nice
13	overview of the state-of-the-art of fire models.
14	MS. KLEINSORG: Thank you. I will pass
15	that on.
16	MR. APOSTOLAKIS: Yeah, that was a good
17	thing.
18	MS. KLEINSORG: Thank you.
19	DR. WALLIS: I don't know who wrote it,
20	but it is a good, a very good job
21	MR. APOSTOLAKIS: A very detailed proper
22	use.
23	DR. WALLIS: of explaining what we can
24	do and what we cannot do.
25	MR. APOSTOLAKIS: Can be state-of-the-art.

1	DR. KLEINSORG: Phil DiNenno wrote it.
2	MR. APOSTOLAKIS: It is the state of the
3	practice of fire analysis.
4	CHAIRMAN ROSEN: I have the feeling that
5	you're being more than not kind to this effort, in
6	the sense that on Slide 10, there is a block entitled
7	"Detailed Quantitative Risk Evaluation" and one could
8	spend however much time you want to talk about that,
9	you know, we're going over Appendix D and all the
10	rest.
11	MR. APOSTOLAKIS: No, but Ray just told us
12	that you can work around it.
13	CHAIRMAN ROSEN: I understand that, but
14	I'm
15	saying that there is a way to do quantitative risk
16	evaluation in NEI 04-02 or referenced by it, shown on
17	these graphs and I don't think you should leave with
18	the impression that it
19	MR. APOSTOLAKIS: After you transition?
20	CHAIRMAN ROSEN: Yeah, yes should
21	leave the impression that it's not there. It is. It
22	just wasn't discussed today. We skipped over it.
23	DR. WALLIS: I thought it was, you know,
24	the use of risk was going to be more was going to
25	play a bigger role in this whole show, that's all.
ļ	I control of the cont

1	MD ADOGROTANTO. Desires the terresition
1	MR. APOSTOLAKIS: During the transition
2	phase, evidently it doesn't. That's really what the
3	message is.
4	MR. MARION: We would be more than happy
5	to brief you after we go through this exercise with a
6	couple of plants. I think that would
7	MR. APOSTOLAKIS: Oh, yeah.
8	CHAIRMAN ROSEN: And to hear in particular
9	where they use quantitative risk evaluations.
10	MR. APOSTOLAKIS: Definitely.
11	MR. MARION: Is that okay, Jeff?
12	MR. ERTMAN: Yes.
13	MR. APOSTOLAKIS: So where are we?
14	CHAIRMAN ROSEN: Well, we're up to the
15	next item on the Agenda, which is Mr. Dipert, I think.
16	MR. APOSTOLAKIS: And this gentleman is
17	talking about?
18	CHAIRMAN ROSEN: The Agenda? Inspection
19	Procedure.
20	MR. APOSTOLAKIS: Thank you very much.
21	MR. HANNON: While we're setting up, this
22	is John Hannon. I want to make sure that I picked up
23	the right signal from the Committee. Based on our
24	initial statement of desire for approval of the Reg.
25	Guide, did I understand from the last discussion that

1	the Committee is not inclined to endorse the Reg.
2	Guide because there was an issue that was still on the
3	table that we had not worked through?
4	CHAIRMAN ROSEN: I think what you heard
5	was that we would need to discuss that amongst the
6	Committee when the presentation is finished.
7	MR. HANNON: If there is if that's
8	going to be an issue, I want us to come back and
9	revisit that before we close up.
10	MR. APOSTOLAKIS: What issue is this? I'm
11	sorry, I missed it.
12	CHAIRMAN ROSEN: There's an open question
13	on engineering equivalency that is still being
14	discussed between the staff and the industry.
15	MR. RADLINSKI: After listening to Liz's
16	presentation, I don't think we have a problem. I
17	think and we were just about to have a sidebar
18	discussion on that. I think we are in agreement
19	pretty much. We just have to work out the final
20	details.
21	CHAIRMAN ROSEN: Well, is there are
22	there changes that would be made in the NEI document
23	or in the Reg. Guide to support that?
24	MR. RADLINSKI: The Reg. Guide does not
25	have to change. I'm not sure about 04-02. I haven't

1	seen the latest version.
2	CHAIRMAN ROSEN: Well, that's the
3	question. If such changes are needed, then we'd have
4	to have
5	MR. WEERAKKODY: I think what we would do,
6	Chairman Rosen, is anything that anything that we
7	change, we would have a little sidebar, because as you
8	know, we have spent a lot of time reading NEI 04-02,
9	so anything that has changed from the version you saw
10	when you get copies, we are going to highlight those
11	pages or those paragraphs for your information. Okay?
12	And that's we will definitely do that.
13	CHAIRMAN ROSEN: Okay, let's go on. We
14	are quite a bit behind.
15	MR. MARION: Alex Marion. Just to make
16	sure I understand the process. The next step for the
17	NRC is to put the draft Reg. Guide out for comment,
18	right? Or is it going to
19	MR. WEERAKKODY: We did that six months
20	ago.
21	MR. MARION: Oh, that's right.
22	MR. WEERAKKODY: September $30^{h}$ , we issued
23	the draft for comments.
24	MR. MARION: I must be thinking about the
25	Regulatory Issues. For some reason, it just came out.
J	I and the second

Sorry.

1

2

3

4

5

6

7

8

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

25

CHAIRMAN ROSEN: Please. No, that's not you -- oh, yes, I'm sorry. Go ahead. Inspection.

MR. WEERAKKODY: Just as a lead-in, before over to Rich Dipert here, when the Commission approved the 805, it clearly endorsed different things that the staff can do to eliminate the uncertainties for licensees who plan to update to 805 because the Commission recognized that on one hand, the licensees who would update to 805 would be spending a lot of resources that the others don't, reinvestigating their licensing basis and, as such, they will find stuff that the other licensees don't. And then also the Commission recognized that any time you change your licensing bases and go to a new environment, as a licensee you take a risk. list the four -- the three key areas, one was the enforcement, the licensees were concerned that when they step out and do self-assessment to transition, they didn't want to be penalized by those findings and such, Commission approved enforcement as the Not meaning that they don't have to fix discretion. the problems, but they can identify them and fix them under the 805 environment. Then the second thing was the Reg. Guide, and I know one of the significant

1	concerns most licensees have even today is that how is
2	the Agency going to implement this. And I think the
3	tool that will address that is 805, the Reg. Guide,
4	which is what we are seeing today. And the third and
5	the final thing that's in front of us is Inspections.
6	And what you're going to hear now from Rich is details
7	of that not details, our plan for that. In
8	comparison to the Reg. Guide, please bear in mind that
9	this is our plan. In other words, the Reg. Guide, we
10	are coming to you for your approval with the finished
11	product. Whereas, the Inspection, what we will go
12	through is what we will deliver over the next nine
13	months. So with that can you go to the second
14	slide, please?
15	Rich is going to go over the first four bullets and
16	I'm going to come back to the last bullet, the Summary
17	of Approach, and when I go to the last bullet, I will
18	address some of the concerns you had with respect to
19	the PRAs and how we would make sure that, you know,
20	our oversight responsibility would address that.
21	MR. DIPERT: Thank you. Can everyone hear
22	me? Is this mike turned up?
23	I'm Richard Dipert. I'm the engineer in
24	charge of this phase of the program. I have the
25	simple part. I have to make it work. And when I

1	addressed the industry for the first time, I said
2	simply, "We will, we will, trust me." I can speed
3	things along I you'll accept that same explanation.
4	CHAIRMAN ROSEN: We trust, but verify.
5	MR. DIPERT: Okay. Then this phase
6	consists of two tasks: preparing input for proposed
7	inspection procedures, parallel to existing procedures
8	7.11, 11.05(t), that's the tri-annual fire protection
9	inspection procedure, and the similar annual/quarterly
10	fire protection inspection procedure used primarily by
11	resident Inspectors at sites. The second part of this
12	task is preparing the training materials for resident
13	Inspectors, regional Inspectors, and headquarter staff
14	doing those inspections. The method of that, delivery
15	of that training is still to be determined.
16	Next slide.
17	DR. WALLIS: Was the Inspector going to
18	determine that some change that's been made is
19	negatively has a negligible effect on risk?
20	MR. WEERAKKODY: Can we if you can wait
21	for the last slide, let me address that.
22	DR. WALLIS: I'm just interested in how he
23	would manage, or she would manage to do that.
24	MR. WEERAKKODY: I'll
25	DR. WALLIS: You'll get to that?
I	

MR. WEERAKKODY: Yes, last slide.

MR. DIPERT: As we looked at the inspection procedure format, we decided to propose producing new inspection procedures. Again, for the tri-annual fire protection audit for plants adopting an NFPA 805 and quarterly, an audit, annual audit procedures for plants adopting NFPA 805.

I think we recognized that there were differences in compliance strategies from the Appendix R plants, which are primarily prescriptive plants. Trying to put these into a single procedure would have been needlessly complicated to inspect both the existing plants and the new ones, new format. We are looking at doing this in a format that is parallel to the existing procedures so that the Inspectors will see procedures that they're familiar with and it should be a straightforward process. I won't say it will be easy, but I believe it will be straightforward to bring the regional Inspectors and the resident Inspectors up to speed with a procedure that they can become familiar and comfortable with.

Also, developing separate procedures will give us a set of procedures that we can allow evolutionary incorporation of lessons learned and we're going to have a lot of those as we go through

1	the
2	DR. WALLIS: Are you going to tell us what
3	new tools the Inspectors will have?
4	MR. WEERAKKODY: The fire models?
5	DR. WALLIS: Are they going to have a fire
6	SPA model?
7	MR. WEERAKKODY: The fire models and the
8	PRA models.
9	DR. WALLIS: Something like a fire SPAR
10	model? Do you know what a SPAR is?
11	MR. WEERAKKODY: Yeah, I know. I used it.
12	For two years. Yes, you know, they will have that
13	yes, the Inspectors have access to the fire protection
14	SDP, they have access to the SPAR if they want to go
15	to that level of detail.
16	MR. APOSTOLAKIS: So it would be a fire
17	PRA?
18	MR. WEERAKKODY: Yes, they will have
19	access to those.
20	DR. GALLUCCI: Ray Gallucci. Research is
21	currently beginning a project where they are going to
22	update the SPAR models for fire PRA where it's
23	available. I think to date, they've done two, but
24	it's very limited by which plants have I don't
25	think more than twenty-five percent of the plants have

1	fire PRAs and none of them have them of the vintage
2	that meets the new NUREG CR6850 Re-quad Study.
3	MR. APOSTOLAKIS: Wouldn't then this
4	adoption of 805 accelerate the process? Wouldn't that
5	be an incentive for the utilities who actually
6	MR. WEERAKKODY: Yes. Yes.
7	MR. APOSTOLAKIS: Because they already
8	have the IPEEE.
9	MR. WEERAKKODY: Yes.
10	MR. APOSTOLAKIS: And all they need to do
11	is upgrade?
12	MR. WEERAKKODY: Yes.
13	MR. DIPERT: Next slide. As part of this
14	phase, we've gathered a working group together. This
15	working group has PRA expertise, fire protection,
16	engineering expertise. We have a representative from
17	the Inspections Branch. And we have regional
18	Inspectors from two of the regions with fire
19	protection electrical and mechanical expertise.
20	The charter for this working group
21	includes serving as a source of knowledge as we go
22	through writing the procedures, reviewing and
23	commenting on the procedures, and reviewing and
24	commenting on the training materials. We're trying to
25	get the regions involved from the very beginning so as

1 to make this process move forward as easily and as 2 quickly as possible. 3 CHAIRMAN ROSEN: You have one 4 representative from each region? 5 MR. DIPERT: No, sir, have one we 6 representative from Region 2 and one representative 7 from Region 4. Right now, we're anticipating -- since the two committed pilots, or one committed and one 8 9 tentatively committed pilots are both from Region 2, we wanted to certainly get them onboard. Region 4 has 10 had some plants that have looked at using PRA 11 12 techniques from NFPA 805 without committing to an NFPA 805 transition and they expressed the interest in 13 14 getting involved in the writing. 15 As we -- on the next slide, we'll discuss how we're going to have all of the regions reviewing 16 this. 17 The other regions are staying in touch, but they do not have active members on the --18 19 CHAIRMAN ROSEN: I just worry about one 20 region later on saying, well, we were too disconnected 21 from the process. We do things differently enough 22 here that --23 Our normal process would MR. WEERAKKODY: allow 24 that. I have Peter Koltay from the 25 Inspection Branch in the back. And every Regulatory

1 product that has an impact on how the regions do business has a formal 30-day -- is that a 30-day 2 3 comment period, Peter? 4 MR. KOLTAY: This is Peter Koltay from the 5 Inspection Branch. We're still going to follow our normal process for issuing the procedures, so that 6 7 means that each region will reflect and comment on the 8 procedures and their comments will be incorporated. 9 If there is any training involved, all regions will be involved in the training. So it's not like we're 10 exclusively going to use Region 2 and another region 11 12 in this process. This process has been 13 CHAIRMAN ROSEN: 14 fragmented in a lot of ways for many, many years and 15 I think it's the poster child for where you need ultimately good communication, when you're changing 16 17 something. WEERAKKODY: One of the -- and I 18 MR. 19 didn't want to talk about it -- we have semi- -- we 20 are developing lesson plans for semi-annual training 21 for the four regions and 805 is one of the subjects 22 that we will cover. 23 MR. KOLTAY: I also see some SRA 24 involvement from the regions as well because --25 Oh, absolutely. CHAIRMAN ROSEN:

MR. KOLTAY: -- this is more risk-informed than we had.

CHAIRMAN ROSEN: When we visit the regions, which we do once a year, we always hear from -- we hear from the SRAs a lot and I remember comments from SRAs like, "Well, we're spending an inordinate amount of time on findings from inspections, and particularly findings from the fire area." So let's just pass that along.

MR. DIPERT: To assist with this, we also have a contractor onboard, Pacific Northwest National Laboratory. This contractor has a great deal of experience, produced the draft Regulatory Guide, and other fire protection standards. In short, here I believe that we have the right group onboard to write it, to write these procedures, and the write group onboard to guide it and comment on it.

Next slide, please. Our milestones for this, this is a very aggressive schedule. We're looking at having draft input on the first tri-annual, the first procedure input, the tri-annual, by June of 2005. We're looking at providing that to the working group for their comment. We're looking at the fire protection section transmitting draft input to the Inspections Branch for regional review by August of

1	2005. We will be making presentations at the NEI Fire
2	Protection Information Forum in late August in San
3	Francisco on the draft pre-decisional input. We'll be
4	holding the regional stakeholders meeting to resolve
5	comments by October of 2005. And we look to have the
6	input for the REV. 0 for the Inspections Branch for
7	review and implementation by December of 2005.
8	DR. WALLIS: Well, this is all just things
9	you plan to do. Do you see any difficulty with
10	providing useful materials to the Inspectors so that
11	they can implement this?
12	MR. DIPERT: No.
13	DR. WALLIS: Are there any snags or
14	anything? Or is it all just going to be
15	straightforward? You can plan it and it'll happen?
16	MR. WEERAKKODY: It's not going to be
17	straightforward. I think we have to work at
18	especially with the inspections in the Regulatory PRN
19	Fire Modeling.
20	DR. WALLIS: Right.
21	MR. WEERAKKODY: Yeah, that's a challenge
22	we have and I'll go
23	DR. WALLIS: I just wonder if it's a bigger
24	challenge than you think.
25	MR. WEERAKKODY: Well, we know it's ahead

of us.

1

2

3

4

5

6

7

8

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

25

DR. WALLIS: Just because you have a schedule doesn't mean to say that you're going to be able to do it.

MR. DIPERT: I expect that REV. 0 may be We have transition pilot plan framework. observational visits that we're going to be seeing over the next two years. The best way to push this -to compare this inspection pilot procedure is to take that against the observation visits of the pilots and use it on a trial basis. To push that procedure, to use it, yes, I expect there will be further revisions I haven't seen a REV. 0 that captured everything in twenty years of engineering practice. But putting this out, I think, helps the regions and the residents capture -- have something to look at. It helps industry look at what they're doing and what they're going to be inspected by and to do it in time to look at most of the observation visits allows us to apply it against that and then to come back as part of the lessons learned and improve it. This is a plan, There are a lot -- I hope I -- when you're correct. I said I had the simple job, I only had to make it happen, that's a little bit "tongue-in-cheek."

DR. WALLIS: Well, I understood that. But

1	this whole idea that you can do it may turn out to be
2	an illusion.
3	MR. WEERAKKODY: 805 was an
4	DR. WALLIS: You have the tough job,
5	really.
6	MR. WEERAKKODY: We've had our challenges,
7	but
8	DR. WALLIS: This is the tough part of the
9	job as I see it, implementing it.
10	MR. DIPERT: Sunil just wants to jump
11	right in there and
12	MR. WEERAKKODY: Now, I have the schedule.
13	CHAIRMAN ROSEN: Alright, this is good.
14	Now you have a clear field to do anything you want.
15	DR. WALLIS: Black writing on a
16	blackboard.
17	CHAIRMAN ROSEN: You're unconcerned by
18	anything by any ideas that might have been put on
19	the last slide?
20	MR. DIPERT: We expect draft training
21	materials, again, to be end of the year. Final
22	training materials, after observation visits. We are
23	looking at training sessions after one or more of the
24	observation visits. We are planning to take these to
25	the regions. Those plans haven't been firmed up yet,

1	but we expect to keep the regions this has to be
2	usable by them. That's the focus. And if it's
3	there's no there's no way not to there's no way
4	that I can fail at this. Failure is not the option
5	here; it has to be useful by them.
6	CHAIRMAN ROSEN: Well, you envision, I
7	presume, some licensees doing some actual fire
8	modeling?
9	MR. DIPERT: Yes.
LO	CHAIRMAN ROSEN: And, therefore, some of
L1	your field people are going to have to recognize
L2	they're looking at fire modeling, a), and b) they
L3	ought to be at least conversive enough to pick up the
L4	phone and ask somebody back here if it's okay.
L5	MR. DIPERT: Yes.
L6	CHAIRMAN ROSEN: So I don't expect them
L7	to
L8	be experts in fire modeling necessarily.
L9	DR. WALLIS: Well, maybe some great big
20	CFD program that uses beautiful colored pictures and
21	says, "This is a fire." And the Inspector has to
22	decide, "Do I believe that?"
23	CHAIRMAN ROSEN: So we kind of gave you
24	the answers already. But you will encounter fire
25	modeling and I guess

what's your view of that?

1

2

3

4

5

6

7

8

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

25

MR. WEERAKKODY: Yes.

MR. DIPERT: I thought -- well, in previous employers, I've been at the point where I've been, both as a researcher at the Bureau of Standards, developed some of the early fire models, and as a Chief Fire Protection Engineer for a State Fire Marshall's Office, I've been in the position where I had to evaluate those fire models and had to help other people, other fire Inspectors, who had less training.

MR. KOLTAY: Let me comment on that a little bit because this has been a touchy point for the past couple of years for us. And I don't know if you remember Doug Coe, who used to be my boss in this area, was very concerned about the training and capability of Inspectors to assess the licensees in this area when they do this transition. And while some discussion has been going on here about PRA and fire models, the first -- at least the first two licensees will have full PRAs and we don't have Some of the thoughts Inspectors who can assess those. we have is to have, just like you indicated, by fire modeling, they may recognize a fire model, but we could develop some kind of checklist perhaps that will

ask them to look at a couple of key areas to give reasonable comfort that the licensee's model makes sense. If you want to go beyond that, anything beyond that would have to be reviewed by at last an SRA or some risk analyst with capability beyond an SRA, definitely not by the Inspectors in the field. But we want to be able to give enough tools to the Inspectors that they can recognize a potential issue.

CHAIRMAN ROSEN: Yeah, SRAs will have to be expert in PRA, and I'm impressed by their growing knowledge levels, but they aren't likely to be experts in fire modeling.

MR. KOLTAY: They may not, and as long as an Inspector can recognize that he has a potential issue with a model or anything that the licensee has done in this area, and can move it up the ladder of expertise in that area, that's good enough for the Inspector and inspection guidance.

CHAIRMAN ROSEN: I should think that any time a licensee does a calculation based on one of the fire dynamics tools that the Inspector can have a look at it for sure, but after about a few hours of having a look, it probably rates a phone call back here for someone to say, "I'm looking at use of a fire model to make a decision to clean an area out or not or make a

1	change or not. My guess is it looks okay, but what do
2	you guys think?"
3	MR. WEERAKKODY: This happens today, but
4	to describe Naeem is in the back there, he's my
5	fire modeling expert. Whenever there is a contingency
6	issue, whenever Inspectors have questions, he gets
7	calls and because he's
8	DR. WALLIS: You're taking a great leap
9	forward, it seems to me, in putting these in
10	combining these fire models with a PRA because the
11	PRAs that we have for accidents don't take much
12	account of thermal hydraulics criteria which bypass a
13	lot of this, an understanding of the thermal
14	hydraulics.
15	MR. WEERAKKODY: I don't see
16	DR. WALLIS: You're going to bring in the
17	
18	DR. KOLTAY: This is success criteria.
19	DR. WALLIS: physics into this?
20	MR. WEERAKKODY: Yeah, I look at the fire
21	models as something that
22	DR. WALLIS: It's success criteria, but
23	it's a lot of you know, it's just very high level.
24	You're not looking at details of how it's modeled.
25	MR. WEERAKKODY: I look at the fire models

1	as something that feeds into the PRA, or could feed
2	into the PRA.
3	DR. WALLIS: Oh, it should, but that
4	MR. APOSTOLAKIS: The physics of it, yes.
5	In the fire PRA, yes. You have the fire modeling,
6	right.
7	CHAIRMAN ROSEN: It feeds into the PRA.
8	It will tell you whether a given cable is damaged or
9	not, presumably, and then you put that into the PRA.
10	MR. WEERAKKODY: I mean I know you had
11	like a half-day presentation on fire modeling from
12	Research, you know, we have come a long way from the
13	days of conburn (phonetic) which are used widely by
14	police. Now we have not one, but Research has given
15	us four models of different degrees of
16	CHAIRMAN ROSEN: You had the
17	applicability for different problems.
18	MR. DIPERT: We'll let Sunil discuss the
19	last page, which may not be the next slide or is
20	this
21	MR. APOSTOLAKIS: Is this part of the
22	Regulatory Guide?
23	MR. WEERAKKODY: No, this is the
24	Inspection.
25	MR. APOSTOLAKIS: Yeah. So the letter we

1	are asked to write is on the Regulatory Guide?
2	MR. WEERAKKODY: Yes.
3	MR. APOSTOLAKIS: So this is extra?
4	MR. LAIN: These are extra presentations.
5	I talked with
6	MR. APOSTOLAKIS: Extra presentations. I
7	need to have some input from the members on what they
8	want to see in the letter.
9	DR. WALLIS: Well, I think this is
10	critical. I think this is critical. I mean, if we
11	don't believe that the inspection can demonstrate
12	that, you know, ultimately the satisfaction of the
13	safety of these changes that are made, then I think it
14	impacts back on the Regulatory Guide and whether it's
15	acceptable.
16	MR. APOSTOLAKIS: I have a inspection
17	program. We know that.
18	DR. WALLIS: See, I heard Dr. Gallucci say
19	that the Inspectors are going to also help us
20	understand what the safety margins are. I mean, and
21	I see one looking at these fire models and saying,
22	well, is it approximately okay for this kind of
23	application or is it appropriate to this application.
24	That takes one level of engineering judgment. It
25	takes quite a different engineering level of judgment

1	to really understand the uncertainties of those models
2	and say, well, not only is this applicable, but it
3	provides me a safety margin. And I see that as a
4	tremendous burden on the inspection activity. We all
5	recognize that the typical Inspector clearly can't do
6	that. Is he going to be able to bring it back to
7	people in the region or back at headquarters that can
8	do that? So I think we have to see a process that
9	enables us to demonstrate that there really is, built
10	into this, safety margin and Defense-in-Depth.
11	MR. WEERAKKODY: Do you want me to go over
12	this?
13	MR. APOSTOLAKIS: No.
14	MR. WEERAKKODY: No?
15	MR. APOSTOLAKIS: Well, the Chairman is
16	there. Why do you look at me?
17	CHAIRMAN ROSEN: Well, I think, yeah, you
18	ought to finish your presentation. You've got one
19	more short presentation there.
20	MR. WEERAKKODY: Okay. What I was
21	planning to do is, in fact, to focus at a high level
22	on the main differences between inspection of the
23	current versus the future 805 plans and in this slide,
24	you know, I have highlighted the three areas that the
25	Inspectors of 805 would focus on. Specifically, our

1	focus is going to shift to the acceptability or the
2	use of fire hazard models. The acceptability of the
3	change condor (phonetic) process that they have used
4	and how they have used Reg. Guide 1.174 and Risk
5	Assessment 2. I know Dr. Wallis mentioned he came
6	here to hear about PRA. One of the things that you
7	should know is that there is a connection between
8	not a between the Regulatory tools that are being
9	developed like, for example, user presentation on
10	NUREG CR6850.
11	So even though we didn't elaborate on that
12	kind of tool, when the Inspectors go and they look at
13	whether a particular model or particular method is
14	acceptable, the Inspectors are going to ask is this
15	acceptable or not. So we are going to rely on the
16	NUREG CR6850 and the fire PRA models and fire PRA
17	methodologies that are specified there. You know,
18	they will be making those decisions.
19	CHAIRMAN ROSEN: And the internal events
20	PRA. It reflects back onto the internal events PRA>
21	MR. WEERAKKODY: To the extent that
22	happens, yes.
23	CHAIRMAN ROSEN: I mean if you have
24	damage, if you calculate damage, after you go through

6850 modeling and you calculate there's going to be

1	some damage to cables, you have to identify what
2	systems are damaged, when are they damaged, and go
3	back into the internal events PRA and make the
4	necessary changes to take those systems out of service
5	at the right moment, and then make the internal events
6	runs and see what the CDF changes are. I mean it's a
7	process. There is nothing mysterious about that, but
8	the tools are hard to use, technically challenging in
9	some cases, and well beyond the buy-in expectations
10	for any resident or regional inspector.
11	MR. WEERAKKODY: I don't know whether you
12	use the most recent tools that NRI and Research
13	developed, the NUREG 1805 (phonetic) tools? I don't
14	know whether Research made a presentation on those.
15	CHAIRMAN ROSEN: On the fire dynamics
16	tools?
17	MR. WEERAKKODY: Yes.
18	CHAIRMAN ROSEN: Yes, I know about them.
19	MR. WEERAKKODY: So I you know, we have
20	been giving repeated training to Inspectors on how to
21	use them, so I think even the Inspectors have come
22	CHAIRMAN ROSEN: You think I'm
23	underestimating the regional and resident Inspectors?
24	MR. WEERAKKODY: Yes, yes, I think so.
25	CHAIRMAN ROSEN: I hope so.

1 MR. WEERAKKODY: Because if you look at my 2 semi-annual training plan, I have a half-day dedicated 3 for training them on that kind of tools. I can't make 4 them experts, but there is a recognition that you 5 can't risk-inform a plant without risk-informing the 6 Inspectors. 7 DR. GALLUCCI: This is Ray Gallucci. All the regional fire Inspectors have been trained on the 8 9 fire protection SDP and I think next month there's the 10 training on NUREG CR6850 in Charlotte, which at least, the SRAs will be attending. So they are -- they 11 12 should be up to speed on all the aspects of the fire protection SDP which, in a sense, is a kind of a 13 14 compilation of some of the more important aspects of 15 NUREG CR 6850. So they have received the training. Whether they're comfortable with it, it varies. 16 17 CHAIRMAN ROSEN: It sounds like the snow, the knowledge is filtering down, but it's going to 18 19 take time and then, of course, it takes years, too. 20 You can't become an expert on something you might have 21 heard about and have been trained in if you've never 22 used it. 23 MR. WEERAKKODY: Yeah, I just came to 24 agreement to hold the next semi-annual fire protection

training at Region 2 because it's -- and then that's

1 going to be like a two and a half day or three day 2 training, and like I said, 805 tools are just part of the picture, and we are going to --3 4 MR. LAIN: Let me make a programmatic 5 statement here that we're trying to get this procedure 6 out, or at least a REV. O out by December, but we 7 really -- this is for post-transition inspections, so 8 it really won't be used until, let's say, Oconee, you 9 The issues are transitioning in -- the end of 2007/2008 timeframe. 10 And so, you know, we're are going to still 11 have a couple of years to identify items that, you 12 know, they need more training and we're still going to 13 14 work on this. We're trying to get a procedure out now 15 to help reduce some Regulatory uncertainties, have the licensees feel a little bit better that this is how 16 17 we're doing this. 18 CHAIRMAN ROSEN: I agree you have some 19 lead time --20 MR. LAIN: So we've got some -- we've got 21 some work to do. 22 CHAIRMAN ROSEN: -- and that's a good 23 thing, and as long as you don't fritter it away. 24 MR. LAIN: Yeah. 25 Now, Mr. Lain, your CHAIRMAN ROSEN:

1	presentation, or Mr. Apostolakis, do you have a
2	request for input?
3	MR. APOSTOLAKIS: Yes. Can I get my input
4	before the presentation? Because the presentation
5	really is not relevant to the
6	CHAIRMAN ROSEN: I don't know what's going
7	to be in the presentation, but I
8	MR. APOSTOLAKIS: Transition of the Pilot
9	Program.
10	CHAIRMAN ROSEN: Pilot Program. I will
11	ask the other members to
12	MR. WEERAKKODY: And we lost two already.
13	CHAIRMAN ROSEN: Well Mario looks like
14	he's gone; Dana may come back.
15	DR. DENNING: I'm okay.
16	CHAIRMAN ROSEN: I'm okay, too. Are you
17	in any
18	MR. APOSTOLAKIS: No, no, but can you give
19	me some advice?
20	CHAIRMAN ROSEN: All right, I understand.
21	Let's just start. Dr. Denning?
22	MR. APOSTOLAKIS: The request is to
23	approve the Regulatory Guide?
24	MR. WEERAKKODY: Yes.
25	DR. DENNING: At the moment, I would have

	176
1	serious reservations. I don't think I'm at that point
2	yet and my colleague can give you some guidance.
3	MR. APOSTOLAKIS: Can you send me an E-
4	mail?
5	DR. DENNING: I'll send you something, yes.
6	MR. APOSTOLAKIS: In the next two or three
7	days?
8	DR. DENNING: Yes.
9	MR. APOSTOLAKIS: Good. Thank you.
10	CHAIRMAN ROSEN: Dr. Wallis?
11	DR. WALLIS: I think I've said it, but I
12	just don't know what you could possibly put in your
13	letter.
14	MR. APOSTOLAKIS: Say again.
15	DR. WALLIS: I said I don't know what you
16	could put in your letter. The Regulatory Guide is
17	supposed to be about Risk-Informed, Performance-Based
18	Fire Protection and we haven't heard much about that
19	at all.
20	MR. APOSTOLAKIS: So you're voting?
21	DR. WALLIS: Like I said, I don't know
22	what took place here today.
23	MR. APOSTOLAKIS: You don't know, so you
24	also have reservations?
25	(No response.)

MR. APOSTOLAKIS: Mr. Chairman?

CHAIRMAN ROSEN: Well, I think this is a process step that's needed. And one needs to get the Reg. Guide out if only to let people know where the staff is headed. I think it's a competent job. is a piece missing, which troubles me a little bit, but I assume that we can -- I'm going to bet that we So, I can rectify that, that that can be handled. would say, having -- yeah, we didn't hear a lot about risk analysis or fire, as Dr. Wallis said. Maybe he had expectations that we would. I did not have those So I don't feel quite the way he does. expectations. I have studied in some detail the re-quantification document, 6850, so I -- at least I know what's intended to be done in the risk analysis and have looked at the dynamics tools and the V&V of those tools, so I at least know what's in process.

I do want to say everything's moving -- a lot of these pieces are inter-connected and they're all moving together at varying speeds, but I think they're all moving in the same general direction, which is to put out a full panoply of tools and techniques used to change the situation we're in in the area of fire protection regulation. I think that's a good thing. I support the staff and I would

1

2

3

4

5

6

7

8

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

vote to issue the Reg. Guide.

MR. APOSTOLAKIS: I

meeting in June you present you

MR. APOSTOLAKIS: I suggest that at the meeting in June you present very clearly what the requirements are during the transition and what the requirements are after the transition. Today, we had to -- started to get about it, but during the transition, it's largely a deterministic effort. After the transition, if anyone wants to make a change, that has to be risk-informed. Right? After the transition?

MR. WEERAKKODY: Yes.

MR. APOSTOLAKIS: Also, there is some problem with the language in the Reg. Guide here. I mean, this quantitative thing being --

MR. RADLINSKI: Can I go back to what the Chairman said here? I agree with the big picture, what they seem to be trying to do, which is to bring in risk information, bring in fire modeling and to upgrade the whole process, and have a far better way of assessing how to make decisions about fires and how to improve public safety. But we seem to have gotten lost in details which are tangential to that. So how to get out of using risk, how to find ways around it and all that kind of stuff.

DR. WALLIS: That's the annoying thing.

1	MR. RADLINSKI: This seems very I'm
2	baffled by that.
3	MR. APOSTOLAKIS: Yes, they seem to be
4	going out of their way not to do a risk assessment.
5	DR. WALLIS: Right.
6	CHAIRMAN ROSEN: Well, I agree with that
7	feeling and that's a little puzzling to me, but I
8	understand it.
9	MR. APOSTOLAKIS: Well, how can we change
10	that?
11	CHAIRMAN ROSEN: Well, I understand it.
12	I understand where it's coming from, I think, having
13	been in the industry for many years, that there are
14	some industry participants who don't want to move this
15	way, want some of the benefits of it, of the risk-
16	informed approaches, and NEI being a consensus
17	organization of all the utilities, is trying to
18	accommodate them. So this comes through.
19	MR. APOSTOLAKIS: But this is voluntary,
20	Steve.
21	CHAIRMAN ROSEN: I understand.
22	MR. PARTICIPANT: Okay, well, thank you.
23	MR. RADLINSKI: Can I interject a comment
24	about your Dr. Rosen, your comment about a missing
25	piece, and I believe its involvement with respect to

1	the equivalency?
2	CHAIRMAN ROSEN: Right.
3	MR. RADLINSKI: Liz Kleinsorg and I had an
4	opportunity to speak outside about this issue and
5	after talking about it, we realized that we were not
6	in disagreement. We are in agreement, okay, so it is
7	not a missing piece. It's not an exception.
8	CHAIRMAN ROSEN: So you don't think the
9	Reg. Guide will change?
10	MR. RADLINSKI: The Reg. Guide does not
11	need to change. They may take some of their examples
12	out and maybe change some of the wording in their
13	document.
14	CHAIRMAN ROSEN: The NEI document?
15	MR. RADLINSKI: Right.
16	CHAIRMAN ROSEN: There might be some
17	changes there. Well, frankly, I didn't spend a whole
18	lot of time on the Reg. Guide after reading it once or
19	twice. I just went to this document. This is really
20	what will be the 04-02 is what will really
21	MR. RADLINSKI: Right, but it's really not
22	the approach that they're going to be changing; it's
23	just some of the examples that they have in there that
24	demonstrates that approach.
25	CHAIRMAN ROSEN: Okay. Well, maybe that

1	simplifies it. We still have the problem, though, of				
2	dealing with the concern of at last two members, maybe				
3	three, that the way this is written, the lowest common				
4	denominator approach, tends to appear as if the Agency				
5	is trying to push a less Reg. risk method, set of				
6	methods than, I think, you would all prefer. So				
7	that's a maybe a case of emphasis or the way it's				
8	presented. In any event, if that's all George has				
9	gone, so we don't need to give him anymore input.				
10	DR. WALLIS: Well, this is I'd like to				
11	see a presentation on how do we move to this Risk-				
12	Informed, Performance-Based Fire Protection approach,				
13	and there seems to be much more of a discussion of how				
14	do we sort of apply doing it. What are all these				
15	other alternatives whereby we can use part of it or,				
16	you know, use qualitative rather than quantitative and				
17	so on. This seems to be a backwards approach.				
18	CHAIRMAN ROSEN: Maybe, Paul, you want to				
19	do your last presentation?				
20	DR. WALLIS: Well, actually I read the				
21	stuff. I thought that the NEI 04-02 was actually				
22	quite a good document. When it was presented here,				
23	this is a precise other aspects than I would have				
24	emphasized.				
25	MR. LAIN: I think we were just trying to				

emphasize probably what was left in discussion between us and NEI. I think that's what they were trying to go over. I think, you know, I think we're in agreement on how to do the combined risk analysis. So I think what they were bringing up were some last issues that we were just trying to work out and get through. So maybe it didn't come through. We could have spent, you know, hours talking about the risk analysis.

DR. WALLIS: Well, one of the things we're always told by -- at least some of the Commissioners, that it's not the ACRS' job to spend a lot of time reviewing processes. And we spent an awful lot of time here reviewing the process. We weren't reviewing the principles, sort of, you know, the big objective and that sort of thing. We got caught up in all these details in the process. That's not really where the ACRS adds the most value.

MR. LAIN: Yes, sir. So for the June meeting, we'll concentrate on the technical. I guess we have an hour and a half for June 2<sup>nd</sup>. Maybe the problem is that some of the members who were not at the Re-quantification Briefings, verification and validation briefings, would have preferred to hear that in some detail. And in even more detail than was

1 presented at those meetings. So I would -- since that 2 sets the foundation of this, the technical foundation 3 of this, perhaps some emphasis on that might be useful 4 so the Committee knows this is not all built on air. 5 MR. NOURBAKHSH: The first day of June we 6 think we have a presentation on re-quantification by 7 Research. 8 CHAIRMANR OSEN: Okay, well that'll help. 9 MR. LAIN: Yeah. Dr. Rosen, this is John 10 HANNON: I just want to revisit this point that I 11 Hannon. think was made earlier by Sunil. We are constrained 12 in the development of the Regulatory Guide to 13 14 consistent with the Rule that it is embellishing. So the Rule itself does not require the rigorous level of 15 PRA assessment that you all are looking for here, and 16 17 so that's what we're constrained by. We can't write something into the Req. Guide that wasn't incorporated 18 19 in the Rule language itself. 20 ROSEN: I think we all CHAIRMANR 21 understand that, John, think what and Ι 22 interested in is where is the state-of-the-art, like 23 Chairman Wallis says, we're not experts on NRC process 24 and the Commission doesn't want us to become experts,

but where we might be able to add value is in some of

1	the more technically-founded areas. So that's why our
2	interest in this is there.
3	MR. WEERAKKODY: I think my take-back is
4	just to make sure on June 2 <sup>nd</sup> our presentation could
5	spend more time on the change evaluation and how we
6	would plan to use the V&V or the fire models and the
7	PRAs to enable that.
8	CHAIRMAN ROSEN: Right.
9	MR. WEERAKKODY: Rather than focus on the
10	overall process.
11	DR. WALLIS: But the title of the Reg.
12	Guide is misleading. It says "Risk-Informed,
13	Performance-Based Fire Protection." It implies that
14	that is what it's selling. Apparently, it isn't.
15	CHAIRMAN ROSEN: I wanted to give Dr.
16	Powers a chance to make any comments about any piece
17	of this that he chooses to because he was out of the
18	room when we went around the table. Dana?
19	DR. POWERS: Well, I suspect that you need
20	to give some serious consideration on first of all,
21	you've got to have a complete Reg. Guide to look at.
22	The ECRS as a whole is not going to accept evaluating
23	half a Reg. Guide. That's
24	CHAIRMANR ROSEN: I think also when you
25	were out of the room, they came back and said that

this one little piece which was not -- on equivalency evaluations, they have had a meeting and they don't have a problem with it and they'll likely not be any changes to the Reg. Guide.

DR. POWERS: Okay. Well, I mean -- it's a painful experience of saying one little piece turned into half the Reg. Guide changed. So the ACRS as a whole is surely not going to be enthusiastic about looking at an incomplete Reg. Guide. I think on this some serious Guide, you need to give consideration of some trial Professor uses, as Apostolakis suggested, because I think there are real serious misgivings about trying to do risk-informed regulations without risk information. And risk information, -- there are places for qualitative evaluations, but quite frankly, the risk information is quantitative information and if you're not going to do that -- you've got to start really thinking about "truth-in-advertising" here.

I think that's -- I think that's where the conundrum is going to arise here.

CHAIRMAN ROSEN: I'm going to add that comes back to Chairman Wallis' comment about the title of this thing. It's Risk Information, Performance-Based fire protection for anybody who wants to go that

1

2

3

4

5

6

7

8

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

way, but there are ways to do it differently, too, in this Reg. Guide.

DR. POWERS: Then there were discussions on fire modeling that may be done in connection with this. We've discussed this in the past and we've certainly seen some very interesting presentations recently on the Risk Re-quantification Study, I think. But I still think that as an institution, we are not moving aggressively to get to the state-of-the-art in that way to support our Inspectors when they have to evaluate other people's fire modeling. And I think that's -- especially when I look at the IPEEEs and I see risk CDF numbers comparable to normal operations and I say we're not investing heavily in this area to to be the state-of-the-art. I mean, we're certainly try to get to the state-of-the-art from a hydraulics. Lots of people question whether we're there or not, but we, at least, try. It's not clear to me that we're making the same aggressive effort in fire modeling that we're -- that the risk information would suggest we should be. And I can be sympathetic with people in the regions when they are concerned about the level of support they're going to have implement some of these things.

CHAIRMAN ROSEN: Yeah, we had a little

1

2

3

4

5

6

7

8

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

1 discussion of that, but that still is to play out. 2 Okay, well, thank you very much. 3 Paul, I will turn the floor over to you 4 for 5 a brief of a summary presentation on transition of the 6 programs. 7 Okay. We'll skip the outline. MR. LAIN: We'll talk -- the high-level objective, I quess is 8 really to provide Regulatory stability to the plants 9 transitioning. Our purpose, there are some proposed 10 11 items that we hope to see from our pilot program. 12 We're really still in the planning stages of putting the pilot program -- we've been really working heavily 13 14 with the Reg. Guide. So we are going to -- our next 15 big, big item, besides the Inspection Procedures, is the pilot program and putting something together. 16 17 So here are the activities to develop a we're planning 18 program plan and on conducting 19 quarterly observation visits and those are going to be 20 negotiated with the pilot plants. But for planning 21 purposes, we've said quarterly observation visits. 22 Each observation visit will have a Trip Report and 23 then at the final, you know, prepare a lessons learned 24 report. 25 Our team right now, we're making up --

1	we're four members: a fire protection engineer, PRA			
2	specialist, and then someone also from regional			
3	support, somebody who's good in safe shutdown			
4	electrical, but also to include the region and get a			
5	regional aspect, the inspector aspect in that, and			
6	we're also going to be requesting PNNL to assist us			
7	since they've got a great background in this field			
8	also. They've been assisting us along the way for the			
9	last five or six years.			
10	DR. WALLIS: Can I go back to the			
11	MR. LAIN: Sure.			
12	DR. WALLIS: You have these pilots and is			
13	the purpose to use this NFPA 805, or is it to use			
14	risk-informed, performance-based methods because it			
15	seems quite possible that these utilities may decide			
16	all to take to shun the risk-informed stuff and			
17	simply find a way around it the way we heard about			
18	this morning.			
19	MR. LAIN: Well, there would be			
20	DR. WALLIS: That's what an NFPA 805 would			
21	let them do. In this case, you wouldn't have learned			
22	much about using risk information at all.			
23	MR. LAIN: From my point of view, and it			
24	makes more sense for them, if they've got issues to			
25	deal with, there are screening processes in the NEI			

04-02 to sort of screen away a lot of the low-risk items.

MR. WEERAKKODY: In practice, it cannot happen, mainly because one of the things we would look at during the pilot transition is changes, change evaluations. And every change evaluation requires a risk assessment. So event though it is a possibility, I don't expect that to happen. And we know Oconee's right now, developing five PRAs or Duke is developing five PRAs for all of their plants.

MR. LAIN: So these are some of the outcomes we are expecting to help us improve the inspection procedures in the SRP and lessons learned to help us develop templates for our License Amendment Requests. There are some in NEI 04-02. I think we're going to be able to hone in and also help us with the templates on the Safety Evaluation Reports, on the review parts.

We are planning to spend, the pilots are planning to spend not just to when the plants send in their License Amendment Requests, but to -- also, the pilots will encompass the NRC review of those License Amendment Requests. So the pilots will also cover that portion of the NRC's review of the License Amendment Requests.

1	You know, we're planning on have good
2	communications with the Inspection Procedures Working
3	Group with NOR RES is still working on products for
4	us, the regions and also industry, NEI and the public.
5	So we're planning on I'm sure we'll have some
6	public meetings along the way.
7	And also, if necessary, we're going to,
8	you know, go back and enhance the Reg. Guide and NEI
9	04-02 for any details that we need to refine or we
LO	find that we need to update.
L1	DR. WALLIS: These outcomes won't occur
L2	until '07?
L3	MR. LAIN: I'm thinking these outcomes are
L4	going to occur along the way.
L5	DR. WALLIS: Along the way.
L6	MR. LAIN: I think, you know, as we are
L7	spending time with the licensee, there will be
L8	questions arising and then we'll work on those and try
L9	to work them in as soon as possible to any of the
20	Regulatory documentation.
21	DR. WALLIS: So you might be announcing
22	the Reg. Guide before '07?
23	MR. LAIN: I think so. And I think we're
24	also going to be looking at including Research's
25	products into the Reg. Guide also. So I think we'll

1 probably end up with a revision before '07. 2 So, the penguin's off the ice, I guess. Industry's interest. Duke. Duke is -- within their 3 4 Letter of Intent said that --5 MR. PARTICIPANT: You're going to be quenched like a fire? 6 7 MR. LAIN: Oconee is a volunteer. They're actually putting a program plan for their -- Liz is 8 9 helping them put a program plan together for their And they -- my initial discussions with 10 transition. 11 them is that they're going to basically flag some best 12 parts for observation visits to come out and see. They'll have stuff completed for us to come review and 13 14 that's going to help us also in putting our plan 15 together. We're talking with Progress Energy this 16 afternoon. Their indications are that they would like 17 Harris to be the second pilot plant. An advantage to 18 19 them is we've already gone to the CFO and gotten their 20 Fee Waiver for their License Amendment Request. 21 that'll be a good advantage for them and for them 22 putting in their time for having us come out and 23 working with us to go over and review their process. 24 So this is where we're at today.

schedule is to try to put the program plan together

1	this summer and start our initial observation visits
2	this fall. Everything else is to be determined.
3	CHAIRMAN ROSEN: Okay. Well, I think
4	that's about all you can do with trying to watch a
5	program that hasn't started yet.
6	MR. LAIN: Yes.
7	CHAIRMAN ROSEN: Planning on trying to
8	watch a program that hasn't started yet.
9	I thank you all for your participation.
10	I would ask the members if they have any final
11	comments?
12	(NO RESPONSE.)
13	CHAIRMAN ROSEN: If not, seeing none, we
14	are adjourned.
15	(Whereupon, at 12:32 p.m., the meeting was
16	adjourned.)
17	
18	
19	
20	
21	
22	
23	
24	
25	

	]	193	
1			
2			
3			
4			
5			