## **Official Transcript of Proceedings NUCLEAR REGULATORY COMMISSION**

Title:	Advisory Committee on Reactor Safeguards
	Plant Operations and Fire Protection
	Subcommittees Region II Visit

- Docket Number: (not applicable)
- Location: Atlanta, Georgia
- Date: Thursday, August 25, 2005
- Work Order No.: NRC-549

Pages 1-138

NEAL R. GROSS AND CO., INC. Court Reporters and Transcribers 1323 Rhode Island Avenue, N.W. Washington, D.C. 20005 (202) 234-4433

1	UNITED STATES OF AMERICA
2	NUCLEAR REGULATORY COMMISSION
3	+ + + + +
4	ADVISORY COMMITTEE ON REACTOR SAFEGUARDS
5	PLANT OPERATIONS AND
6	FIRE PROTECTION SUBCOMMITTEES
7	REGION II VISIT
8	+ + + +
9	Thursday, August 25, 2005
10	8:30 a.m.
11	+ + + +
12	Conference Room 24T20
13	Sam Nunn Federal Center
14	61 Forsyth Street, N.W.
15	Atlanta, Georgia
16	PANEL MEMBERS:
17	JOHN D. SIEBER, Chairman
18	VICTOR H. RANSOM, ACRS
19	GRAHAM B. WALLIS, ACRS
20	DANA A. POWERS, ACRS
21	THOMAS J. KRESS, ACRS
22	RICHARD S. DENNING, ACRS
23	MARIO V. BONACA, ACRS
24	WILLIAM J. SHACK, ACRS
25	
ļ	I

1

		2
1	STAFF:	
2	RALPH CARUSO, ACRS Staff	
3	ASHOK C. THADANI, ACRS Staff	
4	JOHN T. LARKINS, ACRS Staff	
5	W. BILL TRAVERS, NRC Region II	
б	VICTOR M. McCREE, NRC Region II	
7	JOE SHEA, NRC Region II	
8		
9		
10		
11		
12		
13		
14		
15		
16		
17		
18		
19		
20		
21		
22		
23		
24		
25		
	I	

	3
1	I-N-D-E-X
2	AGENDA ITEM PAGE
3	Inspection Staff Succession Planning
4	(V. McCree, RII; J. Shea, RII) 4
5	Recent Greater than Green Inspection Findings
6	Oconee 95002: White Finds on staffing the
7	Safe Shutdown Facility (SSF) in the event of
8	a fire and the SSF Pressurizer Heater adequacy
9	(B. Schin, RII)
10	Sequoyah 95001: White Finding on binding of
11	the 1A RHR Electrical Breaker
12	(S. Freeman, RII)
13	SDP Timeliness/Fire Protection Issues 101
14	(C. Payne, RII)
15	Closing Remarks
16	(W. Travers, RII; J. Sieber, ACRS)
17	Adjourn
18	
19	
20	
21	
22	
23	
24	
25	
l	I

	4
1	P-R-O-C-E-E-D-I-N-G-S
2	MR. SIEBER: This is a continuation of the
3	ACRS meeting with Region II personnel, and the portion
4	of the ACRS that are here today are the Pant
5	Operations Subcommittee and the Fire Protection
б	Subcommittee which comprises the bulk of ACRS members,
7	so there's only a couple that are absent.
8	I would welcome Bill Travers, as he has
9	welcomed me, and as an old friend, and I would report
10	to you that your team did an excellent job yesterday
11	in their presentation. It was very efficient and
12	forthright, and for me, and I'm sure the rest of the
13	members, I gained confidence in the agency's ability
14	to handle the issues that come forward from licensees,
15	and particularly some challenging applications that
16	lie before us right now.
17	And that was one of the purposes of our
18	visit was to get a handle on TBA's applications for
19	Browns Ferry for license renewal, extended power up-
20	rate, combined with the restart activity which looks
21	almost like starting a new plant.
22	And so I think that will be a challenge
23	for both the region and the headquarters staff and for
24	us to understand it and be able to separate the issues
25	and combine them in a way that will allow us to make
	1

(202) 234-4433

	5
1	good decisions.
2	And so I thank you on behalf of the
3	subcommittees for the work that the region is doing in
4	that regard, and since they visit us from time to time
5	at White Flint and report their findings to us, I've
6	always had that confidence in Region II personnel. I
7	also read the website that has your inspection
8	reports.
9	I would point out that our agenda calls
10	for us to conclude by something like 12:15 today, and
11	for me, my next two days of travel must work like
12	clockwork. I'm going to Montana but I have to pick up
13	my wife and mother-in-law on the East Coast to
14	accompany them out there, and every connection looks
15	to me like a bad one, and so I have to leave promptly,
16	and in the event that we aren't done, I don't want to
17	cut short any of the discussion that will go on. I
18	would ask Dr. Powers to take my place to conclude the
19	meeting.
20	So with that, I'd like to ask Dr. Travers
21	to give us a little introduction.
22	DR. TRAVERS: Thanks, Chairman Jack. It's
23	great to see you. Glad the ACRS could come to Region
24	II. It is a good organization and I'm glad you've had
25	the benefit of some of the presentations yesterday.
ļ	I

(202) 234-4433

	6
1	I'm sorry I couldn't be here for the first half of the
2	first day that you were able to take advantage of some
3	of the information developing here at Region II.
4	There are a lot of challenges in Region II
5	and obviously a lot of challenges within the agency,
6	and the Southeast seems to be the targeted area for
7	some of the projects, probably not unsurprisingly,
8	that are being developed, and so we're extremely
9	interested in being ready and prepared for the new
10	work.
11	But the fundamental job that we have on a
12	continuing basis is safety inspection at both nuclear
13	power plants and all of the fuel cycle facilities
14	across the country that are organized under Region II.
15	And that's the reason I was out in Washington at
16	Framatone Richmond yesterday to accompany Commissioner
17	Jaczko, and for the first time myself have the
18	advantage of that tour.
19	We certainly look forward in the future,
20	as we have in the past, to working with ACRS. You are
21	also obviously going to be challenged on some of this
22	new work as it develops, if it develops, and so we'll
23	need to assure that we have the same kind of good
24	coordination and interaction with ACRS as we pursue
25	these matters.

(202) 234-4433

7 There's a lot on the plate, and I think today's first discussion actually, that Vic McCree is qoinq to lead us through, will underscore the challenge we have in the most important element as I see it, and that the personnel, the people side of NRC programs. NRC, in my sense, has always been effective largely or most importantly as a function of the people that work here, and so that's not going to Any organization is really defined by its change. personnel and the people that work. I've been lucky enough to work in enough jobs to see NRC in a broad scope fashion, and I can tell you my experience here in Region II reinforces my view, a similar one I think that you share, that we're very fortunate to have a very professional team here at NRC. But again, welcome, glad you could come. MR. SIEBER: Thank you. As Bill has indicated, and MR. McCREE: certainly made it very clear to the management team, our people are our greatest asset. So the management team, including myself in the Division of Reactor Safety and Joe in the Division of Reactor Projects,

spend a considerable amount of time and effort focused

NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433

1

2

3

4

5

6

7

8

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

25

on identifying our needs, our skill needs, where we are, recruiting, hiring, developing, and putting in place an environment that's enriching enough and focused enough that people feel like staying here. We focus on retention.

But I wanted to take a while to talk about 6 7 Joe and I, our use of the Strategic Workforce Plan, 8 something that we've engaged in for the last two 9 years, as well as our recruiting philosophy and strategy; the use of the Division of Reactor Projects 10 Resident Inspector succession Plan which Joe is going 11 12 to speak, as well as the Division of Reactor Safety Skills Matrix, both of which, again, are tools to help 13 14 us to the end of getting good people onboard; and then talk about staff development training and end with 15 just an overview of demographics that help drive what 16 17 we do.

18The Strategic Workforce Plan is, as you19may be aware, an agency initiative of several years20ago to address our current and long-term successor21planning needs. All staff have to use that web-based22tool to enter their skills and their knowledge.23Management looks at it to confirm their24skill and knowledge level. We use it to determine

where we recruit, how extensively we recruit, and it

NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433

25

1

2

3

4

5

(202) 234-4433

8

	9
1	also facilitates the technical Training Center's
2	development of the training program that all of our
3	staff have to take advantage of.
4	Using that tool does help to increase our
5	efficiency and effectiveness. Prior to that, while we
6	made it work, it was certainly less efficient than it
7	is now. So it's a very helpful tool for us to use the
8	Strategic Workforce Plan.
9	Next slide, please. Our recruiting
10	philosophy and strategy. We've learned over the years
11	that we have benefitted in Region II when we attempt
12	to target folks who have some connection to the South,
13	to the Southeast. We've targeted our recruiting
14	efforts primarily to southern universities, as well as
15	other locations in the South, and that's really helped
16	us in terms of identifying people and also retaining
17	them. When they have a connection to the geography,
18	they tend to want to come and they tend to want to
19	stay. So that's helped us tremendously.
20	We've used tailored vacancy announcements,
21	specifically and I know Joe is going to speak to
22	this we've tried to target our vacancy
23	announcements so that we get the people that we want
24	to apply for jobs.
25	As an example, in our Resident Inspector
	I

(202) 234-4433

	10
1	Program, about five years ago we were hiring people
2	for the position that they would occupy once they
3	joined us, as a project engineer, for example, when we
4	really wanted those people to develop to become
5	residents.
6	So we changed the title of that
7	announcement so that it was a Resident Inspector
8	Candidate Development Program and were able to draw in
9	the operations-oriented people rather than the project
10	management experience that we were getting under that
11	previous posting. That's helped us significantly.
12	Again, we have targeted universities in
13	the South, in the Southeast, such as Georgia Tech,
14	Virginia Tech, NC State.
15	MR. WALLIS: When you target them, what
16	sort of response do you find that you get from these
17	universities?
18	MS. McCREE: The response that we get is
19	a very positive one. We've identified what we call
20	champions. In fact, across the agency we've
21	identified champions for specific universities. We go
22	and visit the different schools and departments that
23	we're targeting, Nuclear Engineering departments at
24	Georgia Tech and NC State, South Carolina State, and
25	others.
I	

(202) 234-4433

	11
1	DR. TRAVERS: Graham, just as an
2	example Georgia Tech is just four stops up, we live
3	next door about six months ago we had a group of
4	students come over and I think we've actually gotten
5	some fair interest from the group. We spent the day
6	with them, had the chance to interact with them and
7	some of the different disciplines.
8	MS. McCREE: It's the student chapter of
9	the American Nuclear society.
10	MR. McCREE: In fact, several of our
11	relatively new hires were members of the group that
12	came over and hosted and talked with.
13	MR. WALLIS: When they actually get hired,
14	that's when you really learn something.
15	DR. TRAVERS: We have quite a few Georgia
16	Tech on line.
17	MR. WALLIS: Because students will flirt
18	with all kinds of potential employers but when you
19	actually hire them, that's when you actually learn
20	something.
21	DR. TRAVERS: In fact, one of them told
22	me, Well, MIT is really the Georgia Tech of the
23	Northeast.
24	MR. WALLIS: You mean it's been corrupted
25	in the same way.
I	1

	12
1	(General laughter.)
2	MR. McCREE: One of the strategies that we
3	use, as well, is certainly using our internship and
4	co-op opportunities to get potential new hires onboard
5	so that they can see what we do, whether it's what
6	they want to do, and we certainly have an opportunity
7	as well to see what they're capable of.
8	And using the co-op strategy, in
9	particular, helps us because it's easier and more
10	efficient for us to hire potential new hires when we
11	bring them in as co-ops and have them here for one or
12	two summers, and we've used that very successfully
13	over the last few years.
14	MR. McCREE: Next slide, please.
15	MR. SHEA: Let me take a couple of minutes
16	to talk about the structure to the Inspection Program,
17	and that's the context in which we look to make sure
18	we have the right folks with the right qualifications
19	to successfully accomplish that.
20	The NRC's entire Operating Reactor
21	Inspection Program is outlined at the highest level in
22	our inspection manual, Chapter 2515, and that outlines
23	the entire Inspection Program: Supplemental,
24	Baseline, Special Inspection programs, and in there
25	indicates that it's imperative that those inspections
Į	I

(202) 234-4433

13 1 be conducted by qualified inspectors and then points 2 to our qualification procedure. 3 That manual chapter for Operating Reactors 4 is manual Chapter 1245, and that details the levels of 5 qualification, the basic and final qualification, as well as refresher training and continuing education 6 7 expectations for inspectors. 8 In the context, all of the training 9 programs are oriented toward establishing really four 10 critical elements that a good inspector needs to have, and that's they understand the legal foundation for 11 12 acting as an inspector in a regulatory framework, that they have a detailed knowledge of the technology that 13 14 they're inspecting, and that gets down to whether that's the NSSS specific training or just the generic 15 16 aspects of pumps and valves or diesel generators and that sort of thing which are generic to the power 17

19 It drives toward making the sure 20 inspectors have good inspection techniques, that is, their ability to gather data, analyze it, and assess 21 22 it against the regulatory structure, and that's with 23 making sure that they have good ability to assess that in a fundamental safety sense. 24

> NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

And finally, the training program makes

(202) 234-4433

reactors.

18

25

	14
1	sure that inspectors have what's critical,
2	communication, the ability to communicate what they
3	see in the field to the licensee, back to management,
4	back to headquarters.
5	MR. WALLIS: Can I ask you about this, you
6	said they learn about the regulatory structure.
7	MR. SHEA: Yes, sir.
8	MR. WALLIS: They must be smarter than
9	some of us. Some of us have been on this committee for
10	10-12 years and we're still trying to figure out some
11	of the details of the regulatory structure. Maybe
12	these guys pick it up quicker. How long does it take
13	for them to really get familiar with the regulatory
14	structure?
15	MR. SHEA: The expectations for someone
16	who comes in at maybe an early mid-career entry is two
17	years to achieve final qualifications, so they can
18	pick up basic qualifications in 6 to 8 months.
19	MR. WALLIS: This is a full-time job, so
20	it is taking quite a while.
21	MR. SHEA: Yes, it does.
22	MR. POWERS: Based on my observation, it's
23	a grind for two years. They're counting the minutes
24	till the time they get through it. I teach R-800 for
25	this and I get them about a third to two-thirds of the
	I

(202) 234-4433

	15
1	way through, and they're looking for the end.
2	MR. WALLIS: Especially your course, I
3	should think.
4	MR. POWERS: My course is so much fun. Of
5	course, it's rigorous and demanding but it's lots of
6	fun.
7	(General laughter.)
8	MR. McCREE: Actually, it's a very sought-
9	after course.
10	MR. SHEA: But clearly, that's a challenge
11	in part to ensure that it becomes not as much of a
12	grind as it perhaps can be, but we make sure that
13	we're giving them real-time assignments that will give
14	them practical application, even while they're going
15	through the qualification process.
16	MR. WALLIS: Do you get any attrition? Do
17	they find that after a year that they don't like it?
18	MR. McCREE: No. The answer is no.
19	MR. WALLIS: That's a good sign.
20	MR. McCREE: We haven't lost any during
21	the training process. We've had some leave after
22	and these are new hires right out of college we've
23	had just a couple leave from this region. I think our
24	attrition rate is less than some of our counterparts
25	in the other regions and headquarters, and I'd like to
I	

(202) 234-4433

	16
1	attribute that to the fact that most of our new hires
2	have co-op'd with us beforehand, so they have a much
3	better understanding of what they're getting into
4	rather than someone who we just bring in right out of
5	school.
6	And again, we try not to do that with our
7	new hires. Mid career, it's a little bit different,
8	they're more mature, if you will, more experienced,
9	and have a much better idea of what they're getting
10	into.
11	MR. POWERS: My observation is that when
12	you pair a new hire with a mentor of some maturity and
13	there's a good working relationship there, it breeds
14	an enthusiasm.
15	MR. McCREE: Indeed.
16	MR. POWERS: I can tell who is doing that
17	in the classes I teach because their enthusiasm and
18	curiosity levels are just much, much higher.
19	MR. McCREE: One of our early lessons
20	learned too because most of our new hires are in
21	the Division of Reactor Safety, new hires meaning
22	right out of college is that we try not to bring
23	them in one at a time because we want them to have a
24	peer group, if you would.
25	In fact, early on we called them Pride
I	

(202) 234-4433

	17
1	Group 1, Pride Group 2 because we bring in several,
2	three or four new hires, and it really helps with
3	their own synergy, at their own level, and it has
4	helped us to retain them and move them along. A
5	couple actually have gone into the Resident Program
6	after about three or four years.
7	DR. TRAVERS: When we think of attrition,
8	there is one element that we're thinking about
9	currently, and that is some of the new jobs that are
10	likely to be created in headquarters as a function of
11	some of the new work that is being done.
12	So we're actually incorporating into our
13	philosophy of looking for people for training some
14	notion that we'll probably lose some folks, and that's
15	not just Region II, but the regions collectively will
16	lose some folks as some of those jobs appear to be
17	attractive in our MSS workshops.
18	MR. LARKINS: Is that a concern?
19	Traditionally the regions have served as the feeder
20	group for a lot of headquarters jobs when they reached
21	the journeyman level, GG-13, 14, as they look for
22	promotions and stuff, and with the challenges you're
23	being confronted with and the need for expertise.
24	DR. TRAVERS: IT's been more of a
25	challenge in Region I, and as real estate prices go up
	I

(202) 234-4433

	18
1	in Washington.
2	(General laughter.)
3	DR. TRAVERS: But it is.
4	MR. McCREE: It's happened, I think it's
5	good for the agency to have that movement of
6	operations field experience to headquarters. We're
7	mindful of that and try to plan for it by populating
8	staff with people who can fall in behind them and do
9	what we need to do.
10	But it is a challenge, and what Bill is
11	alluding to is the fact that the Program Office has
12	allotted us additional FTEs to recognize the
13	likelihood that there will be opportunities
14	MR. LARKINS: But as you said, as real
15	estate prices get higher, there's less movement.
16	MR. SIEBER: Washington is a good place to
17	move away from.
18	DR. TRAVERS: Amen.
19	(General laughter.)
20	MR. RANSOM: Do you put the training
21	materials together here? I presume you have training
22	materials that you use. Right?
23	MR. SHEA: Yes.
24	MR. RANSOM: I'd personally be interested
25	in getting a copy of that.
	I

(202) 234-4433

19 1 MR. SHEA: The training course program is fairly extensive and all oriented toward supporting 2 qualification of 3 the the inspectors. There's 4 classroom training offered both in headquarters and 5 here in the region, and again, some of the attributes about the legal foundation of regulatory structure, 6 7 the technology and inspector techniques are offered in both places. Part of the qualification process, 8 9 there's probably 10 to 15 courses that an individual needs to go through, and that material is here and in 10 headquarters. 11 12 You haven't put together a MR. RANSOM: text or something with this material? 13 14 MR. SHEA: It would not be a single 15 binder, if you will. Some is online, but we can get 16 the representative elements of it. 17 (General talking.) MR. McCREE: I think what would be useful 18 19 is to look at the manual chapter itself, manual 20 chapter 1245 which has several attachments that 21 describe what the qualification program is all about. 22 It tells a person what you have to do to become basic 23 certified and furthermore, what you have to do to complete full qualification. 24 25 That's a relatively new development and it

> NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433

	20
1	was updated about three years ago, so I think that
2	would be a very useful thing.
3	MR. WALLIS: So we understand it's tough
4	material, but nobody flunks out, or do some people
5	fail?
6	MR. McCREE: Well, if that happens, then
7	we have failed.
8	MR. WALLIS: I presume it's very well, you
9	select them so well.
10	MR. McCREE: We have had inspectors who
11	have, for example, not passed one of the series
12	courses.
13	MR. WALLIS: They go back and do it again?
14	MR. McCREE: What we do is we tutor that
15	individual and send them back and have them do it
16	again, that's correct. And we've had a lot of success
17	with that, the second time around. But we've not had
18	anyone fail to become fully qualified, it just may
19	take a little bit more time.
20	MR. SHEA: And then the culmination of
21	that final qualification process is the qualification
22	board in which there are seasoned inspectors and
23	management assessing the full range of knowledge of
24	that person before they put him out in the field, so
25	it's that board's responsibility.
I	I

(202) 234-4433

	21
1	MR. WALLIS: I remember about TMI there
2	was some public criticism of the process where people
3	sort of marginally would fail and eventually be
4	reprocessed and marginally get through and so on. I'm
5	sure that is no longer the case?
6	MR. McCREE: We try to invest on the
7	front-end to make sure that people that we hire are
8	very capable. We've been very fortunate in terms of
9	our new hiring, in terms of grade point average and
10	certainly their college experience, that they're very
11	solid academically. In fact, many of our hires not
12	only have an undergraduate degree but they have a
13	master's degree before coming in.
14	With respect to our mid-career people, we
15	interview then extensively, do very thorough reference
16	checks, and have been very fortunate in terms of the
17	quality and experience base of folks we've hired.
18	Again, even in the resident program,
19	within the last five years we've put a major push on
20	because a number of our residents have been hired in
21	headquarters. We've been very successful with hiring
22	individuals that are SRO licensed, shift technical
23	advisors, shift supervisors who are fatigued with
24	working shift work and have always thought about being
25	a regulator, and this is just the right time for them
	I

(202) 234-4433

	22
1	in their career, and we have a number who are out
2	there in the field right now.
3	MR. SIEBER: It's been my experience that
4	the key person involved in the training and
5	development of resident inspectors is the senior
6	resident at the plant site.
7	MR. McCREE: Exactly.
8	MR. SIEBER: And that performs the check
9	on the quality of the reports that are written and
10	also day-to-day tutoring.
11	MR. SHEA: That's right, and in fact, once
12	a person receives a basic level of qualification after
13	six months, then they can be assigned to a site, and
14	in that context we would look where are the sites
15	where we have the most seasoned senior residents and
16	look to pair those newer basic-qualified folks with
17	some of those more seasoned folks and get that
18	exchange that way.
19	MR. SIEBER: I guess the flip side of that
20	is the biggest mistake you can make as managers is to
21	make somebody a senior resident who really doesn't
22	have all these qualities and attributes because some
23	of them are not the kinds of things that you can
24	readily measure.
25	It has to do with personality, it has to
I	I

(202) 234-4433

	23
1	do with attitude, it has to do with drive, and I have
2	seen a lot of good resident inspectors in my career
3	become so because the senior resident was a very
4	knowledgeable person with a lot of leadership skills.
5	MR. McCREE: We've tried not to make those
6	kinds of mistakes, and we've had the benefit, we
7	mentioned, of experience level. Each year in NRR
8	sends to the commission a paper called Resident
9	Inspector Demographics, and if you look at that paper,
10	historically Region II has benefitted from having the
11	most experienced inspectors, senior residents as well
12	as residents, in terms of time on a site, past
13	experience in the technical field, whether a shipyard
14	or within the industry.
15	So we have had that luxury, if you would,
16	of having had experience to pass along to our new
17	resident inspectors.
18	MR. KRESS: But of your new hires that
19	would like to continue their education, do you have a
20	program, some sort of agreement with Georgia Tech or
21	somewhere that they can go to night school or get off
22	from work?
23	MR. McCREE: The agency has a program that
24	we benefit from that's called 368 Training that we do
25	take advantage of. What you'll find out in a few

(202) 234-4433

1 minutes when I show you're the Division of Reactor 2 Safety Skills matrix is while those opportunities are 3 available -- and we have done that, for example, in 4 the digital systems, digital controls, we sent several 5 of our electrical/INC inspectors over to Georgia Tech to get that type of training -- there is, on the other 6 7 hand, an abundance of training that the NRC offers 8 through our Technical Training Center and the Technical Training Center can contract out for, should 9 there be sufficient interest in that area from all the 10 regions. 11 I had in mind something like 12 MR. KRESS: a BS engineer wanting to get a master's degree. 13 14 MR. McCREE: Right. There are several 15 paths by which a staff member or inspector could 16 pursue that. One would be, as Victor was alluding, 17 sort of on a piece-by-piece approach, course-bycourse, you're justifying those courses in the context 18 19 of their benefit to the agency, but a number of folks 20 have put together advanced degrees through that 21 process. 22 The other avenue is the agency does have 23 some graduate fellowship program, but those are 24 programs where someone steps out for the period of 25 time, the 18 months or so, to get a degree and then

> NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433

(202) 234-4433

24

	25
1	gets that degree and incurs some obligation to the
2	agency and then comes back in.
3	MR. SHEA: There is a fellow from Region
4	III, C.J. Farnham, has gone up to MIT to take on
5	graduate studies.
6	MR. SHACK: I just wanted to ask what
7	number of fellowships do you have per year typically?
8	MR. McCREE: Right now I think C.J. is the
9	only one, however, we have two current co-ops for whom
10	we are paying their tuition or at least part of their
11	tuition to complete their undergraduate degree. And
12	Joe has a resident inspector out at Harris who is
13	actually completing a master's in nuclear engineering
14	through North Carolina State.
15	So it is being done, it is quite
16	challenging, though, particularly as a resident, to
17	have time to do that. You're on call 24/365, so it'
18	makes it very challenging. But that is something that
19	we encourage and we support.
20	MR. DENNING: I don't mean to downplay the
21	importance of the things that you're talking about
22	here and the stimulation of inspectors and their
23	training, but there must also be people that get into
24	this job that really aren't suited for it that are
25	dead wood, and how do you handle that? And I realize

(202) 234-4433

	26
1	that's a really difficult problem for the agency, but
2	how do you do that, how do you identify them and move
3	them someplace at least where they're not doing harm?
4	MR. McCREE: Very carefully, very
5	thoughtfully, and certainly using the support and
6	understanding of senior management, as well as the
7	Office of Human Resources and the individual himself.
8	And certainly the regions are isolated in that
9	challenge.
10	MR. DENNING: Do you have an annual
11	evaluation process that actually works? I mean, does
12	it really work? I've seen lots of them where there's
13	the process but it's done superficially and everybody
14	is afraid to say negative things in these kinds of
15	evaluations.
16	MR. McCREE: We do have an annual
17	evaluation process and that's certainly a formal
18	process, but it's certainly not the only one that
19	allows a manger, supervisor to engage an employee to
20	put in place resources to enable them to perform
21	better.
22	We try to hire individuals who have the
23	will, that share our values and certainly have the
24	base level of experience and/or knowledge to help us
25	accomplish our mission. Our job then is to provide
	1

(202) 234-4433

	27
1	the access to the skills to enable them to do it.
2	When that doesn't happen, then we have to
3	certainly engage that individual and see what job is
4	best for them, and we do that very thoughtfully and
5	very carefully.
6	MR. DENNING: Do you look to the utility
7	for comments on the inspectors, or is that
8	inconsistent with regulatory?
9	MR. McCREE: The answer is yes. This goes
10	back to the early '90s and the Towers Perrin report,
11	where now we formally, as directed by the EDO, when a
12	branch chief or a senior manager engages with a
13	licensee, when we go out for site visits or certainly
14	when they drop in and visit us, one of the specific
15	items that we ask about and we actually document in
16	our trip reports is how our inspectors are performing
17	and if there are any issues that we need to address.
18	So we do get that feedback.
19	DR. TRAVERS: We try to encourage at every
20	opportunity when management interacts with management,
21	I always ask: Are there any problems; are there any
22	issues you want to raise with me about how you see our
23	oversight program working?
24	And so I think the best thing you can do
25	is just try to keep those communication lines open.
ļ	I

(202) 234-4433

	28
1	Sometimes we get some information; sometimes we act on
2	it, sometimes we don't see a need to.
3	But I think Jack brought up a point
4	earlier that there really is an art, almost, to the
5	way inspectors who are serving this regulatory
6	function interact with licensees. It's acquired, it's
7	not just technical, it's a skill set that takes some
8	time to develop, and in some people it takes a little
9	longer than in others. But in the main, we think
10	we're pretty successful.
11	MR. SIEBER: Well, I noted when I was
12	working as a licensee that quite often supervision
13	would come and spend a week at our plant sites,
14	basically to monitor what goes on with the site-based
15	personnel which I thought was a good thing.
16	They would sit in on all the meetings and
17	occasionally I'd be asked what do I think. But
18	licensees are going to be pretty cautious about
19	saying, Well, your resident inspectors are not any
20	good. I don't recall anybody as ever having said
21	that; there may be an instance or two.
22	DR. TRAVERS: It is occasionally said, we
23	have issues that are raised.
24	MR. SIEBER: But I would imagine it's
25	pretty rare.
l	I

(202) 234-4433

	29
1	DR. TRAVERS: It's rare, in large measure,
2	I think it's not needed all that often because we have
3	been fairly successful.
4	MR. SIEBER: I've been flat-out asked by
5	regional administrators what do you think of this
6	person or that person, but the impression that I got,
7	both from outside the agency and inside the agency, is
8	these organizations at the region are basically small
9	enough that the regional administrator and all of the
10	management really know a lot of details about the
11	performance of individuals in that organization. I
12	have always been impressed by that. And I'm sure that
13	this region is the same.
14	MR. McCREE: And that's not a mistake. I
15	mean, as Bill indicated, people are asked that,
16	certainly the residents and even our base inspectors
17	put a lot of time and energy into their development,
18	their hard technical skills, their soft skills as well
19	that are developed for certainly our seniors, our
20	first-line supervisors. They go through the
21	supervisory courses and that enhances their tool bag
22	as supervisors and their ability to interface with the
23	licensee and certainly senior management in that
24	context.
25	We reinforce it certainly through the
I	1

(202) 234-4433

division directors and the branch chiefs, several of whom spoke with you yesterday, as well as twice a year 3 we have our inspector counterpart meetings involving 4 all the inspectors. So that's another opportunity for Bill, and certainly my colleagues and I reinforce the soft issues, if you would, as well as the important safety issues.

MR. SIEBER: Well, the skill set required 8 for inspectors is quite a bit different than, for 9 10 example, working in NRR or other places, and if an individual may not be too terrific an inspector, maybe 11 12 NRR is the place to send them.

One last point perhaps on that 13 MR. SHEA: 14 is that there is an expectation on the first-line 15 supervisors, the branch chiefs who are in the region, that they get out a number of times per year and 16 directly observe the performance of the senior and the 17 residents, both by doing walk-downs of the facility 18 19 and watching them, observing them doing an inspection, 20 and also attending inspection exit meetings where they 21 first part, watch their technical can, in the 22 inspector skills, on the second forum, watch their 23 communication and ability to communicate regulatory 24 issues directly.

So in addition to the feedback that may or

NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433

25

1

2

5

6

7

	31
1	may not come clearly from the licensee through those
2	other venues, the supervisors first-line and second-
3	line have their own base to make those assessments of
4	performance.
5	Let me go to the next item and talk about
6	some attributes of succession planning that are unique
7	to the Resident Inspector Program.
8	The staffing requirements for the resident
9	inspector set out in 1999 established the end policy
10	where at the 18 sites across Region II we have
11	approximately just under 40 resident inspectors out
12	there, depending on the number of reactors at the
13	site.
14	In terms of succession planning, there's
15	one additional element in the resident program that
16	makes managing succession planning, one element more
17	complicated beyond just managing attrition due to
18	retirements or attrition due to folks making mid-
19	career changes.
20	The agency's relocation policy established
21	in 1998 SECY paper and carried forth in the field
22	policy manual, establishes that to ensure continuity
23	on one hand and objectivity on the other hand, the
24	resident inspectors can be at the site nominally no
25	more than seven years and typically no less than four
ļ	I

(202) 234-4433

years, with provisions for extraordinary circumstances.

3 And again, that provides for making sure 4 we have continuity so we're not changing folks out so 5 fast that we can't connect the dots as well, and that they don't stay so long as to lose their objectivity. 6 7 So management in the region and the branch chief tracks and projects into the future the expected 8 turnover dates for both the residents and the senior 9 10 residents, and we can get a sense for what years we're going to have gaps starting to open up that we need to 11 12 plan for. One management tool or enhancement that 13 14 has been made in the recent past is our ability to 15 the assignment of residents and senior overlap residents so that they can get a solid turnover of the 16 issues and performance of that licensee before there's 17 18 a gap. And there have been instances where that's 19 20 caused the agency problems over the past few years, 21 and in response to that we've put in place this 22 ability to double encumber for a period of time the 23 coverage at the site -- I think it's a year for a resident and six months for a senior resident -- and 24 25 allow, again, for a good turnover.

> NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433

1

2

(202) 234-4433

32

In the context of looking ahead and projecting when the different sites are going to have openings or change-out of personnel, we can see where we need to keep some surge capacity -- I call it -- in the region of folks who are going through the qualification process, and that is the Resident Inspector Development Program that Vic alluded to earlier.

Currently we have four folks here in the 9 region who are going through their basic gualification 10 11 program, and that's out of a population of residents 12 of about 40 folks, so that's about a 10 percent surge capacity. And each of those individuals is on a track 13 14 with expectations about when they're going to timely 15 complete their qualifications and are doing well in terms of keeping to that expectation. 16 In fact, we're getting ready to hire on a fifth person into that 17 18 program to keep that surge capacity.

MR. WALLIS: So you have 40 out there and the average resident's time is five or six years, then you're going to have to need eight a year to replace them or something? MR. KRESS: They go someplace else. (General talking.)

MR. WALLIS: They just keep rotating them

NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433

25

1

2

3

4

5

6

7

8

	34
1	around? I see what you mean, they don't go somewhere
2	else, they just go from plant to plant.
3	MR. SHACK: Can they actually return to a
4	plant after some time?
5	MR. McCREE: If I could?
б	MR. SHEA: Sure.
7	MR. McCREE: With respect to surge
8	capacity, that is, if you would, a nominal surge
9	capacity in the Division of Reactor Projects. There
10	are also inspectors in the Division of Reactor Safety
11	who certainly are capable and have interest
12	occasionally in being residents as well. So there are
13	actually several that we know of who would like to, at
14	some point, become a resident. And in fact, each of
15	them are fully qualified, so there's actually more.
16	MR. WALLIS: It's sort of a strategic
17	reserve.
18	MR. McCREE: It's a strategic reserve.
19	I'll have to write that one down.
20	To answer your question, there is no
21	agency policy that would preclude a resident from
22	returning at some subsequent point to serve as a
23	resident or even as a senior at the same site.
24	We have had sub-optimal experiences when
25	we have done that. We have a senior who was once the
	1

(202) 234-4433

	35
1	project manager at Browns Ferry, and in fact, his
2	predecessor was employed at TVA at Browns Ferry 17
3	years before we assigned him. But that's the
4	exception rather than the rule.
5	We generally do not do that simply because
6	of the perception by the licensee that that individual
7	may not be open, and even when we had some inspectors
8	who have been employed by a licensee, we will
9	consciously try not to send that individual or assign
10	that individual to that site to avoid that same
11	perception and questions about objectivity.
12	MR. SIEBER: I thought that was a hard and
13	fast rule.
14	MR. McCREE: Again, that's not a written
15	policy, it's not an institutional policy, but it's one
16	that we try to keep in mind.
17	DR. TRAVERS: But you're correct, very
18	often what happens when people move is they move to
19	another site, especially a resident inspector may move
20	up to become senior, for example, at another site.
21	MR. SIEBER: On the other hand, again as
22	a licensee, there were instances where I would have
23	liked to have hired my staff, NRC personnel, and of
24	course, the ethics issue would prevent me from doing
25	that with anybody having anything to do with our
I	I

(202) 234-4433

	36
1	plant, but I could have hired from somebody else's
2	plant.
3	MR. McCREE: And it's becoming our
4	internal policy not to assign a resident to a
5	licensee, not just to a site but to a licensee for
6	which he or she has served as a resident before. It
7	could become an even greater challenge as licensees
8	combine across regions, and we're aware of that and
9	our policy will have to be reformed by those changes
10	as they occur.
11	But we've found that policy useful, it's
12	helped us in terms of our personnel assignment
13	MR. SIEBER: Now, there used to be a
14	rotation policy of five years which was, to my
15	knowledge, never rigorously enforced just because of
16	the difficulty of playing checkers with few checkers
17	on a big board.
18	MR. SHEA: As I was referring to, it has
19	been revised, it's now actually a seven-year stay
20	time. In fact, the two I was referring to, here's how
21	we track this is for senior residents who is
22	current at the site and the little red circle shows
23	when their seven-year period would expire, and the X
24	reminds us when we would want to think about
25	advertising that upcoming vacancy and make sure we do
Į	

(202) 234-4433

	37
1	that in a timely way so we can get the overlap and the
2	good turnover.
3	MR. McCREE: Just to reiterate, that is
4	rigorously enforced. It's in the EDO's policy field
5	manual. In fact, Bill has to request permission from
6	the EDO to extend it beyond that date.
7	DR. TRAVERS: I don't think we've done it.
8	MR. WALLIS: You might want to level this
9	out a bit. I notice you have no hires in some years
10	and you have a huge number or no moves in some
11	years and then a huge number in other years. You
12	might want to level it off so there's about the same
13	changeover each year or something. Just a comment.
14	MR. McCREE: This slide here again shows
15	the senior residents, and there are a couple of
16	assumptions and again, this is just a tool, there's
17	no magic in this other than experience, logic and
18	reason but one assumption is that the seniors would
19	remain at the site until the end of their tour, seven
20	years, which based on our experience, that's rare.
21	As Joe mentioned by policy, we have to
22	leave them there for four years unless we get Bill's
23	permission, and again, he has to request the EDO's
24	approval.
25	DR. TRAVERS: Sometimes it's just money.
ļ	

(202) 234-4433

38 1 MR. McCREE: It is, it's the cost of 2 relocation. I think it's about \$100,000 per move, and those costs are excessive and we've received guidance. 3 4 In fact, those waivers that Bill could previously 5 request would not likely be approved unless there's 6 some extraordinary reason. 7 MR. SIEBER: One practice that you had, 8 and I think you still have, that I think is a really good practice is take a resident from one plant and 9 10 assign him as a transient inspector to another plant with perhaps similar issues. 11 12 DR. TRAVERS: We do that very often with special inspectors, for example. Even in Region III, 13 14 for example, where David Specie or D.C. Cook has been, we can very often provide team members to some of the 15 team inspections they carry out. 16 17 And where people go on vacation, we very often send senior or resident inspectors to those 18 19 other sites, and in a developmental sense, we're 20 looking for opportunities to broaden the perspective 21 to people to bring in their own jobs. 22 Among licensees, one of the MR. SIEBER: 23 developed complacency things that а in the 24 organization was a lack of communication in this broad 25 breadth of knowledge of what the industry was doing.

> NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433

39 1 You have the potential in the agency to have the same 2 thing occur, and these kinds of thins are efforts that 3 will prevent it or forestall a sense of complacency 4 that develops because the scope is too narrow. So I 5 encourage that. I think that's a very good 6 DR. TRAVERS: 7 point and in an era where the nuclear industry is performing sort of relatively well -- especially in 8 9 comparison to 12-15 years ago -- that guarding against 10 complacency, both within the industry and within NRC, is a very, very key element of what we need to guard 11 12 against. Well, the kind of policies MR. SIEBER: 13 14 that you're talking about and that you employ are the 15 kinds of things that I think help the agency avoid those situations, so that's good. 16 17 DR. TRAVERS: And I mentioned good performance. If you look at the Southeast, in 18 19 particular, the performance of the nuclear industry in 20 the Southeast and the potential for that sort of 21 complacency to take over is quite good. So we

23 MR. SHEA: The point about the 24 distribution of rotation times, on that same tool, 25 this reflects the projections for the resident

> NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

certainly recognize your point, it's a good one.

(202) 234-4433

22

	40
1	inspectors, and you can see that unlike the seniors
2	where it was a little sort of weighted out there in
3	the 2009-10 time frame, the resident inspector
4	rotation distribution is a little more balanced.
5	Some of those folks would go to other
6	sites as their times came up, some of them as senior
7	resident or even headquarters positions came open
8	would be looking to move into those kind of positions.
9	MR. McCREE: So just from an overview, the
10	surge capacity that Joe spoke to within the region is
11	a typical source of new residents to replace the
12	incumbents, and for the most part, the residents
13	within Region II, and in fact, the entire population
14	of the nation of residents, because when a senior
15	resident inspector position is posted, it's posted
16	nationwide.
17	So we have potential incumbents among
18	residents within Region II as well as in other
19	regions, or perhaps even headquarters that there may
20	be some residents who have gone there to gather
21	additional experience and then they come back to the
22	region as a senior resident. And that's always
23	helpful for us to get cross-pollination among the
24	regions and headquarters.
25	MR. THADANI: Just a quick question, Joe.
I	

(202) 234-4433

Changing the five-year to seven-year policy, I assume that would lead to improved morale and so on. Is that the case?

4 MR. McCREE: That is my perception, that's 5 been my experience from speaking to the residents and the seniors is that it's helped them to plan their 6 7 lives better, and we've also been able to assure their 8 objectivity through other means. And one of the 9 requirements that we lay upon inspectors every year is 10 that they do an objectivity visit at another site for at least a week, and that's helped us to, again, 11 promote their objectivity, as well as visits by our 12 branch chiefs. But that seven years has been a help. 13 14 MR. THADANI: Is there any study that says 15 seven years is good, nine years is not good? MR. McCREE: There's nothing scientific 16 17 about that. MR. SHEA: And in the end, any relocation 18 19 is going to have its challenge for the individual, so 20 seven years or eight years. 21 MR. McCREE: But it's a nice round number. 22 The last piece I was going to MR. SHEA: 23 mention -- but may in the discussion on DRS show it in a little bit more detail -- is that in the continuing 24 25 development of our inspectors we have a similar web-

> NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433

1

2

3

(202) 234-4433

41

	42
1	based tool where we track the experiences that the
2	inspectors have, both their prior experience, their
3	internal developmental activities, the classroom and
4	academic training they've had, and from that we
5	attempt to make sure that as we're planning training
б	activities and training opportunities for the whole
7	inspector corps, make sure that we continue to get a
8	good distribution of all those four basic skills that
9	I talked about at the beginning.
10	In the interest of time, perhaps we can
11	look at that tool in the next part of the discussion.
12	MR. McCREE: That's the one I'm about to
13	speak to.
14	I think Yogi Bear once said, You've got to
15	be careful if you don't know where you're going
16	because you might not get there.
17	Several years ago it's been recognized
18	for more than several, about five years ago, and this
19	has been updated certainly since that time
20	recognized that we have a significant succession plan
21	challenge because of our aging workforce and other
22	factors.
23	So we laid out what we thought was a
24	logical tool that would identify the skills that we
25	need, and from that, to complete our tasks.
ļ	1

(202) 234-4433

	43
1	MR. WALLIS: So these needs in this column
2	are the needs above what you have now? Because
3	otherwise you might conclude that you have ten people
4	and you only need two. What you mean is you have ten
5	people and you need two more.
6	MR. McCREE: Understand. These are the
7	needs that we need right now.
8	MR. WALLIS: So you have ten people and
9	you only need two of them? Is that what I understand?
10	MR. McCREE: Let me start in the left-most
11	column. The skills needed are the skills that we need
12	right now to implement the Baseline Inspection
13	Program.
14	MR. WALLIS: So in all columns you have
15	more people than you need?
16	MR. SIEBER: No. Physical security has
17	fewer qualified people.
18	MR. WALLIS: Yes, but in most of them the
19	staff onboard is bigger than the need so you could do
20	away with a lot of these people?
21	MR. SIEBER: No. Some people have more
22	than one skill.
23	MR. McCREE: Let me use an example. Under
24	structural engineering, the first area, the staff
25	needed to complete integrated leak rate response
ļ	I

(202) 234-4433

	44
1	testing, the staff needed is one and we have four
2	onboard who are capable of doing that.
3	MR. WALLIS: Okay, but they're doing other
4	things too.
5	MR. McCREE: They're doing other things as
6	well. So we have more than enough.
7	MR. SIEBER: Well, this doesn't explain
8	whether you have enough people to do all the work,
9	this tells you whether you have enough skills to do
10	individual jobs.
11	MR. McCREE: Correct.
12	MR. SIEBER: The more interesting question
13	is do you have enough overall people with the right
14	skills to do all the work that has to be done. And
15	that's a different answer than this chart will show
16	you.
17	MR. McCREE: That's correct. What this
18	does do for us, however, is identify skills gaps. In
19	other words, the delta between what we have and what
20	we need or what we project we will need because of
21	anticipated losses, for example, due to primarily
22	retirement.
23	DR. TRAVERS: Or new programs like
24	construction inspection.
25	MR. McCREE: Yes.
Į	I

	45
1	MR. SIEBER: Or physical security where
2	you do have a shortfall.
3	MR. McCREE: Right.
4	MR. THADANI: I'm a little bit surprised,
5	why is that a special skill, integrated leak rate
6	response testing?
7	MR. POWERS: What do you mean, it's the
8	hardest test I can think of doing. It's unbelievable
9	difficult and nobody has done it for ten years.
10	(General talking.)
11	MR. THADANI: But is that a special skill?
12	MR. McCREE: It is an activity, it is a
13	line item inspection requirement. Not every
14	mechanical or structural inspector can do it by virtue
15	of just being a mechanical or structural, it takes
16	experience.
17	DR. TRAVERS: We just want to make sure
18	we're tracking the capacity to be able to have the
19	right people and skill to do that.
20	MR. POWERS: It's an incredibly difficult
21	test to do because just the day-to-day variations is
22	bigger than the leak that you're trying to detect.
23	MR. WALLIS: I think it's just words.
24	This is really a task, isn't it; these are task areas
25	rather than what you might think of as skills. It
I	

(202) 234-4433

	46
1	doesn't matter, though, I understand what you mean.
2	MR. CARUSO: The staff need, though,
3	that's not an FTE number, that's a bodies number.
4	MR. McCREE: Correct, exactly.
5	MR. CARUSO: I mean, if you add that
6	number of staff needs up, you don't come to the same
7	FTE as you have onboard.
8	MR. SIEBER: No, you don't.
9	MR. McCREE: I've not done that, but if it
10	weren't I the ballpark, I'd question the adequacy of
11	our FTEs. In fact, you won't see a total number at
12	the end because we haven't thought of it that way, but
13	you ask an interesting question.
14	MR. POWERS: On this integrated leak rate
15	test, we are coming up on the ten-year anniversary of
16	the revised Appendix J so there must be some that are
17	coming down the line. Do you know when we scheduling
18	to do these things?
19	MR. McCREE: We could probably change the
20	schedule.
21	MR. POWERS: It would be interesting to
22	witness one of them because they're incredibly
23	difficult to do.
24	MR. THADANI: You could also go to other
25	regions if necessary for stuff like that.
I	I

(202) 234-4433

	47
1	MR. POWERS: The agency may want to get a
2	specialist in there to do those things.
3	MR. McCREE: Another example I'll point
4	out to you, primarily because he's here, under
5	metallurgical engineering, the staff needs are four,
6	staff onboard is four. However, under 2005 as well as
7	2006, 2007, you'll notice EM&L which stands for early
8	career, mid career and late career.
9	Again, this was a tool primarily driven by
10	our anticipated loss due to retirement. The fact that
11	one of our metallurgical engineers in that are, if you
12	would, discipline, is in the late career, we
13	identified the need to hire a mid-career in-service
14	inspection engineer, and he just happens to be here
15	right now, has a good bit of industry experience from
16	PSE&G.
17	So that's one example of we use this to
18	inform what our needs out, and we went out and got
19	him, so when we update this in a few weeks, we'll be
20	able to remove that. And there are other similar
21	examples. This is a dynamic tool that we use.
22	For example, on the next page under
23	mechanical engineer, there's a clear abundance, if you
24	would, of mechanical engineers but we did identify
25	under projected new hires to transfer an early-career
ļ	I

(202) 234-4433

	48
1	from NRR.
2	We found out last week that that
3	individual has decided not to come which is good for
4	him because an opportunity is available for him at
5	NRR, and actually good for us too because our
6	assessment in the electrical engineering area has
7	determined that we really need a mid career electrical
8	engineer. So we can use that FTE for that purpose.
9	So this a tool, DRP has an analogous one,
10	that we use to identify our needs.
11	And one additional thing that this shows
12	on the far right column you'll see succession action
13	plan and most of what's in there is the training
14	courses that we are specifically targeting to our
15	staff to develop, expand or hone skills that we know
16	we're going to need, particularly among our new hires.
17	You'll see EC, early career, those are training
18	courses for early career.
19	And the vast majority of our training
20	budget we'll have a Training Committee meeting next
21	week, a senior management Training Committee
22	meeting the vast majority of our training budget
23	goes to the Division of Reactor Safety, I think about
24	two-thirds, because the DRS staff are recognized as
25	the experts in a number of technical areas so we
ļ	I

(202) 234-4433

	49
1	leverage our training budget to reflect that.
2	Go back to the power point slide, please.
3	In closing on this slide, there are 17 areas here that
4	we focus on, and we're in the process of enriching
5	this, if you would, to address our needs in the
6	anticipated construction inspection program area.
7	It's a very dynamic area for us and there are some
8	needs that we need to refresh with this.
9	Next slide. I have several slides here
10	really just for your information that provide
11	demographic data, if you would, on Region II staff.
12	An earlier question was asked about
13	graduate training. We do have a number of employees
14	that hold master's degrees, five who have doctorate
15	degrees. What's not shown on here, and I'll enhance
16	it next time, is the number of professional engineer
17	licensees or EIT holders that we have. We do have
18	quite a few of those, so I apologize for not
19	reflecting that. We do have our one regional counsel
20	too we only need one.
21	MR. WALLIS: The next one is interesting.
22	Do you actually hire in at age 40? Otherwise you have
23	a strange population distribution for whenever you say
24	sustain ability, let's say.
25	MR. McCREE: Well, certainly to satisfy
I	I

(202) 234-4433

	50
1	EEOC laws, we cannot exclude individuals over 40.
2	MR. WALLIS: Well, if they just move
3	through, you're going to have a real punch in ten
4	years.
5	MR. McCREE: Right. What we have done
6	and I can say this we have targeted at the entire
7	agency new hires to address our age distribution
8	challenge, and we've been very successful.
9	DR. TRAVERS: Twenty-five percent target
10	for new hires. And again, we're not talking age,
11	we're talking experience level as a function. But it
12	certainly recognizes this issue that the agency has
13	some would call it the perfect storm of things
14	you've got a profile that looks like this in tandem
15	with some of these new projects that are developing,
16	and if you look at both of those factors, it becomes
17	a very difficult situation.
18	MR. McCREE: Next slide, please. It's
19	another complementary slide that talks about years of
20	federal service, and again, this reflects on the far
21	left our success in the last few years on our new
22	hires in terms of staff with less than ten years
23	experience. We've been very aggressive and very
24	successful in that regard.
25	Next slide. I included this one in
	1

(202) 234-4433

	51
1	fact, I just updated it this morning so it's not
2	reflected in the slide that you have there to show
3	the ongoing challenge we have in retirement
4	eligibility and our need to definitely focus on
5	succession planning.
6	There was a dip in optional retirement
7	eligibility in '06, we did have several people retire,
8	some moved to headquarters, but there is an increasing
9	trend in increasing age in our workforce.
10	MR. THADANI: In '04, 60 people did take
11	early retirement?
12	MR. McCREE: No. What that reflects is
13	eligibility for.
14	MR. THADANI: So that's not real.
15	MR. McCREE: No. It's just eligibility
16	MR. WALLIS: How many total employees are
17	there then, because if I look at these other pages, I
18	see the total number of employees is 200 or something?
19	MR. McCREE: Correct, 212.
20	MR. WALLIS: So you have a huge number
21	ready for early retirement.
22	MR. McCREE: Correct. That's the insight
23	that I wanted to share with you.
24	DR. TRAVERS: And one element of that is
25	that it's disproportional in certain areas, so it
	I

(202) 234-4433

	52
1	becomes even more problematic in certain key areas.
2	That's why we want to be as knowledgeable as we can to
3	manage it.
4	MR. DENNING: I wonder if I could talk a
5	little bit about fire protection engineer. I notice
6	as far as the skill set going back there that there
7	were identified as five fire protection, and are those
8	truly fire protection engineers, people with just fire
9	protection skills?
10	MR. McCREE: We have one licensed, I
11	guess, if you would, fire protection engineer, we have
12	several individuals with electrical or mechanical
13	background who have developed expertise, if you would,
14	in fire protection one of whom is sitting in the
15	back there, and they lead our fire protection
16	inspections.
17	On the other hand, we do have two co-ops
18	who are in fact one will join us next spring who
19	will have a degree in fire protection engineering, and
20	the other one next fall. So indeed, they are
21	knowledgeable in fire protection engineering.
22	MR. DENNING: When you're inspecting a
23	site, to what extent do you rely on the resident
24	inspector to check on the fire protection elements, or
25	are there groups of fire protection engineers that go
I	1

(202) 234-4433

	53
1	around and do this? How do you actually do that?
2	MR. McCREE: That's a very good question.
3	The Baseline Inspection Program, there's an inspection
4	procedure for fire protection inspection, and there
5	are two attachments.
6	One is a quarterly inspection requirement
7	that the resident inspectors implement that's
8	primarily focused on the performance of inspecting the
9	plant for transient combustibles, for example,
10	inspecting the licensee's fire drills, or if there's
11	an actual fire, to observe the licensee's performance.
12	That's the function of the resident inspectors.
13	And then we have what's called the
14	triennial fire protection inspection which, again, Bob
15	Schin and Charlie Payne will speak to later this
16	afternoon, will talk about the triennial fire
17	protection inspection which is a team inspection
18	composed of at least four individuals and perhaps a
19	contractor, and that's an integrated examination of
20	the licensee's fire protection program.
21	MR. DENNING: If we move to risk informed
22	performance based fire protection, what we've been
23	told is that the inspectors will be able to go in and
24	look at things and review what the licensee has done
25	in terms of like fire propagation with computer codes
I	1

(202) 234-4433

1 and associated circuits kinds of analyses, things that 2 would really require a great deal of in-depth 3 knowledge. Are those things practical for inspectors 4 to do?

5 MR. McCREE: May I ask that you hold that? Well, the answer is yes. We do rely on contractor 6 7 support for some of the more complex issues, but we have developed, through training, a very sound body of 8 9 expertise, I believe, by comparison to some of our counterparts in the other regions, probably almost a 10 center of excellence in terms of the quality of our 11 12 fire protection inspectors.

Again, when Charlie Payne and perhaps Bob, you may want to sit here along with them in a couple of hours to talk about that. I'd ask that you reiterate that question to them.

MR. SCHIN: It's a good question. It's aproblem that we're facing, how we're going to do that.

19 MR. McCREE: Can you go back to that last 20 This is just a demographic slide that shows slide? 21 agency-wide the ongoing challenge. This is an age 22 distribution chart that shows the green-colored area 23 is what the agency-wide age distribution was in 2000, September of 2000, and the blue is the shift that's 24 25 occurred as of April of this year.

> NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433

	55
1	MR. SIEBER: Everybody got older.
2	MR. McCREE: The way I like to look at it
3	is much more experienced.
4	(General laughter.)
5	MR. McCREE: It just, again, underscores
6	the challenge that faces us right now in terms of our
7	hiring strategy and succession planning. And of
8	course, one of the real factors that we have to deal
9	with here in Region II and in headquarters and other
10	places is we would love to bring aboard to learn from
11	our sage inspectors, to gather that knowledge and hit
12	the deck running, so to speak but we're constrained by
13	office space, so we're having to manage this very,
14	very closely.
15	MR. SIEBER: Thank you. Any questions?
16	If not, we are to the point of a break, and I think if
17	we would come back at ten o'clock by that clock, that
18	would keep us within striking distance of the
19	schedule.
20	(Whereupon, a brief recess was taken.)
21	MR. SIEBER: We're ready now to resume.
22	MR. SCHIN: Good morning. I'm Bob Schin,
23	senior reactor inspector in Engineering Branch 2 in
24	the Division of Reactor Safety. I've been an
25	inspector with the NRC in Atlanta for 18 years, and
I	1

(202) 234-4433

	56
1	primarily covering plant operations and engineering
2	type areas.
3	Next slide, please. The purpose of this
4	section of the discussion is to discuss certain white
5	findings, and in particular the recent inspection that
6	we had for a degraded mitigating system cornerstone at
7	Oconee.
8	This inspection was performed using the
9	inspection procedure 95002 for degraded cornerstone
10	two white findings and during May to June of this
11	year.
12	Next slide, please. The focus of the
13	inspection, as described in the inspection procedure,
14	is to provide assurance that for the two white
15	findings the root causes were understood and
16	corrective actions were adequate. Also, to
17	independently assess the extent of condition and the
18	extent of cause.
19	The two white findings, I'll give a little
20	description of what they were. First, there was a 3rd
21	quarter 2003 finding involving inadequate standby
22	shutdown facility pressurizer heater capacity. That's
23	the pressurizer heaters that were powered from the
24	SSF. And this finding had been closed by a previous
25	95002 inspection that was six months prior to this
	I

(202) 234-4433

one.

1

2

3

4

5

And the second white finding was the 3rd quarter 2004 finding involving inadequate procedural criteria for manning the SSF during a fire. So both of these findings in part involved the SSF.

to little technical 6 Now, give а 7 description of what were the issues. First, the SSF pressurizer heater finding, this issue was licensee-8 9 identified during testing development on March 7, They discovered that they had an insufficient 10 2002. 11 capacity of the pressurizer heaters that were powered 12 by the SSF to assure natural circulation cooling.

What happens is if you don't maintain enough temperature in the pressurizer, then the pressurizer cools down, you lose RCS pressure, and you lose sub-cooling margin.

The way the BMW plants are designed, the hot leg goes into a candy cane which is a high part above the steam generator, and you have flow through the steam generator. The high part there is a hot part and it's subject to voiding, and then once you get voiding, you lose your natural circulation.

They discovered that the pressurizer ambient heat losses were in the range of 143 to 178 kW for each of the units, and that greatly exceeded the

> NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433

	58
1	70 kW that was in the original design basis documents.
2	What happened is that the original design
3	analysis for 70 kW was wrong, the heat loss was really
4	more, and then over the years the amount of heat loss
5	got worse because of poor maintenance of the
6	insulation on the pressurizer, et cetera. So at this
7	point they were greatly exceeding the 70 kW from the
8	original design basis documents and the heat loss
9	exceeded the kW for the pressurizer heaters that were
10	powered by the SSF.
11	MR. WALLIS: So how do you have the
12	insulation degenerate?
13	MR. SCHIN: Maintenance, they will take it
14	off, put it back on.
15	MR. WALLIS: They don't put it on
16	properly? It doesn't deteriorate, does it?
17	MR. SCHIN: It gets beat up. Pieces might
18	be missing.
19	MR. WALLIS: They take it off and bits of
20	it fall off. Okay.
21	MR. DENNING: It gets beaten up and
22	doesn't work very well. The other kind doesn't get
23	beaten up and it works well, this is why people like
24	it, but metallic particularly.
25	MR. SIEBER: There are a lot of reasons
Į	1

(202) 234-4433

	59
1	why they like the metallic. I take it the operators
2	were able to tell by how many they would ordinarily
3	have to put in service during a heat-up, that there
4	was a discrepancy between the 70?
5	MR. SCHIN: Right. Prior to this 2002,
б	there was a case when they lost power to the normal
7	pressurize heaters and power from the SSF and
8	discovered they couldn't maintain pressure.
9	Now, at that time, though, they had
10	reactor coolant pumps running and so the thought was
11	that the spray valve was leaking by and that was
12	affecting it, and they didn't recognize the extent of
13	the problem right off the bat.
14	Normally when the SSF is powering the
15	heater, when you're relying on the SSF, you don't have
16	reactor coolant pumps running at the same time, so you
17	don't have any spray.
18	MR. THADANI: Didn't they find at the
19	Three Mile Island accident that for the high points
20	they had to have some vent capability to promote
21	natural circulation? Does Oconee not have that?
22	MR. SIEBER: They have it. It's supposed
23	to work without only second level safeguards. If you
24	have to get into venting because of design
25	deficiencies in the basic design, then the design
I	I

(202) 234-4433

	60
1	basis is invalid.
2	MR. SCHIN: Right. The procedures are not
3	set up to rely on venting of that candy cane. Not for
4	operation of the SSF, no, they don't rely on that.
5	MR. DENNING: Now, when you talk about SSF
б	powering, you mean that there's a control capability
7	only for certain of the electrical heaters from the
8	SSF?
9	MR. SCHIN: Right, from the SSF. You can
10	switch over the power; certain heaters can be powered
11	either from the SSF or from the normal power supply.
12	MR. DENNING: When you say powered, do you
13	mean control? SSF isn't the power source, is just is
14	a control capability?
15	MR. SCHIN: No. It is a power source.
16	When the plant is normally operating there's power
17	from the normal $4160-4$ kV switch gear out in the
18	turbine building, there's some power that goes over to
19	the SSF and normally powers the SSF. But when you're
20	relying on the SSF in emergency conditions, it can
21	either use that power which is not well protected,
22	it's not safety grade power, or you can use the SSF
23	diesel generator to generate power and power the SSF
24	and power these heaters. That's the design
25	capability. So the SSF does generate its own
I	1

(202) 234-4433

	61
1	electricity.
2	MR. SIEBER: On the other hand, if you
3	require more power than 70 kW, the SSF diesel may not
4	be able to provide that plus everything else.
5	MR. SCHIN: Well, it's probably could,
6	it's a large diesel, I think somewhere around 3,000
7	kW. It's like a normal emergency diesel that other
8	power plants have.
9	MR. SIEBER: But that's not part of the
10	design basis.
11	MR. SCHIN: But the wiring is not such
12	that the SSF diesel can power the other heaters, it's
13	not wired up to be able to do that.
14	MR. SCHIN: So anyway, this was considered
15	to be an inadequate corrective action violation
16	because the licensee had numerous prior opportunities
17	to identify it. It was not considered to be an old
18	design issue.
19	Any more questions about that?
20	MR. DENNING: The words inadequate
21	corrective action, is that what you would call the
22	root cause?
23	MR. SCHIN: That was the violation that
24	was cited by the NRC.
25	MR. DENNING: That's not a root cause.

(202) 234-4433

	62
1	MR. SCHIN: No, that's not the root cause.
2	The root cause would have been the original design
3	analysis was incorrect, the testing was not adequate
4	to pick this up. There were opportunities when the
5	operator should have noticed how many heaters, that
6	they were having to use more than the normal amount of
7	heaters to maintain pressurizer temperature, that type
8	of thing.
9	But there may have been multiple problems.
10	They had a problem with the spray valve leaking and
11	that masked it to some extent.
12	MR. BUNACA: Well, that may have misled
13	them.
14	MR. SCHIN: Right.
15	MR. BUNACA: When you say that there were
16	several opportunities to identify, this was prior to
17	March 2002, I guess.
18	MR. SCHIN: That's true, yes, sir.
19	MR. SIEBER: From day one.
20	MR. SCHIN: Right.
21	MR. BUNACA: I'm just asking because the
22	finding was it the 3rd quarter of 2003, so a year and
23	a half later you cite this finding, but actually the
24	finding that you have in 2003 is for this event in
25	March 2002.
	I

```
(202) 234-4433
```

63 1 MR. SCHIN: I'm not sure about the timing 2 of when we count findings against the action matrix. 3 It's not just when the licensee may have had an 4 inkling of a problem. 5 MR. WALLIS: It's an interesting situation. I think we have other ones like this where 6 7 a thing has been going on for a very long time. 8 MR. SCHIN: Right. WALLIS: And then the licensee 9 MR. 10 eventually wakes up and says oh, we found this problem, and so you penalize them, so there's no 11 12 incentive to find the problem. MR. SCHIN: Right. 13 14 MR. WALLIS: It's kind of counter-15 intuitive, really. There ought to be some reward for 16 at least recognizing the problem. MR. SIEBER: The reward is there was no 17 civil penalty. 18 19 MR. WALLIS: If they'd waited even longer, 20 there would have been more penalty? 21 MR. SHACK: If somebody else had found it 22 instead of them, they would have been hammered. MR. SIEBER: It's the number of lashes. 23 24 You get reduced lashes, reduced strength and number. 25 The second white finding that MR. SCHIN:

> NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433

	64
1	we were looking at was manning the SSF during a fire,
2	and this finding was NRC-identified during a triennial
3	fire protection inspection in February of 2002.
4	And in this case the procedures for
5	staffing the SSF during a fire did not send operators
6	to the SSF until after fire damage had caused a loss
7	of function of steam generator feed water or high
8	pressure injection.
9	So they had already sustained considerable
10	damage due to the fire, and consequently, the
11	pressurizer relief valves could lift many times and
12	potentially fail open, rendering the SSF inoperable.
13	So the citation was for failure to meet
14	the fire protection licensing basis for properly
15	staffing the SSF during a fire before the fire damages
16	the cables.
17	MR. WALLIS: Now, it becomes inoperable
18	because it can't function anymore or because there's
19	no access to it, or why is it inoperable?
20	MR. SCHIN: If you don't staff the SSF in
21	time till after these various things fail for
22	example, if you wait till after you have a loss of all
23	feed water, what happens in a BMW plant when you lose
24	all feed water to the steam generators they have
25	small steam generators and within about seven minutes
I	I

(202) 234-4433

	65
1	the steam generators go dry.
2	MR. THADANI: This is a TMI situation.
3	MR. SCHIN: Exactly. And then the RCS
4	pressure jumps right up to the relief valve set point
5	and you start popping the relief valve. And then
6	within 16 minutes from popping the relief valve, the
7	RCS is heating up and the bubble shifts on the
8	pressurizer over into the reactor vessel.
9	And so the problem is with delayed
10	staffing of the SSF, now you've got some repeated
11	popping of this relief valve for a number of minutes,
12	and that increases the risk of failure of the relief
13	valve. If the relief valve fails open, now the SSF
14	won't work. It only has a small reactor coolant
15	system makeup pump that pumps about 30 gallons per
16	minute, and it can't handle any kind of leakage.
17	MR. WALLIS: It doesn't have the pressure?
18	MR. SCHIN: It does have the pressure,
19	it's a positive displacement pump, but it doesn't have
20	the volume.
21	MR. SIEBER: So this would have been TMI
22	all over again.
23	MR. SCHIN: Could have right. Stuck-
24	open PORV and no
25	MR. DENNING: Main control room assumed
	I

66 1 inoperable. Main control room is assumed 2 uninhabitable. 3 MR. SCHIN: This is during an Appendix R 4 analysis where you lose control of enough equipment 5 that by the design, the safe shutdown analysis, they should be staffing the SSF. 6 7 The idea, and in fact, specific in the licensing basis was that they would send someone to 8 the SSF -- the licensee made a commitment in a letter 9 10 to the NRC that they would send someone to the SSF, when they had a fire in certain areas they would send 11 12 someone promptly to the SSF to be standing by such that if you did lose control, had certain fire damage 13 14 and lost all feed water to the steam generators, the 15 individual would be at the SSF to promptly transfer control such that your relief valves are not going to 16 17 be popping open multiple times. 18 MR. DENNING: Is that an action that you 19 cannot perform from the main control room, or is it 20 assumed that in this fire you lost the main control 21 room? 22 From the main control room MR. SCHIN: 23 you've either -- the problem comes in where the people 24 are still in the main control room, it's habitable, 25 but you've lost control of the plant because of fire

> NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433

	67
1	damage to control cables for various valves and pumps.
2	So that the control room, you've lost either all feed
3	water, main feed water and auxiliary feed water, or
4	you've lost all high pressure injection capability.
5	Part of the problem is the SSF is designed
б	such that when you go to the SSF to activate it, the
7	first thing you do is transfer control to the SSF.
8	It's like an auxiliary shutdown panel on the other
9	plants, you have all these transfer switches.
10	And when you transfer control, now those
11	valves and pumps are powered from the SSF and all the
12	cables out in the plant that are subject to fire
13	damage now are out of the picture.
14	But while they're in the picture before
15	you throw those transfer switches, you could have
16	spurious actuations of valves and potentially cause
17	more damage. In other words, you don't want to wait
18	till after you've had fire damage to the cables and
19	spurious actuations until you throw the transfer
20	switch because by then it might be too late.
21	MR. WALLIS: So why is it only a white
22	finding?
23	MR. SCHIN: It was only a white finding
24	because our significance determination process came
25	out that way, and it depends largely on the initiating
	I

(202) 234-4433

	68
1	event frequency.
2	MR. WALLIS: Because it's so unlikely.
3	MR. SCHIN: Exactly. An initiating event
4	frequency.
5	MR. WALLIS: Because it sounds pretty bad,
6	the scenario you've described.
7	MR. THADANI: I think what you described,
8	to me, is very reasonable way to deal with this issue,
9	but does Appendix R allow you to also assume that
10	relief valve is stuck open or are you postulating
11	certain shorts that create that condition, and if so,
12	then why wait?
13	MR. SCHIN: No, Appendix R is a
14	deterministic design criteria.
15	MR. THADANI: Right, and that's why I
16	don't know if you can postulate.
17	MR. SCHIN: The way our process works,
18	first you have to have a finding where the licensee
19	did something that was contrary to the licensing basis
20	in this case. The licensing basis was that they send
21	someone to the SSF immediately. They didn't do that,
22	they were going to wait till after they had all this
23	fire damage. So that's the finding.
24	Now, when we look at risk, now we can
25	consider the likelihood of a valve sticking open.
I	I

(202) 234-4433

	69
1	MR. WALLIS: So they can be lax if they
2	think that it's not risky? They didn't do what they
3	were supposed to do.
4	DR. TRAVERS: They have to fix that.
5	We're only talking about the classification of the
6	finding as a function of risk and the initiating event
7	probability associated with it.
8	MR. WALLIS: But it's interesting, they
9	obviously were not in compliance, they didn't do what
10	they should have done, but you said well it's okay
11	because it wasn't so risky.
12	(General talking.)
13	MR. SIEBER: I'm with you, I'm a
14	deterministic kind of person.
15	MR. WALLIS: You're a very bad boy but the
16	risk wasn't so bad so it's okay.
17	MR. SIEBER: I would skip that last part.
18	MR. BUNACA: One aggravating circumstance,
19	of course, is the fact that they did not identify
20	this, you found it.
21	MR. SCHIN: Right.
22	MR. BUNACA: I mean, do you account for it
23	when you make a determination of a white is it purely
24	based on the significant determination on a risk
25	basis, or do you have consideration of who identified
I	

(202) 234-4433

	70
1	this problem?
2	MR. SCHIN: No. And the risk only
3	considers if the issue had been the condition had
4	been in place for various time periods, up to three
5	days or up to 30 days or up to a year. If it had been
6	in place for 10 or 20 years, that doesn't change the
7	risk from the NRC's analysis.
8	MR. WALLIS: But it obviously does. If
9	you multiply the risk per year by number of years, it
10	was a bigger hazard.
11	MR. SCHIN: Right, but our process doesn't
12	do that, we stop at one year.
13	MR. BUNACA: Now, if you had a number of
14	findings, different findings, and was consistently the
15	NRC is the one identifying these technical
16	deficiencies, how would you handle it within the ROP?
17	Does it become a cross-carrying issue? I'm not sure
18	about that. Maybe it would be.
19	MR. SCHIN: Possibly. It has to do with
20	how we document things and whether they could be
21	cross-cutting issues, but basically we have this
22	action matrix that once we identify something as say
23	a white finding, it goes on the action matrix and it's
24	on there for so long, for let's say a year, and it
25	will drop off if it's been corrected and we've
	I

(202) 234-4433

	71
1	inspected and verified that the situation has been
2	corrected. So it could stay on for longer than a
3	year.
4	And then if there's any other issues that
5	come on the action matrix that are say white findings
6	in the mitigating system cornerstone that are on
7	during the same quarter, then that makes two that are
8	on the action matrix at the same time and we have a
9	95002 inspection.
10	We've had a number of these at Oconee
11	during the last few years.
12	MR. BUNACA: I mean, that says something,
13	and I'm sure ROP really deals with it. I'm sure you
14	have ways of dealing at some point with it, that's
15	what I was looking for. I mean, it's like treatment
16	of repeat events where you have an issue, supposed to
17	be corrected, the correction is not adequate, so you
18	have a repeat event again. Those are aggravating
19	factors which are important, may be cultural issues.
20	MR. SCHIN: Right. Now, when we get
21	involved, though, we identify what the finding is and
22	they have to implement some corrective action. And
23	then we go back for issues that are white or more, we
24	have a follow-up inspection, and it's either a 95001
25	or 95002 inspection, and we look at what their planned
ļ	I

(202) 234-4433

	72
1	corrective action is and does it address the issue and
2	the causes for the issue, and then we determine if
3	that's adequate and we close the finding. And then
4	the white goes off the action matrix.
5	But now, that doesn't prevent having some
6	other issue two months later that's another white
7	finding that may be in some different piece of
8	equipment or different cause.
9	MR. SIEBER: Well, both of these are in
10	the same cornerstone which is mitigating system, so
11	it's not multiple degraded cornerstones. And you look
12	for cross-cutting issues if the root cause for
13	multiple degraded cornerstones is the same. And so
14	this doesn't appear to fit into that.
15	DR. TRAVERS: You can get into trouble by
16	multiple or repetitive.
17	MR. DENNING: What is the root cause here?
18	On this one, what do you consider the root cause to
19	be? Was it in the Appendix R analysis?
20	MR. SCHIN: The licensee did a root cause
21	analysis and we reviewed that, and they determined
22	that the root cause was multiple and it was because
23	back during the early 1980s when this Appendix R rule
24	came out and they installed the SSF and they had first
25	procedures for the SSF, that the operators who wrote
	I

(202) 234-4433

	73
1	up the first procedures incorrectly interpreted the
2	licensing basis.
3	MR. WALLIS: So it's a procedures problem.
4	MR. SCHIN: Right.
5	MR. WALLIS: Because your description said
6	they didn't send anybody to the SSF, but the
7	procedures didn't ask them to do that.
8	MR. SCHIN: Right. But they had the whole
9	licensing basis and the letters at the time, and they
10	understood that there was what was called a ten-minute
11	rule for the SSF, that if you lost all of the feed
12	water function or all of the high pressure injection
13	function that you had to man the SSF within ten
14	minutes and get it in operation.
15	Then the fire protection rules came out
16	and for manning the SSF in the event of a fire, they
17	apparently incorrectly assumed that that was the only
18	ten-minute window. But the description in the letter
19	to the NRC said that one of the concerns was hot
20	shorts and spurious actuations during a fire, and so
21	that they would man the SSF or send someone to the SSF
22	within ten minutes of the start of the fire so that
23	the person would be there before the hot shorts would
24	occur. But if there were hot shorts and spurious
25	actuations that occurred, there would be someone
	I

(202) 234-4433

	74
1	already at the SSF.
2	But the operators misinterpreted that and
3	they didn't understand apparently that quote, ten-
4	minute window from the start of the fire to get to the
5	SSF within ten minutes or promptly, and they just
6	considered there was one ten-minute window.
7	MR. DENNING: And then to transfer to the
8	SSF?
9	MR. SCHIN: The licensing basis was just
10	that you have someone there promptly from the start of
11	a fire
12	Now, the licensee's root cause said that
13	there were people at the general office most of
14	their engineering in those days was at the general
15	office, not at the plant, so their engineers were in
16	Charlotte and the people at the plant were in South
17	Carolina.
18	But the electrical engineers at the
19	general office understood what the problem was but
20	they didn't communicate with the people at the plant,
21	the operators. The operators who were writing the
22	procedure apparently went on their own and their root
23	cause was they didn't understand.
24	What they said was that during the course
25	of many years since that happened, there were multiple
ļ	I

(202) 234-4433

	75
1	missed opportunities to identify this, when they did
2	their own different inspections, other various NRC
3	inspections, audits. And this issue of timing the
4	staffing of the SSF was questioned on many different
5	occasions, at least half a dozen. And they had some
б	programmatic breakdown as to why it was not picked up
7	on half a dozen different occasions since the early
8	'80s when the problem originally happened.
9	MR. WALLIS: Is this the only BMW plant
10	you have in this region?
11	MR. SCHIN: No. We have Crystal River
12	too.
13	MR. WALLIS: Is the other one doing it
14	right?
15	MR. SCHIN: Yes, as far as we know. Well,
16	they don't have an SSF, so they have to staff their
17	auxiliary shutdown panel at some point. And to be
18	honest, that's an areas that we're looking at, the
19	timing of staffing the early shutdown panel and could
20	there be other problems with that, maybe there could.
21	We're looking at that in fire protection inspections.
22	MR. CARUSO: When you looked at the risk
23	for these two issues, not manning the SSF, but manning
24	the SSF and he pressurizer, did you consider because
25	they both related to the same starting scenario

(202) 234-4433

	76
1	synergistic effects between them in determining risk?
2	MR. SCHIN: Right, we did that. Bob, our
3	senior risk analyst, looked at that and the risk of
4	each one of these and how they would add together, and
5	considered that to correctly assess the risk of both
6	of these being in place at the same time, you would
7	directly add the risk of each one, and it still came
8	out white. It was a high white but it didn't go into
9	the yellow column.
10	And he evaluated why that was appropriate,
11	and it was because the one issue the concern was an
12	early failure of the pressurizer or safety valve early
13	in the scenario, and the other one, the concern was
14	later in the scenario. The timing wasn't at the same
15	time.
16	MR. McCREE: Just so that you know the
17	depth of the risk reviews of STPs, when we have a
18	potentially greater than green finding, the SRAs
19	routinely share their analyses with the support risk
20	group at NRR as well as research. And part of that
21	process called the Significance in Enforcement Review
22	Panel, the SERP, focuses primarily the risk analyses.
23	This was a collegial conclusion we reached on the
24	significance of this.
25	MR. SIEBER: Let me ask a question that
Į	I

	77
1	you may know the answer to or maybe not. The agency
2	has a goal, a time goal as to how long it takes them
3	to go through the significance determination process
4	which is sort of a performance measure on the senior
5	reactor analysts.
6	How are you folks in Region II doing with
7	respect to meeting the time goal to produce the
8	answer?
9	DR. TRAVERS: Good question, and that's
10	the next presentation.
11	MR. SIEBER: I should read ahead, or maybe
12	I did and that's where the question came from.
13	(General laughter.)
14	MR. SCHIN: Do you have any other
15	questions on that? Okay.
16	We have team composition here. It was a
17	small team. We had a lead inspector which was me, a
18	senior reactor analyst, and a basic-qualified
19	inspector who was basically in training for doing this
20	type of inspection.
21	The inspection itself, we had what we call
22	a bagman trip it's an advance information-gathering
23	trip to the site which was done by one person, me.
24	I went for one day and collected all the information
25	that we requested.
I	

	78
1	Then we had a prep week in the office, one
2	week on site, and then we had one additional week in
3	the office because we didn't finish everything we
4	needed to do while we were on site but we brought
5	enough information back with us to finish the review.
6	The results of the inspection were that we
7	didn't have any new findings of significance that we
8	identified. We saw that there were some opportunities
9	for improvement in the licensee's process for
10	determining root causes, contributing causes, extent
11	of cause and corrective actions.
12	We concluded that overall, though, the
13	corrective actions that were already completed
14	which they had done to restore compliance, they had
15	changed the procedures and changed the number of
16	pressurizer heaters that were powered from the SSF
17	and the corrective actions that they had planned, if
18	well done, would have been adequate to address the
19	issues, and we closed the one open white finding.
20	Any other questions?
21	MR. SIEBER: Thank you very much.
22	MR. SCHIN: If not, I'll turn it over to
23	Scott Freeman.
24	MR. FREEMAN: Good morning, everybody. My
25	name is Scott Freeman and I'm the senior resident at
	I

(202) 234-4433

	79
1	Sequoyah and I'm going to talk about a white finding
2	that occurred at Sequoyah where they had a binding in
3	one of that RHR breakers.
4	To start with a little background, TVA
5	began using ABB Services to refurbish their 6900
б	breakers in 1996 and between then and 2000 they had
7	numerous problems with these breakers. In fact, at
8	one point they even removed ABB from the authorized
9	supplier list.
10	It got to the point in September of 2000
11	that the refurbishment cost for safety-rated breakers
12	reached \$31,000, and based on that, in July of 2001
13	TVA decided to replace the safety-related breakers
14	with Siemens breakers and began changing the breakers
15	out in November of 2001.
16	These new breakers were vacuum breakers
17	manufactured by Siemens and modified by Wiley Labs to
18	fit the existing cubicle, and also to make them
19	safety-related.
20	What I have here is a sketch of the
21	mechanism and you have to excuse the quality of this,
22	I had to do this myself, but over here is a drawing of
23	the breaker, this is the cubicle, and the breaker
24	racks into the cubicle this way.
25	What I wanted to point out here was when
	1

(202) 234-4433

	80
1	they started using Siemens breakers, problems began
2	almost immediately, and most of them were associated
3	with this MOC switch, the mechanism-operated cell
4	switch. That's this guy right up here at the top.
5	It sits in the top of the cubicle and is
6	operated by this long arm that goes to the bottom of
7	the cubicle, and that little horseshoe thing there
8	mates up with a slot on this mechanism on the breaker
9	that operates off of the breaker itself.
10	Most of these problems were due to the
11	extra force from this breaker. Because it's a vacuum
12	breaker, it operated about twice as fast as the
13	original which multiplied the forces on this switch up
14	here by four, and that's essentially where most of the
15	problems occurred.
16	MR. SIEBER: That's a cell switch. Right?
17	MR. FREEMAN: The cell switch is up here;
18	it's two of them in parallel.
19	Let's go to the next slide. That's the
20	breaker sitting on the floor, and over on the right
21	there this is one of the buses, there's another one
22	across the room from it.
23	Next slide. That's actually the failed
24	breaker and they're looking at in the warehouse. This
25	part down here is where the problem occurred. This is

(202) 234-4433

1 that operating mechanism that's on the breaker. This 2 is the breaker operating shaft and there's a rod that 3 runs here that slides this up and down as the breaker 4 opens and closes. 5 Next one, that's a closer view of it. There's a slot, a notch right here that mates up with 6 7 a part of the cubicle, and this spring absorbs some of 8 the force, and then there's a bolt right here and an

9 elongated notch. This is where the binding actually 10 occurred.

Let's go to the next one. This is another view of it. You can see the slot here and the elongated notch here.

14 One more. This is the cubicle. The 15 there, this is primary goes in the secondary connection, and this is the MOC switch mechanism here. 16 That notch we just showed you meets up right here, it 17 operates this up and down which moves that rod. 18

19 One more. And this is the MOC switch up 20 it the top of the cubicle and there's the rod coming 21 up from below. This little device right here is a 22 modification they made after they started refurbishing 23 the breakers to absorb some of the force as the 24 breaker opens.

> NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

This goes down when the breaker closes and

(202) 234-4433

25

	82
1	when the breaker opens this comes up, and they had
2	some problems with so much force here it was breaking
3	these things loose.
4	Next slide. This is the list of problems
5	that we looked at that shows eight different failures
6	starting in 2002 going all the way up to the bottom
7	one that is the one that actually got the white
8	finding.
9	MR. BUNACA: Do they go back to ABB?
10	MR. FREEMAN: They did eventually; I'll
11	come to that. That's their ultimate correction.
12	The problems started in 2002 and they
13	started with problems found during initial checks with
14	the breaker in the test position and eventually ended
15	up, worked their way through the problems with the
16	breaker in connect position and showing up during PMT,
17	and eventually at the bottom there, an on-demand
18	failure with the RHR pump.
19	MR. WALLIS: If they failed to close in
20	2002 several times, why didn't they fix it?
21	MR. FREEMAN: They thought they did.
22	There were deeper problems. In fact, there were even
23	problems in 2003 that I didn't put up there because
24	they occurred during receipt inspection.
25	And this last problem, this one on the RHR
ļ	I

(202) 234-4433

	83
1	pump, was attributed to a phenomenon called
2	bradding which I'm going to get to in just a
3	minute and the one right above it was also.
4	MR. SIEBER: It looks like the vendor
5	failed to sailor-proof the mechanism.
б	MR. FREEMAN: That was part of it. This
7	is the bracket on the failed breaker, this is where
8	the problem actually occurred, and this bolt right
9	here this is the side of the breaker, this bolt
10	screws into the side of the breaker. It's a shoulder
11	bolt and it fits up tight against the side, and then
12	this bracket slides up and down in it and there's
13	washers here to take up the space.
14	Well, what happens here is when the
15	breaker opens, this thing goes down and the very top
16	of that notch hits on the bolt. It was hitting on the
17	bolt and it was causing it to mushroom out a little
18	bit, and you almost had to feel it, but it was just a
19	little bit, and Siemens called that bradding.
20	So now when the breaker closes and it
21	tries to go up, this bradding acts as a drag force,
22	and if you et enough drag force, the breaker won't
23	latch, and that's what happened on the RHR pump.
24	The other thing that it depends on is the
25	tolerances between the bolt, the washers and the
	1

(202) 234-4433

	84
1	bracket.
2	MR. WALLIS: What's it made out of, that
3	thing that mushroomed out?
4	MR. FREEMAN: Yes, it's a brass/copper
5	type.
6	MR. WALLIS: Something soft.
7	MR. FREEMAN: Yes, something soft.
8	But what we found was that there was no
9	specs on installation, not tolerance, no clearance, no
10	specs to make sure it would slide.
11	Next one. This is the same bracket
12	disassembled, and actually I'm going to pass these
13	around here. I have some black and white pictures
14	that go with it.
15	You can see right here at the top of the
16	slide, that's the bradding. And it's really hard to
17	see, the only way you really know for sure is run your
18	finger on it and you can feel it.
19	And on these ones going around, I have a
20	picture of this one plus the one previously from the
21	previous failure that they found in the Siemens shop,
22	and we'll come to the Siemens shop in just a minute.
23	MR. WALLIS: Is this the usual kind of
24	thing you get in these boxes?
25	MR. FREEMAN: This one is pretty close to
	I

(202) 234-4433

	85
1	what ABB had, only it's modified just a little bit to
2	absorb the force. This part with the "V" on it
3	actually slides up and down also.
4	But you can see also on these washers up
5	here, marks where the mushrooming had scraped the
6	washers, and there's a good picture of the shoulder
7	bolt. The breaker side goes right in this slot right
8	here.
9	MR. WALLIS: That's a nice hard hammer
10	you've got up there.
11	MR. FREEMAN: Right. Well, Siemens had
12	actually identified this problem in April of 2004 as
13	part of cause investigation for previous failures, and
14	they recommended TVA do inspections.
15	In fact, on those sheets going around,
16	there's ones that describe for the failed breaker and
17	ones for the Siemens breaker they found in the shop.
18	They recommended a visual or a functional
19	inspection, and basically they said you could look at
20	it and look for it or you could functionally test
21	meaning you could take the mechanism apart and try to
22	operate it.
23	And they indicated that a visual was
24	somewhat subjective because bradding was normal, so
25	they told TVA that some bradding could be expected,
ļ	I

(202) 234-4433

86 1 but they also stated that the functional would be more 2 accurate, and the best way is to disconnect the mechanism and operate it through its full range of 3 4 travel. 5 MR. SIEBER: Even if assembled correctly, the end of that slot will always hit the shoulder on 6 7 that bolt. MR. FREEMAN: Well, that was a little bit 8 9 debatable. It was doing it a lot, I'm not sure it 10 would do it every time. MR. SIEBER: It looks like it was designed 11 12 to do it. But you could make it out of 13 MR. WALLIS: 14 a different material that was less susceptible to 15 plastic defamation. Well, you know, then you 16 MR. SIEBER: 17 break the bolt. The problem was really in MR. FREEMAN: 18 19 not anticipating that this force was there. 20 Next slide, please. This is what TVA did 21 about this. Because Siemens had said some bradding 22 was normal, TVA chose to do a visual inspection. Thev 23 had 12 breakers in the warehouse as spare and they did 24 a visual inspection on those by sliding a coin down on 25 that elongated slot to check for bradding and found

> NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433

	87
1	some minor bradding and said that was normal.
2	They inspected the ones in the plant, 6 in
3	the A train of ECCS and 12 in the B train by using a
4	boroscope. The breakers remained racked into the bus
5	and they stuck a boroscope down the side and did a
6	visual inspection with using maintenance personnel
7	only. Engineering wasn't present for the inspection
8	and only reviewed one tape. They were recorded but
9	they reviewed only one tape.
10	MR. WALLIS: They used the visual
11	inspection but you told us earlier it was rather hard
12	to see?
13	MR. FREEMAN: That's my opinion, it's
14	almost impossible to see. Actually, it's my opinion
15	that had they done the functional test here, they
16	would have found the problem, but they chose not to.
17	Next slide, please. So what was NRC doing
18	up to this point? Well, we had been monitoring this
19	using our baseline modules but because TVA was
20	addressing the problems as they occurred, we had no
21	operability concerns, and what I have up here is a
22	list of the ones we did in 2003 and 2004.
23	The bottom one there, we started doing a
24	PI&R annual sample because the problems just kept
25	occurring and we wanted to see, well, what's their

(202) 234-4433

	88
1	corrective action program doing about it. In fact, we
2	had exited on that PI&R sample but pulled it from the
3	report because they had two failures between the time
4	of the exit and the time the report went out.
5	After the RHR pump failed, we got a little
6	bit more concerned. DRS sent two inspectors up for a
7	one-week inspection, and they raised questions about
8	qualification testing. They asked them: Did you not
9	do the thousand endurance cycles that the triple E
10	standards call for?
11	And the residents, after that happened,
12	started looking back for previous problems and we
13	found that an identical problem to this had occurred
14	in June of 2003 where the corrective action document
15	said the bolt was too tight and the mechanism was
16	binding. And they basically at that time just
17	loosened the bolt and went on.
18	MR. WALLIS: Even when it was new.
19	MR. FREEMAN: Yes, it was during receipt
20	inspection.
21	Also, Chuck Castoe and Steve Cahill came
22	up and had a visit with TVA management to let them
23	know we were really concerned about it.
24	Next slide, please. At that point, TVA
25	really started looking for the causes. Up until this
ļ	I

(202) 234-4433

	89
1	point they had been laying off the cause on the vendor
2	all along, saying vendor problems, vendor problems,
3	vendor problems. But when we got more involved in it,
4	they dug deeper and found some process problems.
5	The first one was this engineering
6	document change process. That's really their like-
7	for-like engineering process. And they did that
8	because it was basically easier to implement. They
9	didn't have to sign off a document every time they put
10	one of these breakers in. And this essentially
11	resulted in them not addressing the impact of the
12	faster breaker operation. Because of that process,
13	they didn't look at all these problems with the MOC
14	switch.
15	The other thing was they didn't hold the
16	vendor accountable for qualification testing. They
17	were supposed to be getting documentation approving
18	all the qualification, and the vendor didn't do it and
19	they didn't push it. Consequently, the vendor
20	basically did a technical justification in lieu of
21	qualification testing on the original breaker.
22	MR. SIEBER: So it basically was not
23	physically tested.
24	MR. FREEMAN: The first one they went
25	through five iterations of design; the very first one
Į	

(202) 234-4433

	90
1	was not tested, after that they started doing them.
2	Next slide. Disposition. This was the
3	white finding beginning July 1, 2004: The RHR train
4	was inop for 14 days and the delta CDF came out to be
5	about 1.3E to the minus 6, and the main drivers were
6	the reduced sump recirculation for small or medium
7	break loca because of the one RHR pump being out, and
8	no sump recirculation for loss of 125V DC battery
9	board 2.
10	That's because losing that battery board
11	would prevent the opposite RHR pump from starting, so
12	there would be no RHR.
13	Next one. Conclusions.
14	MR. SIEBER: This is a BWR. Right?
15	MR. FREEMAN: No, it's a PWR. It's an ice
16	condenser.
17	Conclusions. I put there the process
18	worked because as the problems continued to get worse,
19	NRC attention got more focused and eventually the
20	licensee dug deep enough and found their own problems.
21	MR. WALLIS: How long did that take?
22	MR. FREEMAN: Well, essentially from when
23	they started in 2001 until 2004, but we really started
24	looking in 2003.
25	MR. WALLIS: So there's no expectation for
I	I

(202) 234-4433

	91
1	time on your conclusion that the process worked?
2	MR. FREEMAN: Well, that's why I have the
3	process didn't work up there.
4	MR. WALLIS: Which conclusion is correct?
5	MR. FREEMAN: Well, they're both right
б	because actually the problem did get solved, but we
7	had a suspicion all along and the residents had a
8	suspicion all along that there were problems with
9	these breakers. But to really dig into and find out
10	would have required a very intensive design
11	inspection, and in order to continue doing the
12	remainder of the baseline inspections, as long as we
13	felt they didn't have any operability concerns, we
14	kept on doing the baseline inspections. It's kind of
15	a resource question.
16	MR. CASTOE: But it's also a risk
17	question. The previous failures were not greater than
18	green, they were not risk-significant. When the RHR
19	pump failed on demand, that became risk-significant.
20	MR. FREEMAN: That's true.
21	MR. SCHIN: That was the first failure
22	that was actually a component in service.
23	MR. FREEMAN: Where we had an operability
24	question.
25	MR. CASTOE: And in NASA-speak, that
ļ	I

(202) 234-4433

92 1 became an out-of-family failure and that's what really 2 got our attention because it was out of family from knew 3 the other ones which we were not risk-4 significant. Chuck Castoe, by the way. So by our 5 process, I think the process worked in terms of we engaged when the risk went up. 6 7 MR. WALLIS: This seems to be a problem. 8 When you've got breakers which are poorly designed, 9 they're going to fail, and they failed in various modes and they failed tests and stuff, but nothing is 10 done until it fails in some risk-significant mode, 11 12 although it's waiting to happen. Well, I think that's kind of 13 MR. FREEMAN: 14 my dilemma when I sit and thing about whether this 15 worked or not. Well, not optimally, of 16 MR. SCHIN: 17 course. If they had taken the initiative which we felt they should have, then optimally you would have 18 19 had resolution of this well before failure. 20 They did repair a lot of the MR. CAHILL: 21 individual problems. They had a myriad of small 22 problems that cropped up but the root driver that 23 being the accelerated force of this different type of 24 breaker and the incompatibility. But they fixed each 25 individual problem and really never stepped back, and

> NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433

	93
1	like he said, they relied on the vendor and the vendor
2	fixed each problem, and they never stepped back and
3	said we really have a bigger compatibility issue here.
4	MR. WALLIS: Are there other breakers on
5	some other circuit which is even more risky that are
6	the same breakers?
7	MR. FREEMAN: Yes, they had these breakers
8	in all of their essential switch gears.
9	MR. WALLIS: So I would think the delta
10	CDF would be bigger if you said the breakers are going
11	to fail.
12	MR. FREEMAN: Well, this was the only one
13	that was actually inoperable.
14	MR. WALLIS: But the others are waiting to
15	be inoperable.
16	MR. SCHIN: They only had a small portion.
17	They were phasing these in, they weren't in all
18	safety-related locations.
19	MR. CAHILL: The other thing we did was
20	make sure they had one train.
21	MR. SCHIN: And we went through and
22	analyzed where each one of these Siemens breakers was.
23	MR. WALLIS: They could have been on every
24	train and then you lose the whole thing. It's a
25	common cause failure.
ļ	I

(202) 234-4433

	94
1	MR. CASTOE: We looked at it and NASA
2	looked at it and they moved breakers based on risk
3	significance. They took them out of certain
4	components and put them in other components to keep
5	the risk significance low.
6	MR. FREEMAN: Yes, after the RHR failure,
7	they moved them to where they had them only in one
8	train to eliminate the common cause. But again, that
9	was after the NRC really got looking at it.
10	MR. DENNING: I think there's an important
11	aspect of this, though, if I'm understanding it
12	properly, that has something to do with the way we
13	license things versus the way Europeans license
14	things, and I don't know whether it's really that
15	deep.
16	But the problem always comes up when
17	you're taking out a breaker, the breaker that actually
18	was there originally, and you're replace it with some
19	other breaker and you have to have interface equipment
20	that's different, that's new.
21	MR. FREEMAN: That was my other
22	conclusion.
23	MR. DENNING: And I'm wondering now and
24	then that has to be made safety grade through
25	commercial dedication process.
ļ	I

(202) 234-4433

	95
1	MR. FREEMAN: Exactly what they did, yes.
2	MR. DENNING: And now, you don't do any
3	inspection of what the NRC doesn't do any
4	inspection of vendor facilities. Is that true? Like
5	in this case, how did they certify it to be nuclear-
6	qualified? Did they do like a thousand cycles and
7	this kind of stuff?
8	MR. FREEMAN: Well, it turns out they were
9	supposed to and TVA had a contract with Wiley to go
10	through this commercial grade dedication process, and
11	they were supposed to include qualification in
12	accordance with our Triple E standards.
13	Siemens and Wiley interpreted that and
14	said, Well, using this standard and I can't
15	remember the number they can do a technical
16	specification in lieu of endurance testing. TVA
17	didn't call them on that which they should have done,
18	and they eventually admitted they should have done.
19	Had they done that, they would have done the thousand
20	cycle testing and may have found these MOC switch
21	force problems.
22	MR. DENNING: The utility has to make
23	sure, it's their responsibility that whatever was done
24	to qualify it was really done.
25	MR. FREEMAN: Yes, that's how I see it.
	I

(202) 234-4433

	96
1	MR. THADANI: But the Vendor Inspection
2	Branch also has a responsibility to at least go
3	through certain inspections.
4	MR. WALLIS: I don't understand this at
5	all. I mean, you're hammering a piece of brass with
6	a piece of steel, someone must have at a very early
7	stage in design asked: Is it going to mushroom? I
8	don't understand how it ever got to be designed this
9	way. It seems very peculiar, but maybe I'm naive.
10	MR. FREEMAN: Well, this was actually a
11	first of a kind type situation. There are other place
12	that are doing this new breaker in existing cubicle
13	situation; they all seem to be different. This was
14	the first one to put Siemens breakers in these ABB
15	cabinets, and because of these two process problems,
16	they actually missed things they should have got.
17	MR. CARUSO: As a result of this
18	experience, do you have a good sense that TVA watches
19	closely for unforeseen problems when it replaces old
20	equipment with new equipment, especially from a
21	different vendor or a different design?
22	MR. FREEMAN: Well, I say they learned a
23	lesson. I don't know if they're going to do it every
24	time, we just have to keep watching them.
25	MR. CASTOE: They have the right checks an
ļ	I

(202) 234-4433

	97
1	balances in their process, they just didn't follow
2	what their own process says in this case. They went
3	back in their corrective action program and looked at
4	their process and found five other indications, five
5	other modifications where they had used this process
6	and did not follow their process.
7	MR. CARUSO: If they were replacing a lot
8	of components in a large plant that hadn't operated
9	recently, would you be concerned?
10	MR. FREEMAN: I would want to check, yes.
11	MR. CAHILL: This is Steve Cahill. What
12	Scott was saying about the first of a kind situation,
13	TVA was alone in their false sense of security about
14	this because if you saw all those Siemens breakers
15	you saw at Browns Ferry, those used to be GE
16	Magnablast breakers TVA had gone through Wiley and
17	gotten those Siemens breakers to change out all those
18	things in the same type of process, and that's not the
19	first time Wiley had done that, they had done it at
20	two other plants.
21	So they worked well, TVA had great success
22	with Wiley using Siemens breakers, so they figured we
23	can use them over here at Sequoyah to fix this
24	problem. And what Scott was saying, that's the first
25	time Wiley had ever done those Siemens breakers in an
ļ	

(202) 234-4433

(202) 234-4433

	98
1	ABB cabinet, and they got molded in that false sense
2	of security and figured they could use less than their
3	normal full design change process and they did the
4	like process, and apparently that was a poor decision
5	in hindsight.
6	MR. SIEBER: Are these breakers unique to
7	the combination of the metal-clad switch gear and the
8	breaker body itself, using one vendor for the cubicle
9	and another vendor for the breaker?
10	MR. FREEMAN: They are unique and Wiley
11	was supposed to modify them to make them fit, so you
12	could basically just roll the old one out and roll the
13	new one in.
14	The reason they went for like-for-like was
15	because at Browns Ferry they didn't use like-for-like,
16	they had to sign off every time they changed a breaker
17	out, 200 or however many times it was, and essentially
18	they didn't want to do that again, they didn't think
19	it was worthwhile. That was the main reason.
20	MR. SIEBER: But do they think it would
21	have been worthwhile at this point in their history?
22	MR. FREEMAN: They do now, yes.
23	MR. SIEBER: Of course, signing off
24	doesn't usually fix anything, it just implicates
25	somebody.
ļ	I

(202) 234-4433

	99
1	MR. FREEMAN: Well, there were some other
2	checks too that the system engineer was supposed to
3	do.
4	MR. THADANI: So did they issue a Part 21
5	report on this?
6	MR. FREEMAN: I don't think so, but I
7	don't really know, I don't know for sure.
8	MR. CAHILL: You mean at Three Mile
9	Island? There was some other site that was doing the
10	exact same purchase of these breakers for an ABB
11	cubicle and TVA shared information with them, and they
12	had a lot of leverage with Wiley to get these things
13	fixed. They basically weren't going to pay Wiley any
14	money now until the TVA problems were addressed, and
15	that was the only example of where this application
16	was going on anywhere else.
17	So to answer your question, the intent of
18	a Part 21 was addressed by that.
19	MR. FREEMAN: Back to what you said
20	earlier, they have now removed all the Siemens
21	breakers from the emergency close positions in the bus
22	and intend to eliminate them completely by spring of
23	next year. They're going back to the ABB breakers.
24	And that's the end of my presentation.
25	Thank you.
I	I

(202) 234-4433

	100
1	MR. SIEBER: Thank you very much. Well
2	done.
3	MR. WALLIS: Well, it's a real object
4	lesson how one little tiny detail, the way one little
5	bolt behaves in a little slot can prejudice the safety
6	operation of an important piece of equipment.
7	MR. DENNING: And PRA didn't find it, did
8	it.
9	MR. FREEMAN: That was actually part of my
10	last conclusion was that these new type of designs can
11	result in unforeseen problems, and utilities really
12	need to watch that.
13	MR. RANSOM: Doesn't this equipment have
14	to go through a qualification program?
15	MR. FREEMAN: It was supposed to, yes, and
16	they did a technical justification in lieu of actually
17	operating it, the vendor did. They read a loophole in
18	the code and TVA didn't call them on it.
19	MR. DENNING: Well, it's a subtlety as to
20	what's like.
21	DR. TRAVERS: The other thing that's been
22	touched on here, I think, that's important is this
23	reliance on vendors and the question arose here who do
24	we hold responsible. Well, we hold the licensees
25	responsible and they'll be the ones who are subject,
I	

(202) 234-4433

101 1 potentially, to enforcement for matters of this sort, 2 and so they really need to be a little bit more 3 proactive and involved, we believe, in these sorts of 4 endeavors. 5 MR. SIEBER: Well, strangely enough, we're back on schedule. Thank you very much. 6 7 MR. PAYNE: Good morning. Are we ready to 8 continue? My name is Charlie Payne. I'm the branch 9 chief Engineering Branch for ΙI which has 10 responsibility for fire protection. Also, I have both the regional SRAs under my direction. 11 I'd like to start off with covering the 12 types of fire protection findings in general that we 13 14 have. You're probably familiar that Hemic and MT fire wraps have been an issue for several years. We've got 15 four sites that have those. 16 We've had circuit analysis, associated 17 circuit issues, manual actions in lieu of protecting 18 19 the cabling which is actually a subset of circuit 20 analysis -- this is a pretty significant problem here 21 in Region II and I'll discuss that a little bit 22 more -- reactor coolant pump seal cooling, and safe 23 shutdown. 24 The circuit analysis is also kind of tied 25 to safe shutdown because if we have problems with

> NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433

	102
1	manual actions, then their ability to achieve safe
2	shutdown is also in question.
3	And then we've got just miscellaneous
4	other things like smoke detectors in the wrong place
5	or oil retention dikes that don't handle the capacity
6	of the tank.
7	MR. SIEBER: Do you have instances of
8	where a licensee relies on manual actions but didn't
9	ask for NRC approval to do so?
10	MR. PAYNE: We have some occasion where
11	the licensees did that but there's a high number of
12	instances where they didn't. And I'll cover that when
13	I get to the manual actions log.
14	The Hemic issue, it's a long standing one,
15	it affects four plants. All four of these licensees
16	are going to NFPA 805, and so that's part of the basis
17	for why they're going to NFPA 805 but hopefully that
18	will get resolved when they do their transition.
19	The recent testing that NRR and research
20	have done showed that these fire wraps don't meet the
21	one-hour and three-hour resistance rating. And NRR
22	has issued a draft generic letter for comment to
23	basically say that this is a problem and require the
24	licensees to come up with a plan on how they're going
25	to address this issue, and they're going to track all
I	I

(202) 234-4433

	103
1	of this nationwide.
2	MR. THADANI: So do they declare these
3	inoperable and pass some compensatory measures in
4	place
5	MR. PAYNE: That's right. And most of
6	these plants have had fire watches in place, but for
7	example, Harris, we've got our triennial inspection
8	team doing that. They were there for the first week
9	last week, they're going back next week. And one of
10	the things we pointed out to them is that they need to
11	be looking at the bigger picture with their
12	compensatory actions. A fire watch isn't necessarily
13	the only thing that they could do to help reduce the
14	risk presented by this.
15	And also in Harris's situation, they
16	disagreed with the results that we came up with on
17	Hemic. They felt like their Hemic was different, and
18	so they just did a series of tests of their own that
19	I don't have the official results on, but they're
20	trying to demonstrate that their Hemic wrap is
21	actually adequate to maintain a one-hour and three-
22	hour barrier.
23	MR. SIEBER: Didn't the agency do some
24	tests at Wiley within the last year or so on Hemic, or
25	did they
ļ	I

(202) 234-4433

	104
1	MR. PAYNE: Yes. We just completed some
2	testing and issued the results this spring, and that's
3	the basis of the generic letter.
4	MR. WALLIS: I have a couple of questions.
5	What does this stuff wrap and how widespread is it
6	within the plant?
7	MR. PAYNE: Depends on the facility. Some
8	licensees have used it to achieve train separation
9	when they had Train A and Train B.
10	MR. WALLIS: Twenty feet or something,
11	whatever the distance is?
12	MR. PAYNE: Right.
13	MR. SIEBER: Yes, and adjacent cable train
14	MR. PAYNE: But for example, Harris uses
15	it extensively in their plant, and so that's one of
16	the reasons it has a significant impact on them. But
17	McGuire and Catawba, they use it but not extensively.
18	MR. DENNING: Tell me something about 805?
19	Do they use 805 to get around having to suppose you
20	can't demonstrate one-hour and three-hour, we don't
21	believe the tests that they come up with, is the only
22	conclusion then that one would then have to replace
23	those wraps? Or can you use 805 in some way to get
24	around it so that you say you prove that it wasn't
25	risk-significant, or something like that?
ļ	

(202) 234-4433

	105
1	MR. PAYNE: I think you can prove that if
2	it's not risk-significant, then you don't need to have
3	the wrap there.
4	Now, there's a requirement also to
5	maintain defense in depth, so I'm not sure how the
6	interface between those will happen. But for example,
7	if you don't have any ignition sources in this
8	compartment but you do have both trains in there,
9	Appendix R would say you've got to wrap them or
10	separate them or something like that. But really, the
11	likelihood of a fire is so small that they're meeting
12	the requirement but it's really a waste of money and
13	they think it's something that is not required. So
14	that's what 805 will be able to achieve for them.
15	MR. SIEBER: And then all you have to do
16	is hope that there really isn't any ignition sources.
17	MR. PAYNE: That's part of what we do. We
18	go through there and our new inspection process pretty
19	much has us counting all the different ignition
20	sources. We send our SRAs often out on the pre-
21	inspection visit with our team and he walks around all
22	the fires that we're contemplating and inspecting, and
23	helps us decide on whether these are problems or not.
24	MR. POWERS: Then you have to depend on
25	your hot work permitting requirements during shutdown
I	1

(202) 234-4433

	106
1	to ensure that there are no ignition sources in there.
2	MR. PAYNE: That is correct, we take that
3	into account. We'll look at their administrative
4	controls and we'll talk with the senior residents and
5	the DRP branch chief.
6	MR. POWERS: The trouble, for instance,
7	when we were at Browns Ferry recently, they were
8	displaying their permitting requirements for work and
9	things like that, and not once did hot work show up on
10	any of their lists.
11	MR. PAYNE: Well, it's certainly a factor.
12	When we come up with an issue, they try and one of
13	their responses is okay, we've got an administrative
14	control, for example, that says hot work, the
15	likelihood is going to be less than what you're
16	assuming, and then we'll have to evaluate that aspect
17	of it.
18	MR. POWERS: And it's just a persistent
19	problem, especially when you get to these things where
20	the argument is made that there are no ignition
21	sources or there are no combustibles. It works either
22	way because trapped combustibles are just a consistent
23	problem during shutdown.
24	MR. PAYNE: The circuit analysis, it's
25	again another set of long-standing issues, and it's
ļ	I

(202) 234-4433

1 primarily related to associated circuits and spurious 2 equipment operations. So the licensees did a pretty 3 good job of identifying these pieces of equipment, the 4 main components are important for safe shutdown and we 5 need to protect or separate those pieces of equipment. But the associated circuits, the stuff 6 7 that helps make sure that that equipment operates 8 correctly, the protective circuitry -- I can't think 9 of what I wanted to say, sorry -- but it's associated 10 with making sure that the equipment will work Those circuits weren't actually evaluated 11 correctly.

And what we have found is that sometimes those circuits run in the same area, were not protected, and if you had a fire in that, you would get some kind of spurious actuation that they weren't planning on that opened a valve that's normally closed and would divert flow away from where you need it to be.

often by the licensees.

12

20 RIS 2004-03 was issued to resolve this, 21 and it gave the licensees a year of enforcement 22 discretion to let them identify these issues, get them 23 into their corrective action program, and start 24 initiating corrective action. And there would be no 25 risk evaluation done. In other words, no matter what

> NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433

(202) 234-4433

107

	108
1	the risk was, as long as they identified them and
2	started getting a program to fix them, we would give
3	them discretion.
4	We've only been able to close one finding
5	to date out of all of our list of stuff, and that's
6	because the licensee had actually gone out and
7	corrected the issue, and so we gave them discretion on
8	that.
9	Most of the other issues we have, the
10	licensees have not been very aggressive in trying to
11	come up with a resolution on it. Also, a lot of them
12	are going to NFPA 805, and so they're saying when we
13	go to NFPA 805, we'll fix this issue because it's
14	identified and it will be part of the process.
15	Part of our concern in that is that some
16	of these plants aren't going to be actually
17	transitioning for another four or six years, so what
18	are they doing in the interim. So when the
19	enforcement discretion expires at the end of the year,
20	we need to be having a plan on is this going to be
21	adequate for the interim for those plants.
22	MR. WALLIS: This is something that comes
23	up all the time when you've got something which plants
24	should be doing and they're very dilatory about it,
25	and it doesn't seem to be any sort of scale. I would
Į	I

(202) 234-4433

	109
1	think that as they get later, they get penalized in
2	some way and something happens. Give them an
3	incentive to get on and do the job.
4	MR. McCREE: We do have that capability
5	and have exercised it in other areas via our
6	enforcement policy.
7	MR. WALLIS: But it's up to your judgment
8	to say now you've taken such a long time, we're going
9	to whip you into shape.
10	MR. PAYNE: One of the things to remember,
11	though, is that for all of these issues, the licensees
12	have instituted compensatory actions. So from a risk
13	perspective, it probably is not an issue, but if you
14	start getting enough of them added together, then you
15	start having to reevaluate whether there's really a
16	problem or not.
17	Next I want to talk about the manual
18	operator actions which, like I said, is a subset of
19	circuit analysis, and it's often used to mitigate
20	spurious equipment operation in lieu of cable
21	protection, but on occasions they do have some risk-
22	significant critical operator actions that they're
23	doing instead of trying to operate the equipment from
24	the main control room.
25	Licensees have long believed that it was
ļ	I

(202) 234-4433

	110
1	an acceptable alternative to Appendix R3G2
2	requirements, and Region II is one of the first that
3	identified that licensees were doing this and this was
4	a problem, and it's used extensively in Region II.
5	We've got some plants that have tens of
6	not hundreds of manual actions imbedded in their fire
7	protection procedures.
8	MR. WALLIS: This led to something. We
9	had a meeting on this just last year. Didn't this
10	lead to some agency action to clear this matter up,
11	all these plants that were taking credit for manual
12	action without getting permission and so on?
13	MR. SIEBER: Well, we wrote a letter on
14	it.
15	MR. WALLIS: We wrote a letter on that
16	too. Did that lead to some agency action?
17	MR. SHACK: Well, there's a Nuclear
18	Newsflash that they withdrew that draft rule
19	yesterday.
20	MR. WALLIS: The rule isn't going to come
21	out after all?
22	MR. SHACK: They proposed to remove it,
23	they requested permission to do that.
24	MR. PAYNE: Originally there was a plan
25	for manual actions that were determined to be
I	

(202) 234-4433

	111
1	feasible and we had established some proposed
2	criteria for measuring feasible that it would be
3	acceptable for those to be used in lieu of protection.
4	But there are a number of problems with that, one of
5	which is if you have enough of them from a risk
6	perspective, the likelihood of 100 percent success all
7	the time is pretty small, even if they are feasible.
8	We've been having problems at some of our
9	sites where we've identified non-feasible actions
10	where the operator just couldn't do the job. And like
11	I said, they often have high human error probability.
12	MR. WALLIS: That was a concern we had, I
13	remember, in our meeting with these folks that were
14	presenting this stuff about operator actions, and they
15	had to go down these stairs and along here and put
16	some ladder up and do something or other, and we were
17	thinking are they really going to be able to do this
18	with the conditions which are current in the plant.
19	MR. PAYNE: And it may be only one
20	operator that they've got dedicated to doing that, and
21	if he breaks his leg climbing up that later.
22	Reactor coolant pump seal issues, to date
23	we have identified five Region II licensees that have
24	this concern, and just to recap, if you lose reactor
25	coolant pump seal cooling, Westinghouse has shown that
ļ	I

(202) 234-4433

(202) 234-4433

for after 13 minutes or so you don't want to be 2 restoring seal cooling or thermal barrier cooling to that seal because you could get a small break loca 3 4 through the reactor coolant pump seal, thermal shock and it would cause the seal to dislodge or get tilted, you get popping, numerous different concerns. 6

7 And they issued guidance probably about 10 or 15 years ago that ended up getting implemented into 8 9 the EOPs that if you have a station blackout, when you 10 lose the reactor coolant pump seal cooling as a result of that, do not restore it when you get the power back 11 because you don't know how the reactor coolant pump 12 seal is going to perform, and you may not have your 13 14 equipment needed to compensate for a small break loca.

15 And what they recommend is that you cool 16 down the plant and get established and then get established and then do an evaluation on your reactor 17 coolant pump seals before you restart. 18

19 Well, we found that some licensees didn't 20 implement that guidance when you have fire that causes 21 you to lose reactor coolant pump seal cooling, and 22 often their mitigation strategy for the fire to 23 achieve safe shutdown required them to go out there 24 and come up with a way to restore charging.

Quite often that's the way they do it is

**NEAL R. GROSS** COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433

25

1

5

	113
1	they'll protect one charging pump and that charging
2	pump is going to go through the reactor coolant pump
3	seal. They didn't isolate it.
4	And we had some licensees, as you'll see
5	on my slide here, that took 60 to 90 minutes to
6	restore charging flow, and they just turned it back
7	on, went right to the reactor coolant pump seal, and
8	we said, How do you know that that's not going to
9	cause a seal loca?
10	And we processed one of them at Surry and
11	it turned out to be a white finding after we did an
12	extensive Phase 3 analysis of it, and the other four
13	plants were still processing. Well, I take that back.
14	We did North Anna already which is the sister plant of
15	Surry. Because of their plant configuration and the
16	way they implemented their fire procedures slightly
17	different than Surry, it turned out to be a green
18	finding for them.
19	MR. WALLIS: Do they all have the new seal
20	material? There was an improved seal material that
21	Westinghouse came up with.
22	MR. PAYNE: You mean the high temperature
23	seals?
24	MR. WALLIS: Have they installed that
25	material in all of these plants?
ļ	I

(202) 234-4433

	114
1	MR. SIEBER: That doesn't solve the
2	problem.
3	MR. WALLIS: But it's still an
4	improvement, though.
5	MR. PAYNE: That is true. And when we
б	first identified this issue, Surry was the first site
7	that we identified this with, our original risk
8	analysis said just losing the seal cooling was going
9	to cause a small break loca, and after interactions
10	with NRR and Westinghouse, we came to the conclusion
11	that the analysis with the new high temperature seals
12	will protect them adequately. If you just remove the
13	seal cooling you should be all right.
14	MR. SIEBER: And leave it alone.
15	MR. PAYNE: Leave it alone, that's right.
16	And we have some licensees that that's their strategy
17	is they make sure that when they lose the seal
18	cooling, they'll go out there and isolate it before
19	they restore their charging for later on.
20	The 60 to 90 minutes is tied towards how
21	long before they lose pressurizer level, and when it
22	gets down to the bottom, they need to have charging
23	flow coming back.
24	MR. SIEBER: And that's based on tech spec
25	leak rates. Right?
	1

	115
1	MR. PAYNE: That's right.
2	MR. SIEBER: Sixty to 90 minutes. Not a
3	seal leak.
4	MR. PAYNE: That's correct. Well, the
5	actual 60 to 90 minutes include tech spec and up to 25
6	or 21 GPM, the station blackout type of criteria that
7	we applied, but not the 200 or 480 GPM that risk
8	analysis had looked at.
9	MR. THADANI: If the licensees chose in
10	the past to deal with station blackout and the breaks
11	in the service water system where you lose seal
12	cooling most of the time, they would have taken care
13	of not only that issue but also this because they
14	would have had capability for some level of charging
15	fairly quick basis.
16	MR. PAYNE: That's right.
17	MR. BUNACA: So those plants that opted
18	for that option, they would be okay.
19	MR. PAYNE: Yes. If they could come up
20	with some way to quickly restore cooling to the seal,
21	they would have been all right.
22	For example, there are some plants that do
23	that, they recognize that they need to get cooling
24	back and their procedures prioritize some actions to
25	get the seal cooling done, and 13 minutes is generally
I	

(202) 234-4433

	116
1	the criteria.
2	You did ask a question about NFPA 805.
3	All of the plants in the country right now that are
4	going to NFPA 805 are in Region II. That's Duke
5	Energy with their Oconee, McGuire and Catawba plants.
б	That's the order that they intend to transition to
7	NFPA 805.
8	Recently Progress Energy has indicated
9	their intent to transition to 805 with Harris first,
10	then Crystal River, Robinson, and Brunswick.
11	We've gotten some indication that Dominion
12	is interested in it, primarily, I think, from a Region
13	I plant, the Millstone site, but they would
14	transition, obviously, all their plants if they do
15	decide.
16	MR. SIEBER: Once you do an initial plant,
17	each plant is easier for incorporation.
18	MR. PAYNE: And then Oconee and Harris are
19	the private plants for the agency and what we'll be
20	doing is actually sending some observation teams three
21	or four times a year during this two-year transition
22	to observe their process, to give them some feedback
23	on are they heading in the right direction or not,
24	what kind of issues do they have with that, and also
25	help us to develop our inspection procedure that we'll
ļ	1

(202) 234-4433

	117
1	have to use with this new process.
2	They'll be getting enforcement discretion
3	during the transition, and that also applies to the
4	old issues that they have if they committed during
5	'05, so they were supposed to be intending to get some
6	more licensees interested in transitioning. So far
7	it's only been progress in Duke Energy.
8	But you do do a risk evaluation on these
9	fire protection issues, but trying to identify any
10	risks of red color or severity level 1.
11	MR. THADANI: But they have to do a fire
12	PRA, don't they, a good quality fire PRA?
13	MR. PAYNE: It is not required, actually.
14	MR. THADANI: I though the reg guide just
15	issued guidance on that.
16	MR. DENNING: I think that was our issue,
17	Ashok.
18	MR. THADANI: And I'm saying I thought the
19	staff agreed to modify the reg guide to include the
20	language, and that's the reason I'm trying to ensure
21	that's in fact what was done.
22	MR. SHACK: I think they agreed for that
23	specific change they would use a PRA-like process to
24	evaluate the change in risk, but you don't have to do
25	a full fire PRA, you only have to do a PRA-like
I	

(202) 234-4433

	118
1	analysis that encompasses the change that you're
2	making.
3	MR. SIEBER: That's right, so you can end
4	up piecemealing it.
5	MR. PAYNE: The licensees that are doing
6	it now recognize the benefit of a fire PRA, and the
7	ones that are transitioning now have a plan of
8	basically developing a fire PRA. But it is not
9	required, as Mr. Shack said, to transition.
10	And the findings are going to be open
11	until the transition is complete, unless we come up
12	with a process to somehow track them outside of our
13	open items list.
14	I'll talk about SDP timeliness. That was
15	a concern that you had. Just a little bit of
16	background, fire protection and SSDPC were in the same
17	branch up until October of last year, and we shared
18	resources between those two inspections, and there's
19	15 required inspections a year in Region II.
20	And often what happens, the inspector that
21	was on the fire protections team would be going on an
22	SSDPC or another fire protection inspection.
23	MR. McCREE: Just to be clear, that's the
24	engineering inspection, that's Safety Systems Design
25	and Performance Capability inspection. These are the
I	

(202) 234-4433

	119
1	two, quote, largest team inspections that we do under
2	our Baseline Inspection Program, fire protection and
3	the engineering inspection are SSDPC.
4	MR. PAYNE: So as a result, once we got
5	the report issued, I didn't have any resource to
6	dedicate to working on this, on any open items that we
7	had unless they were simple. If they were pretty easy
8	to disposition, we could get those processed through
9	the SDP and issued either in the report or shortly
10	thereafter.
11	But the complicated ones, for example, the
12	safe shutdown issues, the reactor coolant pump seal
13	issues, they took much longer to do, and I didn't have
14	anybody to pull off of a team inspection to work on
15	these issues.
16	It had some long-term effects too because
17	if I did try and start somebody on that issue, they
18	probably couldn't get done with it before they did
19	need to get on the next inspection let's say he had
20	four weeks to work on it couldn't get through it
21	and then he'd be wrapped up on the next inspection.
22	And then if I had somebody else that had
23	a month's worth of time available, that person would
24	have to reinvent the wheel, if you will, trying to
25	catch up to where the analysis was and understanding
I	

(202) 234-4433

	120
1	the issue and then trying to make some headway.
2	It was very inefficient, we lost a lot of
3	continuity, and if I tried to keep one inspector on
4	it, then it was hit and miss as another inspector was
5	available over time.
6	And I've got an example if you'd like to
7	go through that where that happened.
8	MR. McCREE: So you've got a complete
9	picture, the level of effort required to evaluate the
10	significance of fire protection findings in general,
11	and particularly the complex ones, is rather
12	significant. The SDP Appendix D inspection under
13	Chapter 0609 is excuse me Appendix F, is very
14	resource-intensive. It requires a combination of
15	certainly our senior more seasoned inspectors to be
16	involved in the data gathering and analyses, as well
17	as the senior reactor analyst.
18	The picture that Charlie is painting for
19	you is a true one. We've gone through some
20	organizational issues as well as a resource issue and
21	the work itself is quite time-consuming. So it takes
22	very deft management and very close coordination to
23	get it done in a timely way.
24	MR. PAYNE: And if you go to the next
25	slide, you'll see some of the things that Victor was
I	1

(202) 234-4433

	121
1	talking about. It's very difficult, the SDP is 24
2	pages long; most of the SDPs in the reactor area are
3	only a couple of page long and they're usually fairly
4	cookbookish. And then there's another 116 pages worth
5	of guidance that you don't just learn it and forget
6	about it, you're going to have to keep referring to it
7	because it covers different situations, so the
8	situation you're in, you're going to have to evaluate
9	each of those things independently.
10	MR. POWERS: Are all your plants are
11	currently Appendix R plants?
12	MR. PAYNE: No. It's a combination.
13	MR. POWERS: You've got them all?
14	MR. PAYNE: Yes.
15	And as Victor also mentioned, it requires
16	a lot of data collection. One of the things that we
17	found out, and it's on the next page, Step 2.8 is very
18	difficult to do. It basically says once you're done
19	with figuring out what the fire risk is, now go back
20	into the reactor SDP and see if you've got any
21	equipment to help mitigate this issue.
22	Well, what a lot of people don't recognize
23	is that that means I've got to go find out where all
24	the cables are for all the mitigation equipment and
25	see if they run through this fire area and are
ļ	I

(202) 234-4433

	122
1	affected by the fire, because they obviously didn't
2	protect them because that's not part of their safe
3	shutdown strategy.
4	And trying to figure that out and then
5	also figuring out does this equipment really work or
6	not is difficult.
7	And as Victor also mentioned, it requires
8	someone with a lot of plant operational understanding
9	to integrate all of that. Most of my inspectors are
10	electrical inspectors. We've taught them about
11	integrated plant operations, but they haven't operated
12	a plant and they don't know some of the
13	interrelationships between that.
14	And I only really have one senior
15	inspector that has integrated plan operations, and
16	that's Bob. You've heard from him. I've got another
17	senior mechanical inspector that he does a good job of
18	it but he's really a mechanical inspector, he's not an
19	ops inspector.
20	MR. McCREE: This goes to the earlier
21	question where we were looking at the succession
22	planning strategy. We asked about what that meant,
23	how many, quote, fire protection experts we have.
24	Charlie has one senior, quote, licensed
25	fire protection engineer, but Bob and McKenzie Thomas,
l	I

(202) 234-4433

123
we've developed into fire protection experts, but what
they also bring, and it's absolutely essential to
implementing this inspection in a quality way is the
integrated plant operations knowledge that allows us
to not only find things but then evaluate the
significance of it.
MR. PAYNE: In particular, the 90-day time
limits goal that you were discussing with Bob earlier,
it's really kind of unrealistic for complicated fire
protection issues.
If you figure out all the different things
that need to be done in order to process a greater
than green finding to final determination, that 90-day
goal, it basically requires the SDP to be done within
two weeks. I have a hard time getting it done in two
months, let alone two weeks, unless it's a fairly
simple fire protection issue.
MR. POWERS: And this problem just doesn't
go away, does it, and we started off with an SDP that
was okay, to say the least, and now we've gone to one
you can understand, you just can't do. It's like they
don't want us to find fire issues in the plant.

23 MR. PAYNE: Yes, and we recognize that, 24 and as a matter of fact, we just got done with a team 25 going to V.C. Sumner to work on one of the reactor

> NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433

coolant pump seal issues at V.C. Sumner, and we had on 2 that team Bob, my senior reactor analyst, a reactor analyst from NRR, a fire protection expert from NRR, 3 4 plus a contractor from Sandia who is probably the fire protection expert -- you may know him, Steve Nolan -he was on the team. 6

7 And they went through to process these 8 open issues that we had with V.C. Sumner, and it took 9 them a full week of time, and the intent was to do a 10 Phase 2 analysis so we could proceed on with the SDP, and they ended up doing basically a Phase 3 analysis 11 because it was going to come out greater than green, 12 it was going to be yellow or white, and then we'd have 13 14 to do a Phase 3 probably to make sure it was right.

So they went ahead and worked on it and it 15 16 came out the issues were green. And that was a 17 success, but it required special organization to get this talent pool together to make it work. 18

19 of our simpler issues, for On some 20 example, the smoke detector, it requires basically 21 that you have very low degradation in order for you to 22 screen it out green. If you look at Phase 1 of our 23 SDP, anything that's greater than low degradation 24 requires you to go to a Phase 2 analysis. And most of 25 those issues will probably screen out in the Phase 2

> **NEAL R. GROSS** COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433

1

5

	125
1	fairly easily, like the smoke detector or the alarm,
2	but the other ones that require you to go to the end
3	to 2.8 which are the safe shutdown ones, they're the
4	ones that take a long time to do.
5	MR. McCREE: We've had a significant
6	amount of discussion with NRR and other folks in
7	headquarters about the timeliness goal and the
8	implications for fire protection, and I believe we're
9	at a level of understanding now where our process is
10	being changed. In fact, the metric will recognize
11	that for some issues like fire protection, 90 days is
12	really not realistic, that it would take longer, and
13	in fact, the overall goal will be 180 days, but the
14	process will take this into account.
15	We also had discussions last week in
16	fact, we did our lessons learned on this visit at
17	Sumner that Charlie was just talking about, and what
18	did we learn from that that could help us to evaluate
19	in a more timely manner other more similar findings.
20	And developed the understanding that may indeed allow
21	Steve Nolan to be involved in some other thorny
22	findings that we have and areas where we need to train
23	our inspectors and SRAs to help them to deal with
24	other issues.
25	MR. POWERS: The problem with extending
I	I

(202) 234-4433

	126
1	the time is it doesn't eliminate your basic problem,
2	you just don't have the manpower to do it, and
3	bringing in contractors is great, except now on your
4	succession planning you have to take into account
5	contractors which is quickly becoming a formidable
б	problem for you, and there's no obligation on the
7	contractor to have succession planning there either.
8	MR. McCREE: We also discussed that and
9	the need to transfer or develop our own expertise such
10	as that which Steve Nolan has, and that's going to
11	take a while, but there's an integrated way to get
12	there.
13	One is sending people along with Steve to
14	develop that knowledge and classroom training. We
15	need to have that in-house.
16	MR. POWERS: Do you need it in-house or is
17	the better solution is anything that you can screen
18	out in an expeditious way and I mean literally in
19	a day that you can toss over the fence to NRR and
20	let them handle
21	MR. PAYNE: We have some ideas and we
22	tossed them around also in the lessons learned meeting
23	that we had and we're making some proposals to them
24	that would help expedite the SDP, simplify it, in
25	particular with Step 2.8, and we're going to forward
l	I

(202) 234-4433

	127
1	that as a recommendation to change it.
2	And they were open to the idea, and
3	they're going to evaluate and see if maybe that's
4	something we could do where Step 2.8 is actually a
5	go/no-go kind of step, and if we're okay with that,
6	we'll go forward with that as being a final result,
7	and if everybody in the circ decides that we need a
8	better answer, this is a little bit too complex, then
9	we'll commit to going to a Phase 3 type of analysis
10	and committing the resources to doing that.
11	DR. TRAVERS: But having those resources
12	centered as opposed to distributed.
13	MR. POWERS: And it's not a criticism of
14	you but if every region tries to set up the kind of
15	expertise and divert the manpower that's going to be
16	required because you could send a guy and say work
17	180 days on this but you're going to do it one month,
18	then two weeks off doing something else, then one
19	month, you'll end up in the same problem. You'll come
20	back and say it's going to take 270 days to do this.
21	I mean, you'll never get out of this problem.
22	And if it's an integrated analysis where
23	you have to look at plant ops, electronics, mechanical
24	and fire all at the same time, you're never going to
25	get there. I mean, it's not your fault, I'm not being
I	I

(202) 234-4433

	128
1	critical of you guys, it's just that they're asking
2	you to do the infeasible here.
3	MR. SIEBER: It's an agency-wide problem,
4	and as I see it, you have a moratorium on associated
5	circuits, you have the introduction of 805, and in
6	fact, the triennial exams have not covered every
7	issue. You have operator manual actions to deal with.
8	And to me it looks like the day after a huge snowstorm
9	and there's a lot of work that needs to be done to get
10	back to normal, and the question is how vulnerable are
11	during the months and years that it will take to get
12	to a backlog that is normal.
13	MR. SCHIN: And that's a good question.
14	We addressed that in this recent meeting with the
15	licensees that are going to NFPA 805 and what they
16	have for compensatory actions for all of these non-
17	conforming conditions that they're finding is fire
18	watches. So like Oconee has fire watches roving all
19	over the plant covering all the different areas.
20	So what we're going to have to get into
21	when we next meet with them over the next few months
22	is how many of these non-conforming conditions, we
23	have to look at what type of things they are.
24	In all cases, a fire watch may not cut it.
25	You may have, even after you have the fire watch,
I	

(202) 234-4433

	129
1	there may be some net increase in risk, and so you
2	don't want to have too much of that.
3	MR. SIEBER: You know, a fire watch is a
4	guy with a day's training and eight bucks an hour, and
5	he may be a roving fire watch but he's watching five
6	fire areas or ten fire areas.
7	MR. SCHIN: Right, exactly.
8	MR. SIEBER: To me there are better ways
9	to do that
10	MR. SCHIN: Right, but by our regulations
11	they're not clearly required.
12	MR. SIEBER: It says it's okay.
13	MR. POWERS: This story on the SDP for
14	fire has just been going on since the start of ROP,
15	it's just a very difficult area and it does not seem
16	to me that it's getting the kind of management
17	attention at headquarters that it deserves. I mean,
18	they keep coming up with "Well, it satisfies this" all
19	the time. I mean, I think you guys have got a real
20	problem.
21	MR. McCREE: What we have is this tool
22	that, as Charlie indicated, is good for screening
23	relatively straightforward issues. It's a bit more
24	resource-intensive when the issue is more complex.
25	We've been working very closely with NRR on this
ļ	I

(202) 234-4433

	130
1	issue, as I indicated, and the resources and
2	timeliness, all those factors, we have understanding
3	and we have what we have, and we'll just work our way
4	through it.
5	MR. POWERS: Like I say, I think you guys
б	are doing better than I would have ever expected.
7	Actually, I'd expect you to be screamingly angry over
8	this.
9	MR. THADANI: There is a focus on the
10	timeliness issue at headquarters, but I'm not
11	convinced of this focus on really understanding how
12	complex this is.
13	(General talking.)
14	MR. POWERS: I mean, I think that's the
15	take-home lesson here
16	MR. McCREE: It's the reason why we
17	leveraged this visit at Sumner is to develop that
18	understanding and have the lessons learned.
19	MR. McCREE: It's going to take what it's
20	going to take to get a quality answer, and to get a
21	quality answer, I think there needs to be a broader
22	understanding of what it takes to get there.
23	MR. POWERS: Well, you do this trip to
24	Sumner and you come up with some interesting
25	conclusions, I think it will be useful to us if you
	I

(202) 234-4433

	131
1	come share it with us like at a Fire Protection
2	Subcommittee or something like that and just focus in
3	on this whole step here. I mean, I think that would
4	fun. Don't you, Richard?
5	MR. DENNING: Absolutely.
6	MR. POWERS: And see what the strategy is
7	for handling this.
8	MR. WALLIS: I would like to know what's
9	going on in the other regions. Presumably they have
10	the same situations.
11	MR. SIEBER: In three more years we'll
12	know
13	MR. PAYNE: The NEI is sponsoring a fire
14	protection information forum next week, and all the
15	branch chiefs, except for one, and some NRR
16	representatives are going to be there. And while
17	we're there, I've asked them to have a meeting to talk
18	about this, because I've got the same impression that
19	are we an outlier, are we the only ones that have
20	problems or not.
21	And just anecdotally, I found that at
22	least Region IV has a long list of fire protection
23	issues.
24	MR. POWERS: Based on historical evidence,
25	you guys are better prepared in fire protection than
I	1

(202) 234-4433

	132
1	the other regions, if you ask me.
2	MR. PAYNE: I would like to try and get
3	that feedback from them as well.
4	MR. SIEBER: You're on easy street,
5	relatively speaking.
6	(General laughter.)
7	MR. PAYNE: We'll, we'd at least like to
8	think that we've got a plan for moving forward, it's
9	just that it's not something we can implement
10	instantaneously.
11	MR. SIEBER: Well, there's a tremendous
12	amount of work and it's complex work, and I think
13	those are the two keys, and I think that there's a
14	failure to recognize how important fire protection is.
15	If we add all modes, all pipe PRAs, all of a sudden it
16	would stick out, but fire is probably in the same
17	realm of importance as normal day-to-day operation or
18	shutdown operation. That being the case, maybe the
19	resources need to follow.
20	MR. WALLIS: What needs to happen in
21	Washington to solve this problem.
22	MR. PAYNE: The interesting thing is if
23	you look at the amount of time they expect us to spend
24	on the triennial inspection, it's 200 hours every
25	three years, we spend well over that because that's
I	I

(202) 234-4433

	133
1	assuming three inspectors for two weeks basically, and
2	I need more than three inspectors on that team to do
3	an adequate inspection.
4	And that's what I tell them, we need to
5	focus on finding safety-significant issues, we'll work
6	out the risks afterwards. It's not something we can
7	ignore, obviously, but he priority is making sure that
8	the plants are safe.
9	MR. SIEBER: My impression, just working
10	with a few licensees, is the licensees aren't prepared
11	from a documentation standpoint to make your job
12	efficient.
13	MR. PAYNE: That is true, we have found
14	that out during our inspections.
15	MR. SIEBER: I mean, it's one of these
16	paper-shuffle deals.
17	MR. SCHIN: My experience is that our
18	inspection procedures and the number of hours for the
19	inspectors for two weeks would work out fine if we
20	didn't have any findings. So our problem is we're
21	always having findings.
22	MR. PAYNE: I've got just a couple more
23	slides, if you don't mind.
24	The next slide is just a current status.
25	We have 31 open items, seven of them are new this
I	1

(202) 234-4433

That doesn't include LERs that the licensees year. they've got a fire protection open if issue. 3 Seventeen of them are tied to plants that are going to 4 NFPA 805; four of them are Hemic, as I mentioned; seven circuit analysis issues; seven of them we're working pending SDP; and three of them are potentially greater than green.

That's the Turkey Point findings that are 8 9 on headquarters' tracking list and I've got my senior reactor analyst and the project engineer from DRP at 10 Turkey Point today. They're working on identifying 11 the information they need to do this SDP, with the 12 goal of completing it by the end of September. 13

14 We have four other issues that are pending 15 additional inspection or information from the 16 licensee. I've got eight of them that we've resolved 17 but we just haven't documented them in the report, we're in the process of doing that. And one of them 18 19 we've done a regulatory conference and we're pending 20 the final significance determination which we hope to 21 do next Tuesday.

22 Corrective actions, we've covered some of 23 We've obtained help from DRP as well as NRR to this. 24 help us work on these open items. We've obtained 25 additional contractor support in FY '06 to free up

> **NEAL R. GROSS** COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433

1

2

5

6

7

	135
1	some of my inspectors to work on SDP stuff.
2	Also, as we staff up we're planning to
3	have two separate fire protection inspection teams,
4	one team is doing an inspection, the team that just
5	finished is working on any open items, any URIs that
6	they identified, and they'll have 6 to 8 weeks to work
7	on this and it will be the whole team that's going to
8	be available to do that.
9	MR. McCREE: Going back to contractor
10	support very briefly. You mentioned earlier on the
11	engineering inspection, the SSDPCs were going from
12	about five a year to 18. In the past, Charlie would
13	get one, maybe two contractors a year to train for the
14	fire protection school program.
15	We've got NRR's attention and they're
16	going to give us four this year which is twice. It
17	was very difficult but we've convinced them that
18	that's needed to not only address a backlog but to
19	allow Charlie some flexibility in scheduling his
20	inspections.
21	MR. PAYNE: Correct. Right now I don't
22	have the staff to do two full teams independently.
23	Plus like this year, we're still supporting the
24	engineering inspections, but starting this coming
25	fiscal year, we've got dedicated people, I'm staffing
	I

(202) 234-4433

	136
1	up, and while I'm still staffing up, I've got the
2	contractors to help us out.
3	And part of that, like I said, we're
4	restricting our support of other inspections to really
5	high priority issues like special inspections or AITs,
6	that kind of thing.
7	And that's all I have.
8	MR. SIEBER: I think we're at the end of
9	the agenda.
10	DR. TRAVERS: We're very suspiciously on
11	time, Chairman. I think you laid down a challenge to
12	us, and perhaps to the committee as well. We're on
13	time here.
14	I guess I'll just sum up by saying I think
15	we've covered a pretty broad range of topics. I think
16	they were arranged in advance with your staff so there
17	would be items that the committee was interested in.
18	And so we certainly do appreciate the
19	opportunity to have a dialogue with you, not just
20	today but on an ongoing basis as is appropriate for
21	any of the issues at hand. Whether they be Browns
22	Ferry or wherever, we can hopefully support your
23	activities by providing some of the insights that we
24	gain from our conduct of the inspection program here
25	in Region II and throughout the regions, actually.

(202) 234-4433

	137
1	MR. SIEBER: I can tell you, without
2	reservation, that the meeting and the reports that
3	your folks gave us are excellent, and they really add
4	to the perspective that we have in the functioning of
5	the agency, because in the regions this is where the
6	rubber meets the road. And individual inspectors and
7	branch chiefs see in more detail the issues and the
8	problems and give us a very good perspective of the
9	kinds of things that we ought to be focusing on and
10	directing our attention.
11	So I, personally, and my colleagues truly
12	appreciate your spending the effort to be our hosts,
13	and I'm sure that we will meet again, perhaps pretty
14	soon or at least with some or your personnel because
15	there are a lot of activities that are going on.
16	I also think, having met a number of your
17	folks either here or on other occasions, that you have
18	an excellent staff and very talented and very
19	knowledgeable, and I think that's a tribute to the
20	many good years of management of the Region II office.
21	So I wish, on behalf of my colleagues and
22	the full committee and our staff, to thank you very
23	much for hosting our visit here.
24	DR. TRAVERS: It was our pleasure. Glad
25	you could come.
ļ	

(202) 234-4433

		13	38
1		MR. SIEBER: Thank you.	
2		And with that, I would like to adjourn the	he
3	meeting.		
4		(Whereupon, at 11:50 a.m., the meeting wa	as
5	concluded.)		
6			
7			
8			
9			
10			
11			
12			
13			
14			
15			
16			
17			
18			
19			
20			
21			
22			
23			
24			
25			
	I		