

DISCLAIMER

UNITED STATES NUCLEAR REGULATORY COMMISSION'S
ADVISORY COMMITTEE ON REACTOR SAFEGUARDS

June 18, 2008

The contents of this transcript of the proceeding of the United States Nuclear Regulatory Commission Advisory Committee on Reactor Safeguards, taken on June 18, 2008, as reported herein, is a record of the discussions recorded at the meeting held on the above date.

This transcript has not been reviewed, corrected and edited and it may contain inaccuracies.

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25

UNITED STATES OF AMERICA
NUCLEAR REGULATORY COMMISSION

+ + + + +

ADVISORY COMMITTEE ON REACTOR SAFEGUARD
(ACRS)

+ + + + +

SUBCOMMITTEE ON ESBWR

+ + + + +

WEDNESDAY

JUNE 18, 2008

+ + + + +

ROCKVILLE, MARYLAND

+ + + + +

OPEN SESSION

+ + + + +

The Subcommittee met in open session at
the Nuclear Regulatory Commission, Two White Flint
North, Room T2B3, 11545 Rockville Pike, at 8:30
a.m., Dr. Michael Corradini, Chairman, presiding.

COMMITTEE MEMBERS:

MICHAEL CORRADINI, Chairman

JOHN D. SIEBER

CHARLES H. BROWN

DENNIS C. BLEY

NEAL R. GROSS
COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 COMMITTEE MEMBERS PRESENT (CONTINUED):

2 J. SAM ARMIJO

3 WILLIAM J. SHACK

4 OTTO L. MAYNARD

5 JOHN W. STETKAR

6

7 CONSULTANTS TO THE ACRS PRESENT:

8 GRAHAM B. WALLIS

9 THOMAS S. KRESS

10

11 NRC STAFF PRESENT:

12 AMY CUBBAGE

13 CHANDU PATEL

14 MOHAMMED SHAMS

15 MOHAMMED ABID

16 RICHARD McNALLY

17 DAVID SHUM

18 GEORGE GEORGIEV

19 RAO TAMMARA

20 AMAR PAL

21 PAUL SHEMANSKI

22 JAY RAJAN

23 ANDREY TURILIN

24 PAT SEKERAK

25 TOM SCARBROUGH

NEAL R. GROSS
COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 NRC STAFF PRESENT (CONTINUED) :

2 JOHN FAIR

3 RENEE LI

4

5 ALSO PRESENT:

6 JEFF WAAL

7 CLEMENT RAJENDRA

8 JERRY DEAVER

9 KEVIN BAUCOM

10 PIJUSH DEY

11 DAVE KECK

12 STEVE HAMBRICK

13

NEAL R. GROSS
COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25

AGENDA

<u>AGENDA ITEM</u>	<u>PAGE</u>
Opening Remarks and Objectives	5
DCD Sections 3.2, 3.3, 3.4, 3.5, 3.10, 3.11 and 3.13 (Jeff Waal)	5
Break	
SER Sections 3.2, 3.3, 3.4, 3.5, 3.10 3.11 and 3.13 (Chandu Patel)	111
Lunch	
DCD Sections 3.9, 3.12 and 3.6 with 3.9.5 (Jeff Waal)	199
Break	
SER Sections 3.9, 3.12 and 3.6 with 3.9.5 (Chandu Patel)	275
Adjourn	

P-R-O-C-E-E-D-I-N-G-S

8:30 A.M.

1
2
3 CHAIRMAN CORRADINI: The meeting will
4 come to order. This is a meeting of the Advisory
5 Committee on Reactor Safeguard Subcommittee on the
6 ESBWR. My name is Mike Corradini, Chair of the
7 subcommittee. Subcommittee Members in attendance
8 are: Jack Sieber, Charles Brown, Dennis Bley, Sam
9 Armijo, Bill Shack somewhere, Otto Maynard, John
10 Stetkar, and our consultants, Graham Wallis and Tom
11 Kress.

12 The purpose of this meeting is to
13 discuss Chapter 3 of the Safety Evaluation Report
14 with open items associated with ESBWR design
15 certification application.

16 The Subcommittee will hear presentations
17 by and hold discussions with representatives of the
18 staff and the ESBWR applicant, General Electric
19 Hitachi Nuclear Energy regarding these matters.

20 The Subcommittee will gather
21 information, analyze relevant issues and facts and
22 formulate proposed positions and actions as
23 appropriate for deliberation by the full committee.

24 Harold Vandermolen is the designated
25 Federal Official for this meeting. The rules for

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 participation in today's meeting have been announced
2 as part of the notice of this meeting previously
3 published in the Federal Register on June 5th, 2008.

4 A transcript of the meeting is being
5 kept and will be made available as stated in the
6 Federal Register notice. It's requested that
7 speakers first identify themselves and speak with
8 sufficient clarity and volume so that they can be
9 readily heard.

10 We've not received any request from the
11 members of the public to make oral statements or
12 written comments. And just a couple of side notes,
13 this is our sixth, or seventh, I've lost track,
14 subcommittee on various of the chapters of the
15 ESBWR.

16 We will, just to remind the members of
17 the subcommittee, the full committee will take up a
18 possible interim letter for Chapter 3 in the July
19 full committee meeting.

20 So, we'll proceed now with the meeting.

21 I'll call upon Jeff Waal with General Electric.

22 Jeff, to begin. Is it Waal?

23 MR. WAAL: Waal, right.

24 CHAIRMAN CORRADINI: Okay.

25 MR. WAAL: My name is Jeff Waal. I'm

NEAL R. GROSS
COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 from regulatory affairs staff of GEH in Wilmington
2 North Carolina. And we're here today to discuss
3 Chapter 3 of the DCD Application for the ESBWR.

4 As you know, Chapter 3 is a large
5 chapter. So, we've broken it down into four
6 separate discussion areas. And sometimes it might
7 be presented out of order, just for ease of
8 understanding.

9 We're going to start off with Sections
10 3.1 to 3.5, and then 3.10, 3.11 and 3.13, followed
11 by Sections 3.9, 3.12 and 3.6. And then tomorrow,
12 we'll follow up with sections 3.7 and 3.8.

13 What we're going to do right now, and
14 it's divided into those four sections, and we're
15 going to start with the first section now, which is
16 Sections 3.1 to 3.5, which will be presented by
17 Clement Rajendra.

18 MR. RAJENDRA: My name is Clement
19 Rajendra. I'm with ESBWR Engineering Group. I'm a
20 civil structural engineer. We start with an
21 overview of Section 3.1 to 3.5.

22 We start with an overview of Section 3.1
23 to 3.5. Section 3.5 describes the components of
24 ESBWR with the NRC's General Design Criteria.
25 Section 3.2 provides the seismic, safety and the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealgross.com

1 quality group classifications of system structures
2 and components. 3.3 describes wind and tornado
3 loadings. 3.4 describes the flood protection design
4 basis and 3.5 describes missile protection design
5 basis.

6 In Section 3.5, provides evaluation --
7 sorry. Section 3.1 it provides an evaluation of the
8 ESBWR design versus the NRC General Design.

9 MR. WALLIS: I have a question right off
10 the field. When you say --

11 CHAIRMAN CORRADINI: I thought you were
12 going to just sit there and relax.

13 MR. WALLIS: When you say the -- well,
14 if I don't get an answer to this question, I may
15 relax. You say evaluation of ESBWR design. What
16 seems to be being evaluated by the staff is not a
17 design at all. It's the design approach and the
18 procedures followed in the design.

19 It's not design-specific. It seems to
20 me it could apply to a generic reactor that looked
21 something like the ESBWR.

22 MR. WAAL: Yes.

23 MR. WALLIS: Isn't that what we're
24 talking about today?

25 MR. WAAL: Yes.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. RAJENDRA: You also provide design
2 details of Seismic Category 1 structures.

3 MR. WALLIS: Requirements.

4 MR. RAJENDRA: Well, we actually provide
5 details and --

6 MR. WALLIS: Well, for instance, it says
7 your tornado velocity must be so many miles an hour
8 and so on. There's no evaluation of the actual
9 response of the structure to this velocity.

10 MR. WAAL: Great.

11 MR. RAJENDRA: That is correct in
12 Section 3.5. But in Appendix Z --

13 MR. WALLIS: Well, maybe you've got
14 something hidden that I didn't see.

15 CHAIRMAN CORRADINI: Let him finish,
16 Graham.

17 MR. WALLIS: Yes. Yes.

18 MR. WAAL: I think --

19 CHAIRMAN CORRADINI: Go ahead.

20 MR. RAJENDRA: Appendix 3G, we actually
21 provide the response of the structures to, of
22 Seismic Category 1 structures. So, the results of a
23 certain amounts of details are provided in Section
24 3G for Seismic Category 1 structures.

25 MR. WALLIS: Okay. Well, please go

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 ahead. Maybe we'll find that when we get there.

2 MR. DEEVER: Many of the appendixes
3 provide lots of the details.

4 MS. CUBBAGE: Well, they are part of the
5 DCD. This is Amy Cubbage. They're part of the DCD,
6 they're just not part of the main chapter.

7 CHAIRMAN CORRADINI: Yes. All the
8 seismic, specifics seismic responses are in sections
9 Appendix 3F and 3G, as I remember.

10 MR. RAJENDRA: 3A --

11 MR. WALLIS: So you have to go through
12 so many inches of paper, and then you find there's
13 an appendix somewhere?

14 CHAIRMAN CORRADINI: Oh, sure. All the
15 fun graphs are in the appendixes.

16 MR. WALLIS: Oh, okay.

17 MEMBER SIEBER: But they still revert to
18 -- discuss fundamentals. There's a big ITAAC for
19 all of this, right?

20 MS. CUBBAGE: Yes.

21 MEMBER SIEBER: So that's where you're
22 going to get to the details. And we aren't going to
23 get there if some inspector's going to get there
24 with his trouble.

25 MR. RAJENDRA: In 3.1 --

1 MS. CUBBAGE: I think that comment needs
2 to be addressed by GE.

3 CHAIRMAN CORRADINI: Say it again. I
4 didn't hear Jack's comment then if I misunderstood
5 what you're saying. Repeat it Jack.

6 MEMBER SIEBER: I think that there's
7 going to be a big ITAAC associated with the details
8 of the design. What we've said out here is a lot
9 rules. We've got parameters, enough of them to say,
10 yes, this will fit 90 percent of the sites. But the
11 details will occur during constructions and that's
12 where inspection will determine whether it's
13 designed and constructed properly as opposed to
14 having the details in the DCD.

15 MR. KINSEY: I guess -- this is Jim
16 Kinsey from GEH. That's generally the structure of
17 the application. We provide a significant level of
18 detail in the DCD, in the associated appendixes and
19 topical reports that have been or are being reviewed
20 and evaluated by the staff.

21 And then as you mentioned, we have some
22 criteria that are applied and they're described in
23 Section 14.3 of the DCD that provide the criteria
24 for establishing the ITAAC and those criteria are
25 confirmatory at a later point in the process, post-

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 certification.

2 MS. CUBBAGE: Right. I just wanted to
3 make it -- it sounded like you were saying that
4 everything was DAC, and that's not the case.
5 They've done the seismic design and the seismic
6 analysis, the structural analysis, the staff.

7 In addition to the DCD, the staff has
8 audited detailed calculations at GE Hitachi's
9 offices and we're prepared to discuss those
10 tomorrow.

11 MR. KINSEY: Right. So, specifically in
12 the subject of Chapter 3, as Amy mentioned, we've
13 done a predominate amount of the design. The
14 staff's evaluated that. And there really is other
15 than some piping design-work, there is no DAC per se
16 in this section of chapter.

17 CHAIRMAN CORRADINI: But just, maybe I
18 misunderstood Jack's point. But let's just take, if
19 we're at North Anna, then in some sense, this is a
20 site which has been considered. If I go to a
21 different site, then the subsequent COL would have
22 to be submitted and show it fits within that
23 envelope.

24 That's my interpretation of what I
25 thought Jack was saying. Maybe I misunderstood you,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 Jack.

2 MEMBER SIEBER: No, that's correct.

3 MS. CUBBAGE: But I think it's the
4 expectation that this site would be fit within the
5 envelope that's been established for the
6 certification.

7 CHAIRMAN CORRADINI: But it --

8 MS. CUBBAGE: It would need to be
9 verified.

10 CHAIRMAN CORRADINI: Right. But just to
11 take it one step further, it would be that
12 applicant's job to show that it fits within.

13 MS. CUBBAGE: Well, that would be a
14 departure from the certified design.

15 CHAIRMAN CORRADINI: Right.

16 MS. CUBBAGE: They would have to
17 actually apply for an exemption with then come in
18 with their combined license application if they
19 don't fit within the seismic spectra that this
20 plant's analyzed for.

21 CHAIRMAN CORRADINI: Okay. Thank you.

22 MR. RAJENDRA: All those parameters are
23 spelled out in Chapter 2. So, all the binding
24 parameters, the wind velocity, the tornado speeds,
25 the seismic spectra, they're all spelled out in

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 Chapter 2. And the applicant, when they prepare
2 their Chapter 2, they have to compare site-specific
3 parameters with the plant, standard plant parameters
4 and show that the standard plant bounds all of those
5 characters.

6 And if they're not bounding, then they
7 have to provide a site-specific evaluation.

8 MEMBER BLEY: I want to ask a question
9 of how the process goes on --

10 CHAIRMAN CORRADINI: Sure.

11 MEMBER BLEY: -- when you get to COL
12 stage. Because I still haven't completely gotten my
13 thumb in this. Something Jack said was that these
14 will be decided by an ITAAC by an inspector, rather
15 than coming back for this kind of an issue for a
16 review by staff and our opportunity to review and
17 confirm that the site specific things are in fact
18 making --

19 MS. CUBBAGE: The site-specific, the
20 question you just asked sir, that's part of the
21 combined license application review. That will be
22 part of your scope of review, our scope of review,
23 before we issue a license.

24 MEMBER BLEY: Thank you.

25 MS. CUBBAGE: And then once the design is

1 approved, then the verification that it's been
2 constructed in accordance with the licenses, the
3 ITAAC, in most cases, except for the DAC areas which
4 we've discussed at length on other discussions --

5 CHAIRMAN CORRADINI: Even though you've
6 done it at length, can you just for the people with
7 a bad memory, can you just sail over them?

8 MS. CUBBAGE: Those are areas where the
9 ITAAC are provided in lieu of design detail. And
10 those ITAAC verify that the design is completed in
11 accordance with the proscribed acceptance criteria
12 that are certified. So, we approve the process and
13 the method.

14 MEMBER BLEY: And those therefore, do
15 not come back for review by us or by staff?

16 MS. CUBBAGE: They do not. They do not.

17 CHAIRMAN CORRADINI: Right. Once
18 approved --

19 MS. CUBBAGE: Well, I mean, when you say
20 the staff --

21 MEMBER BLEY: Okay, yes.

22 MS. CUBBAGE: The staff includes Region
23 2, and the staff --

24 CHAIRMAN CORRADINI: The Headquarter
25 Staff.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MS. CUBBAGE: -- the headquarter staff
2 will be involved in the verification of ITAAC that
3 are associated with DAC, and that will not be a
4 sampling. That will be 100 percent.

5 MEMBER BLEY: I guess that's the piece I
6 don't have a complete handle on. What kind of things
7 end up in DAC. And it sounded like much of the INC
8 results will be DAC and won't actually come back for
9 that kind of detailed review that might find places
10 where things aren't properly like in line the way
11 you might expect.

12 MS. CUBBAGE: Right. And I don't want
13 to completely highjack this, but I will just offer a
14 little bit on that. Is that we're not fully
15 established on the process yet for ITAAC
16 verification for DAC. But it's very likely that the
17 vendors will submit topic reports for review and the
18 staff will review and approve those.

19 And then the combined licensed
20 applicants would reference those as part of their
21 DAC closure.

22 CHAIRMAN CORRADINI: All right. Does
23 that help?

24 MEMBER BLEY: It helps, just a little
25 concerned.

1 CHAIRMAN CORRADINI: Go ahead.

2 MEMBER BROWN: If it only meets the
3 majority or a large number of the criteria, the
4 site-specific that's what the report said, you
5 know, 80-90, meets most of the -- the design meets
6 most of the sites, if it doesn't, does that
7 invalidate the design? It's a question.

8 MS. CUBBAGE: It means that the --

9 MEMBER BROWN: Who goes back and does,
10 and makes sure that what you've got is now going to
11 be satisfactory for that site where the criteria
12 didn't match relative to the spectra and whatever
13 else to it.

14 MS. CUBBAGE: That's part of the
15 combined license review. So, if we were to receive
16 a combined license application today, as part of
17 their application, they would need to provide the
18 verification that they fall within the envelope of
19 the certified design.

20 And if they don't they would need to
21 provide site-specific information for our review and
22 approval before we could issue a license. And they
23 would actually be -- it would be a departure to the
24 certified design.

25 MEMBER BROWN: Okay. Somebody has to

NEAL R. GROSS
COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 re-review the design?

2 MS. CUBBAGE: Absolutely.

3 MEMBER BROWN: In those areas?

4 MS. CUBBAGE: Yes.

5 MEMBER BROWN: Is it across the board?

6 I mean, is this -- are you able to break it down
7 into some areas you'd be okay, and not? I presume
8 you --

9 MS. CUBBAGE: We would only have to
10 review those areas that they were departing. So,
11 only the criteria that they didn't meet.

12 CHAIRMAN CORRADINI: Just to send it,
13 for an example, if they met wind loads, flooding
14 but seismic was different, you'd review seismic?

15 MS. CUBBAGE: Review seismic.

16 MEMBER BROWN: One hundred percent?

17 MS. CUBBAGE: Well, I mean, yes. I
18 mean, we're actually doing that on some areas right
19 now in other design centers. That's not the case
20 with this design center.

21 MR. RAJENDRA: In Section 3.1, provides
22 a road map to the different DCD sections where the
23 general design criteria are met. So, in Group I, we
24 have the overall requirements for criteria 1 and 5,
25 in Group II, the protection by multiple fission

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 product barriers, criteria 10 and 19, Group III,
2 protection and reactivity control systems, Group IV,
3 fluid systems, Group V, reactor containment and
4 Group VI, fuel and radioactivity control.

5 MR. WALLIS: Let me go back to my other
6 question. Are you going to give us any indication
7 about how your design meets Group II in terms of any
8 detail?

9 MR. RAJENDRA: It refers to other
10 sections of the DCD.

11 MR. WALLIS: That's right.

12 MR. RAJENDRA: It provides only a --

13 MR. WALLIS: On your presentation, if I
14 look through your slides, it's all at a very high
15 generic level.

16 MR. RAJENDRA: Right.

17 MR. WALLIS: It doesn't give any detail
18 at all of the ESBWR itself. So, apparently, you're
19 not going to get into any detail today?

20 MR. RAJENDRA: Not in this presentation.

21 CHAIRMAN CORRADINI: Not for that topic.

22 MR. RAJENDRA: Not for that topic.

23 MR. WALLIS: Well, I will have no --

24 MR. RAJENDRA: Not for that topic.

25 MR. WALLIS: -- idea when I leave about

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 how the ESBWR meets these criteria? I'm just
2 assured that you have designed it so that it should
3 meet these criteria?

4 MS. CUBBAGE: Graham, I think 3.1 is
5 more of an introduction roll-up type of a section.
6 I think you'll be hearing more detail later.

7 CHAIRMAN CORRADINI: To put it
8 different, Graham, if we had 3.1 in September of
9 2007, you'd be a happy camper. But it just happens
10 to appear in a chapter that didn't start in
11 September 2007. This is essentially, if I remember
12 correctly, 3.1 is where you actually point to the
13 rest of the DCD --

14 MR. RAJENDRA: Rest of it.

15 MS. CUBBAGE: DCD.

16 CHAIRMAN CORRADINI: -- as to where all
17 these individual things will be addressed.

18 MR. RAJENDRA: Right.

19 MR. WALLIS: So, it's sort of backwards.

20 CHAIRMAN CORRADINI: Well, we could say
21 it that way.

22 (Laughter)

23 MEMBER MAYNARD: Our review of it is
24 backwards.

25 MR. RAJENDRA: Section 3.2 provides

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 classification of Structure Systems and Components.
2 The Section 3.1 is the seismic classification. And
3 this is based on RG 1.29 and SRP 3.2.1.

4 Seismic Category I is required for all
5 safety-related systems, structures and components.
6 We are using a Seismic Category II for those non-
7 safety-related systems, structures and components
8 whose failure could degrade the performance of
9 safety-related systems, structures and components.

10 We also have some safety -- non-safety-
11 related SSCs that are assigned to Seismic Category
12 I, when required by certain reg guides.

13 MEMBER ARMIJO: Could you give me a
14 couple of examples of those non-safety systems?

15 MR. RAJENDRA: The fire water service
16 complex, the fire water storage tanks, they are not
17 supporting a safety-related function. But RG 1.13,
18 because it provides make up water for the spent fuel
19 pool, they have to specify it requires a seismic
20 Category I classification.

21 MR. DEEVER: Sometimes we do upgrades
22 also. Line cranes, we do the floor net, only need
23 to be Category II, but we're making them a Category
24 I in order to provide our customers you know,
25 maneuverability and flexibility in operation.

1 MR. RAJENDRA: Some, the remaining SSCs
2 are assigned Seismic Category NS.

3 MEMBER SHACK: One of the things that I
4 was curious about are the components that you didn't
5 classify as Seismic I or II, but you had designed to
6 meet SSCs. Now, if you're designing to meet SSCs,
7 why aren't they Seismic I or II?

8 MR. RAJENDRA: Because we are not using
9 the same -- like for instance, Seismic Category II,
10 we don't use the same QA requirements. The
11 components are not required to meet Appendix B 50
12 Program for QA.

13 In the case of -- but the Seismic
14 Category II, follows the acceptance criteria of
15 Seismic Category I. But in the case of NS, if
16 you're using full SSC, we could use international
17 building code for the -- the design rules will be
18 different. We don't have to use nuclear codes for
19 the design.

20 MEMBER SHACK: Okay.

21 MR. RAJENDRA: But the seismic input
22 will be SSC.

23 CHAIRMAN CORRADINI: So, it's a -- I
24 guess I'm -- I heard your answer. I don't fully
25 appreciate it. Can you try it again? Are you

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 saying that it's the QA trail, but from a structural
2 standpoint, they will be just as robust as a
3 Category I? Is that what I heard you just saying?

4 MR. RAJENDRA: Yes. For Seismic
5 Category II, yes. The Seismic Category II, the
6 design as far as the design calculations, acceptance
7 criteria, the design codes, will be just as robust.
8 But as far as material traceability and whether or
9 not we have paper trail on the materials, whether or
10 not we have the appropriate inspections, those will
11 not be -- will not follow the Appendix B 50 Program,
12 10 CR 50 Appendix B Program.

13 CHAIRMAN CORRADINI: So, just to make
14 sure I'm clear, so even though they are seismic --
15 let's just go with your explanation. I don't think
16 I could repeat that.

17 MR. RAJENDRA: Yes.

18 CHAIRMAN CORRADINI: So, in an analysis
19 of an event, they will be credited, or they cannot
20 be credited? They cannot be credited for their
21 performance?

22 MR. RAJENDRA: They are credited for
23 their performance, but they themselves do not
24 perform a safety-related function. The system does
25 not contain safety-related components, and is not

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 supporting a safety-related function.

2 But, if it fails, it will not degrade
3 the performance -- the safety-related performance of
4 a safety-related structure.

5 CHAIRMAN CORRADINI: It won't fall upon
6 a credited audit.

7 MR. RAJENDRA: Fall upon -- that's
8 exactly right.

9 CHAIRMAN CORRADINI: Fine. Okay.
10 That's what I thought.

11 MR. RAJENDRA: Right. And that is
12 seismic related. But we also have non-seismic
13 structures that are designed to the same SSC, but
14 use different codes and standards, like
15 international building code.

16 But the seismic input would be the same.

17 CHAIRMAN CORRADINI: Identical.

18 MR. RAJENDRA: Yes. Because in Chapter
19 II, we define seismology and the seismology is only
20 a single seismology defined for the standard design.

21 MR. WALLIS: Now I have another
22 question, I'm sorry. These categories are very
23 nice. But then you have to design specific
24 reactors. Do you know how to design large masses of
25 water which are being shaken in some seismic fashion

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 in a structure? Do you know how to design a
2 structure to hold large masses of water which is
3 being sloshed around in a seismic event?

4 MR. RAJENDRA: They are considered in
5 the design for -- the sloshing is considered as one
6 of the loading conditions.

7 MR. WALLIS: Is this something that's
8 covered by these categories in some way? Or, you
9 know how to do it?

10 MR. RAJENDRA: They're part of the load
11 definitions, the hydro-dynamic loading is part of
12 the load definitions.

13 MR. WALLIS: So well understood it's a
14 state-of-art technology?

15 MR. RAJENDRA: Yes.

16 MR. WALLIS: Okay.

17 CHAIRMAN CORRADINI: Be careful what you
18 just said. He's leading you -- that's a lawyer
19 question.

20 (Laughter)

21 MR. KINSEY: This is Jim Kinsey, from GE
22 Hitachi.

23 CHAIRMAN CORRADINI: Careful.

24 (Laughter)

25 MR. KINSEY: It's an understood

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 technology. I don't know that we would consider,
2 state-of-the-art at the moment, but I'll let Clement
3 handle it.

4 CHAIRMAN CORRADINI: They will follow
5 the codes.

6 MR. KINSEY: We will follow the
7 established standard.

8 MR. WALLIS: And the codes adequately
9 cover this large masses of water.

10 CHAIRMAN CORRADINI: By definition.

11 MR. WALLIS: That's a yes answer?

12 MR. RAJENDRA: To the best of our
13 knowledge, yes. The hydrodynamic, or the way we
14 understand it, yes.

15 MR. WALLIS: Thank you. Thank you.

16 MR. RAJENDRA: Section 3.2.2, we deal
17 with System Quality Group definitions. They follow
18 RG 1.26 and SRP 3.2.2. We have Quality Group A,
19 that's pressure-retaining portions and supports for
20 reactor coolant pressure boundary.

21 Quality Group B, pressure-retaining
22 portions and supports not in Quality Group A for
23 safety-related containment isolation, ECCS and RHR
24 functions.

25 Group Category, pressure-retaining

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 portions and supports for other safety-related
2 functions not included in Quality Groups A and B.

3 And finally, we have Quality Group D,
4 which is pressure-retaining portions and supports
5 for other systems that contain radioactive material.

6 MR. WALLIS: It doesn't mean anything to
7 a layman, does it? A, B, C, D, it could as well be
8 X, Y, Z and Q. It doesn't mean anything. These are
9 standard terminologies, and so forth?

10 MR. RAJENDRA: These are terminologies
11 developed in -- the Quality Group A and C are
12 addressed in RG 1.26.

13 MR. WALLIS: This is traditional Nuclear
14 Regulatory --

15 MR. RAJENDRA: Yes, 1.26. Yes.

16 MR. WALLIS: -- style. Okay.

17 MR. RAJENDRA: RG 1.26. Section 3.2.3
18 Safety Classification. These classifications are
19 consistent with those use in ABWR DCD. They are
20 closely tied to Quality Group classifications for
21 safety-related SSCs.

22 We define Safety Class I as the reactor
23 coolant and pressure balance components and
24 supports. We define Safety Class II as mechanical
25 SSCs involving containment isolation functions not

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 included in Safety Class I, ECCS and RHR functions.

2 Then we define Safety Class III as all
3 other mechanical safety-related SSCs not included in
4 Safety Class I and II, and all safety-related
5 electrical and I&C SSCs are Safety Class III. And
6 finally, the Safety Class N, which is non-safety
7 related SSCs.

8 These are excerpts of Table 3.2.1, we
9 have shown here the -- an example for System B11.

10 MR. WALLIS: I'm sorry. If you're
11 trying to explain this to a member of the public,
12 what's the difference? Does Safety Class I mean
13 that the chance in failure is one in a million, or
14 something like that? And Safety Class II means one
15 in a hundred thousand? What's the difference in
16 terms of relationship to safety?

17 MR. RAJENDRA: If I could skip forward
18 to -- yes, that's right. Go back. This gives an
19 explanation of Safety Class I. If you have Safety
20 Class I, that's the Quality Group is A and --

21 MR. WALLIS: But these are just numbers.
22 What's the --

23 MR. RAJENDRA: No, no, I mean it gives
24 you --

25 CHAIRMAN CORRADINI: I think he's going

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 to explain.

2 MR. RAJENDRA: It gives you what Quality
3 Assurance we are using, and what is the
4 corresponding ASME code class, and when you use ASME
5 code class gives you for ASME.

6 MR. WALLIS: But if I go back to my
7 students and I try to explain to them, they've
8 designed this thing so that the reactor system
9 boundary is in tact and will only fail with a
10 probability of one in a billion, or something, what
11 do I tell them?

12 I can't tell them this, because it means
13 nothing to me.

14 MR. WAAL: I think what you tell them is
15 that, you know, Safety Class I has a higher level of
16 quality assurance.

17 MR. WALLIS: But is it good enough? How
18 do I know -- how do they reassure the layman that
19 it's good enough. How do you do that? This is
20 gobbledygook to a layman.

21 MEMBER SIEBER: Safety classes refer to
22 components within a group of components. If you
23 look at slide seven, it tells you what the safety
24 classes are.

25 MR. WALLIS: Is there anyway to put it

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 in perspective for the public, or is it all just to
2 some sort of arcane regularly world that we're in.

3 MR. RAJENDRA: The ASME rules, for
4 instance, the difference between safety --

5 CHAIRMAN CORRADINI: It's arcane ASME
6 rules, it's not arcane regulatory rules.

7 MEMBER MAYNARD: I think we're asking
8 them a question though, that maybe should be --
9 that's more of an NRC philosophy. The applicant's
10 here to show whether they comply with the regulatory
11 requirements. It not necessarily their job to
12 defend the regulations as being adequate.

13 MR. WALLIS: So you think I should ask
14 the question of the NRC rather than the applicant?

15 MEMBER MAYNARD: Well, I actually think
16 it's more of one that's for outside of design
17 certification. It's more of the regulatory
18 philosophy than it is for a design application.
19 They're showing whether they comply or don't comply
20 with the --

21 MR. WALLIS: So there's no way to
22 interpret it to a public meeting? There's no way
23 you can explain this to a public meeting?

24 MEMBER SIEBER: These code requirements
25 actually apply to existing plants too.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 CHAIRMAN CORRADINI: It would be to
2 their benefit they were able to.

3 MR. WALLIS: It would. It would help, I
4 think.

5 CHAIRMAN CORRADINI: But I think they
6 don't have to.

7 MR. WALLIS: Okay.

8 CHAIRMAN CORRADINI: It's not their job
9 to.

10 MR. WALLIS: Good enough. I know. It
11 would be nice if they could.

12 MEMBER STETKAR: Let me see if I can --
13 I might be able to help. This might be too
14 detailed, but let me try it.

15 CHAIRMAN CORRADINI: I was afraid of
16 this.

17 (Laughter)

18 MEMBER STETKAR: No, I just -- I didn't
19 think about this before, but given the discussion
20 just recently. If I look on table 3.2.1, which is
21 your classification table, not on your slides, but
22 back in the details, and I look at the plant service
23 air system, and I look at the plant instrument air
24 system, I notice that the plant service air system
25 is Safety Class II, the instrument air system is N,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 the service air system is Quality Group B, the
2 instrument air system is D, dog, the QA on service
3 air is B, boy, and the instrument air is E, Edward
4 the service air piping is Seismic Category I, and
5 the instrument air is NS.

6 That sounds somewhat contrary to me,
7 because as I understand the systems, the instrument
8 air system is much, much more important than the
9 service air system. So, I'd like to understand how
10 this classification process, the decision process to
11 come to these classifications, works, in regard to
12 this specific example.

13 MR. DEAVER: Well, I think that requires
14 a full understanding of what the systems are, what
15 their functions are and so forth. Those are really
16 covered in the other chapters.

17 MEMBER STETKAR: And I thought I did
18 understand what the system functions were. The
19 instrument air, in fact, is a backup to the high
20 pressure nitrogen system, which is a safety-related
21 system. It has containment penetrations.

22 CHAIRMAN CORRADINI: You're on page
23 3.2.27.

24 MEMBER STETKAR: I'm on page --

25 CHAIRMAN CORRADINI: 3.2.27.

1 MEMBER STETKAR: Indeed, 3.2.27 of the
2 DCD rev four. So, I was curious, to try to help
3 Graham understand how these classification criteria
4 are applied in practice, those two classifications
5 indeed seemed a bit reversed to me, understanding
6 how the functions that those two systems provide.

7 MEMBER SIEBER: Well, the failure of the
8 instrument air system, everything in there is
9 failsafe, right? If you have a valve that ought to
10 close to achieve its safety function, the lost of
11 instrument air, the value will close because it's --

12 MEMBER STETKAR: But that's also true
13 for the service air, which doesn't supply anything.

14 MR. DEAVER: Well, in many cases, like
15 on valves we have accumulators, and maintaining that
16 pressure in the accumulator is the safety part of
17 it, is supplying the air isn't necessarily
18 important. You know, it's necessary to keep it
19 pressurized, but the plant in its day-to-day
20 operations, the accumulators are --

21 MEMBER STETKAR: But whatever you say
22 for the instrument air system, I could say equally
23 bad things about the service air system and say it's
24 much less important, and yet it seemed to be
25 designed, it's designed --

1 MEMBER SIEBER: To a higher standard.

2 MEMBER STETKAR: -- and quality
3 requirements seem to be higher than, consistently
4 higher than the instrument air system.

5 MR. KINSEY: This is Jim Kinsey at GE
6 Hitachi. This may not be all of the answer, but
7 just on a first glance on the table, it appears that
8 the portions of the service air system also form a
9 portion of the containment boundary. So, I believe
10 that a portion of this classification is related to
11 that boundary function, rather than the --

12 MEMBER STETKAR: That's also true for
13 the instrument air system RG then, I think. I
14 think. I'm not quite sure about that.

15 MR. KINSEY: It's not called out that
16 way in the table, but I understand.

17 MEMBER STETKAR: I'm not sure about the
18 instrument air system, because I didn't look at the
19 piping plan. I know the service air does go through
20 the containment.

21 MR. KINSEY: It's only those components
22 that are part of the boundary that are Class II.
23 Everything else is --

24 MEMBER STETKAR: It's Class M.

25 MR. KRESS: Well, having been around for

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 a while with this committee, maybe I could add
2 something to this here. There was a process of
3 using importance measures to reclassify SSCs. And
4 this is a partial answer I think to Graham's
5 question. Because these importance measures have
6 something to do with the failure probabilities.

7 Now, there's a little bit of a problem
8 there, but if you're looking for why something may
9 be classified as it is, you can go to these
10 importance measures and back-relate it to the
11 probability that it's going to fail. So, it does --
12 it is disconnected, because it's the old problem of
13 here's the PRA, and here's design basis. They're
14 disconnected to some extent, but when you go through
15 the importance measures, you find out why some of
16 these things may have to be, have a better
17 treatment, more quality assurance.

18 There never was to my mind a connection
19 between how much quality assurance goes into the
20 failure probability. That connection never has been
21 made. But that's the rationale behind the
22 classification system use in the PRA. And it makes
23 some sense.

24 MR. WALLIS: that was very helpful, Tom.
25 You said you could use -- what I'm trying to

1 determine is what GE used.

2 MR. KRESS: Yes. They'll follow the
3 design basis.

4 MR. WALLIS: Is there a traceable
5 rationale somewhere which can be followed to see why
6 we have these Es, Ds, Cs and Bs and I's, II's, and
7 III's for these various systems? Is there a
8 traceable rationale somewhere?

9 MS. CUBBAGE: I think we should wait
10 until the staff presents and we can attempt to
11 address the regulatory requirements.

12 MR. WALLIS: If I wanted to know why is
13 this and E, and not a C, can I find that in your
14 documentation somewhere?

15 CHAIRMAN CORRADINI: That's your last
16 question to try to answer and then we'll move on.

17 MR. WALLIS: We'll move on.

18 MEMBER SHACK: There are reg guides that
19 tell you how to do this classification.

20 MEMBER SIEBER: Yes, there are.

21 MR. WALLIS: What did they do?

22 MEMBER SIEBER: They followed the reg
23 guides.

24 MR. RAJENDRA: Yes. We followed the reg
25 guides. Now, in the case of 3.2.3, the safety

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 classifications we used, they are consistent with
2 the ABWR DCD.

3 CHAIRMAN CORRADINI: So that leaves me
4 -- so I get one question here. I guess I'm -- so is
5 there anything in here that is different than is
6 already in existence on how you would classify
7 things? I guess that's what I was going to do. I
8 can't -- everybody else is much more energetic than
9 I am on this.

10 I'm taking a look at an ABWR that's in
11 Japan, if it was put here, or a current BWRs, and if
12 I overlaid them to here, what systems or components
13 or structures appear up at top different, or unique.
14 In my list it was, essentially the isolation
15 condenser, the PCCS that would be in this
16 classification scheme.

17 But other than that, these all look the
18 same. Am I off base, or is there something -- can
19 you give us a perspective about what is different
20 about this, and if I were to classify current
21 reactors under this scheme. You see my question?

22 MR. RAJENDRA: Right.

23 CHAIRMAN CORRADINI: Is there something
24 different here about it?

25 MR. DEAVER: I think you would find a

1 very consistent pattern for components and systems
2 that have been traditional BWRs.

3 CHAIRMAN CORRADINI: Okay.

4 MR. DEEVER: Obviously, for new systems,
5 we have to --

6 CHAIRMAN CORRADINI: Right.

7 MR. DEEVER: -- you know, classify them
8 based on the standards and our understanding of
9 them.

10 CHAIRMAN CORRADINI: But in those cases,
11 and I probably missed a few, but I was looking at
12 the new design, the different design of the vacuum
13 breakers, the isolation condenser, the PCCS, the
14 GDCS, those are all in a classification scheme that
15 I would expect are important relative to seismic
16 category and importance.

17 But save those and some others, is there
18 anything here that's different in terms of how you'd
19 classify current plant components? No?

20 MEMBER ARMIJO: Maybe if they interfere
21 with a passive safety system in some unique way.

22 MEMBER SHACK: RTNSS is something that
23 doesn't arise in conventional PW --

24 CHAIRMAN CORRADINI: B.

25 MEMBER SHACK: -- operating reactors --

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 BWRs, not PWRs, but operating reactors. I mean,
2 that's an advanced light water reactor concepts.
3 But most of the RAIs that I could find in this
4 chapter were basically on your treatment of
5 component -- everybody agrees on the safety class I
6 and II sort of things. It was how you treated RTNSS
7 components that seemed to bring up discussions with
8 the staff.

9 And that that's a different
10 classification than the conventional design basis
11 acts in classification. That really is something
12 that gets closer to the PRA and to some other
13 requirements. And that's you know, where the
14 controversies seem to be by and large.

15 MR. RAJENDRA: That is correct.

16 MEMBER SIEBER: If you just go by the
17 code and regulations, RTNSS systems are non-safety.
18 And if you desire to have more reliability, or
19 substance to them, then you pop some regulatory --

20 MR. SHACK: Well, no, we have SECY
21 guidance that tells us how to do things in RTNSS.

22 MR. DEAVER: But I would say that many
23 of these systems that are quote, basically non-
24 safety, if there's a segment of pipe --

25 MEMBER SIEBER: -- that goes through a

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 penetration --

2 MR. DEAVER: -- goes though a
3 penetration, or if's a path that is needed --

4 MEMBER SIEBER: -- penetration in a
5 safety to the isolation valves --

6 MR. DEAVER: -- those are then designed
7 to a, you know, a higher classification in order to
8 be consistent with the standards.

9 MS. CUBBAGE: And that's exactly the
10 situation. Our reviewer for instrument air and
11 service air was confirming that the service air --
12 it's the containment penetrations that elevate that
13 portion of that system. Otherwise, they're
14 consistently applied.

15 MEMBER STETKAR: And in fairness, I just
16 did a little homework here, and I believe the -- if
17 the drawings, the simplified drawings are reasonable
18 cartoons, the things that I thought were probably
19 instrument air containment penetrations, are
20 probably included under the high pressure nitrogen
21 system. Because the connections are outside the
22 containment. So, it in fact may be consistent.

23 CHAIRMAN CORRADINI: Dennis.

24 MEMBER BLEY: Mr. Chairman, I hate to
25 drag this out any further, but Tom put something on

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 the table and it begs a question I'd like GEH to
2 answer. Was the PRA and its importance measures in
3 any way used to define these categories, what
4 components within these categories?

5 MR. DEEVER: We don't have anybody
6 representing PRA here. I know --

7 MR. RAJENDRA: We don't have anybody
8 representing PRA.

9 MEMBER BLEY: Well, you have people who
10 did the assignment. Did they use the PRA, or the
11 importance measures? It was suggested that they
12 might. I just want you to tell us.

13 MR. DEEVER: I would say that the
14 process was that we initially established the
15 categories based on our understanding on the
16 functions of the systems and the equipment. PRA has
17 been an evolving thing.

18 If there have been times when PRA has
19 come back and said, well, these components have more
20 significant, and we have actually have made changes,
21 to be consistent. But PRA in the sequence of events
22 wasn't necessarily the first item completed.

23 MEMBER BLEY: So it may have made things
24 change as far as the class they were assigned to?

25 MR. DEEVER: Well, you know, they helped

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 established the RTNSS equipment and those sort of
2 thing.

3 MEMBER BLEY: Okay, for RTNSS.

4 MR. DEAVER: For RTNSS, yes.

5 MS. CUBBAGE: For RTNSS, yes.

6 MEMBER BLEY: Okay.

7 MS. CUBBAGE: And RTNSS is more than
8 just reliability and availability. It does impact
9 the classification from a design perspective for
10 some of the important RTNSS systems, they're Seismic
11 Category II, correct?

12 MR. RAJENDRA: Yes.

13 MS. CUBBAGE: Rather than NS.

14 CHAIRMAN CORRADINI: So, just to make
15 sure I understood the conversation. The RTNSS --

16 MS. CUBBAGE: They're different.

17 CHAIRMAN CORRADINI: The RTNSS
18 categorization analysis may have elevated certain
19 systems?

20 MR. RAJENDRA: That is correct. In fact
21 a good point --

22 CHAIRMAN CORRADINI: Can you give me an
23 example of that just so I can write it down and not
24 forget something.

25 MR. RAJENDRA: The auxiliary diesel

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 building that you have not seen, it's in DCD
2 revision five, that is not -- it is categorized as
3 Seismic Category II to improve reliability. But it
4 is not adjacent to any safety-related structure that
5 its failure would compromise a safety-related
6 function of a structure.

7 But it's simply called Seismic Category
8 II to improve reliability. That's an example.

9 CHAIRMAN CORRADINI: Go ahead.

10 MS. CUBBAGE: I believe it's all the
11 RTNSS B components.

12 CHAIRMAN CORRADINI: Thank you, Amy.

13 MR. RAJENDRA: This is --

14 MEMBER SHACK: I have my cheat sheet
15 here so I know what you mean.

16 MS. CUBBAGE: Yes.

17 MR. RAJENDRA: This is Table 3.2-2,
18 defines minimum Quality Group, Seismic, Electrical
19 and QA requirements classifications for each safety
20 class. As you can see here, this matrix provides
21 according to the safety classification, the
22 different quality group ASME code class, seismic
23 category, the electrical classification and quality
24 assurance.

25 And in Table 3.2-3, provides quality

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 group designations and corresponding codes and
2 industry standards.

3 We also provide, in some cases, core
4 classification boundaries of -- in two figures.
5 Here's an example of the classification boundaries
6 for power conversion systems. This slide is kind of
7 busy. You can see here that the turbine building,
8 this is the main steam system going from the reactor
9 to the main steam condenser. It shows the break in
10 quality seismic Category I break, happens at the
11 pipe anchors indicated -- at the boundaries
12 indicated.

13 On the left-hand side, is Seismic
14 Category I. On the right-hand side, is Seismic
15 Category II.

16 CHAIRMAN CORRADINI: So, just again,
17 this is for my edification. Because I read this a
18 couple of times, and I probably just still don't get
19 it. So, Seismic Category II, comes down to the fact
20 that it is not going to compromise a Seismic
21 Category I function, but it itself is not going to
22 necessarily going to be called upon to function
23 during a seismic event. Do I have -- I have I said
24 it approximately right?

25 MR. RAJENDRA: It doesn't support the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 function of a safety-related system.

2 CHAIRMAN CORRADINI: Nor does it hamper
3 it?

4 MR. RAJENDRA: Yes. Right.

5 CHAIRMAN CORRADINI: And that's
6 essentially the cross-over point.

7 MR. RAJENDRA: Yes. Right, right.
8 Right.

9 CHAIRMAN CORRADINI: Okay. And then you
10 said something in the discussion of the busy picture
11 that I want to understand. The designation between
12 Category I and Category II in the cartoon --

13 MR. RAJENDRA: Yes.

14 CHAIRMAN CORRADINI: -- is what again?
15 You said it relative to? I can't remember exactly
16 how you phrased it. Is there a piping division?
17 Because it appears to be in a building, which must
18 mean there's some sort of anchoring difference.

19 MR. RAJENDRA: Yes. That's the anchor.
20 That's the pipe anchor, is on the left-hand side is
21 Seismic Category I, and the right-hand side is
22 Seismic Category II.

23 CHAIRMAN CORRADINI: So, it's literally
24 the design of the anchor changes as you cross that
25 boundary?

1 MR. RAJENDRA: That's right.

2 CHAIRMAN CORRADINI: And assuming the
3 isolation values, or the multiple isolation values
4 shut down or close, everything can rip off and fall
5 into the ocean for it matters, life is okay?

6 MR. RAJENDRA: That's right. Seismic
7 Category I is protected.

8 CHAIRMAN CORRADINI: Okay.

9 MR. DEEVER: Typically, category changes
10 happen at valves or restraints, which you know, you
11 see physical features here, typically.

12 CHAIRMAN CORRADINI: Okay. But to go
13 from cartoon to reality, the piping structure would
14 be in the building. What's the building's
15 categorization, Category I?

16 MR. RAJENDRA: The building, Seismic
17 Category I, that's right.

18 CHAIRMAN CORRADINI: Okay. Thank you.

19 MR. RAJENDRA: And the next picture is a
20 similar picture for the feed water system. We'll
21 move on to Section 3.3, wind and tornado loadings.
22 Seismic Category I and II structures are designed to
23 withstand 150 miles an hour wind, measured as a 3-
24 second gust.

25 MR. WALLIS: So, this is converted to a

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 pressure.

2 MR. RAJENDRA: Right.

3 MR. WALLIS: What's the density of the
4 air then? What temperature does it have, and
5 pressure?

6 MR. RAJENDRA: The rules we used to
7 convert the wind velocity, which is a 3-second gust,
8 to a velocity pressure, the rules we follow ASCE
9 standard 7-02.

10 MR. WALLIS: Well, that doesn't tell me
11 anything. Is it cold air, or high pressure? Is it
12 some sort of maximum air density that's used? Does
13 it have water in it? I mean, is this a wind which
14 is full of hailstones, or raindrops, or is it just a
15 benign, warm breeze, or a full wind, a warm air
16 wind? I don't know. But it seems to me it might
17 make a difference.

18 Do you question these things, or are you
19 just sort of flying by a blind -- just routinely
20 apply some standard?

21 CHAIRMAN CORRADINI: If I were on their
22 side, I would say, I am following the reg guides as
23 specified.

24 MR. WALLIS: You have to apply
25 standards.

1 MR. RAJENDRA: Yes.

2 MR. WALLIS: But you have to also have
3 some curiosity about the basis for the standard, it
4 seems to me.

5 MR. RAJENDRA: There's plenty -- all the
6 design standards that we use are already supported
7 by another research.

8 MR. WALLIS: And they consider water in
9 the air?

10 MR. RAJENDRA: Which is pretty much the
11 state-of-the-air. That is the current state of
12 knowledge of the day.

13 MR. WALLIS: But it may not be right.
14 It may not be good. It may be, as we know, that
15 some standards sometimes have lacunae in them, have
16 faults or errors, or miss things. I just wondered
17 if you have a curiosity about whether this wind had
18 water in it, or hail. Does that make a difference?

19 CHAIRMAN CORRADINI: I suspect he
20 follows Bechtel topic report BC Top 3(a), Revision
21 3, Tornado and Extreme Wind Design Criteria for
22 Nuclear Power Plants, issued 1974.

23 MEMBER SIEBER: That's what I'd do.

24 (Laughter)

25 MR. WALLIS: I know that. But this sort

1 of -- without curiosity applying paperwork standards
2 can sometimes lead to design errors.

3 MEMBER BROWN: That's a problem with the
4 regulations. I mean, if out of the tons of stuff I
5 ever built and had vendors delivered to me, I've
6 never ever had a manufacturer or vendor sit down --
7 what we told him to build, that's what he built.

8 I mean, if didn't tell him there were
9 hailstones in it, he didn't build -- he didn't have
10 the wind with hailstones. That's a regulatory
11 functions, design guidance function as opposed to
12 asking these guys to -- just personal opinion by the
13 way. You can shoot me if you want.

14 CHAIRMAN CORRADINI: Feel free. This is
15 what we're here for.

16 MEMBER BROWN: Okay, all right.

17 MEMBER SIEBER: This is a free zone.
18 This is a gun-free zone.

19 MEMBER BROWN: A gun-free zone, that's
20 good. I like that.

21 (Laughter)

22 MR. WALLIS: I understand.

23 MEMBER BROWN: I'm trying to make a
24 point. I think the line of questioning is not very
25 useful. That's personal opinion again. It's not

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 very useful for this venue under these
2 circumstances. They're going to go take the reg
3 guides and the other design guidance and ASME stuff,
4 whatever it is, and they're going to apply that.
5 They aren't going to say, well, this doesn't make
6 sense.

7 Occasionally, a bright light alights
8 somewhere and somebody says, you know, this is
9 driving me to do some really dumb things, and it
10 doesn't really apply to this plant design. Well,
11 that's like -- that was a light bulb doing off, we
12 really appreciated it when somebody did that.

13 And we'd say, oh, yes, you're really
14 right, we don't want to spend the extra \$4 million
15 to get that done. We'll take that off the table,
16 give us the money back, by the way, since we already
17 paid you for it, and get on with the reduced, or
18 more relaxed design.

19 MR. WALLIS: Well --

20 MEMBER BROWN: I throw that in. I just
21 wouldn't --

22 MR. WALLIS: I just want to make a
23 statement. I don't want to abandon this line of --
24 and walk. But, as I'm ACRS consult, not a member of
25 the committee, I have done some work for utilities

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 and manufacturers since I've retired. And I'm
2 astonished at what I sometimes run into which seems
3 to be, you said -- we look at it, let's not worry
4 about what really happens. Let's just satisfy the
5 regulations, you know, and then see if the NRC will
6 accept it.

7 That to me, is not really what I expect
8 as sort of the really -- an engineer of integrity to
9 do. An engineer of integrity should say, I have
10 designed this thing for what really happens and it's
11 going to work for what really happens, not in some
12 strange world of regulations. And I've said my
13 piece now, and I'm going to be quiet.

14 But it does concern me, because now I've
15 got on the other side, I have even more concern
16 about the process. Thank you.

17 MEMBER ARMIJO: I think I saw something
18 where, to GEH's credit, is on the tornado winds,
19 velocities, over 330 miles an hour, which is in
20 excess of reg guides and other requirements. And I
21 was going to ask, why in the world did you go beyond
22 the requirements. So somebody must be looking at
23 that and saying, that's really not good enough.

24 And I think that's your point, is this
25 -- are the requirements and regs really good enough.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 MEMBER MAYNARD: Well, the ASME code
2 requirements are more than just a paper set of
3 requirements. The ASME code requirements put
4 together with participation, input, industry, NRC,
5 there's a lot of different inputs and checks and
6 everything on that. So, I think that's a lot more
7 than just a paper requirement that goes into ASME
8 code requirements.

9 MEMBER SIEBER: Well, it is just a talk
10 about tornados, you have to add the transitional
11 velocity to the rotational velocity to get the wind
12 loading. And that's what they did. I think that's
13 what the code calls for. On one side of the tornado
14 it's going to be less, on the other side it's going
15 to be the sum of the two.

16 CHAIRMAN CORRADINI: Can we move on.

17 MR. RAJENDRA: Yes. The next slide is
18 on the tornado loads. Seismic Category I and II
19 buildings are designed for design basis tornado with
20 maximum winds of 330 miles and hour.

21 A comment was made that this exceeds the
22 current RG 1.76, that is correct. The current RG
23 1.76 says 216 miles an hour. But that reg guide was
24 actually issued after we had submitted this design
25 specification. The value we used was based on an

1 interim design guide which was much higher.

2 Although the RG 1.76 value released, we
3 did not go back and change it. We just kept the
4 same value that we had.

5 The control building emergency
6 filtration unit air intake openings are provided
7 with tornado dampers. All the Seismic Category I
8 buildings are essentially designed as unvented
9 structures, that means there is no vent openings
10 that would allow difference in internal pressures to
11 double-up between the compartments.

12 The remainder of plant structures,
13 designs do not adversely impact Seismic Category I
14 structures or components.

15 The next is Section 3.4. We described
16 the flood protection design basis. The methods
17 deals with the external flood sources as well as
18 internal flood sources. For the external flooding,
19 the external flooding is protected number one by
20 ensuring that the design plan grade is at least one
21 foot above design flood level.

22 And that requirement that we design is
23 reflected in Table 2.01 in Chapter 2. So, if a
24 plant has -- when they are siting a plant, they have
25 to make sure that that requirement is met.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 If that requirement is not met, then the
2 -- as on a site specific basis, they have to
3 describe what additional protection measures they
4 have to provide and that will be provided as part of
5 the COL application. Or, they have to raise or
6 artificially change the grading of the site to suit
7 that condition.

8 Walls below flood level are designed for
9 hydrostatic loads. We have provided -- water stops
10 are installed in joints before flood and ground
11 water levels.

12 External surfaces are waterproofed below
13 grade. We provided by using waterproof membrane for
14 the basement walls, and use a mud mat with a Zypex,
15 it's a trade name, waterproofing material added to
16 the concrete that's added to the mud mat. And that
17 provides waterproofing at the basement, below the
18 basement.

19 Water seals are installed at pipe
20 penetrations below grade and the roofs are designed
21 to prevent pooling.

22 CHAIRMAN CORRADINI: Can I ask a
23 question?

24 MR. RAJENDRA: Yes.

25 CHAIRMAN CORRADINI: Since we had a lot

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 of flooding recently and it's now on my mind, does
2 ESBWR design, in some sense is a bit underground.
3 That is, the vessel sits low. That helps you with
4 the water pools relative to seismic, but have you
5 done an analysis, does it hurt you relative to
6 flooding? Or, does it -- is there a compromise?

7 I guess what I'm trying to get at is,
8 from the design of the system, was there a conscious
9 decision to position the system relative to where it
10 would be for flooding hazard versus seismic hazard?
11 Or, are they looked at separately and independently?

12 Because as I saw, we're going to get to
13 this tomorrow, so I don't -- don't answer about
14 seismic. As I saw it, you weighed the water. You
15 weighed the isolation condenser. You weighed the
16 PCCS and you told us how high it was, and you
17 jiggled them. But the jiggling and how they're
18 impacted by the jiggling is how much I stick them
19 inside the earth. But the more I stick them inside
20 the earth, the more I'm prone to an external
21 flooding issue.

22 So, can you give me some feeling as to
23 how you thought this through, or was there an
24 independent analysis of this?

25 MR. RAJENDRA: The two analysis are

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 independent. The flooding protection is
2 independent. The flooding protection is provided by
3 waterproofing the structure, and providing all of
4 these protection. These are basically hardened
5 protections, they're not active systems. They're
6 hardened protections, passive protections.

7 MEMBER SHACK: Well, I think what Prof.
8 Corradini was really asking is, why did you decide
9 to locate it the way you did? Was that basically
10 driven by the seismic considerations, or were there
11 other considerations as to how you chose?

12 CHAIRMAN CORRADINI: Or, were there
13 interaction in the considerations that said, no,
14 don't go down ten meters because that's too low, go
15 up five, and that gives us, you know, there is an
16 optimal. I'm just trying to understand your design
17 thinking in all of this.

18 MR. RAJENDRA: Jerry, do you have any?

19 MR. DEAVER: Well, some of the things
20 that came to mind for me is like, in the fuel pool,
21 or the storage pool, we put it at ground level. You
22 know, I think that was more of a safeguards
23 considerations. So, there's a lot of considerations
24 given. But I think, mainly we embed our reactors
25 for seismic purposes and containment and dynamic

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 loadings and things like that. We want to dampen
2 the structures such that we don't get amplification
3 going up in the building.

4 So, I think -- flooding is just a
5 different concern, you know. That's mainly an
6 exterior building concern that we have to protect
7 against.

8 MR. WALLIS: You mentioned fuel pool.
9 Is that part of the discussion. I haven't really
10 heard about it yet. It obviously is a concern and a
11 seismic and are there other events?

12 MR. DEAVER: That was primarily a
13 Chapter 9.

14 MR. WALLIS: Exception to our discussion
15 today.

16 MR. DEAVER: Right.

17 MEMBER MAYNARD: I just had a question
18 on your design levels. Just looking at your table
19 3.4-1, there's only one foot different between the
20 design flood level and the designed groundwater
21 level.

22 MR. RAJENDRA: Right.

23 MEMBER MAYNARD: That seemed a little
24 narrow to me. It shouldn't make any difference, I
25 mean, the site's going to have to show they meet

1 both of those, but it seemed like that was a pretty
2 small difference between the ground water level and
3 the flood level, design level.

4 MR. RAJENDRA: These values actually
5 come from utilities URD document. That's what the
6 utilities got together, decided what new plants
7 should use, their standard design parameters. And
8 the ESBWR pretty much followed that guidance.

9 MEMBER MAYNARD: On what --

10 MR. RAJENDRA: Yes.

11 MEMBER MAYNARD: -- the site to show
12 that they're design flood level, or their flood
13 levels and groundwater levels are below that, but it
14 just seemed like it's a pretty narrow band.

15 CHAIRMAN CORRADINI: Is this -- you're
16 on 3.4-1.

17 MEMBER MAYNARD: Yes. 3.4-1.

18 CHAIRMAN CORRADINI: Where it's 14 point
19 -- where the feet?

20 MEMBER MAYNARD: Yes.

21 CHAIRMAN CORRADINI: Okay. Fine.

22 MEMBER MAYNARD: Design flood levels
23 14.3 feet, design ground --

24 MR. RAJENDRA: The table.

25 MEMBER MAYNARD: -- water 13.3 feet.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 CHAIRMAN CORRADINI: Right.

2 MEMBER MAYNARD: And the finish grade
3 level's 14.8.

4 CHAIRMAN CORRADINI: Before we go ahead,
5 I guess I want to understand the interaction.
6 Because Prof. Wallis always educates me every time.
7 So, let's say, they are going to build this
8 somewhere in Illinois --

9 (Laughter)

10 CHAIRMAN CORRADINI: -- a place where,
11 it's underwater, a lot of water right now. And the
12 estimate is that, how would I change the design? I
13 would waterproof, or would I change the elevation of
14 the design relative to how much I inserted into the
15 ground? Would I essentially just have to use the
16 word, you didn't say waterproof, you had a nicer
17 word for it.

18 But, I would essentially then have a
19 sealing to a higher level, and the base design would
20 stay the same? What would be an approach since the
21 utility would come back to you, so their COL would
22 pass muster?

23 MR. RAJENDRA: Well, the application
24 would have to address the fact that now you have
25 that high a water level. Which means, they would

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 provide some sort of a dikes to prevent --

2 CHAIRMAN CORRADINI: A levee?

3 MR. RAJENDRA: Yes.

4 (Laughter)

5 MR. RAJENDRA: And first, that would
6 have to be proven to work on a seismic event.

7 CHAIRMAN CORRADINI: Okay.

8 MR. RAJENDRA: You know. That's what I
9 would guess that they would have to provide, some
10 sort of a barrier.

11 CHAIRMAN CORRADINI: It would be
12 something that would be a site specific change, not
13 necessarily a plant change to that site.

14 MR. DEEVER: Our intent is to have
15 standard plant designs. And so we're not going to
16 change the elevation in the ground or anything like
17 that.

18 MEMBER BROWN: Well, the ground's not a
19 big issue. Here I've got a river that's flooded,
20 and I've got -- look out over the towns you see in
21 the pictures, and you see little parts of peaks of
22 roof. That's 20, 30 feet up. I mean, they're
23 buried. So I'm just sitting here thinking, all I
24 see is a cooling tower from a plant sitting out
25 there. That's --

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 (Laughter)

2 MEMBER BROWN: I guess so we build
3 levees or dikes, or protective walls.

4 MEMBER SIEBER: Don't build your plant
5 on a flood plain.

6 MEMBER BROWN: Well, we don't
7 prohibit --

8 MS. CUBBAGE: That's if the site doesn't
9 meet the proscribed site parameters.

10 CHAIRMAN CORRADINI: But Otto brought it
11 up, so it's fault.

12 (Laughter)

13 MR. WALLIS: Well, the key question
14 would seem to be, what's the design flood level.

15 CHAIRMAN CORRADINI: Well, I think their
16 answer back is that it would be a site-specific
17 parameter. That's if I understand --

18 MR. WALLIS: But again, I mean, there
19 are floods now that are in your area which may be
20 above the traditional design-specific.

21 CHAIRMAN CORRADINI: University of Iowa
22 is dealing with that at the moment, but yes.

23 MEMBER MAYNARD: And I do think that's a
24 serious issue for siting. And I know that Dr.
25 Powers has brought this up several times, is how

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 much can you rely on past data versus what's the --
2 I think it's going to be a challenge for somebody
3 deciding what's the design flood levels and stuff
4 for that site.

5 MEMBER BROWN: 500-year flood headline,
6 that was an impressive.

7 CHAIRMAN CORRADINI: But it was the
8 governor, so I don't know. Sorry.

9 (Laughter)

10 CHAIRMAN CORRADINI: Remove that from
11 the record. Expunge that. I'm sorry, that was --

12 MEMBER SIEBER: Too late.

13 (Laughter)

14 CHAIRMAN CORRADINI: Go ahead.

15 MR. RAJENDRA: Next section addresses
16 the internal flooding. The internal flooding
17 sources are due to pipe breaks and cracks and piping
18 of fire hose discharges. The protective features
19 provided to mitigate or eliminate consequences of
20 internal flooding includes, structural enclosures or
21 barriers, curbs and sills, leak detection
22 components, floor drainage systems. Although, we
23 have not taken any credit for flood drainage systems
24 in the flooding evaluation.

25 MR. WALLIS: This flooding is due to

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 something like a fire hose discharge. It's not due
2 to something discharged from your big tanks of water
3 which you have in this building?

4 MR. RAJENDRA: Right. There aren't
5 considered to fail.

6 MR. WALLIS: They're never allowed to
7 fail.

8 MR. RAJENDRA: Yes. They're not
9 considered to --

10 MR. WALLIS: And that piping isn't
11 allowed to fail?

12 MR. RAJENDRA: They are designed to
13 Seismic Category I standards. They're not, we don't
14 postulate a failure of those.

15 MR. DEAVER: Most of our pools are just
16 gravity pools. And as such, there's not high
17 pressure piping associated with them. So,
18 generally, it's not a big design challenge.

19 CHAIRMAN CORRADINI: But, I guess I
20 thought you were going to answer it differently
21 since we have a reactor pool, and all reactor pools
22 kind of leak. The monitored leakage rate has got to
23 be known within some sort of tech specs. And then
24 if not, you have to go in and fix it. So, I would
25 assume these pools would be of the same sort of

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 thing.

2 You have an open pool. You're always
3 monitoring the level, and you always should know the
4 leakage. And if it goes beyond some sort of
5 acceptance level, you have to go in and fix it. The
6 owner, or the licensee would have to go in and
7 maintain it within specs.

8 MR. DEAVER: Exactly. We have -- we
9 control all the water levels. We monitor leakage.

10 MEMBER SIEBER: You're actually
11 controlling the level, though.

12 MR. DEAVER: Oh, yes. We're aware of
13 water level at all times.

14 MEMBER SIEBER: Right.

15 MR. WALLIS: I guess therein the problem
16 would be some inadvertent opening of a drain valve
17 or something, it wouldn't be a natural thing. It
18 would be some human error, most likely cause a large
19 internal flood.

20 MR. DEAVER: Typically, that would
21 probably be the case.

22 MR. WALLIS: Or a water hammer, or
23 something like that, a fire line, there have been
24 water hammer in fire lines.

25 MR. DEAVER: Most of our pools are there

1 for safety purposes. So, typically, they're not
2 operating. So, it shouldn't get into a lot of those
3 problems.

4 MR. RAJENDRA: Next slide, section 3.5
5 is on missile protection, design basis. Seismic
6 Category I structures are designed for missile
7 protection. Systems requiring missile protections
8 are safety-related systems and off gas charcoal bed
9 absorbers.

10 The Seismic Category II structures are
11 not designed against missile protection, because
12 inside, we don't have any seismic category safety-
13 related components.

14 MEMBER BROWN: Say that again?

15 MR. RAJENDRA: Seismic Category II
16 structures are not designed for missile protection
17 in general, except in the case of turbine building,
18 we have the charcoal bed absorbers. That room is
19 provided with missile protection. But other, the
20 rest of the Seismic Category II structures are not
21 designed to resist missiles.

22 That's the key difference between
23 Seismic Category I and Seismic Category II.

24 MR. DEEVER: Is that external missile
25 versus internal?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. RAJENDRA: External and internal.

2 MR. DEAVER: Okay.

3 MEMBER SHACK: Just to address Dr.
4 Wallis's issues, you know, this is the deterministic
5 chapter. You get another shot at all this stuff
6 when you go to the PRA. We missed you during that
7 meeting.

8 CHAIRMAN CORRADINI: We'll get a shot of
9 that in the next slide.

10 MR. WALLIS: No, it's not entirely --
11 there's a turn to the minus seven per year screening
12 criteria.

13 MEMBER SHACK: Well, yes, those, there
14 are those.

15 MR. WALLIS: There is some --

16 MEMBER SHACK: But things like internal
17 floods, I mean, you would come back to the PRA.

18 MR. WALLIS: Right.

19 MEMBER SHACK: And in fact, you know, if
20 you found a vulnerability, you may do something
21 about it.

22 MR. WALLIS: I was a bit surprised by
23 your answer to the PRA. I thought this was a design
24 in which the PRA was integrated from the beginning.

25 MEMBER SHACK: But he's looking at

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 meeting requirements now.

2 MEMBER SIEBER: He has to meet the
3 rules.

4 MR. DEAVER: Well, it's been an
5 interactive process. I'm not trying to say it
6 wasn't part of the initial design, but it's been
7 interactive.

8 MR. KRESS: It was implicit too.
9 Because the design was such as to eliminate a lot of
10 the severe accident issues, which were known from
11 past PRAs. So, it's implicit in the design.

12 MR. RAJENDRA: Rotating equipment,
13 examined for a possible source of credible and
14 significant missiles. In the case of main turbine
15 missiles, the turbine is located in a manner
16 favorable to containment location.

17 In a subsequent slide, you'll see a
18 picture of the turbine missile trajectory, and how
19 the safety-related buildings are located away from
20 it.

21 MEMBER STETKAR: Can I ask you a
22 question?

23 MR. RAJENDRA: Yes.

24 MEMBER STETKAR: I got confused reading
25 through the DCD and the SER. Is -- and you don't

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 have numbers up here, or -- no you don't.

2 CHAIRMAN CORRADINI: You mean, pages,
3 you mean?

4 MEMBER STETKAR: No, no, no, no.
5 Numbers. Is the design basis turbine -- main
6 turbine missile generation frequency for the ESBWR
7 standard plant, is it designed to a 10^{-4} , per year
8 turbine missile generation frequency, or a 10^{-5} per
9 year?

10 MR. RAJENDRA: That's addressed more in
11 Chapter 10, but it's my recollection that we
12 committed to 10^{-5} . And that actual calculation will
13 be submitted as part of the COL applicant commits to
14 doing that as part of the COL application.

15 MEMBER STETKAR: I guess I need some
16 clarification and there's a table 3.5-1 in the DCD
17 that lists probabilities. And I looked at changes
18 in the DCD.

19 MR. RAJENDRA: Yes.

20 MEMBER STETKAR: There were text changes
21 that as the DCD evolved from Rev 3 to Rev 4, took
22 out several references to that 10^{-5} and put in
23 qualifiers that said, if the turbine were designed
24 with a typical type, with an advanced type of rotor,
25 then it could meet the 10^{-5} .

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 But it seemed like Section 3.5 focuses
2 now on a 10^{-4} frequency. And since I come from the
3 PRA background --

4 MR. RAJENDRA: Yes, yes.

5 MEMBER STETKAR: -- I'm going to have a
6 follow-up on that on the PRA. But from just a
7 strict design-basis criterion, because this is a
8 design criterion that you're going to specify for
9 your turbine vendor, is it 10^{-4} , or 10^{-5} ?

10 Because the -- the reason I bring it up
11 is, the SER consistently seems to assume that it's a
12 10^{-5} . It will be a question for the staff later.
13 But something like 90 percent of the words and
14 numbers that I can see in the DCD, focus on 10^{-4} .

15 So, I'm curious which it is. Because
16 it's a number difference, but it is a design spec.
17 Anybody have an answer to that?

18 MR. PATEL: My name is Chandi Patel. I
19 guess I'm the culprit for SER.

20 MEMBER STETKAR: No, no, no, no.

21 (Laughter)

22 MEMBER STETKAR: You're GEH who is
23 specifying the design.

24 MR. DEEVER: I'm not sure we have a
25 knowledgeable person here to answer that.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. KINSEY: This is Jim Kinsey from GE
2 Hitachi, our turbine expert isn't in the room, but
3 we may be able to gather that information during the
4 break and then --

5 MEMBER STETKAR: I'd appreciate it.
6 Because I got really confused. The numbers --
7 you'll see when we get to the next slide here, I
8 have a follow-up that's more of a PRA-related
9 question, but I wanted to get the design down first
10 before I asked the follow-up.

11 MR. KINSEY: We'll follow that up at the
12 break.

13 MEMBER STETKAR: Thanks.

14 MR. RAJENDRA: The turbine missile
15 issues are fully addressed in Section 10.2, we
16 basically make a reference to that from Section 3.5.

17 The COL applicant's going to provide the
18 turbine and inspection program, and turbine missile
19 generation floor with the calculation to show that
20 our commitments are met.

21 Missiles from pressurized component
22 failures are evaluated. This is the picture I told
23 about where the site is arranged in such a manner
24 that the low trajectory turbine missile does not
25 impact any of the safety-related buildings.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 MEMBER STETKAR: Now I get to ask the
2 PRA question. I noticed that -- and it relates back
3 to this table 3.5-1 in the DCD where Table 3.5-1
4 says that the, "Under nominal conditions, the
5 probability of a turbine missile generation should
6 be less than $1E^{-4}$, 10^{-4} event per year."

7 "That if the probability raises to
8 somewhere between 10^{-4} and 10^{-3} , you can continue
9 operation until the next refueling outage. Between
10 10^{-3} and 10^{-2} , you can operate for 60 days. And if
11 the probability increases to greater than 10^{-2} , you
12 can still operate for six days."

13 So, there are criteria there, and
14 obviously the licensee would have to do an
15 evaluation to confirm those probabilities. I notice
16 that essentially, all of the electrical building is
17 within the target area from the low trajectory
18 turbine missiles. And you mentioned earlier that
19 Seismic Category II structures are not designed
20 against missiles.

21 The PRA has absolutely no input to it
22 from turbine missile initiating events. So, I was
23 curious whether GE has looked at the risk from
24 turbine missile damage to the electrical building,
25 recognizing it's a non-safety structure, but it

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 includes a heck of a lot of RTNSS equipment that's
2 required for post-72 hour event response.

3 Have you looked at that issue at all,
4 given the fact that I can operate for a rather
5 extended period of time with allowable turbine
6 missile generation frequencies that are fairly
7 measurable?

8 MS. CUBBAGE: I believe the post-72 hour
9 equipment has been relocated to the ancillary diesel
10 building.

11 MR. RAJENDRA: well, there are now -- if
12 I recall, there are no RTNSS C, B, equipment in the
13 electrical building?

14 MEMBER STETKAR: Is that right? Okay.

15 MR. RAJENDRA: Yes.

16 MS. CUBBAGE: That's probably a change
17 in Rev 5.

18 MR. RAJENDRA: Yes.

19 MEMBER STETKAR: Ah, geez, I thought I
20 was so good, I went up and I read Rev 4. I have
21 Rev 5.

22 MEMBER ARMIJO: You told us to read
23 Rev 5.

24 MEMBER STETKAR: Yes, for the PRA that's
25 true.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 MEMBER ARMIJO: But this is a -- that's
2 what this is?

3 MEMBER STETKAR: Well, but the SER and
4 the DCD -- the SER seems to be on Rev 3 and-a-half
5 or 4. So, I was trying to be fair for this meeting.

6 MEMBER SIEBER: Take an average.

7 MEMBER STETKAR: It's not clear. I
8 wanted to ask the staff later on that. But in fact,
9 the PRA, at least Rev 2 of the PRA, I did not look
10 at Rev 3, of the PRA, makes no mention of turbine
11 missile damage. But it might not be relevant if in
12 fact everything's been relocated to a building
13 that's not -- where is that other building, the new
14 building on this picture?

15 MR. RAJENDRA: Yes. I can tell you
16 where it is. The part machine shop that you see,
17 indicated at HM, it's going to be moved to, well,
18 it's west, right, not south. So, it's west. North
19 is turbine building, reactor building -- turbine
20 building is not the reactor building. So, hot
21 machine shop moves west and the auxiliary diesel
22 building is located between what the service
23 building and the part machine shop.

24 MEMBER STETKAR: Oh, okay.

25 MEMBER BLEY: Can you point to it with

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 your pointer?

2 MR. RAJENDRA: Yes.

3 MR. DEAVER: Basically, this building is
4 moving down and the auxiliary --

5 MEMBER BLEY: -- will be right in there
6 somewhere, well outside the of the range of the
7 turbine missiles.

8 MR. DEAVER: From the other side.

9 MEMBER STETKAR: Thank you. And that's
10 going to contain not only the diesels, but all of
11 the switch gear, all of the -- for connecting
12 between the diesels and the safety-related battery
13 charges, and so forth? All the medium voltages, I
14 think 6.9 kV and medium voltage switch gear will be
15 in that building?

16 MR. RAJENDRA: I know that it contains
17 the diesels.

18 MEMBER STETKAR: Well, but I mean, the
19 diesel's can generate power, but if the switch gear
20 is destroyed, that's not so good.

21 MR. RAJENDRA: Right.

22 CHAIRMAN CORRADINI: I think they're
23 going to have to take that under advice and get back
24 to you.

25 MEMBER STETKAR: Okay. Thanks.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. SHAMS: I can answer that question.
2 My name is Mohammed Shams. I reviewed the RTNSS
3 stuff for GE. They created a new building
4 altogether, with new diesel generators. They still
5 have diesel generators in the electric buildings,
6 however, they're not required to address the long
7 term safety. They're there to address uncertainty
8 with some of the performance of RTNSS systems.

9 So, by definition, they're not required
10 for seismic response.

11 MEMBER STETKAR: Okay. I understand the
12 diesels. But the switch gear that the, you know,
13 there has to be bus work that the diesel's generate
14 electricity using --

15 MR. SHAMS: That is included in that
16 building also, the --

17 MEMBER STETKAR: In the new building?

18 MR. SHAMS: -- the required -- in the
19 new building.

20 MEMBER STETKAR: Okay. Thanks.

21 CHAIRMAN CORRADINI: Go ahead.

22 MS. CUBBAGE: And I should say, I don't
23 know whether this helps or confuses matters on the
24 turbine missile probability, but the ITAAC
25 requirement is to verify that the probability of

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 turbine failure resulting in ejection of a turbine
2 rotor is less than 10^{-4} . That's the ITAAC in DCD
3 Rev 5.

4 MEMBER STETKAR: So it is Rev 5, DCD
5 Rev 5.

6 MS. CUBBAGE: That's tier one.

7 MEMBER STETKAR: Okay.

8 MS. CUBBAGE: I will say that the text
9 in Chapter 10 appears to be a little bit confusing.
10 So I can understand where you're coming from.

11 CHAIRMAN CORRADINI: Thanks. Let's --
12 thanks.

13 MR. RAJENDRA: The section continues
14 with Section 3.5 missile protection. Tornado
15 generated missiles, other limiting natural phenomena
16 hazard, Seismic Category I buildings are designed to
17 resist tornado missiles.

18 The site proximity missiles for ESBWR
19 standard plant is assumed to be statistically
20 insignificant, meaning it's less than $1E^{-7}$. The
21 site -- the COL applicant has to address site
22 specific hazards because these are standard plants,
23 that's about the best we can do is to make the
24 assumption that there are no significant site-
25 specific missiles.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 And the same thing with the aircraft
2 hazards. We consider them to be statistically
3 insignificant, and the COL applicant for a
4 particular site has to show that the aircraft hazard
5 is less than $1E^{-7}$.

6 And Section 3.5 also provides barrier
7 design procedures to prevent local and overall
8 damage due to missiles.

9 MR. WALLIS: Is there a number on
10 statistically insignificant?

11 MR. RAJENDRA: $1E^{-7}$. MR. WALLIS: $1E^{-7}$.

12 MEMBER STETKAR: Which is ten times,
13 well, about four times higher than the total risk
14 from everything else combined that's evaluated in
15 the PRA.

16 CHAIRMAN CORRADINI: Except for seismic.

17 MEMBER STETKAR: Except for seismic.

18 That's right. The seismic is not evaluated.

19 MR. RAJENDRA: That concludes my --

20 MR. WALLIS: 10^{-7} is the cutoff. The
21 actual value is presumed to be less than that. Or,
22 is that 10^{-7} -- where does 10^{-7} come from?

23 MR. RAJENDRA: It comes from the
24 regulations.

25 MR. WALLIS: Oh, it comes from the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 regulations.

2 CHAIRMAN CORRADINI: You asked.

3 (Laughter)

4 MR. RAJENDRA: That's the end of
5 Sections 3.1 to 3.5.

6 MEMBER SHACK: If you have no further
7 questions on 3.1 to 3.5, we'd like to proceed then
8 with Sections 3.10, 3.11 and 3.13.

9 CHAIRMAN CORRADINI: Sure.

10 MR. WAAL: This is the continuation of
11 discussion on Chapter 3. Right now, we would like
12 to talk about sections 3.10, 3.11 and 3.13 DCD.
13 With me are Jerry Deaver and Kevin Baucom who will
14 be doing the presentation.

15 MR. BAUCOM: Overall, Section 3.10
16 provides the requirements for qualification of
17 equipment to seismic conditions. It requires
18 requirements for seismic and dynamic qualification
19 of all the mechanical and electrical equipment. It
20 outlines that qualification be performed by test,
21 analysis, or a combination of the two, and also that
22 mechanical and electrical equipment are designed to
23 withstand earthquake and other dynamic loads with a
24 sound basis.

25 The general criteria for qualification

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 is --

2 MEMBER BROWN: Can you wait a minute?

3 MR. BAUCOM: Yes.

4 MEMBER BROWN: You -- the idea of test
5 or analysis, is there -- there's nothing in this, at
6 least what I saw in the presentation, in the
7 materials that defines how do you decide whether
8 you're going to test or analyze. Is there a set of
9 criteria that you've established to determine -- I
10 mean, test is obviously --

11 MR. BAUCOM: Is the preferred method.

12 MEMBER BROWN: -- the preferred method.
13 But if you're not going to test, what basis have you
14 all said, hey look, we can't. I mean, other than
15 huge -- I recognize --

16 MR. BAUCOM: Yes.

17 MEMBER BROWN: -- taking a turbine
18 generator and going off and trying to run a seismic
19 test is somewhat difficult.

20 MR. BAUCOM: Generally, that's a
21 reasonable conclusion. That if it's practical to
22 test it, the intention is to test it. But where
23 that line is, because all the equipment is not you
24 know, hasn't detail specified --

25 MEMBER BROWN: Is that laid out as a

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 metric somewhere? Is there some design standard or
2 criteria that you've put out to the people that know
3 that that's -- how do you know that's going to
4 happen? I mean, from lots of experience, people
5 just assume not test. They'll say, well, gee, we
6 built this stuff before and it works just fine. So
7 they just -- and we know how to do it.

8 MR. DEAVER: Well, typically, the
9 passive components that don't have any active
10 motion --

11 MEMBER BROWN: You mean, non-rotating
12 equipment?

13 MR. DEAVER: Right, or valves, or you
14 know, actuators and things like that. The passive
15 components like that typically we do by analysis.
16 And you know, reactor pressure valves --

17 MEMBER BROWN: You mean electrical
18 cabinets? Your instrumentation and control, or your
19 other control electrical control or hydraulic
20 control functions, whatever they happen to be for in
21 plant, in compartment type components, you would do
22 those analytically? So, you just wouldn't test
23 them? That's what I got out of your statement. I'm
24 not trying to attack you. I'm just, that's what I
25 got out of your statement.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. DEAVER: Well, I think, yes, it's
2 very dependent on the components. I mean, like for
3 valves and stuff, we have to do functional testing
4 to make sure the valves can actuate. You know, so
5 there's different considerations.

6 MEMBER BROWN: You going to do that
7 under the seismic conditions to see that they work
8 before -- obviously they worked before, that's your
9 functional test? They work afterwards, after the
10 thing's gone through it. And you test them again,
11 or you just -- that's what I'm trying to get at.
12 Whether it's valves, whether it's electric
13 actuators, whether it's control cabinets --

14 MEMBER SIEBER: Diesel generator.

15 MEMBER BROWN: Yes, all those are huge.
16 So, those won't fall --

17 MEMBER SIEBER: They won't test them.

18 MEMBER BROWN: They won't test those, I
19 recognize that, and it will be done by analysis.
20 But the rest of the control functions and all of
21 that other type stuff that you have to use in order
22 to make sure something's going to happen after the
23 fact for your passive components, is you know, that
24 the passive systems have operated, and now you need
25 something else subsequent to that.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 Or, is it supposed to continue operating
2 anyway. I mean, the plant's not supposed to crumble
3 under a seismic event. It's supposed to be useable
4 after that.

5 MR. DEEVER: Right. Components need to
6 be, remain functional, after an SSE, of course.

7 MEMBER BROWN: So, what I got out of it,
8 you're not -- you're just going to kind of analyze
9 these things, and not test them. That's what I got
10 out of that.

11 MR. DEEVER: No, not necessarily. A
12 good example of something we're doing, like the
13 control rod blades. We actually do physical testing
14 with offset components based on seismic motions, and
15 you know, that we have bounded. And so, we will do
16 physical testing insertion of blades, and drives,
17 under scram conditions under a seismic event.

18 You know, we don't shake the building,
19 but we offset the components and make sure the
20 components can be inserted. So, you know, where
21 it's important, we do testing. You know,
22 particularly in more dynamic conditions like that.

23 MR. WAAL: You know, generally, what
24 happens too, is you evaluate what the requirements
25 are for the component, and let's say for example,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealgross.com

1 you have something like the main control board,
2 which is very large. It may be a combination of
3 analysis and test. You analyze the structure to
4 show that it meets that stress requirements and
5 maybe frequency requirements --

6 MEMBER SIEBER: Test all the parts.

7 MR. WAAL: -- and then you test the
8 parts so that they can withstand the seismic
9 environment when they're installed in the structure.

10 Or, if you have a valve that has to
11 operate during a seismic event, not an exceedingly
12 large valve, you can do a shaker table test to show
13 that it operates during a seismic event. And that's
14 all in accordance with the industry standards, the
15 IEEE standards for qualification of equipment.

16 MEMBER BROWN: Do they require the test
17 to be done for -- for instance, a lot of the
18 cabinets that you have for the instrumentation,
19 reactor instrumentation, they've got to work before,
20 they've got to work during, they've got to work
21 after.

22 MR. WAAL: Right. Right.

23 MEMBER BROWN: What -- I would expect
24 those to be tested, and I would have expected
25 somebody to have a list that says, these items will

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 be tested. And I didn't see any of that in this
2 document at all. And it's the only place I would
3 guess I would have expected to see it, since this is
4 components, not the rest of cloud diagrams and
5 stuff.

6 MR. BAUCOM: I think it depends on the
7 requirements for the equipment. Seismic Category I
8 and it needs to be -- it needs to operate before,
9 during and after an event, that's included in the
10 specification for the equipment.

11 MEMBER BROWN: But we're not going to
12 know that when we determine whether the application
13 of satisfactory, or what-have-you, when we give our
14 Betty Crocker, Good Housekeeping Seal of Approval.

15 MR. BAUCOM: Section 3.11 contains a
16 list of equipment subject to qualification. And in
17 there, the EQ program does make reference to it, but
18 it doesn't -- well, I'm going to be careful on the
19 revision of the DCD that I'm speaking to. But, it
20 does make reference that seismic and dynamic is part
21 of an equipment qualification program in general.

22 So, there is a list of equipment in
23 Section 3.11.

24 MR. DEEVER: But we don't specify
25 whether it's test or analysis.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. BAUCOM: No, we don't. But we do
2 itemize the equipment that requires it.

3 MEMBER BROWN: What I'm looking for is
4 what's going to be tested and what's not and how
5 that decision would be made, or at least see how the
6 -- what the thought process would go. Some stuff, it
7 seems to me, has to be tested.

8 CHAIRMAN CORRADINI: That wasn't -- we
9 did -- I guess to put it differently, it wasn't
10 obvious from the section to determine that. Is
11 there somewhere we can look so we can understand it?

12 MR. BAUCOM: That's fine.

13 CHAIRMAN CORRADINI: That's what I think
14 you're asking.

15 MEMBER BROWN: Well, I just -- my
16 interest in this type of stuff is, you'd like to
17 know going in are they going to test it? There's a
18 lot of new equipment if they're -- that they're
19 proposing. This entire plant is run off of
20 computer-based systems, displays, controls,
21 everything. And that's fine. Not a problem.

22 But how are you then going to take those
23 designs, which have not been fundamentally tested in
24 this environment before, how are you going to bring
25 those forth and show that they meet the requirements

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 or the criteria. And I can't think of any
2 circumstances, other than the diesel generators or
3 turbine generators, where I would be comfortable
4 with not seeing a fully functional definition of
5 what's going to be tested.

6 MEMBER MAYNARD: Especially for
7 electrical cabinets and equipment.

8 CHAIRMAN CORRADINI: Absolutely.

9 MEMBER MAYNARD: Now the staff, I don't
10 know if they're going to -- typically the staff does
11 the seismic qualification review and I don't know if
12 you guys are going to cover that, or is that part of
13 the DCD stage, or is that part of the seismic?

14 MEMBER SIEBER: COL.

15 MR. PATEL: My name is Chandi Patel.
16 Yes, there is a section 3.9.2 in that we do look at
17 the, you know, seismic qualification of equipment
18 and component and you know, metallurgy and other
19 things, this afternoon.

20 MEMBER MAYNARD: And as part of that
21 review, do you review whether they've done analysis
22 or whether they do testing, and whether you accept
23 their rationale for what they've chosen to do?

24 MR. PATEL: Well, I will have to get to
25 the reviewer. I'm a project manager, so I don't get

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 in that much detail. So, this afternoon, we should
2 be able to answer that.

3 MEMBER BROWN: I didn't see that is
4 3.29, so I didn't do an exhaustive review. I went
5 back to 3.10 where it paid attention to the
6 electrical stuff. And I went after -- and that's
7 what I went and looked at in more detail.

8 So I mean, the bottom line I take out of
9 this, is right now, there's no -- correct me if I'm
10 wrong, is that there's no definition of what will be
11 tested or not. There's it will be tested or
12 analyzed, there's a list of systems, but there has
13 not been a definition of what falls into what falls
14 into what category.

15 CHAIRMAN CORRADINI: What falls into
16 what category. Are we hearing that right?

17 MR. BAUCOM: I think if you look, an
18 explicit definition is not.

19 MEMBER BROWN: And that's really what
20 I'm looking for.

21 MEMBER SIEBER: That's consistent with
22 past practice. There would -- if you had an
23 electrical cabinet, you may test relays on a shake
24 table. The cabinet, you may analyze. And so
25 there's often, or sometimes a mixture of both.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER BROWN: I mean, for example,
2 there's a lot of -- people make relays for seismic
3 qualification, they're rotary relays. Everybody
4 thinks they're fine. And we use those in the Navy,
5 but you go find -- run a shock test on those, and
6 you'll find out that they'll close contacts for any
7 where from 30 to about 70 milliseconds. Well, that
8 can be disastrous if certain things happen under
9 those circumstances.

10 And that's why even though they build
11 the part, theoretically to meet a seismic or a shock
12 requirement, whatever you want to call it, that
13 doesn't mean it will perform that function
14 satisfactorily inside of a larger component. It
15 doesn't always work that way, based on orientations,
16 et cetera, residences, whatever goes on. And it
17 could be -- could cause problems.

18 So, there's small parts, there's big
19 parts. And where you want electrical isolation or
20 relays are used, and therefore, they become
21 critical, contacts, you know, how connectors are
22 done, how tightly are they locked in. You start to
23 slide circuit cards in and out, it doesn't take much
24 to dislodge them and all of a sudden, your displays
25 or your protection function don't work right or

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 don't work at all.

2 MR. DEAVER: Or do.

3 MEMBER BROWN: Or do, and so do unusual
4 things. That's another way of phrasing it.

5 MR. DEAVER: Well, what you're talking
6 about it, how -- you know, considerations that are
7 required in the specification of how do you qualify.

8 MEMBER BROWN: That's -- I think that's
9 -- personally that's what I'm interested in seeing.
10 And I agree with John, that's what my understanding
11 of past practice is, and that's what we'd like to
12 see in these circumstances.

13 MR. DEAVER: And that's a level of
14 detail that DCD doesn't get into.

15 CHAIRMAN CORRADINI: Where would we
16 expect to see that level of detail?

17 MEMBER SIEBER: COL.

18 CHAIRMAN CORRADINI: Is it the COL
19 stage?

20 MEMBER BROWN: I mean, these are
21 components used --

22 MEMBER SIEBER: Yes, you're buying them.
23 You're buying them. You have to -- you buy at the
24 COL stage. And that's where you specify how you're
25 going to achieve seismic qualification.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 CHAIRMAN CORRADINI: So, can the staff
2 help us there just so we understanding.

3 MS. CUBBAGE: I mean, I think we're
4 relying on regulatory guides and IEEE standards,
5 specifically IEEE 344 talks about seismic
6 qualifications pursuant to equipment.

7 CHAIRMAN CORRADINI: But it would be at
8 the COL stage where the equipment is specified that
9 one would have to make the determination?

10 MR. ABID: Sir, I believe -- let me --
11 my name is Mohammed Abid. IEEE 344 1986 NRC noticed
12 that reg guide 1.100, revision 2. And that lays out
13 pretty much how the testing and also the analysis be
14 performed for the components.

15 We're talking about switch gears -- I
16 mean, the relays and all those, I mean, they're
17 tested pretty much. And the rest of them are like
18 switch gears, they're analyzed by analysis.

19 There's a sequence in IEEE 3.23 where EQ
20 is, and that request for the Class IE items, where
21 you know, they go through the thermal aging, a lot
22 of mechanical aging, and then it goes through the
23 seismic analysis. If it qualifies good for
24 functional requirements during and after the seismic
25 event.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 So, I think 344 has, I mean, it's pretty
2 clear in that.

3 CHAIRMAN CORRADINI: Can you say it
4 again?

5 MR. ABID: IEEE 344, 1986, has been
6 endorsed by NRC.

7 MEMBER BROWN: 344, and I'm trying to
8 remember, I can't quite. When you do shake testing
9 on the electrical equipment --

10 MR. ABID: Right.

11 MEMBER BROWN: -- you have -- they do
12 that under load, so you can see what actually
13 happens?

14 MR. ABID: It has to be. It depends
15 upon the classification of the component. If it's
16 required for --

17 MEMBER BROWN: IE.

18 MR. ABID: -- the site's IE, then it has
19 to.

20 MEMBER BROWN: Only required for IE,
21 right?

22 MR. ABID: If it has -- it has, supposed
23 to perform that function, yes.

24 CHAIRMAN CORRADINI: But does it provide
25 criteria as to whether you do the test or analysis.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 I guess that's been the question we've been trying
2 to get at.

3 MR. ABID: I mean that, IE should answer
4 that. We are still in the design stage. If it is
5 required to test, it has to be tested, I think. I
6 don't know, you have to help me out with that. But
7 I know we can tell what standards are used to do the
8 testing.

9 THE REPORTER: Your name please?

10 MR. ABID: Mohammed Abid.

11 MEMBER BROWN: Do you ever look at the
12 submissions of analysis and say, we really think we
13 need a test on this one, and go back? I don't
14 recall any RAIs like that, but there might be some.

15 MR. ABID: I mean, testing is always
16 better than analysis. Let's put it this way. But
17 if it cannot be performed, if the test cannot be
18 performed, analysis has to meet the requirements of
19 the regulatory guidance and that should be. That's
20 what we had in the industry standards so far, all
21 the plants have gone through that for the
22 qualification.

23 MS. CUBBAGE: And I know you guys don't
24 like it when I put you off to another chapter, but
25 this is part of the ITAAC verification. They're

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 required to do test and/or analysis to demonstrate
2 that they've -- the facilities were constructed to
3 perform, da, da, da, da, da.

4 MEMBER BLEY: Infamous Chapter 14?

5 MS. CUBBAGE: Yes, Chapter 14. So I
6 know there have been RAIs in Chapter 14 that speak
7 to whether something's going to be a test, or an
8 analysis, and whether we need to specify one or the
9 other, or whether in some cases, it's appropriate to
10 say, test or analysis in accordance with whatever
11 the standard is.

12 So, you know, we can try to get some
13 information to you over the course of the day here,
14 or we can try and hit that when we talk about the
15 ITAAC process.

16 MEMBER BLEY: Let me sneak in a question.
17 I can wait for the ITAAC process if that's where it
18 comes up. If they're doing analysis rather than
19 testing, wouldn't that be done at this stage rather
20 than at the ITAAC stage?

21 MS. CUBBAGE: Well, they have to actually
22 procure equipment before they can qualify it.

23 MEMBER BLEY: Okay, fair enough.

24 MEMBER MAYNARD: I do know that for
25 existing plants, there have been cases to where the

1 NRC staff did not agree with the analysis and that
2 testing had to be done to finish the qualification,
3 but that was existing plants.

4 MEMBER BLEY: At what stage was that
5 decision made?

6 MEMBER MAYNARD: Well that --

7 MEMBER SIEBER: During construction.

8 MEMBER MAYNARD: -- during the
9 licensing, that's when we were doing the licensing
10 as we were building it and refusing everything. And
11 it was before the plant got built, or finished, but
12 it was, or licensed to operate. But it was in the
13 final stages.

14 MEMBER BLEY: Before we did design
15 service.

16 MEMBER MAYNARD: It was in the final
17 stages of construction.

18 MEMBER BROWN: That's kind of late, isn't
19 it?

20 MEMBER SIEBER: That's the way --

21 MEMBER BROWN: I know that's the way it
22 used to be. I know that's the way it used to be.
23 But the way it used to be is also fairly cumbersome
24 from the licensee and others knowing what they have
25 to do in keeping their costs under control. I mean,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 you don't want cost and time to bring a plant on
2 line to start getting up into the 15-year time frame
3 as opposed to you should go back and look in the
4 '60s and stuff, it was a six-year time frame roughly
5 from licensing to plant operation.

6 MS. CUBBAGE: Right. Well, certainly
7 with the Part 52 process, the regulations that we
8 need to resolve, safety issues prior to certifying a
9 design. So, by confirming that these equipment will
10 qualified to appropriate standards, that's the basis
11 for our finding of reasonable assurance.

12 MEMBER BROWN: I'd still like to have
13 some definition of what's going to be tested and
14 what's not. I'm just skeptical.

15 CHAIRMAN CORRADINI: We're going to have
16 to wait until Chapter 14 as well.

17 MEMBER BROWN: I could -- I mean, if --

18 MEMBER MAYNARD: Well, I think some of
19 that's still going to be at the COL stage, because
20 again, the equipment, until that is finalized,
21 purchased, at that stage, I think some of it will be
22 a COL.

23 MS. CUBBAGE: When you say COL --

24 MEMBER SIEBER: If you would do that now,
25 you would have to buy the equipment to test it. By

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 the time you installed it, it would be obsolete.

2 MEMBER BROWN: Yes, but why couldn't --
3 say that again?

4 MEMBER SIEBER: In the six or seven years
5 it would take from the testing of a prototype until
6 you actually install it, chances are the model
7 number or a design change are pretty big.

8 MEMBER BROWN: I don't know. I mean, if
9 you read through this thing, they talk about pieces
10 that are, gee, we know how to use them, therefore,
11 we've used them before and past data shows they're
12 okay, so that we ought to get on to the business.

13 MEMBER SIEBER: Containment, penetrations
14 fall into that.

15 MEMBER BROWN: If something changes over
16 a seven or eight year period, then the test data is
17 no good. So that seems kind of like a losing
18 proposition. I don't mind waiting until ITAAC
19 Chapter 14, now I know what ITAAC is.

20 CHAIRMAN CORRADINI: Well, that's the
21 start of it. Amy was going to say something to
22 finish off.

23 MS. CUBBAGE: I mean, yes, it's a two-
24 edged sword here. I mean, there's the staff, needs
25 to decide they have enough information on the design

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 to reach a safety conclusion, and we also need to
2 decide if we have enough ITAAC to verify that the
3 facility's been constructed in conformance with the
4 design we've certified. So, it's a two-part thing.
5 And Chapter 3 is where we talk about the standards
6 and the criteria.

7 MEMBER SIEBER: Right.

8 MR. DEEVER: Just one last statement.
9 When we go out and actually procure equipment, in
10 some cases, the equipment has been previously
11 qualified either by test or whatever. And so it is
12 somewhat dependent on the procurement process as to
13 in come cases which way it goes. It could be a
14 prior test, or they need a new test, or maybe
15 analysis.

16 MEMBER BLEY: I have no problem with it,
17 prior tested, but it better be, look exactly the
18 same down to where the bolts are located, and how
19 many cards are in the cabinet and where the switches
20 are. It's very dependent upon location of
21 components and their restraint. If somebody changes
22 in between, then you have to --

23 MR. DEEVER: Yes. I'm talking more down
24 to the basis component level.

25 MEMBER BLEY: As opposed to assemblies.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. DEEVER: Yes.

2 MEMBER BLEY: Well, I mean, but you can't
3 qualify an assembly based on the qualification of
4 five parts that go into the assembly. It doesn't
5 work very well. Well, you know where I'm coming
6 from.

7 MR. BAUCOM: I think we've beaten this
8 one up. But, basically, just the --

9 CHAIRMAN CORRADINI: Okay. Turn the
10 page. So you've answered the question there, didn't
11 you?

12 MR. BAUCOM: Pardon?

13 CHAIRMAN CORRADINI: On the slide, you --
14 no, the one I just turn --

15 MEMBER SIEBER: The next slide.

16 CHAIRMAN CORRADINI: One slide next.

17 MR. BAUCOM: Well, this one was actually
18 aimed at supports.

19 CHAIRMAN CORRADINI: Okay.

20 MR. BAUCOM: One more slide, Jerry.

21 MEMBER BROWN: You mean supports, by you
22 mean pipe hangers or?

23 MR. BAUCOM: Brackets into the --

24 MEMBER BROWN: Mechanical stuff.

25 MR. BAUCOM: Yes, mechanical stuff.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 CHAIRMAN CORRADINI: Oh, okay.

2 MEMBER SIEBER: Right.

3 MR. BAUCOM: But the intention's to test
4 the supports with representative equipment installed
5 so you've got the, you know, you don't have to try
6 to simulate the dynamic load.

7 MEMBER BROWN: You made a statement about
8 you don't rely on experience. You've said it again
9 here. But yet, on page -- I'm looking at the SER
10 GEH stated that it "follows the methods outlined in
11 IEEE 344 when existing test data or experience data
12 are available, the equipment database is reviewed to
13 determine the previous testing experience meets or
14 exceeds the new requirements."

15 And yet, earlier, you said you're not
16 going to do that.

17 MR. BAUCOM: That was actually the
18 subject of an RAI.

19 MEMBER BROWN: I know. That's what I'm
20 reading. That's what I'm reading, but --

21 MR. BAUCOM: We responded to that by
22 saying we will not use actual experience in some
23 later revs of the DCD.

24 MEMBER BROWN: Okay. So I'm going to
25 hope when I finish reading the rest of this that the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 staff, that that shows up. I saw it in one place,
2 but I didn't see it in the other, so.

3 MR. PATEL: Again, my name is Chandu
4 Patel. I know what you are talking about. We -- if
5 you go a little later, in after all the discussion,
6 we said GE has agreed not to use experience as a,
7 you know, criteria.

8 MEMBER BROWN: I will go look for that.

9 MR. PATEL: It's like RAI 2, 3.10 to
10 3.40. You know, it's just, I know it's really long
11 going this discussion back and forth. We have so
12 many back and forth in this issue. You know, so
13 it's a little long before you get to the conclusion.

14 MEMBER BROWN: Okay. All right. Thank
15 you.

16 CHAIRMAN CORRADINI: Go ahead.

17 MR. BAUCOM: Start Section 3.11. Section
18 3.11 provides the requirements for the environmental
19 qualification of the mechanical and electrical
20 equipment. The conditions that are applied there
21 are used to involve the most limiting design
22 conditions that can be present.

23 We do specifically include all three
24 categories of 50.49(b)(1), (b)(2) and (b)(3)
25 equipment in the EQ program. And there is a table

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 3.11.1, does identify specific equipment that will
2 be included in the EQ program. The fundamental
3 requirement is that equipment in a harsh environment
4 must be able to function properly during any design
5 basis accident conditions.

6 We consider the range of --

7 MR. WALLIS: When you say function
8 properly, is this some kind of probability of
9 success in functioning, or is it --

10 MR. BAUCOM: No, it needs to meet its
11 intended function.

12 MR. WALLIS: Yes. But you can never
13 guarantee 100 percent probability that it will work.
14 I mean, 100 percent probability 1 that it will work.
15 What does function properly mean?

16 MEMBER SIEBER: It's deterministic.

17 MR. WAAL: I think it means that when
18 they put it through the testing program --

19 MEMBER SIEBER: It passed.

20 MR. WAAL: -- it met the qualification,
21 they show that how it operates before the test
22 program, during and after and it meets the --

23 MR. WALLIS: Then you have a question of
24 how many tests to you need in order to be
25 statistically significant? Or do you just test it

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 once?

2 MEMBER BROWN: No, it's a deterministic
3 test. You go, you shake it --

4 MEMBER SIEBER: You do it once, it passes
5 or fails.

6 MR. WALLIS: There's no such thing.

7 MEMBER BROWN: Well, that's the way it's
8 done. I mean, you run a test, you shock it five or
9 six times, and you make sure that it -- or a seismic
10 test, or whatever the spectrum is --

11 MR. WALLIS: Testing one bolt is good
12 enough to show --

13 MEMBER BROWN: I didn't say a bolt. I'm
14 just -- I'm speaking of a larger assembly or when I
15 look at protection equipment, for instance. They
16 test it. You shake it in multiple plains and then
17 you make sure it worked before, it doesn't shut
18 anything down, or not work during, and then it
19 provides its protection function afterwards.

20 If it does, then that's considered the
21 gold standard. It's not done 500 times to come up
22 with a statistical basis, or at least that's my past
23 experience.

24 MEMBER BLEY: Mine too.

25 MEMBER BROWN: Is that anything

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 consistent -- inconsistent, oh, okay. Thank you.

2 MR. WAAL: And there is generally, you
3 know, there is one test item to be tested for an
4 instrument, but the testing parameters have some
5 margin built in to take into account variations in
6 the test and variations in operating conditions so
7 that you have a high probability. It's not one, I
8 know, that the equipment will operate as installed,
9 or as intended when it's installed in the plant.

10 MR. WALLIS: There's a high probability.

11 MR. WAAL: When you look -- you cannot
12 guarantee probability of one.

13 MR. DEEVER: I think along with that,
14 there's a lot of redundancy in the equipment and
15 functions, so it's all factored in on the big
16 picture. Not to say it completely can't fail.

17 MEMBER BLEY: You guys just said
18 something that bothers me a little. From what I've
19 seen of these kind of tests, they aren't done enough
20 by any means to establish a failure rate under this
21 insult condition. They're done enough to show that
22 it works and no a whole lot more, and sometimes
23 that's not more than one time. So, to make a claim
24 that there's a high probability of success, I really
25 want to know what that's based on.

1 MR. WAAL: Well, like I said, because of
2 the margin that's given in the test parameters,
3 which is sufficiently larger than what the design
4 parameters are. It shows that that test item can
5 meet those design conditions. And the margin for
6 example, I think it's ten percent margin on seismic,
7 is supposed to cover variations in the design of
8 manufacturing.

9 MEMBER BLEY: Has there been enough
10 testing to convince anyone that that's the case?
11 That in fact, you need one or two samples to gain
12 confidence that it covers the manufacturing
13 variable.

14 MR. WAAL: Well, I don't think that's the
15 intent of these industry standards.

16 MEMBER BLEY: I don't think so either.
17 But we're claiming that it's giving us this fairly
18 high confidence, and I'm wondering what that's based
19 on. It's based on the margin.

20 MR. WAAL: Right.

21 MEMBER BLEY: On the test, not any way
22 sampling to see that you're covering manufacturing
23 variability.

24 MR. WAAL: Right.

25 MEMBER BLEY: I thought I heard that

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 right. Okay.

2 MR. DEY: My name is Pijush Dey, GE --

3 CHAIRMAN CORRADINI: Microphone.

4 Identify yourself please.

5 MR. DEY: This is Pijush Dey, General
6 Electric Hitachi. On that topic of margin and the
7 confidence limit like on the testing, my experience,
8 I had that same. They do say, for example, required
9 response spectra in the seismic test, and the test
10 response spectra, TRS level, generally is very high,
11 higher level than the RRS level.

12 And they do test multi-access. Some of
13 the time you do not need multi-access test. They do
14 three axial tests on the two axial tests. And that
15 has a lot of, you know, high margin out of that
16 test.

17 And they do the shake table tests --

18 MEMBER BLEY: I'm sorry. I didn't
19 understand.

20 MR. DEY: Shake table tests, and they do
21 in the, you know, 50(b) cases, or 3SSC cases, so
22 they do test more than one or two, or sometimes as
23 they write the different specification based on that
24 they do the testing.

25 And I've seen tests in the Wiley Lab in

1 Alabama, the big structure, the valves and the
2 cabinets, et cetera, that you know, has -- after
3 testing, we inspect visually any damage. It's -- we
4 put it in the bench and it was simulated as the,
5 just like in the plant how it functions.

6 And they do apply the seismic spectra
7 higher level in that. And after the testing, we're
8 going to go back and look at the visual inspection
9 basis any damage or anything happen and we see that
10 it is still functionable they way it was intended.
11 So that's done, actually.

12 CHAIRMAN CORRADINI: Go ahead.

13 MR. BAUCOM: Conditions for qualification
14 do consider all the thermodynamic conditions
15 present, temperature, pressure, humidity as well as
16 radiation and chemical. And the qualification, I
17 think we beat this one as well, is in accordance
18 with IEEE-323 as it's been endorsed by the
19 applicable reg guides for harsh environment and keep
20 it duty safe.

21 Loss of HVAC is considered as a part of
22 the design basis. Because there are no safety-
23 related HVAC systems within the ESBWR.

24 MEMBER STETKAR: How did you determine
25 your design qualification temperatures for equipment

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 in the reactor building and control building for 72
2 hour response after -- with no HVAC? In particular,
3 the rooms in the reactor building that have a DCIS
4 cabinets and remote check amp panels and the
5 invertors? I notice that the design temperatures
6 tend to be 122 Fahrenheit, with the exception of the
7 rooms that I guess have the invertors, those are
8 145.

9 I saw you had heat loads, I kind of read
10 through Appendix 3.H, and I saw you had heat loads
11 specified for those rooms. But since you don't have
12 the equipment yet, are those just nominal heat loads
13 for now, or design heat loads? Or, how do you know
14 what the heat input to those areas are?

15 Because it's kind of a, you know,
16 chicken and the egg sort of process, that you
17 specify that the equipment has to meet 122 degrees
18 Fahrenheit, the vendor will say, yes, indeed. It
19 meets 122 degrees Fahrenheit. You go measure the
20 temperature in the room, and it's, you know, 147
21 degrees Fahrenheit because the vendor's equipment
22 put out more heat than you estimated that it would
23 be put out. I was curious how that process works.

24 MR. DEEVER: Well, at this stage, what
25 has to happen is that people have to estimate the

1 heat loads based on the expected equipment and you
2 know, the information available on equipment. So,
3 those heat loads at this point, would be a process
4 is, to bound those such that we understand them.

5 Then basically, understanding the heat
6 load, then they can do a temperature analysis.

7 MEMBER STETKAR: But these are modest,
8 relatively modest -- I mean, we design equipment for
9 an existing power plants to higher temperatures than
10 this. You say that we're bounding the heat loads,
11 we're actually estimating pretty modest heat loads
12 in these rooms.

13 And in fact, let me kind of follow-up on
14 it. There are tables that show how the heat loads
15 change as a function of time. And in one location,
16 for example, 17-1/2 kilowatts, heat load for the
17 first two hours drops to 2 kilowatts after two
18 hours. In another location, 5.7 kilowatts for the
19 first two hours drops to 4.7 from 2 to 24, and then
20 it drops to 3 kilowatts after 24. What design
21 features absolutely guarantee that those heat loads
22 indeed will shut off and drop to those values at
23 those times?

24 Because that's important. If they don't
25 drop to those values, then the equipment

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 qualification must be much different, should it?

2 MR. DEEVER: Well, what's bounding or
3 limiting here is our battery power. In most cases,
4 there's some functions that will operate up to 24
5 hours and there simply isn't enough power to operate
6 those components any further.

7 So, to a large extent it's bounded by
8 our ability to operate the equipment.

9 MEMBER STETKAR: It's bounded by the
10 design assumption that you have to assume that the
11 batteries do fail. If they don't --

12 MR. DEEVER: It's not necessarily a
13 failure, it's --

14 MEMBER STETKAR: If indeed they last
15 longer than that time, then the heat loads would be
16 substantially longer, extended to longer durations,
17 wouldn't they? In other words, if the design is
18 based on the assumption that at 2.0 hours, the heat
19 load drops catastrophically by a factor of oh, 8-
20 1/2, something must be shutting off that heat load
21 positively or your design should, I would think,
22 account for the fact that indeed, that heat load
23 might persist.

24 MR. DEEVER: Well, the basic philosophy
25 is to be able to conserve battery powers. So, at

1 certain stages, you know, after they've been
2 monitoring a function, and it's no longer necessary
3 to monitor, rather than just continue to operate it,
4 they'll shut it down to conserve batteries.

5 MEMBER STETKAR: They being the
6 operators?

7 MR. DEAVER: No, this is all automatic.

8 MEMBER STETKAR: Ah. The automatic
9 system. That's what I was asking. What design
10 features shut these things down. I guess we haven't
11 seen -- is this all in Chapter 7 of the DCD, how
12 this stuff works?

13 MR. DEAVER: That's principally where
14 it's at, yes.

15 MEMBER STETKAR: I guess we'll wait until
16 seven then.

17 CHAIRMAN CORRADINI: Go ahead.

18 MR. BAUCOM: Some equipment is affected
19 by -- potentially affected by submergence and the
20 qualifications for those programs do include the
21 actual submergence water chemistry and the
22 operability requirements that be met. And
23 additionally, radiation sources from any conditions
24 and the resulting integrated doses are included in
25 the EQ program for equipment aging and various

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 conditions.

2 The final section, 3.13, we do not
3 explicitly have a Section 13 in the DCD.

4 MEMBER STETKAR: I was looking for it.

5 CHAIRMAN CORRADINI: Sorry about that,
6 but I saw it was included and I just asked where it
7 was.

8 MR. DEAVER: The material that is --

9 MEMBER SIEBER: -- just say, go some
10 place else.

11 MR. DEAVER: The sequence was that --

12 CHAIRMAN CORRADINI: That's fine.

13 MR. DEAVER: Okay. You understand.

14 MR. BAUCOM: That material is covered in
15 Section 3.9, so for this presentation, we elected to
16 defer to 3.9.

17 CHAIRMAN CORRADINI: Good.

18 MR. BAUCOM: 3.10 and 3.11 do provide the
19 basis for qualification of the equipment for
20 seismic, dynamic and environmental conditions in
21 accordance with the applicable reg guides.

22 CHAIRMAN CORRADINI: Any questions by the
23 members?

24 Thank you very much. And we will take a
25 break until 10:45.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 (Off the record from 10:29 a.m. to 10:45
2 a.m.)

3 CHAIRMAN CORRADINI: Okay. Let's get
4 started. Mr. Patel, are you the lead on this?

5 MR. PATEL: Yes, sir.

6 CHAIRMAN CORRADINI: Okay. It's all
7 yours.

8 MR. PATEL: I guess it's still morning.
9 Good morning. My name is Chandu Patel. I'm a lead
10 project manager for the review of Chapter 3. What I
11 will do in the beginning is just to give you an idea
12 of what the broad picture of how we handle Chapter 3
13 here, because there are so many sections and so many
14 reviews involved, so I'll just walk you through this
15 general idea, and then we will go into specific
16 sections.

17 This one just gives you the detail of
18 each section and the title which is easy reference
19 and by now you have an idea of most of the things we
20 have followed here. So, I will not go much into
21 detail with this thing.

22 These are the people. I thought it
23 would be a good idea for the subcommittee to know
24 who are the real players. I'm just a messenger.
25 What I'm going to do is, I'll try to relay the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 message. And if there is any tough question which I
2 cannot handle, I'll point to those guys.

3 This is the important slide, and this is
4 just to set the stage for you guys. I know some of
5 the members aren't here for the numbers, but this
6 will give you some idea.

7 CHAIRMAN CORRADINI: We're really not
8 engineers.

9 MR. PATEL: I would like to have, you
10 know, if you guys are going to ask the questions,
11 where would be the focus and what are the areas
12 where we still have open questions. At least we
13 have -- that was the intent of this slide.

14 Originally, we had about 583 RAI totals
15 so far until about a week ago. Now, it's 588. Out
16 of that --

17 (Laughter)

18 MR. PATEL: So far, now we have as of
19 last week, we have 57 open RAIs. And out of that,
20 you can see, in Section 3.8, we have 19. So, we
21 did --

22 CHAIRMAN CORRADINI: That's seismic?

23 MR. PATEL: Yes. And that's where we had
24 a lot of questions, of 125 RAIs just in 3.8.

25 The next one is 3.9. And also after 3.9

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 has gone, it goes from 3.1 to 3.96 -- 3.91 through
2 3.96. But, where I would appreciate, I guess, we
3 will concentrate is most of the RAIs still open are
4 in 3.95, you know, which is reactor internals and
5 steam dry issues and flow operation. Those are the
6 more, main in 3.9. Everything else is relatively
7 clean.

8 In 3.6 is the next one, which we have --
9 Dr. Wallis and another, had some questions asking
10 for previous ACRS. And we still have about seven of
11 the issues still open. So, 3.6 is pipe breaking, or
12 location and all that. So, that will be this
13 afternoon.

14 And equipment qualification, 3.11. That
15 one is relatively clean. The only area we have
16 questions outstanding is in the area of the
17 qualification for the radiation environment and the
18 temperature. So, this is just general overview.
19 Now, I'll go to --

20 MEMBER STETKAR: Can I ask?

21 MR. PATEL: Yes.

22 MEMBER STETKAR: This is really quick, I
23 hope. Does this SER apply to Rev 3 or Rev 4 of the
24 DCD?

25 MR. PATEL: Thank you, very much.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER STETKAR: You're welcome.

2 (Laughter)

3 MR. PATEL: No, that's a good thing. I
4 should have said that, you know. The intent -- the
5 way -- okay. The past trouble, this SER was being
6 prepared from -- okay, I had input all the way from
7 March 2007, okay? Or, May of 2007, let's say.
8 Because March of 2007 was when we got Rev 3.

9 So, I had input from May of 2000 (sic)
10 through all the way up to December, January of 2008.
11 And by that time, you already had Rev 4 in house.
12 So, when we started to write, it was supposed to be
13 on Rev 3. And most of the concentrated reviews was
14 on Rev 3.

15 But what I have done, if it makes it
16 easier, instead of making item open and leaves it
17 only Revision 4, we closed it based on because they
18 have already changed something. Like, instead of
19 making item, like confirmatory, we just said, this
20 item is resolved because it's already included in
21 Rev 4. Does that make sense?

22 MEMBER STETKAR: So the document that we
23 received, then is -- pertains to Rev 4 of the DCD?

24 MR. PATEL: As you said, I think you are
25 the one you said, it's three and a half.

1 MEMBER STETKAR: I did say it was three
2 and a half.

3 MR. PATEL: No, no, no. What I did
4 exactly, okay, let me just -- because I know every
5 page of the safety variation.

6 (Laughter)

7 MR. PATEL: Believe me, I have spent
8 quite a lot of time.

9 MEMBER STETKAR: Bless you for that.

10 MR. PATEL: The intent was like, as I
11 said, like some of the RAIs had open, or like
12 confirmatory. And if I could use Rev 4 to close it,
13 I did it. But other than that, we did not discuss
14 anything more detail in Rev 4. Okay. So, Rev 4 is
15 not.

16 MEMBER STETKAR: So, let me -- I'm still
17 trying to understand. Does that, because I was
18 trying to go back and forth from the SER to the DCD
19 and spot check things in the design. Does that mean
20 that you have to now go through, formally go through
21 Rev 4 of the DCD?

22 MR. PATEL: Yes. And give you the --

23 MEMBER STETKAR: For Chapter 3?

24 MR. PATEL: Yes.

25 MEMBER STETKAR: And you have not done

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 yet.

2 MR. PATEL: No.

3 MEMBER STETKAR: Okay. Thanks.

4 MS. CUBBAGE: We're on five. We're on
5 Rev 5 now.

6 MR. PATEL: Let me give you --

7 MEMBER STETKAR: You're at five.

8 MS. CUBBAGE: We're not going to --
9 excuse me, Chandu. Let me just --

10 MR. PATEL: Yes.

11 MS. CUBBAGE: Basically, the SE is
12 written to the design in Rev 3. And to the extent
13 that we could close issues with material that was
14 provided in Rev 4, we did that so that we could
15 provide as much closure as we could in this
16 document.

17 MR. PATEL: And for a fact, an example is
18 this. Like turbine building. If you read safety
19 regulation 4, Rev 3, it says everything is great,
20 like they have Seismic Category II. But all
21 everybody knows now, that in Rev 4, they have
22 changed it and we did not address it.

23 Safety 4.1, we settled the issue.

24 MEMBER STETKAR: Great, thanks. That
25 explains. But now, when you update the SER, it will

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 be updated to Rev 5 of the DCD?

2 MR. PATEL: Yes.

3 MEMBER STETKAR: Okay, thanks.

4 CHAIRMAN CORRADINI: Which is the
5 expectation is, the last Rev.

6 MS. CUBBAGE: We do anticipate there will
7 be some cleanup necessary in a later Rev to address
8 some of the RAIs that are still open. But the
9 design will be as it is in Rev 5.

10 MEMBER STETKAR: Okay.

11 MS. CUBBAGE: Unless an RAI results in a
12 design change.

13 CHAIRMAN CORRADINI: I understand.

14 MEMBER STETKAR: Before we continue, let
15 me just get in one question, because --

16 CHAIRMAN CORRADINI: You already had your
17 one question.

18 (Laughter)

19 MEMBER STETKAR: No, one question I --
20 another question. This is to Amy. I'm like a
21 little terrier who grabs you, you know, by your
22 calf, and never lets go.

23 Back when we reviewed the SER for DCD
24 Chapter 5, I asked a question about why the SER did
25 not contain a review of the main steam isolation

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 valves. And I was told, well, it will be in Chapter
2 10. So, I waited and we got to Chapter 10, and it
3 wasn't in Chapter 10, and you said it will be in
4 Chapter 3.

5 I couldn't find a review of the main
6 steam isolation valve design. I'm not talking about
7 structural design, seismic response, but the design
8 of the valve itself, its operator, the design
9 criteria for closure time, things like that.
10 Similar to things like you've reviewed for squib
11 valves and other parts of the plant.

12 That's not in Chapter 3. So, where are
13 the main steam isolation valves, and for that
14 matter, the main feed water isolation valves
15 reviewed by the staff, since they are -- now I
16 learned they are in fact the Class I, Class II
17 seismic boundary. So, their operation and design
18 should be worked out.

19 MS. CUBBAGE: And exactly which aspects
20 of the design you talking about?

21 MEMBER STETKAR: The operator, the valve
22 type.

23 MS. CUBBAGE: That's not a level of
24 detail we have at this time.

25 MEMBER STETKAR: For the main steam

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 isolation valves? They're described in DCD Chapter
2 5, I think they are. That's why I was looking for
3 it in Chapter 5 of the SER when we started this.
4 And you said, well, no, they're probably in 10. And
5 then we got to 10, well, no, they'll be in Chapter
6 3, and they're not.

7 MR. PATEL: And I do remember your
8 question, believe me. When we were going through
9 Chapter 5, and yes, we did say, we will look into
10 Chapter 3 when we come to Chapter 3.

11 Now, I'm going to say one more thing
12 that Tom Scarbrough's not here.

13 MS. CUBBAGE: He will be this afternoon.

14 MR. PATEL: This afternoon, we will be
15 able to answer your question. Because I asked that
16 question to the staff two or three times.

17 MEMBER STETKAR: Okay. Thanks. I'll
18 wait.

19 MR. PATEL: Because I was fully aware of
20 his question before.

21 MEMBER STETKAR: I'm not talking about
22 the seismic design of the structure.

23 MR. PATEL: No.

24 MEMBER STETKAR: I'm talking about the
25 design of the valve itself, how it works.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. PATEL: Yes. And Tom Scarbrough is
2 the one person who can at least give a little bit.
3 Because we don't really go into so much detail for
4 the operator and you know, detailed reviews.

5 MEMBER STETKAR: Okay.

6 MR. PATEL: But at least he will be the
7 most qualified person.

8 MEMBER STETKAR: Okay, thanks.

9 MS. CUBBAGE: And I think with respect
10 tot he level of design detail that's currently been
11 provided, I think GE would have to chime in on that.

12 MR. PATEL: Yes. But maybe we will do
13 this afternoon.

14 MEMBER STETKAR: By the way, I didn't
15 have any particular questions about the design.

16 MR. PATEL: No.

17 MEMBER STETKAR: I just want to make sure
18 the staff actually looked at it somewhere and there
19 was some record that you have.

20 MR. PATEL: All right. Now I'll go
21 through specific sections.

22 MEMBER ARMIJO: Before you do that, I
23 want to make sure I follow you. In the SER, you had
24 a reference to an RAI 3.2-7 related to lack of
25 detail on PNIDs. And is this -- in your list of

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 open RAIs, there's no 3.2. Is 3.2-7, is that now
2 resolved?

3 MR. PATEL: Yes.

4 MEMBER ARMIJO: So, you have adequate
5 detail, or you're going to get adequate detail at
6 some time so you can look at the PNIDs sufficiently
7 to do your review?

8 MR. McNALLY: This is Rich McNally from
9 engineering mechanics branch. And I believe GE has
10 made a commitment that we can receive final PNIDs.
11 We will also have the ability to audit, as part of
12 DAC closure, to look at design specifications, which
13 would actually include the basis for the design
14 classification breaks.

15 This will be an on going change until
16 the as-builts are complete. So, this is really part
17 of detailed design, and will be subject to the
18 future reviews during audits.

19 What we've done here, is a review of the
20 simplified diagrams and --

21 MEMBER ARMIJO: And on the basis of those
22 commitments, you've closed out RAI 3.2-7, you have
23 enough that you can close that?

24 MR. McNALLY: Correct, correct.

25 MS. CUBBAGE: Well, I'll also say that GE

1 Hitachi did provide PNIDs for many, if not all of
2 the systems on the docket. They're not part of the
3 detail of the design certification, the DCD. But
4 they have been submitted.

5 MEMBER ARMIJO: Okay, thank you.

6 MEMBER BLEY: While that issue was
7 brought up, I have a comment about it. The RAI here
8 was requesting something more than the simplified
9 PNIDs to be able to do the classification. I don't
10 recall a similar RAI to be able to do a thorough
11 review of the system so that you could really
12 identify possible problems at the detail level,
13 which is where the problems tend to crop up.

14 MS. CUBBAGE: The reason the PNIDs were
15 actually submitted was because of RAIs that were on
16 Chapter 6 and I believe 9, where we wanted
17 additional detail.

18 MEMBER BLEY: Oh, it was raised.

19 MS. CUBBAGE: Absolutely.

20 MEMBER BLEY: Okay, I hadn't found it.

21 MS. CUBBAGE: -- reactor systems, and
22 balance of plant reviewers insisted on those PNIDs
23 being submitted.

24 MEMBER BLEY: And there was just -- okay.
25 So, they are submitted on the docket to address

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 these issues.

2 MS. CUBBAGE: Yes. They're proprietary
3 and they're not part of the DCD.

4 MEMBER BLEY: The previous comments of
5 the sort, gee, all I had was a very simplified one,
6 and I couldn't address those kinds of things should
7 be cleared up in the future.

8 MS. CUBBAGE: I don't know that we would
9 have, for example, you may be referring to
10 instrument air.

11 MEMBER BLEY: It came up there, but the
12 concern really was really across all the systems.

13 MS. CUBBAGE: Right. But the major
14 balance of plant systems, we have PNIDs for those.
15 We have GDSCS, ICS, PCC.

16 MEMBER BLEY: And they have been reviewed
17 now and it's detail given.

18 MS. CUBBAGE: -- SLC, yes.

19 MEMBER BLEY: For performance?

20 MS. CUBBAGE: Yes.

21 MEMBER BLEY: Okay, thanks.

22 MR. PATEL: For the classification, the
23 systems and structures, I guess we have really
24 discussed quite a bit already about -- there are a
25 couple of issues. And I guess -- let me just, this

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 is Patel talking.

2 I have been in the nuclear industry for
3 almost like 35 years now. And I can go way back to
4 1978, about these safety classification, safety, you
5 know, I and II and III. Now, this is my
6 understanding, if I was a teacher in the class, I
7 would tell -- this is how I will classify it.

8 Category I, is like reactor coolant
9 pressure boundary, or anything required to protect
10 the reactor. It's like defending death. The first
11 defense is reactor coolant pressure boundary. So,
12 that's Category I.

13 The second one, comes like containment.
14 That's the defense, and that's number II. Anything
15 which requires any affluent to get, any release
16 getting out, will be in Category II, Safety Category
17 II.

18 Three, is anything which try to
19 eliminate, I mean reduce, the exposure to the
20 radiation level getting out, will be Category III.

21 And now, same thing type quality group,
22 is just corresponding to pressure boundaries A,
23 Safety Category II is B, and like that, okay. So,
24 that's my understanding and it should be discussed
25 in regularly guide if you go back and they do go in

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 some details.

2 MS. CUBBAGE: Chandu, Rich would like to
3 try that.

4 MR. McNALLY: Yes. I can elaborate on
5 that. 10 CFR 50, really establishes the basis for
6 quality Group A for the reactor coolant pressure
7 boundary, establishes that anything that's small
8 enough that its failure could be overcome by normal
9 reactor coolant make up, would be excluded from the
10 reactor coolant pressure boundary.

11 Anything that's Quality Group A, of
12 course, would have the highest level of quality.
13 It's equivalent to ASME Section III, Class I. It
14 has fatigue analysis applied to it. It's got the
15 highest design requirements imposed on it, the
16 highest material requirements imposed. And so this
17 coincides with the risk informed categorization
18 process.

19 Quality Group B, is a little lower
20 quality, as Chandu indicated. It's typically
21 identified in RG 126. RG 126 really distinguishes
22 between Quality Group B and Quality Group C.
23 Anything that's Quality Group A, B, or C of course,
24 is safety-related.

25 Quality Group B represents ECCS systems,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 containment boundary and anything that's required
2 for safe shutdown of the reactor. Quality Group C,
3 is any support system, or any system that would
4 result in a radiation release in excess of 10 CFR
5 100. So those three quality groups are the highest.
6 They're equivalent to ASME Section 3, Class I, II
7 and III. They're all Seismic Category I.

8 And there's also, in terms of safety
9 class, that GE has indicated, that's based on ANS
10 58.14, which the NRC does not currently endorse at
11 this point. It was considered too broad to endorse,
12 but I am on a committee that is working to get that
13 standard updated to reflect the new reactor designs.

14 And of course, that gets into other
15 components that are not pressure boundary. It
16 should be emphasized that Quality Group A, B and C
17 are really just pressure boundary components and
18 their supports.

19 MR. WALLIS: You mentioned the word, risk
20 informed. But you didn't mention anything about
21 probabilities. So, we assume that somehow this high
22 probability is understood that ASME when they
23 defined these categories and they know what they
24 mean by high probability?

25 MR. McNALLY: Well, I believe these were

1 developed before the PRAs were ever applied. And of
2 course, there is a risk informed approach that has
3 been used now for operating reactors. But we're
4 using a deterministic approach primarily here for
5 advanced reactors.

6 And the RTNSS approach is really more of
7 an illustration of the PRA risk-informed approach.
8 And that does distinguish between the relative
9 importance of various components. And those are
10 thrown into the Quality Group D category.

11 MR. WALLIS: It's never been clear to me.
12 I mean, you get something like out force and you go
13 to the pressure allowed by ASME and there's never
14 been clear to me how that translates into
15 probability of failure.

16 MR. McNALLY: Well, that's --

17 MR. WALLIS: Is that, I think, made at
18 some stage by the staff?

19 MR. McNALLY: That's not my particular
20 area, but I'd say that is handled by the RTNSS
21 process.

22 MS. CUBBAGE: It's a service levels --
23 are you talking about for ATWS, where the that's
24 service level C? So basically, so there could be --
25 this is Amy Cubbage. Sorry.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 Yes, I guess I'm not a mechanical
2 expert, but it's expected that there could be some
3 deformation. They'd have to do inspections before
4 they could start up.

5 MR. McNALLY: I know one issue was
6 brought up related to the importance measures. You
7 raised the question on that. And staff did have
8 recognition of these importance measures. And an
9 example of something that was added because of risk,
10 were the vacuum breaker valves. These were not
11 originally included, but was recognized based on
12 their risk significance as an important safety item
13 and was eventually brought into the program and was
14 categorized appropriately.

15 You know, one major issue here that is
16 really fundamental to what we look at in satisfying
17 GDC 1 and GDC 2, is the importance to risk. The way
18 the criteria reads now, is that it's anything that's
19 important to safety needs to be considered for
20 seismic and also for appropriate quality levels.

21 And industry has emphasized the
22 importance on safety-related components, as they
23 should. But it's also recognized that there's
24 additional components that are important to safety
25 that may not be safety-related. And those are the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 ones that are included in the RTNSS process.

2 MR. WALLIS: The importance to risk
3 measure of something, the importance to safety is a
4 vague term because you don't know what safety is.

5 MR. McNALLY: Correct. So that's a way
6 of helping to quantify it. But as we know, numbers
7 can be manipulated.

8 MR. PATEL: All right. I'll just quickly
9 summarize what we mainly use the RG 1.26 and 1.29,
10 just to assure ourselves that the classification for
11 seismic requirement and also the quality assurance
12 is consistent with the regulatory guide. And our
13 findings was that in general, they are consistent
14 with regulatory guide 1.29. When I say, in general,
15 it's because this one, this ESBWR because of the
16 RTNSS issues, there are some of the, you know,
17 differences in the quality group.

18 And we have still some of the open items
19 related to that. Because it depends on the risk
20 factor. If the system is important for the -- if it
21 is risk-dependent type of a system, then we have to
22 consider, you know, for the quality assurance also.
23 And that is one of the open item.

24 Also, we made sure that there are --
25 there should not be any non-safety building to --

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 adverse impact of the non-safety building on the
2 safety building. Okay. So, just giving the
3 example, say like we had issue with the turbine
4 building earlier. Of course, it was Safety Category
5 II, so there was no problem. But now if they are
6 thinking of making it non-safety, then we will have
7 some of those type of issues still going on.

8 In general, they are in compliance with
9 GDC 1 and 2. Other than there are two, three open
10 items, and I will discussed those few items. The
11 first one is, I think we already discussed about the
12 diesel. We have already discussed this quite a bit.

13 And the second one is the one I'm
14 talking about, basically, RAI 3.2-6, if you look at
15 the safety-relation 14.2, it's all over. Because
16 it's really widespread of the quality assurance
17 purpose. We all have to look at each component,
18 make sure whatever is significant of that system
19 overall, and then decide on the quality assurance
20 purpose. But that's why that open item is there.

21 And the last one, we yearly opened it
22 after we issued the safety-relation for Rev 3. We
23 had no problem with Rev 3. Okay, so this is because
24 of Rev 4 changes.

25 MEMBER STETKAR: I was thinking about

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 something else, but when you look at risk
2 significance for RTNSS determination, is it on an
3 absolute or relative basis? In other words, is it a
4 significance of a system relative to an absolute
5 risk target, for example, 10^{-6} for damage frequency?

6 Or, is it relative to the existing
7 evaluated risk, in other words greater than a 20
8 percent contributor to the evaluated core damage
9 frequency. You understand what I'm asking?

10 MR. PATEL: Richard, do you have?

11 MR. McNALLY: Well, you know, again, the
12 quality groups are really deterministic approach.
13 They're not aligned with a particular probability
14 value. RTNSS is different for Quality Group D.
15 Those are non-safety related components that do have
16 a relative importance. And those are -- can be
17 calculated with the probability of effects would be,
18 should they fail on safety.

19 And the list of those components are
20 designated in the DCD under Chapter 19. That's an
21 evolving list the way I understand it. It's just
22 preliminary at this point and will be added to as
23 the expert panel takes further looks at it. But
24 that's the best we've got now.

25 We've noted that these are primarily

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 just active components and they're being assessed in
2 terms of what impact they would have on safety
3 should they fail.

4 MEMBER BLEY: I have a follow-up question
5 about the qualification process, the deterministic
6 nature. And I admit, I'm not fully up-to-date with
7 how things are done today. Is there any requirement
8 or standard practice that when results of
9 qualification testing are submitted for NRC review,
10 that they see the history of the testing, maybe, if
11 there were several failures, and then changes or
12 something leading to finally a successful
13 qualification, do you see that history, or you just
14 see the certification that component passed the
15 test?

16 MR. McNALLY: Well, seismic and
17 environmental qualifications is not really my area.
18 I'm more concerned with 3.2. I would think that
19 those records would be subject to audit by the NRC
20 staff. I'm not sure that they're really at that
21 point yet, other than we have a list of components
22 that are subject to either seismic or environmental
23 qualification and that those should be comprehensive
24 of all the safety-related components.

25 MEMBER BLEY: We'd be interested in that

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 if it's possible to learn about that.

2 MS. CUBBAGE: Right. Our EQ reviewers
3 will be sitting in front of you this afternoon.

4 MEMBER BLEY: Oh, today.

5 MS. CUBBAGE: Or, yes, today.

6 MR. PATEL: He's here. I guess. Maybe
7 when we get to his section.

8 (Laughter)

9 MEMBER BLEY: Okay. I'll try to remember
10 to ask again.

11 MS. CUBBAGE: He's our EQ, I was thinking
12 about --

13 MR. McNALLY: Seismic.

14 MS. CUBBAGE: Mr. Scarbrough as well.

15 MR. PATEL: Mr. Scarbrough, he's here.

16 MR. McNALLY: At the appropriate moment.

17 MR. PATEL: Yes.

18 MS. CUBBAGE: We'll get there.

19 MEMBER MAYNARD: I want to make sure I
20 understood a statement you made just a little
21 earlier. You said you didn't have a problem with
22 Rev 3, but Rev 4, apparently introduced additional
23 questions.

24 MR. PATEL: Turbine building?

25 MEMBER MAYNARD: Turbine building. Yes.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. PATEL: It was categorized as Seismic
2 Category II as of Rev 3.

3 MEMBER MAYNARD: Yes.

4 MR. PATEL: But in Rev 4, they changed
5 it.

6 MEMBER MAYNARD: Yes. Now, I started to
7 ask a question earlier, it shows you are reviewing
8 as the revs come out or something that has change
9 the conclusion that you had drawn on an earlier
10 revision.

11 MR. PATEL: Yes.

12 MS. CUBBAGE: Absolutely. We actually
13 had RAI milestones in the fall and into January,
14 where we, the staff, made a comprehensive look at
15 Rev 4, and we asked any additional RAIs we felt we
16 needed to, based on the content of Rev 4. And this
17 is a good example. We do have RAIs we've asked on
18 this topic.

19 MEMBER MAYNARD: Because economic -- just
20 if you have two things, they can close issues out,
21 or it can raise new issues that you've already
22 closed. So, I'm glad to see --

23 MR. PATEL: If there is no more question
24 on 3.2, we can move to 3.3.

25 CHAIRMAN CORRADINI: Yes.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. PATEL: I guess for the wind and --

2 MEMBER BLEY: I'm sorry.

3 MR. PATEL: Sorry.

4 MEMBER BLEY: You got way past me because
5 I notice there wasn't a review of 3.1. And I had a
6 simple question about it, because something there
7 just kind of got under my skin. Mostly that's the
8 requirements, but under each one, you have a
9 criterion, and they give a criterion.

10 MR. PATEL: Right.

11 MEMBER BLEY: And then they say, here's
12 our evaluation against the criterion.

13 MR. PATEL: Right.

14 MEMBER BLEY: For example, the instrument
15 and control system meets all these criteria, but
16 there is no such system, and I didn't see an RAI or
17 anything that said, we got to look at this later on.

18 MR. PATEL: No. Let me -- I was the
19 person responsible for 3.1, so I could tell you what
20 I did. I looked at the description in 3.1, and if
21 you see, everywhere they say, for this, they will be
22 discussing particular section. So, and I went
23 through all the criteria in 3.1 and I guess I didn't
24 look at for instrument one. In general, we --

25 MEMBER BLEY: Instrument controls.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. PATEL: Instrument control. Now, I
2 do remember there was one in GDC, I think, 5. I
3 believe. Because there's the shared system, I think
4 for, you know --

5 MS. CUBBAGE: And that's if you have a
6 multi-unit site.

7 MR. PATEL: That's right.

8 MS. CUBBAGE: This is a certification for
9 one unit.

10 MR. PATEL: And that criteria is not
11 applicable here. But other than that, I quickly
12 went through and I did not see any need for
13 discussing here what, you know, if you have any
14 particular question, that should be addressed in the
15 particular, whichever design criteria is applicable,
16 it should be discussed in that section.

17 MS. CUBBAGE: Let me try. We don't have
18 a specific SRP that tasks us in this chapter to do
19 this. All the other SRPs do it. The SRP for
20 Chapter 7, you ensure that the appropriate, right in
21 the SRP, it will say, GDCs X, Y, or Z are applicable
22 here and we make a finding in Chapter 7 that they
23 either have or having met those GDCs.

24 MEMBER BLEY: So, 3.1, really --

25 MS. CUBBAGE: It's a point. It's a

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 point.

2 MR. PATEL: It's just a --

3 MEMBER BLEY: It's a map.

4 MS. CUBBAGE: It's a map.

5 MR. PATEL: Yes.

6 MEMBER BLEY: So, there's no -- okay.

7 MR. PATEL: There's no excerpt, there's
8 nothing.

9 MEMBER BLEY: There's no review of that
10 directly.

11 MS. CUBBAGE: Right. But Chandu went
12 ahead and did a sanity check on it to make sure that
13 everything was being covered.

14 MEMBER BLEY: That was just my -- it
15 doesn't say it will be this well, it says it is.
16 But it's over in the other section where you chase
17 that. Fair enough.

18 MR. PATEL: And just to make sure, what I
19 did, I just looked at past evaluation safety-
20 relation and I was consistent. Whatever they
21 discussed, then I just made a very simple statement
22 saying, this is what we're discussing in sections.

23 Okay. Ready to go next.

24 CHAIRMAN CORRADINI: Yes.

25 MR. PATEL: For wind and tunnel loadings,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 we have discussed this out. They have designed for,
2 first of all, we did use the Regulatory Guide 1.76
3 and as it was pointed out, for tornado wind, they
4 are exceeding the requirement of 1.76. So we did
5 not have any significant problem with any of the
6 issues in this area.

7 There was only one thing which we wanted
8 to make sure and that was the open RAI which we
9 asked them, because the Radwaste Building, it was
10 not originally -- they were not intending to design
11 for the same wind speed of 330 miles per hour, and
12 we had to ask some follow-up questions, and finally
13 they decided to qualify Radwaste Building for the
14 tornado wind velocity whatever they have at (b)(2).
15 And so they issue in Section 3.3, were all resolved.

16 Now there was a discussion earlier --
17 just let me make sure. Yes. There was discussion
18 about ASME standard, and if there any more question,
19 we can discuss more about tornado loadings. But that
20 we also can do in 3.5.3. But is there any question
21 about you were asking about -- stop to discuss about
22 tornado loadings? Or, it looks we don't need to go.

23 CHAIRMAN CORRADINI: We're happy. We're
24 happy.

25 MR. PATEL: Okay, good.

1 MR. WALLIS: I'll ask you about this wind
2 pressure. What do you mean by wind pressure? The
3 pressure varies around a structure when there's flow
4 past it. And you have to know how to calculate the
5 variation of pressure around the structure, not just
6 some pressure somewhere. Do they know how to do
7 that without testing?

8 MR. SHAMS: I'm sorry, what was the
9 question, one more time?

10 MR. WALLIS: If I put a building in a
11 strong wind, I get all kinds of different pressures
12 in different places. I may get a lot of suction on
13 certain places, for instances. Do they know how to
14 calculate those things of any old building of any
15 old shape. I'm not sure that they do without a
16 test. Do they have to put it in a wind tunnel?

17 MR. PATEL: You want to answer, or do you
18 want me to?

19 MR. SHAMS: You want to take a shot at
20 it, go ahead.

21 MS. CUBBAGE: GE's stepping up.

22 MR. RAJENDRA: This is Clement Rajendra,
23 GEH. ASC 702, provides additional factors for
24 shape, height, et cetera, to adjust the direct
25 velocity pressure to the actual forces on the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 building.

2 MR. WALLIS: So, there is a format for
3 doing all this.

4 MR. RAJENDRA: That's correct. And
5 similarly, we have for tornado loads. The BC
6 topical report provides the associated factors to
7 convert to -- from the velocity pressures, to
8 convert that to the actual forces on the building.

9 MR. WALLIS: What is a velocity pressure
10 now? That's not a technical term I'm familiar with.

11 MR. RAJENDRA: Velocity pressure is
12 simply a conversion of the velocity to a pressure, a
13 force. But then how that, the shape of the
14 building, the exposure conditions, all of that
15 factor into a total lateral load that is applied to
16 the building. Those are additional factors that you
17 take that into account.

18 MR. WALLIS: But does this include
19 fluctuating pressures?

20 MR. RAJENDRA: If by fluctuation, you
21 mean gas, that is included.

22 MR. WALLIS: Is this a question of where
23 I should look at the standards and see if it's
24 adequate?

25 MR. RAJENDRA: That is correct.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 (Laughter)

2 CHAIRMAN CORRADINI: I think they'd be
3 glad to get those for you.

4 MS. CUBBAGE: The question while GE was
5 up about the standards in this area, and Mohammed
6 Shams would like to address that.

7 MR. SHAMS: I would like to address Dr.
8 Wallis's question about whether or not ASCE 7
9 process considers the density of the air, or you
10 know, things of that nature. I just wanted to
11 highlight, I'm not going to directly say yes or no.
12 But I'd just would like to highlight that ASCE 7
13 standard has been around for over 30 years. And
14 it's a consensus standard. It's the state of the
15 air for wind calculations. They based a lot of
16 their provisions on wind tunnel testing. A lot of
17 their provisions also were calibrated based on
18 results after storms.

19 So, they went and took all these
20 considerations into account. So, it is a reliable
21 standard to the most of our knowledge.

22 MR. WALLIS: Thank you.

23 MR. PATEL: So we go to the next slide.
24 This is for external and internal flooding. We
25 staff did look at the GDC, Section 3.4.11 for

1 external flooding and internal flooding. The
2 external flooding is from the resulting of natural
3 phenomenon. And there's a statement, I guess, as
4 they discuss in GDC, they have -- they are going to
5 design for the maximum flood level plus one feet
6 above the maximum flood level. So, it will be a
7 kind of a site specific flood level. They have to
8 decide on a plan specific, site specific, and then
9 one feet above that.

10 For the external flooding, there is no
11 concerning.

12 MR. WALLIS: Where does the one foot come
13 from?

14 MR. PATEL: Well, that's what GE
15 decided --

16 CHAIRMAN CORRADINI: It comes from the
17 URB.

18 MR. WALLIS: But the television last
19 night said that the Mississippi might get
20 significantly above the highest flood that's ever
21 recorded. It may be more than one foot. Is the
22 magic number one foot adequate?

23 MR. RAJENDRA: This is Clement Rajendra,
24 GEH, for the 3.5 design, it's not site specific. We
25 have to set these flood levels and ground water

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 level at some point. And for that, we use the URB
2 as guidance. So these, the two -- the one foot for
3 flood and the two foot for ground level comes from
4 the URB specifications.

5 Now, each site then, has to then look at
6 their flood level and make sure that their flood
7 level is below this one foot. If it does not, it
8 becomes a departure, and that has to be addressed as
9 a departure.

10 MR. WALLIS: If you had a flood which is
11 large, you have waves on that flood? Where the wind
12 blows, I would think waves bigger than one foot are
13 very common.

14 MR. RAJENDRA: Well, since the flood
15 level is below -- the highest flood level is below
16 the finished ground elevation, there is no issue of
17 floods coming in -- waves coming up. If the flood
18 waters are above the ground, then you would have
19 waves.

20 MR. WALLIS: Where did the one foot come
21 from?

22 CHAIRMAN CORRADINI: URB.

23 MR. RAJENDRA: URB. It's arbitrarily
24 chosen for the standard design.

25 CHAIRMAN CORRADINI: Tell him what the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 URB is, I apologize.

2 MR. RAJENDRA: Utility Resolution
3 Document.

4 MR. WALLIS: -- is one meter?

5 MR. PATEL: No, one feet. One feet.

6 CHAIRMAN CORRADINI: Yes, one foot.

7 MR. WALLIS: It seems low to me as a
8 margin. One foot is nothing to compare with the
9 size of a big flood. That bothers me. It seems a
10 very small margin.

11 MEMBER SHACK: You put all the margin in
12 the design flood.

13 MR. RAJENDRA: Yes.

14 MR. WALLIS: I guess the staff has it all
15 under control.

16 MR. PATEL: The only issue for internal,
17 this external, internal flooding which we had open
18 item, was -- one was the emergency operating
19 procedure. If they had external floods, then they
20 should have some type of operating procedure how
21 they're going deal with, and that item is closed
22 now.

23 And the other one is for the RTNSS,
24 there was no discussion about how they were going to
25 protect the RTNSS system. And that is, now we will

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 be following, coordinating our review with RTNSS
2 people you know, and that's area 22.5-5.

3 And the third one, open item was I guess
4 this was the NRC, so I'll just tell something. We
5 were not convinced completely we are to make sure
6 ourselves that whatever calculation they made for
7 internal flooding, that there was some good basis
8 for it. So we asked them to prove up, review the
9 calculations. Because we did not have any detail
10 dimensions in everything. And after we showed the
11 safety-relation, we have looked at the calculation
12 and convinced all staff that it was okay. So, that
13 item is closed.

14 MEMBER BROWN: So the third bullet is the
15 internal. I mean, that's like pools of --

16 MR. PATEL: Yes.

17 MEMBER GROWN: Pools dumping down into
18 the drywall, that type of stuff.

19 MR. PATEL: Internal floodings, right.
20 In earlier version of DCD, we had no dimensions and
21 other things, so we could not independently say,
22 okay, what GDC is okay. So, we wanted to look at
23 detailed calculations. And we ran, and we have
24 confirmed that it's okay. So it is closed.

25 MR. WALLIS: I was concerned when I read

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 that GEH assumed a volume of water and found out
2 high the level would be. Where does this assumption
3 come from? It must come a design of some sort. You
4 can't just assume an arbitrary volume of water. It
5 must know something about the size of attack or
6 something.

7 MR. PATEL: Yes.

8 MR. WALLIS: So, you can't just assume
9 it. This bothered me, the word assume. You know,
10 they must take the volume of water, which is
11 actually designed, and then see what it does. Is
12 that what they did, or did they just assume a
13 volume?

14 MR. PATEL: Dave. Do you have -- he's
15 the guy who looked at calculations. Dave Shum will
16 answer.

17 MR. SHUM: My name is David Shum, I'm
18 from pipe system branch. And we know that crack --
19 the size of break they're shown -- I mean the design
20 pipe break area. So we know that --

21 MR. WALLIS: And you know the volume of
22 water that could --

23 MR. SHUM: And you know water, how much
24 water falling out of the crack at the pipe break.

25 MR. WALLIS: So you didn't assume

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 anything. You know these values.

2 MR. SHUM: We -- I mean --

3 MS. CUBBAGE: It's a postulated.

4 MR. SHUM: Right.

5 MEMBER BROWN: It's a postulated crack.
6 They assume it gets there. They know the amount of
7 water.

8 MR. SHUM: So, you kind of -- you know,
9 you kind of say, for example, you've got a fire
10 protection pipe --

11 MR. WALLIS: So the SER is wrong. You
12 did not just assume a volume of water, you know how
13 much volume of water you he.

14 MR. SHUM: You postulate.

15 MEMBER BROWN: Well, just hold it. If a
16 fire pipe breaks, and you've got something pumping
17 water in, you have to make an assumption as to when
18 you turned the pump off, I guess.

19 MR. SHUM: Yes.

20 MEMBER BROWN: Other wise, because that's
21 fire protection. So this is just going to keep
22 pumping the water in there as long as the pipe
23 breaks and there's nothing restraining it, if you're
24 pumping water and you've got a giant tank. I mean,
25 did you all include looking at the PCC and the GDCS

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 water breaking and flooding down into the dry well
2 area? Yes or No?

3 MS. CUBBAGE: Or, GE, would you like to?

4 MR. SHUM: No.

5 MR. RAJENDRA: This is Clement Rajendra.
6 Those big GDCS pools, there is no postulation that
7 those would break and the water will flood. They
8 are designed to Seismic Category I standards, and
9 they are not postulated to break.

10 MEMBER BROWN: So there is no, they will
11 never fail.

12 MR. RAJENDRA: Well, they're not
13 postulated to fail.

14 MR. SHUM: They should not fail by
15 design.

16 MR. RAJENDRA: By design.

17 MEMBER BROWN: So if all the water came
18 down in there, you didn't look at that?

19 CHAIRMAN CORRADINI: Not within the
20 design basis space.

21 MR. RAJENDRA: Basis.

22 CHAIRMAN CORRADINI: But within the PRA,
23 it better have been looked at.

24 MR. PATEL: This kind of, yes.

25 MR. WALLIS: But the fire protection

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 system, you assume that all the water in the tank
2 flooded?

3 MR. RAJENDRA: No. There is an
4 assumption that the break, the leak will be detected
5 and isolated within a certain time period specific.

6 MEMBER BROWN: Okay, so that's how you
7 determine the volume after that.

8 MR. RAJENDRA: Yes. Right. That's
9 right.

10 MR. WALLIS: So, it's the time period.

11 MR. RAJENDRA: There's a time period.

12 CHAIRMAN CORRADINI: Thank you.

13 MR. WALLIS: So it's not an assumption.

14 MEMBER BROWN: They picked a time which
15 is an assumption.

16 (Laughter)

17 MR. WALLIS: I just think that it should
18 be clear that these are not just assumptions out of
19 the blue, they have some basis.

20 MR. PATEL: I guess I should have made an
21 earlier remark that some of the sections were very
22 small, you know, and this would be one of the area
23 which I would like to skip if there is a --

24 CHAIRMAN CORRADINI: No, skip it.

25 MR. PATEL: Exactly. Because there's not

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 much you know, in this. Again, for this internally
2 generated missile, we have looked at -- I'll go both
3 internally generated missile inside containment and
4 outside containment. So, we'll make it faster.

5 Basically, we did look at the missile
6 and what kind of missile there could be. They -- GE
7 has categorized for outside data, categorized like
8 two types of missile, rotating, and rotating
9 component and also pressurized component.

10 We did look at what will be like
11 possibility, if there's any possibility of real
12 generation of missile. And our conclusion was there
13 is no significant impact. And we had no issue other
14 than RTNSS system again. The have not provided any
15 protection, or at least, we were not clear about
16 RTNSS system protection. So that was the only open
17 item in that area, for both.

18 Only difference between inside and
19 outside containment is inside containment, they
20 included one more possible missile is gravitational
21 missile. You know, if you have some hoist sitting
22 around and then they forget to, you know, stabilize
23 it and something happens. So that was the only
24 difference.

25 But basically, you know, as we had

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 concluded for the outside of containment, there was
2 no significant impact from this internal missile for
3 the inside and outside containment. So, that takes
4 care of SRP 3.5.11 and 3.5.12.

5 MR. WALLIS: No, I was a little
6 concerned.

7 MR. PATEL: Yes.

8 MR. WALLIS: You said there was a 10^{-7}
9 per year screening criteria.

10 MR. PATEL: That -- these are the
11 probability of like, what kind of missiles can you
12 have. You know, like, if you were to -- previous
13 one. Select. Rotating equipment, what kind of
14 impact they can have. And we looked at it, and
15 there's 120 bolts. You know, you cannot penetrate,
16 you would need repairs. It would not penetrate the
17 casing.

18 MR. WALLIS: It just -- the thing that
19 interested me is you had a probabilistic screening
20 criteria 10^{-7} per year. But then your discussion of
21 the ASCR was very qualitative about how robust
22 things were and things like that, which doesn't give
23 me any number. It just says they're robust.

24 MS. CUBBAGE: Are you looking at internal
25 versus external?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. WALLIS: Is there a probabilistic
2 basis somewhere for these claims that it's robust
3 enough?

4 MS. CUBBAGE: I think the issue is
5 internal versus external. I think you're getting
6 them --

7 MR. PATEL: No, but he's asking is that
8 for acceptance criteria 10^{-7} . And Dave, correct me,
9 Dave this one does not have 10^{-7} criteria.

10 MR. SHUM: This --

11 MS. CUBBAGE: You've got to get to the
12 microphone.

13 MR. PATEL: Yes, this one is just for
14 qualitative purpose. The other one is later on,
15 coming for, in the next section. What you're
16 talking about, 10^{-4} , it comes later on.

17 MS. CUBBAGE: This is a deterministic --

18 MR. SHUM: All this data --

19 MR. PATEL: This is a deterministic
20 approach here.

21 MR. SHUM: All this data from, you know,
22 as stated in the SER 3.5.1 are from Reg Guide, I
23 mean, the standards. Off hand, I don't remember
24 exactly where, it's 1.76, or something like that.
25 Because I didn't write this.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. PATEL: What, 3.5.11.

2 MR. SHUM: All this data, you see the
3 rate of occurrence of missile, P sub(1), that's less
4 than 10^{-7} , or P sub(2), blah, blah, blah.

5 MR. PATEL: Yes, okay.

6 MR. WALLIS: Well, I'm just saying, that
7 when I read the section that you're, the page 342 to
8 350-something, there seemed to be a lot of
9 qualitative statements about how the explosive squib
10 valves were unlikely to produce missiles and all
11 these components were very robust. There seemed to
12 be such qualitative statements, I just wondered if
13 that was good enough. And I just wondered how much
14 of this conclusion is based on a sort of a sense
15 that things are all right qualitatively, or is it
16 based on some evidence which is more substantial.

17 MR. PATEL: I think this 5.1.1 was really
18 on a qualitative analysis. Yes, I -- this
19 discussion in 3.5.1 which was, it's not really
20 3.5.1, this was generally discussion which is
21 applicable later on. If you go on to the on site
22 missiles and all that thing, you know, because 3.5.1
23 has no -- there is no acceptance criteria like,
24 there's no SRP which is 3.5.1, per se. So, this is
25 a description was for general purpose which could be

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 applicable to all 3.5 -- on all missiles. So,
2 3.5.1.1 which was really, this is only qualitative
3 acceptance.

4 MR. WALLIS: Qualitative acceptance means
5 staff judgment?

6 MR. PATEL: Yes. That's what we use.

7 MR. WALLIS: And there's no way I can
8 quantify how good the staff's judgment is?

9 MR. PATEL: If you think about it, we do
10 have some discussion about failure of the rotating
11 equipment and what is the, you know, possibility for
12 this to become a missile. And it's ending in
13 judgment that says, it might penetrate the you know,
14 pipe casing, but it will not damage anything. And
15 that's a judgment call.

16 Now, 3.5.1.3, the turbine missiles.
17 This is the issue here. As of Rev 3, we were okay.
18 Everything was fine and we -- what you were talking
19 about, that they will be providing the proof that it
20 will be 10^{-5} , you know, probability and all that.
21 And we had no problem.

22 And then they change, and now we are
23 again, we have finally resolved and made it an ITAAC
24 issue. They will be solved, they will be resolved
25 with the ITAAC.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 CHAIRMAN CORRADINI: What does that mean
2 here?

3 MR. PATEL: That, okay, first of all --

4 CHAIRMAN CORRADINI: Let's take this one,
5 which I think I kind of maybe understand.

6 (Laughter)

7 CHAIRMAN CORRADINI: Explain to me how
8 you're going to resolve it at the ITAAC stage.

9 MR. PATEL: In the ITAAC it will say,
10 well, first of all, let me just make sure
11 everybody's up to speed.

12 CHAIRMAN CORRADINI: No, no, good. This
13 is good. A tutorial is good. Go ahead.

14 MR. PATEL: Sub (1) orientation, okay.
15 This is a very favorable turbine orientation. If
16 you look at so many plants, operating plants, and I
17 have been involved with, Vine, Redwood, all I don't
18 -- I couldn't name some of the things.

19 CHAIRMAN CORRADINI: We didn't hear that.

20 MR. PATEL: Okay, good. I'm sorry. They
21 are not favorably oriented. This is the best
22 orientation. So, given this best orientation, the
23 acceptance criteria is like 10^{-4} . If you can -- by
24 looking at the material, when applicant receives the
25 turbine, they will have to go through all of the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 missile generation, and they will have to prove it
2 to us that it will be less than 10^{-4} .

3 And the confusion, and we looked at the
4 DCD, it started, it says GE recommends that it
5 should be less than 10^{-5} . But our acceptance
6 criteria is 10^{-4} .

7 MR. KRESS: What's the basis of that
8 acceptance criteria?

9 MR. PATEL: Well, okay. Now --

10 CHAIRMAN CORRADINI: Are you just asking
11 how you actually determine it? That's what I'm
12 still struggling with.

13 MR. PATEL: Yes. Yes.

14 MR. KRESS: No, I want to know why it's
15 good to go.

16 MR. PATEL: No, no.

17 CHAIRMAN CORRADINI: Why is it good now?

18 MR. KRESS: Yes. Why is it a good
19 number. How do you determine that's the number?

20 MR. PATEL: Well, first of all, I'm not
21 responsible --

22 (Laughter)

23 MS. CUBBAGE: No, no, no, no.

24 MR. PATEL: George.

25 MR. GEORGIEV: My name is George

1 Georgiev. I'm with the division of engineering, the
2 component integrity section. The question as I
3 understand it, how these numbers get derived and
4 accepted by the NRC.

5 We have guidance on the street, it's a
6 regulatory guide, and standard review plans. And
7 this was published and operating experience indicate
8 that these numbers are good. But a little tutorial
9 of how it works.

10 At this design stage, there is no
11 turbine built. If GE would have done bounding
12 analysis to postulate certain conditions and come up
13 with numbers, a type of a report would have given
14 you these numbers. At this time, we have no
15 numbers.

16 But when the turbine is procured at the
17 site, as a part of the turbine, the turbine
18 manufacturers develop this report which include
19 results of inspection, results of materials,
20 properties such as impacts, strength of the material
21 et cetera.

22 And the results of the pre-service
23 inspection and the results of the material
24 properties, you can use to calculate crack growth
25 and postulate within how many years something bad

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 will happen with the turbine. And that factors into
2 the turbine maintenance program, which means how
3 often you're going to open up the turbine case to
4 look at it and inspect it. And that's why it's
5 important that the better turbine material you have,
6 the better the low probability, the less often you
7 have to go and inspect the turbine. And that's --

8 CHAIRMAN CORRADINI: And then the second
9 part of the question that Tom asked, is why is 10^{-4}
10 acceptable, what's the basis for that?

11 MR. KRESS: In the first place, that's a
12 probability, and is that over the lifetime of the
13 reactor?

14 CHAIRMAN CORRADINI: Per year. It's per
15 year.

16 MR. GEORGIEV: Per year. Yes. Per
17 reactor. It is a frequency, yes.

18 MR. KRESS: The units didn't indicate
19 that.

20 MR. GEORGIEV: And 10^{-4} is a number that
21 the staff has determined is acceptable for favorably
22 orientated turbine. If it's unfavorably oriented,
23 then it goes by one, or the magnitude.

24 MR. KRESS: Yes, I understand a limit, my
25 question is, why is it that.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. PATEL: Okay. Let me try. I'll take
2 a shot. This just happened in my -- I just thought
3 of something. Because you have favorable
4 orientation, right? First of all, you've got P1,
5 which is 10^{-4} . Now you have to figure out what is
6 the probability that will hit the critical target.
7 In this case, it's pretty low. And as long as total
8 probability is less than 10^{-7} which is our
9 acceptance criteria for any --

10 MR. KRESS: This is derived from the 10^{-7}
11 value, you're saying?

12 MR. PATEL: Yes, yes. You know, there is
13 very little probability that there's anything, it's
14 going to be hit. So as long as you keep 10^{-4} you're
15 okay. You know, this is my interpretation, okay. I
16 have not seen any regulation, but this is what I
17 would think that that's the logic, that there's no
18 critical target. I used to do this thing in '74.

19 MR. KRESS: It's the starting point, is a
20 10^{-7} for critical data. And you can back it into
21 the missile finding from there.

22 MR. PATEL: Yes.

23 MR. KRESS: That makes some sense.

24 MR. PATEL: Typically, this is Busch. I
25 don't know how many guys remember Busch. These were

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 the people in 1972, like for turbine missile. Most
2 of the time, this failsafe failed between, most
3 critical is like five degrees this way, that way.
4 And as long as you avoid that angle, you are okay.

5 CHAIRMAN CORRADINI: And in your
6 analysis, or your design -- not your design, sorry.
7 GEH's design, the window was 25 degrees?

8 MR. PATEL: It's a big, you know. So you
9 know, that's why it's really, this is the best
10 design. I mean I'm not a salesman for GE.

11 CHAIRMAN CORRADINI: I understand.
12 (Laughter)

13 MR. KRESS: The probability of hitting
14 that window --

15 MR. PATEL: Exactly.

16 MR. KRESS: -- is, you take the whole
17 spherical volume around it, and you take a fraction
18 of that spherical volume. And that's the --

19 MR. PATEL: It's a very, very -- there's
20 no critical target in that area. You know, if you
21 are really very conservative, not even --

22 MR. KRESS: It's a volume and not an
23 area. Or is --

24 MR. PATEL: Well, I guess you can -- you
25 have --

1 MR. KRESS: An area of sphere or
2 something.

3 CHAIRMAN CORRADINI: No, it's a --
4 because it can go high. They look at all that.

5 MR. PATEL: It can go real high.

6 MEMBER STETKAR: You do high missiles and
7 low missiles.

8 MR. PATEL: Yes.

9 CHAIRMAN CORRADINI: One last thing, and
10 then we will stop bothering you.

11 MR. PATEL: Okay.

12 CHAIRMAN CORRADINI: So now I understand
13 the 10^{-4} for the number. Now, you had grades that
14 after, if it's 10^{-2} you have six days' operation.
15 So this must be experiences occurring of the same
16 turbine somewhere else in the population of those
17 types that during that time, you experienced some
18 other missile being thrown, I assume. Because it's
19 not going to be that particular machine.

20 MEMBER STETKAR: High vibration
21 indications.

22 CHAIRMAN CORRADINI: It's a high
23 vibration.

24 MR. GEORGIEV: Well, this brings in the
25 vibration, the over speed protection and various

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 other factors.

2 CHAIRMAN CORRADINI: Okay. That's fine.
3 That helps me a lot.

4 MEMBER STETKAR: I don't want to let him
5 off the hook though.

6 CHAIRMAN CORRADINI: Thank you.

7 MEMBER STETKAR: Since I've established
8 that the SER applies to DCD Rev 3 and a half,
9 certainly 3 to 4, there are no open items this
10 particular topic on turbine missiles.

11 MR. PATEL: Yes.

12 MEMBER STETKAR: My question is, and I
13 recognize now that in Rev 5 of the DCD, we've moved
14 diesels around, and we have a new building, but I'm
15 going to play the game for this SER, which is 3 and
16 a half, or 4. In Rev 4 of the DCD, the electrical
17 building contained the diesel generators and the
18 plant, whatever they are, PIPs, the busses, the PIP
19 busses that provide power to the safety-related
20 battery chargers and so forth.

21 So, my question is, why is there not a
22 concern in this SER with respect to turbine missile
23 damage to RTNSS equipment. Because there are
24 concerns in the SER in other type, seismic damage to
25 RTNSS equipment, environmental qualification of

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 RTNSS equipment --

2 MS. CUBBAGE: Yes, I'm going to take this
3 one. The electrical equipment you're referring to
4 was never B1. And we've gone away from B1, B2. If
5 you were at the PRA meeting, and how it's gone. It
6 was never B1. So, B1 was the stuff that needed to
7 be protected.

8 MR. SHAMS: I can also try.

9 MEMBER STETKAR: Okay.

10 MR. SHAMS: Mohammed Shams. We actually
11 approached the issue in a different route, which is,
12 we were engaging GE to prove that whatever
13 classification they have for this RTNSS equipment is
14 sufficient. And we were going at it that way,
15 knowing that there is missile issues, knowing that
16 there is seismic issues. And that approach actually
17 succeeded knowing that in Rev 5, they recognized
18 that whatever they had is inadequate, and they moved
19 things around and changed the design.

20 So, it's not like we ignored it, we just
21 approached it in a different way.

22 MS. CUBBAGE: Right. You wouldn't have
23 seen a chapter 3 RAI that the staff had chapter 22
24 RAIs on these two.

25 MR. SHAM: Right. We had in 22 RAIs --

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER STETKAR: No, I get it.

2 MS. CUBBAGE: With classification and
3 design.

4 MR. SHAM: We approached it --

5 MEMBER STETKAR: Okay.

6 MR. SHAM: -- can you prove that this
7 equipment is actually, can be reliably available
8 after an event, external event.

9 MEMBER STETKAR: Okay. Thank you.

10 CHAIRMAN CORRADINI: Keep on going.

11 MR. PATEL: 3.5.1.4, these are again,
12 tornado generated missiles. And we reviewed and
13 there was no, any open issue with this one. And I
14 guess we have beat the tornado-thing quite a bit.
15 Is there any question on this, in this area? It did
16 comply with the regulatory guide 1.76 and 1.76, so.
17 If not, then I'll go to the next.

18 Site proximity missiles, you know in
19 the, I'll go to the next -- both slides at the same
20 time, aircraft hazard. They are very much similar.
21 And both of these, site proximity missiles, accept
22 aircraft, and also the aircraft, they fall into the
23 category of the site specifications and they are,
24 you know, included in Chapter 2, table 2.0-1, and
25 also they are supposed to be addressed by COL

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 applicant. And they will, they should be able to
2 prove it to us that the probability of missile is
3 10^{-7} .

4 MR. KRESS: If you have a site or you
5 have multiple sources of external missiles, do you
6 keep each one of them at less than 10^{-7} , or is it
7 the summation of each one of them?

8 MR. TAMMARA: The total probability.

9 MR. KRESS: It's the total. You add them
10 all up.

11 CHAIRMAN CORRADINI: Come to the mike,
12 please.

13 MR. TAMMARA: My name is Rao Tammara. I
14 reviewed the 3.5.1.5 and 1.6. This will be the
15 total probability of all the --

16 MR. KRESS: All of them.

17 MR. TAMMARA: All incidents or accidents
18 or whatever. So, it's accumulated effect.

19 MR. KRESS: That's what I wanted.

20 MR. TAMMARA: Total, yes.

21 MR. PATEL: 3.5.2, the critical
22 components are protected by externally generated
23 missiles. We have looked at all the critical
24 component, and it showed that they are protected.
25 They are located in, they call it, tornado

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 registered building. You know, and that's why the
2 protection. So in this section, we did not have any
3 significant open item, other than, again, RTNSS.
4 You know, we are -- we were not -- they did not
5 address RTNSS-type of issues, okay.

6 3.5.3, that's the one which is, I think,
7 we have no significant problem because they have
8 designed all the thickness off up to 330 mile per
9 speed, concrete thickness of the building. So they
10 are much more conservative than what we would have
11 required according to the RG 1.76. So, in this
12 area, we have no concern. Is there any question on
13 this. Okay.

14 I guess we're go next to Mohammed Abid
15 will discuss about Chapters 3.10.

16 MR. ABID: I am Mohammed from the
17 division of engineering dealing with mechanics
18 branch of NRC. And I'm going to be discussing SRP
19 Section 3.10 for the ESBWR design specification for
20 seismic and dynamic qualification of mechanical and
21 electrical equipment.

22 We reviewed the applicants matters of
23 test and analysis employed to ensure the structural
24 integrity and the ability of Seismic Category I.
25 Mechanical electrical equipment including the I&C

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 components under the full range of normal and
2 excellent loading, including seismic and the reactor
3 building vibrations.

4 We have listed the reg guides that GE
5 used in their design. And I don't have to go one-
6 by-one, and also the industry standard, IEEE 344,
7 1987. 1987 was endorsed by NRC by Reg Guide 1.100,
8 Revision 2, in 1988.

9 Next slide. We have SER items of
10 interest. We had like three open items, three RAIs
11 that remain open. And based on the Revision 5 of
12 the ESBWR design certification, they're closed now.
13 I can go details on these.

14 3.10-1, we requested -- this RAI
15 requested General Electric Hitachi to revise the COL
16 information to require COL applicant to provide a
17 milestone for submitting and implementation schedule
18 for seismic and dynamic qualification of ESBWR
19 mechanical and electrical equipment.

20 In its response, GE stated that DCD tier
21 2, Section 3.10-4, would be revised accordingly in
22 Revision 5. And we confirmed that; we looked at
23 Revision 5, and they did that. And we consider this
24 RAI closed.

25 RAI 3.10-6, requested GE Hitachi to

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 provide basis for the assumed number of SRV
2 actuation events --

3 MEMBER BROWN: Before you go on, you talk
4 -- you wanted a schedule, an implementation
5 schedule. I'm just trying to understand what this
6 is. It's a milestone for submitting an
7 implementation schedule. So they've agreed to
8 submit a schedule.

9 MR. ABID: They have provided a section
10 that agreed, yes.

11 MEMBER BROWN: For seismic and dynamic
12 qualification of all the mechanical and electrical
13 equipment.

14 MR. ABID: Yes.

15 MEMBER BROWN: I would presume then they
16 would then identify all the lists of equipment and
17 when they would be qualified, or tested? Because,
18 am I reading too much into this?

19 MS. CUBBAGE: This is a schedule that
20 we've asked that a COL item, such that the COL
21 applicants would commit to providing milestones at
22 which time they'd be implementing these programs and
23 the staff would have an opportunity to audit the
24 implementation.

25 MEMBER BROWN: So, this provides a tag to

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 go pull on --

2 MS. CUBBAGE: Right.

3 MEMBER BROWN: -- once a licensee is
4 going to use the plant, is going to start his
5 procurement design process, what-have-you. Am I --
6 and so now, you have this schedule that he then
7 commits to to provide this information to you all?

8 MS. CUBBAGE: Right.

9 MEMBER BROWN: To NRC, to the staff.

10 MS. CUBBAGE: Not GE, but the combined
11 licensed applicants.

12 MEMBER BROWN: The combined licensee.

13 MS. CUBBAGE: This is consistent with
14 Commission policy in SECY 05-0197 on operational
15 program reviews. And, yes, basically --

16 (Laughter)

17 MEMBER BROWN: I'm on top of that one.

18 MS. CUBBAGE: Yes.

19 CHAIRMAN CORRADINI: If it wasn't on the
20 record, don't worry.

21 MEMBER BROWN: This part?

22 MS. CUBBAGE: Yes. The Commission has
23 indicated for, in our policy, has said that the
24 operational programs will be implemented after
25 issuance of a license, and there will be licensed

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 conditions that must be fulfilled so that these
2 programs are implemented.

3 And so the Commission policy was that
4 these programs would be described in the FSAR, and
5 then we would have the licensed conditions for
6 implementation.

7 MEMBER BROWN: Okay. Now, is it possible
8 to have this thing that you get submitted tell you
9 whether they're going to do this qualification by
10 test or analysis --

11 MS. CUBBAGE: I think we'll have to
12 defer --

13 MEMBER BROWN: -- so that the licensee
14 identifies --

15 MS. CUBBAGE: I'd have to defer to --

16 MEMBER BROWN: Have him identify when you
17 get this list, I mean, it --

18 MS. CUBBAGE: I'll need to defer to the
19 technical staff as to whether they need to know at
20 this stage whether it's going to be a test or
21 analysis, or if it's sufficient that the equipment
22 will be qualified.

23 MR. SHAMS: Can I try to answer that?

24 MEMBER BROWN: I'm not sure yet, because
25 I'm not sure I got the question right.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. SHAMS: I think I got it. I've been
2 hearing your question all day, and I'll just take a
3 shot at it.

4 MEMBER BROWN: Yes, I love to repeat, so,
5 it's an old habit.

6 MR. SHAMS: I think the process starts
7 there. There's an IEEE that has several ways of
8 qualifying an equipment, be it analysis, design, or
9 testing. I'm sorry, be it analysis or testing. And
10 your question was, when do I get that piece of
11 information?

12 I think the staff is at the other end of
13 that equation in the sense that, whatever the
14 applicant gives to us, we have the ability to
15 quantify, did the analysis actually, is it
16 appropriate for an equipment like this? Can I
17 analyze a cabinet, an electric cabinet with relays
18 inside of it? That's not an analysis problem, that
19 would have to be a test problem.

20 So, at this point, is where we say, no,
21 analysis would not work, here, that would have to be
22 a --

23 MEMBER BROWN: Okay. I'm not looking for
24 it to say, what they would, but that they provide a
25 basis for the decision as to whether they test or

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 analyze. I mean, that's what you would need, I
2 would think.

3 MR. SHAMS: I would imagine they would
4 have to provide a basis. And if again, if the basis
5 is not provided, the staff has the ability to say,
6 is analysis an appropriate approach to qualify this
7 piece of equipment.

8 If you're qualifying a pipe, I'd say
9 analysis could be appropriate. If you're qualifying
10 an electric cabinet, I'd say analysis is not
11 appropriate.

12 MEMBER BROWN: Okay. But shouldn't when
13 they submit that, why wouldn't they automatically,
14 if they're going to say analysis, why wouldn't they
15 have to say what the basis was at the same time as
16 opposed to you coming back and saying, gee, what's
17 the basis, you didn't give it to us.

18 MR. SHAMS: Right. I think the answer
19 for that is because the detail is not at this level
20 of the design, and --

21 MEMBER BROWN: No, no. I understand
22 that. I'm saying, when they submit the paper saying
23 what they're going to do, that they don't omit the
24 basis at the time they come to you, at the
25 appropriate time when they're doing the design

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 procurement testing decision process.

2 MR. SHAMS: I would imagine that --

3 MEMBER BROWN: Not that they know before.

4 I'm not trying to get to --

5 MS. CUBBAGE: To fulfill the ITAAC, the
6 licensees will have to have all the documentation to
7 support their conclusion that they have qualified
8 the equipment appropriately. And then the NRC will
9 be able to inspect that.

10 MR. ABID: The functional requirement of
11 the component will drive testing on the design.

12 MEMBER BROWN: Say that again?

13 MR. ABID: I think the component -- it
14 depends on what kind of classification component
15 has.

16 MEMBER BROWN: Oh, I understand that.

17 MR. ABID: What kind of safety content is
18 going to provide, you know, Class IE will be tested,
19 definitely. Non-Class IE, you can go by training of
20 the type of equipment, you know. Sensors, their
21 strength, there's two different things. Sensors
22 will be tested, some will be analysis, you know. We
23 discussed that before with G.

24 MEMBER MAYNARD: I think some of this
25 will come down to a commercial risk for the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 licensee. The sooner they provide it, the more --
2 the less likely of a delay of having to redo it. If
3 they wait until the end and it's not acceptable,
4 then they may have a delay in their --

5 MEMBER BROWN: Your point is the one I'm
6 trying to make. When they submit this, and say,
7 we're going to, here's the list, we're going to
8 test, analyze, test, analyze, that now the staff has
9 got that, and they say, why is analysis okay? But
10 it's now four years, or three years into the
11 process, and now it's a little bit late. Because
12 it's a risk. It's a risk.

13 MS. CUBBAGE: The operational program
14 review, you know, we can go out and look at their
15 program before they implement it. And then, after
16 they implement it, we can verify by ITAAC. So
17 there's an opportunity --

18 MEMBER BROWN: All I'm really interested
19 in, Amy, is when they send you the list, it says
20 what's going to be tested, what's going to be
21 analyzed, they provide a basis at that time for why
22 they're going to do an analysis as opposed to --

23 MS. CUBBAGE: I personally can't answer
24 that question as to when we'll know --

25 MEMBER BROWN: No, not when you will

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 know, that they will tell you why they're going to
2 use -- is this -- am I that hard?

3 MS. CUBBAGE: I understand what you're
4 saying. I just can't answer you.

5 CHAIRMAN CORRADINI: They just won't get
6 it approved.

7 MEMBER BROWN: I quit. Go on. I've
8 thrown in the towel here. I've just been beaten
9 into submission.

10 MS. CUBBAGE: No, I understand what
11 you're asking and we'll try to get you an answer.

12 MR. PATEL: As for 3.10-6, I guess if
13 you have anything.

14 MR. ABID: Any questions on 3.10?

15 (Laughter)

16 MR. ABID: All right. 3.10-6. Requested
17 GEH to provide basis for the assumed number of SRV
18 actuation events and the total SRV durations stated
19 in the DCD. In its response, GEH stated that ESBWR
20 design with isolation condenser system and its large
21 steam volume results in zero SRV openings. During
22 design, this is anticipated operational
23 equivalencies.

24 Because ICS is sized to prevent SRV
25 actuations with 3 or 4 trains in operation, Section

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 5.4.6.3 is the reference in the DCD for that, GEH
2 concluded that the number of SRV actuation events
3 and the total SRV test durations as stated in the
4 DCD is conservative.

5 The staff finds GEH response
6 satisfactory for the assumed SRV actuation events
7 and test durations. And we consider the RAI as
8 closed.

9 MEMBER BROWN: The design basis
10 anticipated operational occurrences, it's just
11 normal operation, or is this a design-basis
12 earthquake, or? I have no idea what it is.

13 MR. ABID: Anticipated -- operational,
14 sorry.

15 MR. PATEL: Anticipated operational.

16 MEMBER BROWN: That's an earthquake?

17 CHAIRMAN CORRADINI: Yes, that's an
18 earthquake.

19 MEMBER BROWN: So it won't activate
20 during the design-basis earthquake.

21 MR. ABID: That's correct.

22 MEMBER BROWN: Okay, thank you.

23 MR. PATEL: Let me just make the record,
24 I think, clear. I believe AOO, Anticipated
25 Operational Occurrences, is also considered like the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 first level of a transient. It happens.

2 MEMBER BROWN: You mean a power
3 transient.

4 MR. PATEL: Yes. Yes.

5 MEMBER BROWN: A big power demand, or a
6 turbine generator, a valve trip.

7 MEMBER STETKAR: There's some definitions
8 in there.

9 MR. PATEL: Yes. That's the lowest level
10 of --

11 MEMBER BROWN: Okay. So, it's
12 operation --

13 MEMBER STETKAR: No frequently than
14 roughly one in --

15 MR. PATEL: I just want to make sure
16 everybody --

17 MEMBER BROWN: So it's not just for the
18 -- I doesn't happen an earthquake, but during major
19 plant transients as well.

20 MR. PATEL: Yes. It's no --

21 MEMBER BROWN: Okay. That's fine. Thank
22 you.

23 MR. ABID: Can we go to RAI 3.10-8,
24 requested GEH to address the adequacy of the seismic
25 qualification of ESBWR mechanical and electrical

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 equipment for plant site and High-Frequency seismic
2 excitation.

3 In its response, GEH stated that ESBWR
4 certified seismic design response spectra uses a
5 single envelope ground motion containing both low
6 frequency and high frequency ground motions to
7 generate in-structure response spectra for use in
8 seismic qualification of mechanical and electrical
9 equipment. The seismic qualification of ESBWR
10 mechanical and electrical equipment meets the IEEE
11 344 1987 requirements.

12 The concludes that ESBWR design is
13 adequate for plant site with high frequency seismic
14 excitation. RAI 3.10-8 is considered closed.

15 MR. PATEL: Is there any question? Can
16 we go to 3.11?

17 CHAIRMAN CORRADINI: We're going to come
18 back to this one a lot of times. So I understand it
19 in this context.

20 MR. PATEL: All right. Amar Pal will be
21 discussing our evaluation for 3.11.

22 MR. PAL: Good afternoon. I'm Amar Pal.
23 I'm with the NRO/DE/EEB. I'm going to talk about
24 the environmental qualification of the ESBWR design.

25 The regulations and the regulatory

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 guide, next slide, applicable for this section are
2 10 CFR 50.49, 10 CFR 52.47 (b)(1) for ITAAC and the
3 several GDCs, 1, 2, 4 and 23 of Appendix A and III,
4 XI, XVII of appendix B. The important Regulatory
5 Guides are 1.89, 1.97, 1.209, 1.180. And industry
6 standards are IEEE. Other guidance, SECY 05-0197.
7 And one item is missing, is the SRP, and the SRP one
8 there.

9 The technical summary, the equipment
10 covered under the EQ programs are safety-related
11 mechanical equipment in the harsh environment, and
12 this mechanical equipment includes the lubricants,
13 the grease, the fluid, et cetera, which has
14 significant aging.

15 Electrical equipment important to safety
16 and harsh environment includes safety-related
17 electrical equipment, non-safety-related electrical
18 equipment whose failure could prevent satisfactory
19 operation of the safety-related function and certain
20 post-accident and monitoring equipment. These are
21 called B1, B2 and B3 in this order.

22 Then safety-related digital and non-
23 digital, meaning analog, I&E equipment in the mild
24 environment.

25 MEMBER BROWN: What's a mild environment?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. PAL: Where the temperature is not
2 going to change with accident conditions.

3 MEMBER BROWN: What about the maximum
4 conditions under which it has to operate, is that
5 considered?

6 MR. PAL: It will have a maximum
7 temperature, whatever the temperature is.

8 MEMBER BROWN: I mean, just from normal
9 operations.

10 MR. PAL: Normal operation.

11 MEMBER BROWN: Forget the accident.

12 MR. PAL: And it is not going to change
13 substantially, or significantly for the accident
14 environment.

15 MEMBER BROWN: Is that mild environment
16 defined in a spec somewhere, an industry spec, an
17 IEEE standard, or is that in, somebody keeps quoting
18 344, or whatever. Is that for LE equipment, is
19 that --

20 MR. ABID: I could give you an example of
21 what we used in the industry way back for the
22 environmental qualification. Certain companies for
23 like the reason three areas, consider like 10 to 4
24 for rads, 10 rads to 4 radiations as equal to or
25 less than is mild; 104 degrees Fahrenheit equal to,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 or less than is mild. Anything above that is
2 considered harsh and they evaluate that based on the
3 equipment qualifications.

4 MEMBER STETKAR: Let's get specific for
5 this design. Is 122 degrees Fahrenheit --

6 MR. ABID: It's for the containment, yes.

7 MEMBER STETKAR: Well, no, let me finish.

8 MR. ABID: Yes, go ahead.

9 MEMBER STETKAR: Is 122 degrees
10 Fahrenheit considered a mild environment or not?

11 MR. PAL: It could be mild environment if
12 the temperature in that area does not change dealing
13 in accident condition.

14 MEMBER STETKAR: If an increase from --

15 MR. PAL: Exactly. If it normally
16 operated at that temperature, then, and it doesn't
17 change during an accident situation, then that is a
18 mild environment.

19 MEMBER STETKAR: Okay. If it changes
20 from, I'm sorry, if it changes from 85 degrees
21 Fahrenheit to 122 degrees Fahrenheit, it that --

22 MR. PAL: It's not a mild environment.

23 MEMBER BROWN: During, that's during an
24 accident.

25 MR. PAL: Yes.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER BROWN: Is that, that's what I
2 heard you say a minute ago.

3 MEMBER STETKAR: So, we do have locations
4 in the ESBWR reactor building that contains safety-
5 related digital I&C equipment that are not
6 considered a mild environment, is that correct?

7 MEMBER BROWN: In the reactor building?

8 MEMBER STETKAR: Yes. Yes.

9 MEMBER BROWN: Digital I&C is inside the
10 reactor building?

11 MEMBER STETKAR: Yes. Just, yes. The
12 reactor building is not the containment. The
13 reactor building is the reactor building. So, I'm
14 looking at specific rooms here that have a normal
15 operating temperature of 85 degrees maximum during
16 normal power operation, and have an accident
17 temperature of 122 degrees Fahrenheit.

18 MEMBER ARMIJO: And there is digital I&C
19 equipment in that?

20 MEMBER STETKAR: There are safety-related
21 digital I&C in the reactor building. There are four
22 corner rooms or quadrants, or whatever you want to
23 call them, on this plan, that contain all of the
24 safety-related digital I&C, except for the stuff
25 that's in the control building, that also changes in

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 temperature.

2 So, that is not a mild environment, is
3 that correct?

4 MR. PAL: That's my understanding, yes.

5 MEMBER STETKAR: Because there's a
6 footnote to the tables in the DCD that seems to tell
7 me that GEH considers that to be a mild environment.
8 So that's, it's important. That actually is an
9 important distinction, but it's important to get to
10 specific examples.

11 MR. ARMIJO: But that equipment would be
12 then qualified to the harsh environment.

13 MEMBER STETKAR: Well, it should be
14 qualified to 122 degrees Fahrenheit, which is my
15 earlier question about how do you know the
16 temperature will actually be that.

17 MEMBER BLEY: Well, that's in contrast
18 though, to the mild environment. It seems to me it
19 goes to the point of, it ought to be what the
20 expected temperature may be in that room under even
21 non-accident conditions, as well as accident
22 conditions. I mean, it is a temperature-controlled,
23 air conditioned --

24 MEMBER STETKAR: Under normal conditions,
25 it is. Under accident conditions, it's not. That's

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 the whole point.

2 MEMBER BLEY: Don't you have to -- I'm
3 not familiar with this. Wouldn't you have to
4 consider a loss of air condition as -- it's not an
5 accident in terms of a reactor accident, but it's a
6 loss of some plant support.

7 CHAIRMAN CORRADINI: I think John is,
8 well --

9 MEMBER STETKAR: I'm pursuing it.

10 MEMBER SIEBER: It takes three days to
11 get there.

12 MEMBER STETKAR: A long-lived topic here,
13 so.

14 MS. CUBBAGE: The staff is pursuing the
15 issues of the reactor building environment as well.

16 MEMBER STETKAR: Let me ask, we've gone
17 over this a few times with temperature. I had
18 another question though, that I wanted to ask. And
19 I didn't ask GEH, but I wanted to get your opinion.

20 In those reactor building rooms that
21 contain the DCIS, and the safety-related electrical
22 equipment, the invertors, I notice that the humidity
23 is not controlled. They specify a maximum design
24 temperature to qualify the equipment against, but
25 during accident conditions, there's no control over

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 humidity in those locations. Is that a concern?

2 MR. PAL: Qualification will consider 100
3 percent humidity.

4 MEMBER STETKAR: Okay. That was -- okay.
5 That was -- thanks.

6 MS. CUBBAGE: And we're going to try to
7 get back to you on the --

8 MEMBER STETKAR: That's pretty difficult
9 with solid state digital equipment.

10 MS. CUBBAGE: This is Amy on the -- oh,
11 do you want -- on the mild environment we were going
12 to try to get back to you. But if --

13 MR. WAAL: Actually, we have an answer
14 for that.

15 CHAIRMAN CORRADINI: You have to identify
16 yourself.

17 MR. WAAL: This is Jeff Waal, GEH. And
18 table 3H.13, in Appendix H -- in Appendix 3H. We
19 have a definition of the mild environment, which is
20 122 degrees Fahrenheit.

21 MEMBER BLEY: What about a humidity
22 requirement?

23 MR. WAAL: There's a humidity 30 to 65
24 percent for typical conditions, and less than 95
25 percent for abnormal conditions.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER STETKAR: Okay. That's a
2 different definition. Thank you, by the way. I'm
3 looking at the table right now.

4 That's a different definition from what
5 I heard earlier. Because you're defining a mild
6 environment, although the notes in the table say
7 normal, I don't care whether it's normal or
8 abnormal. You're defining the mild environment as a
9 temperature, not a change in temperature condition.

10 MR. WAAL: That's correct.

11 MEMBER BLEY: That's what I would have --

12 MEMBER STETKAR: That's a little bit
13 different from what I heard earlier. Because what I
14 heard earlier seemed to say that mild versus harsh
15 was a change in temperature condition, not an
16 absolute. You're defining it as an absolute.

17 Because this table is consistent with
18 the notes that I had read in the DCD as far as
19 stating that these are considered to be mild
20 conditions. But it seemed to be different from what
21 I heard earlier.

22 MEMBER BLEY: That's what I would have
23 expected it to be.

24 MEMBER STETKAR: Okay.

25 MR. PAL: Maybe Paul can share something.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 Mild environment.

2 MEMBER STETKAR: Thanks, by the way. I
3 missed that table. I didn't get that far.

4 MR. SHEMANSKI: Paul Shemanski, division
5 of engineering, electrical engineering branch.

6 Basically, the definition of a mild
7 environment is one that does not change
8 significantly during the course of an accident. And
9 I guess GE has chosen a specific number of 122
10 degrees, which is fine. But, in reality, whatever
11 the environment is, that is what the equipment has
12 to be qualified for.

13 In other words, I've been in a number of
14 plants where the temperature has been as high as 160
15 degrees, and that basically is their mild
16 environment. That particular room never changes
17 during an accident condition.

18 So, the bottom line is, the equipment
19 then would have to be qualified for that number, 160
20 degrees Fahrenheit.

21 MS. CUBBAGE: And our HVAC reviewer's not
22 here, but I know he has questions about the cooling
23 in the reactor building, the justification of this
24 equipment being in a mild environment is based on
25 normal conditions. They have HVAC, but it's non-

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 safety. And if the diesel's are available, they can
2 use the non-safety cooling. And when no active
3 cooling's available, they're relying on passive
4 cooling in the reactor building, and we have some
5 open RAIs on that as to what the conditions will be
6 in those areas, and to justify the passive cooling
7 will be effective.

8 MEMBER STETKAR: I don't know --

9 MS. CUBBAGE: And then, whatever the
10 conditions are, the equipment will have to be
11 qualified for those conditions.

12 MEMBER BROWN: During a reactor accident
13 circumstances based on your --

14 MS. CUBBAGE: Yes.

15 MEMBER BROWN: Okay.

16 MEMBER STETKAR: Because according to the
17 tables in the DCD, the normal expected temperature
18 under active ventilation in those rooms would be 85
19 degrees Fahrenheit for most of the areas that I'm
20 looking at. But -- and it, according to these
21 tables, is expected to increase to 122 degrees
22 Fahrenheit, which GE has defined as a "mild"
23 environment.

24 And I don't particularly care personally
25 what constitutes a mild environment, unless that

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 word means something in terms of qualification and
2 licensing space. If that word doesn't mean
3 anything --

4 MR. SHEMANSKI: Where it does have
5 significance from the standpoint that equipment in
6 the mild environment is typically not expected to be
7 exposed to aging parameters.

8 In other words, and as such, it is not
9 required to have a qualified life. So, there is
10 some significance to the --

11 MEMBER STETKAR: There's no qualified
12 life to the safety-related digital instrumentation
13 installed?

14 MR. SHEMANSKI: Well, its qualified life
15 would be in this case 60 years. It would be the
16 licensing period of the plant itself.

17 MEMBER SIEBER: It is active, so you
18 replace it --

19 MEMBER BLEY: You mean, you really expect
20 to put a cabinet of electronic equipment in, and
21 it's going to last for 60 years?

22 MR. SHEMANSKI: Yes, if it's not exposed
23 to significant, if it's not exposed to significant
24 aging stressors, that would be the expectation.

25 MEMBER BLEY: It's going to be

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 interesting.

2 MR. SHEMANSKI: I mean, we have plants
3 out there now with --

4 MEMBER BLEY: I mean, you can't get a
5 television to last that long, with all the latest
6 digital technology involved.

7 MEMBER SIEBER: It's not safety-related.

8 (Laughter)

9 MR. PAL: Aging program summary, the
10 equipment is designed to have the capability to
11 perform its design safety function under all
12 anticipated operational occurrences in normal
13 excited and post-excited environment and for the
14 length of time for which its functions are required.

15 The environmental capability of the
16 equipment is demonstrated by approved testing and
17 analysis. A QA program meeting the requirements of
18 Appendix B to 10 CFR Part 50, is established and
19 implemented to provide assurance that all
20 requirements have been satisfactorily accomplished.

21 EQ of mechanical and electrical reliance
22 equipment must meet the requirements of 10 CFR part
23 50.49, GECs 1, 2, 4, 23 of Appendix A and 10 CFR 50
24 criteria Bs 11 and 17 of Appendix B. The qualified
25 life is verified using methods and procedures of

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 qualification and documentation as stated in IEEE
2 323 1974.

3 The EQ program, region operation program
4 part SECY 05-0197, and this is for the revision 5 of
5 the DCD. GH has proposed an ITAAC to verify EQ
6 equipment has been qualified for the regulations.
7 This item also discussion in Revision 5, not in
8 Revision 3.

9 EQ records will be maintained in an
10 auditable from the entire period during which the EQ
11 equipment is installed.

12 MR. WALLIS: I just wonder if the 1974
13 method is appropriate since there's been all kinds
14 of changes in technology in over 30 years. Is it
15 still --

16 MR. PAL: The latest revision is 2003.

17 MR. WALLIS: So there is a new addition.

18 MR. PAL: Yes. But the NRC did not
19 endorse the 2003 portion yet, so we cannot use that
20 at this time.

21 MEMBER ARMIJO: Even if it's better? Why
22 not?

23 MR. SIEBER: It's not endorsed.

24 MR. PAL: But it's not endorsed. We
25 don't know what is --

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER ARMIJO: Has NRC reviewed it in
2 the process of endorsing it?

3 MR. PAL: It's in the works right now.
4 The next slide talks about that. I can't -- it's in
5 the process. We've not finished that part yet.

6 MR. WALLIS: It's still being reviewed
7 whether or not you should replace it after 30 years?

8 MS. CUBBAGE: The review on going is with
9 respect to our RAI.

10 MR. WALLIS: Why don't you just do it
11 instantaneously without any review. Presumably it's
12 better.

13 CHAIRMAN CORRADINI: Just a minute ago,
14 didn't you say how did I trust the codes and
15 standards? I just want to make sure we'll all on
16 the same page here.

17 (Laughter)

18 CHAIRMAN CORRADINI: Got you there.

19 MS. CUBBAGE: There have been cases where
20 a new standards would relax --

21 MEMBER ARMIJO: Sure, I understand that.

22 MS. CUBBAGE: -- have a relaxation in
23 the area, and the staff may not find that
24 acceptable.

25 MEMBER ARMIJO: Right. But that should

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 be pretty quick to find that.

2 MEMBER SIEBER: Nothing with codes and
3 standards are quick.

4 MS. CUBBAGE: Or reg guides, or
5 regulations.

6 MEMBER BLEY: I asked a question earlier
7 that I thought you said we'd get to. And these
8 codes and standards might answer it if I read them.
9 But, do these require documentation of the whole
10 test program when tests are required, including
11 failures as well as successes?

12 MR. PAL: I don't think the EQ -- I do
13 not contain the failures. It only will contain the
14 successes.

15 MEMBER BLEY: That's what I thought.
16 Okay, so that hasn't changed.

17 MR. WALLIS: That's very strange.

18 MEMBER STETKAR: You pass -- fail four,
19 pass the fifth, turn in --

20 MR. SHEMANSKI: Paul Shemanski. Let me
21 try and answer your question again.

22 MEMBER BLEY: Thank you.

23 MR. SHEMANSKI: First of all, let me just
24 back up with the IEEE standard. I was on the
25 working group from NRC that developed the IEEE 323

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 2003 version. Overall, it's a pretty good document.
2 The reason the staff has not yet accepted it, or
3 endorsed it, because there, it does have a few
4 shortcomings as Amy mentioned. There are some
5 technical relaxations in there. So, the expectation
6 is that the staff, right now, we're in the process
7 of endorsing, of revising Reg Guide 1.89, and when
8 we revise -- when we complete the revision of 1.89,
9 we are likely to accept this new 2003 version of
10 IEEE. But we will accept it with some exceptions.

11 It's a fairly decent document. It is.
12 But right now, the standard of record is the 1974
13 version. So, we're still locked into the 1974
14 version.

15 MEMBER BLEY: Since you worked on the new
16 one --

17 MR. SHEMANSKI: Yes.

18 MEMBER BLEY: Are we missing anything
19 important by using the old standard instead of the
20 new? Did it pick up some things we really ought to
21 be paying attention to, and if that's true, are you
22 actually --

23 MR. SHEMANSKI: Well, it actually did
24 pick up a few items. It introduced the inclusion of
25 EMI, RFI and power surge testing, particularly for

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 the new breed of microelectronics coming out, the
2 computer-based electronics. So, from that
3 standpoint, it was an enhancement. The 1974 version
4 did not really have EMI, RFI or power surge. So
5 there are some --

6 MEMBER BLEY: Are those things covered in
7 any way in this -- in our current review?

8 MR. PAL: Yes. Yes. The digital I&C
9 components are going to follow the latest revision
10 of the IEEE 323, which is endorsed by the guide
11 1.209.

12 CHAIRMAN CORRADINI: Did you follow that?

13 MEMBER BLEY: I'm a little confused. If
14 it's endorsed for one reg guide why --

15 MR. PAL: It's only because of that EMI,
16 RFI.

17 MS. CUBBAGE: For the digital I&C.

18 CHAIRMAN CORRADINI: Is that another
19 way --

20 MEMBER BLEY: Especially for digital I&C.

21 MR. PAL: By in the environment.

22 CHAIRMAN CORRADINI: So it is approved
23 another way.

24 MR. PAL: It's only for mild environment
25 digital I&C requirements.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. SHEMANSKI: Yes. That's correct.

2 MEMBER BLEY: It's not like it just came
3 out last year. It's been on the streets for a
4 while.

5 MR. SHEMANSKI: In answer to your
6 question about how does the staff review
7 qualification test results, and I'm speaking
8 primarily of 3.11 now, environmental qualification
9 of electrical and mechanical equipment. At this
10 stage of the game, we're basically reviewing the
11 methodology that GE is using to actually do the
12 qualification testing.

13 That has not been done yet. That will
14 be done later down the line. EQ has been identified
15 as an operational program, subject to an ITAAC.
16 It's one of 15 or 20 operational programs. And the
17 intent is that prior to fuel load, and probably
18 pretty close to fuel load, the staff will conduct a
19 very in depth EQ inspection.

20 I've done 20 of these in the past over
21 the years. Typically it's a team of about ten
22 people. I go out, and we spend one week at the
23 site, usually, that's where the documentation is.
24 And we do a very thorough inspection of the EQ test
25 reports.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 And the people that are looking at the
2 reports are knowledgeable in this area. They know
3 what they're looking for. And basically we look at
4 the EQ test reports to make sure that the individual
5 pieces of equipment have been properly qualified to
6 the pressure temperature profiles that result from
7 the accidents, to make sure they've incorporated
8 aging, temperature and radiation aging, make sure
9 that any anomalies that occurred, or failures during
10 the qualification program, were documented in the
11 test report.

12 So, there is some information there with
13 regard to your previous question about how do we
14 look at failures. But the bottom line is --

15 MEMBER BLEY: Their record has to include
16 the whole program.

17 MR. SHEMANSKI: Their record has to
18 include the whole program. And then we follow that
19 up with a walk-down to make sure that the equipment
20 is installed in the orientation it was tested.

21 If it was tested vertically, it better
22 be installed vertically. So, it's a verification
23 right at the end. There is a high risk, though,
24 involved. Because if problems are developed at that
25 point, it could be a delay in licensing, and that

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 has happened in the past.

2 But typically, it takes a long time to
3 develop this information, and that's why EQ is one
4 of the last things looked prior, just prior to fuel
5 load. So that is where we get the confirmation of
6 the EQ program. That's a very important aspect of
7 EQ.

8 CHAIRMAN CORRADINI: Go ahead.

9 MR. PAL: We did not receive the RAI
10 response for the environmental parameter questions.
11 There were several questions on those sides, so
12 that's still an open item.

13 And the COL item is, COL applicant will
14 provide a full description and milestone of program
15 implementation of the EQ program that includes
16 completion of the plant-specific equipment
17 qualification documentation. And that's specified
18 in Revision 5 of the DCD.

19 CHAIRMAN CORRADINI: Okay.

20 MR. PATEL: Okay, the last one is really,
21 we know there's nothing to be said anymore. I guess
22 we accepted the ASME requirement and everything is
23 clean. We're going fairly fast now. There should
24 not be, there is no open issue, nothing.

25 CHAIRMAN CORRADINI: Okay.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. PATEL: It's pretty straightforward.
2 Thank you.

3 CHAIRMAN CORRADINI: Some of the members
4 had questions, I saw. No? Okay. In that case,
5 then we'll just take a break for lunch. We'll be
6 back here at 1:30.

7 (Off the record for lunch break, 12:30
8 p.m. to 1:30 p.m.)

9 CHAIRMAN CORRADINI: We're back in
10 session. Mr. Waal.

11 MR. WAAL: Good afternoon, everybody.
12 This is continuation of review of Chapter 3 of the
13 ESBWR DCD. In this session, we're going to talk
14 about Sections 3.6 and 3.9. But in keeping with
15 doing things out of order, we're going to start with
16 3.9.

17 MR. KRESS: We like it this way.

18 MR. WAAL: Which is mechanical systems
19 and components. We have Dave Keck, Jerry Deaver,
20 and Pijush Day, from the ESBWR engineering who will
21 do the presentation.

22 MR. KECK: My name is David Keck. I'm
23 with GE Hitachi nuclear energy. And I am
24 responsible for the reactor internals. I'll be
25 going through most of section 3.9.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 This first slide simply lists the
2 different subsections within 3.9 that we'll be going
3 over. Special topics, the first area special topics
4 covers is design transients. Normal and thermal
5 transients event and dynamic loads are defined. And
6 this section basically just points to different
7 areas within 3.9 that defines the transients used,
8 tables and things like that.

9 This section also lists computer
10 programs used in the design, and it also discusses
11 experimental stress analysis consistent with
12 Appendix 2 of the code, basically snubbers, pipe
13 load restraints.

14 And then a section on faulted condition,
15 evaluation considerations, each of the Seismic I
16 Category equipment, well, selected Seismic I
17 equipment, is individually discussed with respect to
18 code requirements. Tables contain your
19 requirements, analysis or testing, and if analysis
20 is elastic or inelastic.

21 3.9.2 dynamic testing and analysis of
22 systems, components and equipment, the first section
23 it talks about piping vibration, thermal expansion,
24 dynamic effects. You know, the program's divided in
25 two phases, which is pre-operational and initial

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 startup. And this just discusses the general
2 requirements. The measurement techniques,
3 monitoring requirements, test evaluation, acceptance
4 criteria, and any reconciliation and corrective
5 actions.

6 The seismic qualification of safety-
7 related mechanical equipment, whether it is testing,
8 and/or analysis, basically lists criteria then goes
9 through components and each component's approach to
10 analysis and testing.

11 Then the dynamic response of reactor
12 internals under transient and normal operating
13 conditions our, the GEH vibration prediction methods
14 and how this applies to components and discusses
15 allowables and touches on the steam dryer and
16 separator.

17 MR. WALLIS: This has a steam dryer,
18 being a BWR.

19 MR. KECK: Yes.

20 MR. WALLIS: Of course, you know all
21 about steam dryer FIV and that sort of thing.

22 MR. KECK: There's been some issues
23 lately.

24 MR. WALLIS: What method do you use to
25 protect the behavior of the steam dryer and that

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 sort of vibration and so on. Or, are these evolving
2 with the other methods that are evolving.

3 MR. KECK: We did submit, and there are
4 three LTRs involved with the steam dryer that we
5 have submitted. And there is one LTR specifically
6 for the load, developing the loads for the steam
7 dryer. And this was submitted at the end of
8 February. Jeff, I don't know if you want to talk
9 more.

10 MR. WAAL: That particular topical report
11 had to do with a new evaluation method called PBLE,
12 Plant-based Load Evaluation, for developing loads to
13 be applied to the dryers. And then we also, once we
14 develop the loads, we use a computer program to run
15 transient analysis and load combinations in order to
16 determine and ensure that the allowable stress
17 criteria in that --

18 MR. WALLIS: This captures the forcing
19 function from the steam line and all that sort of
20 thing?

21 MR. WAAL: Yes.

22 MR. KECK: Acoustic loads.

23 MR. WAAL: Yes.

24 CHAIRMAN CORRADINI: So, let me just ask
25 a general question. This is, everything you're

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 going through is the type of analysis one would go
2 through whether it be ESBWR or any BWR for putting
3 in for a new certification.

4 So, what's unique about this design in
5 terms of the reactor internals that makes this
6 analysis different, either as Professor Wallis was
7 asking relative to a new analytical procedure, or
8 because the design is different? Can you give me a
9 kind of a summary there?

10 MR. DEEVER: Specific to the steam
11 dryers, or during internal?

12 CHAIRMAN CORRADINI: The reactor
13 internals and the jet cells. Not just the dryers.

14 MR. DEEVER: Well, I think we've gone
15 through the configuration of reactor internals
16 before. What we've done in our evaluation program
17 is, we look for similarities to past reactors and
18 we've identified, you know, whether we need a
19 vibration program or those or not.

20 Then, we have the chimney, which is a
21 new component and the partitions that are in it.
22 So, part of our, what's different in our DCD is
23 addressing these new components particularly and how
24 we're treating those.

25 We have the Appendix 3L which deals with

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 vibration for reactor internals, and there we
2 concentrate on the chimney partitions, the -- we
3 have select injection line that comes into the
4 vessel, which is different.

5 So, we've focused testing and so forth
6 on these newer components. And with the steam dryer
7 program, you know, we're following basically the
8 industry program of addressing the vibration issues
9 that have occurred in the past with dryers.

10 MEMBER ARMIJO: To that point, does the
11 existence the chimney make the loads on the dryers
12 milder or more severe or no different?

13 MR. DEEVER: Really, it's not going to
14 make any real difference. What we've done, we've
15 kept the volumes above where the chimney partitions
16 end. Mixing volume is very representative of past
17 BWRs. So, the space as comes -- the steam comes
18 out, until it gets into the separators. That's very
19 representative, and we should get typical mixing.

20 Then likewise is, we come up out of the
21 separators, there's a similar relationship between
22 the separators and the dryers. So that volume is
23 very equivalent or the same as past reactors.

24 So, we're not expecting any difference
25 in dynamics between those volumes coming up through

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 the reactor.

2 MEMBER SHACK: But are you looking at
3 scale model testing for this particular
4 configuration?

5 MR. DEEVER: As a complete reactor
6 internal component?

7 MEMBER SHACK: Well, at least as complete
8 as you do for the current operating reactors. I
9 mean, you know, you talk about an ANSIS thing, well
10 ANSIS is fine, once I know the loads on the dryer.
11 I'm perfectly willing to believe you can analyze the
12 dry with ANSIS. What I want to know is, how you get
13 the loads on the dryer. That's the tough part of
14 this problem. And you know, we haven't seen a GE
15 acoustic model yet, even for the up rate, so maybe
16 your LTR covers that.

17 MR. WAAL: That's GLTR that was talking
18 about --

19 CHAIRMAN CORRADINI: And that was
20 submitted when, I'm sorry?

21 MR. WAAL: At the end of February.

22 CHAIRMAN CORRADINI: Oh, the end of
23 February. So, staff is still reviewing it, I
24 assume?

25 MS. CUBBAGE: That's right. We're going

1 to be issuing our RAIs on that in July. And we do
2 have a presentation prepared today at a high level,
3 and then the details will need to follow when we're
4 further along with that review.

5 MEMBER SHACK: But you've benched marked
6 this against data is it Quad Cities again?

7 MR. DEEVER: No. Well, they benchmarked
8 it against several plants, including Susquehanna and
9 others. Typically what we found is, that the ABWR
10 was a dryer that was instrumented on startup. It
11 had very low stresses and strains involved in that
12 startup test program. So, we're adopting the ABWR
13 design as far as the steam dryer is concerned.

14 MR. KECK: Same setback from the main
15 steam nozzle, similar bank configuration.

16 MR. DEEVER: So, we recognize we have 15
17 percent more flow in our ESBWR as compared to ABWR,
18 but we're trying to, as much as possible, duplicate
19 that geometry which seems to be a good geometry.

20 Plus, I might mention that we've got
21 some programs going to mitigate loads, these
22 acoustic loads as a means to reduce any loadings on
23 the dryer.

24 MR. WALLIS: How many steam lines are
25 there?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. DEAVER: There's four.

2 MR. WALLIS: There are four.

3 MR. DEAVER: Typical for a BWR.

4 MR. WALLIS: So, this is a misleading
5 figure?

6 MR. KECK: It's a -- well, it's a 2-D
7 figure. I wouldn't use the word misleading.

8 (Laughter)

9 MR. KECK: It's a cross section cut on
10 two plains.

11 MR. DEAVER: There's only one steam
12 nozzle shown in this figure, and that's the extended
13 long one at the top. There are four of those.

14 CHAIRMAN CORRADINI: So, I guess I'm, to
15 get back to it, I kind of started this. Just so let
16 you guys going here, so what you're saying is, in
17 terms of volumes, the, what I'll call the plenum
18 volume coming into the dryers is the same here,
19 except for you've interposed now the chimney.

20 And it's your -- the design, your
21 analysis seems to indicate that the presence of the
22 chimney does not change anything coming into the
23 dryer relative to, well, maybe saying nothing,
24 modest -- it doesn't have a large effect on what the
25 loads would be coming into the dryer?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 So, whether I had the chimney there or
2 not, it seems not to have a big effect on dryer
3 loads? What about vibrations within the chimney?
4 Are you going to eventually get to that?

5 MR. KECK: We'll have sensors on the
6 chimney.

7 MR. DEEVER: Well, what we've done is,
8 we've gone through a test program. I think I
9 described that in one other meeting. Where we went
10 through a --

11 CHAIRMAN CORRADINI: Yes, can you remind
12 me since I have a bad memory. I'm sorry.

13 MR. DEEVER: Well, we had a 12-scale, a
14 6-scale and then essentially a full-scale single
15 cell that we monitored. We sent a steam water
16 mixture. This was a Hitachi test done in Japan.
17 So, we had sensors along the length of the chimney,
18 and we monitored pressures going up the chimney.

19 CHAIRMAN CORRADINI: At full pressure
20 temperature?

21 MR. DEEVER: No. These were not at full
22 pressure temperature. This was an air-water
23 mixture.

24 CHAIRMAN CORRADINI: Oh, I thought you
25 said steam water. I'm sorry. I misheard you.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 Excuse me.

2 MR. DEAVER: And so from that data, then
3 they've been able to extrapolate that data to
4 determine what the stresses are and you know, there
5 were a couple of different kind of tests where they
6 -- they're basically assuming non-coherence between
7 the two cells, you know, adjacent cells in the
8 chimney, such that it basically creates the worst
9 case as far as the loading condition.

10 CHAIRMAN CORRADINI: These were two
11 chimneys, excuse me, again? I remember the three
12 scales that you just said, but these were two
13 adjacent chimneys with different flow
14 characteristics?

15 MR. DEAVER: Well, what we did is, one
16 cell where we monitored flow through a cell, but
17 they also changed the configuration to be more like
18 a cruciform shape, where they could identify
19 interaction effects across the different partitions.

20 CHAIRMAN CORRADINI: Oh, I see. In terms
21 of what was injected into that one chimney, into
22 that one chimney.

23 MR. DEAVER: Right.

24 CHAIRMAN CORRADINI: So, you had a full
25 4x4, but in three different scales?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. DEAVER: No. I wouldn't say it's a
2 4x4. It's one cell, but then it -- within that same
3 cell configuration, they had a configuration that
4 was basically four quadrants.

5 CHAIRMAN CORRADINI: Okay. I see.

6 MR. SIEBER: Just so they could get flow
7 on both sides of the pin.

8 CHAIRMAN CORRADINI: I understand. All
9 right. Thank you.

10 MR. DEAVER: And I guess what I'm saying
11 is that between the coming up from the chimney which
12 is you know, kind of the equivalent of flow coming
13 out of the core --

14 CHAIRMAN CORRADINI: Right.

15 MR. DEAVER: -- that that gets mixed, and
16 then it goes through the separator, that gets mixed,
17 goes into the steam dryer at that point. And we've
18 got more DP's coming through the core, so a lot of
19 the drivers in that --

20 MR. WALLIS: That mixing region above the
21 chimney is fairly shallow isn't it? So --

22 MR. DEAVER: It's two meters.

23 MR. WALLIS: Yes, have your cell figure
24 right then?

25 MR. KENT: I think it is.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. DEEVER: Yes.

2 MR. WALLIS: That's two meters up there?
3 It's very broad. You're not going to mix from side
4 to side. You're going to mix a few channels, but
5 you're not going to mix everything together.

6 CHAIRMAN CORRADINI: You have to be at a
7 microphone, I'm sorry to say.

8 MR. WALLIS: It will do some mixing, but
9 it won't volumize.

10 MR. DEEVER: I guess what I'm saying is,
11 in prior BWR geometries, if you could basically
12 eliminate the chimney --

13 MR. WALLIS: You get the same thing.

14 MR. DEEVER: -- you have the same thing.
15 You have the same amount of volume above. And so
16 when it came out of the core, it had, it's the same
17 ability to mix.

18 CHAIRMAN CORRADINI: And there is a gap
19 at the core level between the chimney and the core,
20 yes?

21 MR. DEEVER: Here, no. No. The
22 partitions fit directly on top of the core plate.

23 CHAIRMAN CORRADINI: Top guide.

24 MR. DEEVER: Because at that point, they
25 really don't want cross flow. They want to keep the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 flow confined to the cells.

2 CHAIRMAN CORRADINI: Okay. So my
3 memory's wrong. I remember some sort of -- we were
4 told there was some sort of gap between the core and
5 the chimney. Maybe I'm just misremembering.

6 MR. DEEVER: We'll never be able to make
7 it perfect.

8 CHAIRMAN CORRADINI: So within
9 tolerances, it's no gap.

10 MR. DEEVER: Right.

11 CHAIRMAN CORRADINI: Got it. Fine.

12 Thank you.

13 MR. WALLIS: How do you get performance
14 out of the separator if it's 15 percent more slow,
15 but yet the same size separator?

16 MR. DEEVER: Well, what we've done to the
17 separators is, the normal pitch between separators
18 has been 12 inches. We've changed that pitch to 11
19 and a half inches now. And so we have
20 proportionately quite a few more separators.

21 CHAIRMAN CORRADINI: You added
22 separators.

23 MR. DEEVER: Than we've had in the past.

24 CHAIRMAN CORRADINI: But they're
25 smaller.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. DEAVER: No, the separators are the
2 same design, except that the spacing between them
3 have been condensed.

4 CHAIRMAN CORRADINI: Okay, all right.

5 MR. DEAVER: So we have like 379
6 separators, I don't know what the equivalent number
7 would have been if we had just the 12-inch pitch.
8 It would have been, you know, 30 or 40 less
9 separators, I believe. So that way we can get more
10 performance out of --

11 MEMBER BROWN: -- pressure drops or
12 anything of that nature.

13 MR. KECK: And also the steam dryer, the
14 face area has increased to accommodate the --

15 MEMBER BROWN: Okay. So you did change
16 the design proportionately.

17 MR. DEAVER: But what we have is a little
18 bigger diameter of -- ABWR and ESBWR have the basic
19 same inside diameter, but the flanges are a little
20 different at the top. We're able to expand the
21 dryer a little bit because of the wider flange
22 configuration which allows --

23 MR. KECK: Larger diameter, but yet, we
24 maintain the same distance, annular distance,
25 annular space between the dryer and the vessel wall.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER ARMIJO: But you've sized it for
2 the 15 percent more steam flow.

3 MR. KECK: As far as the face area in the
4 dryer, yes.

5 MR. DEEVER: We were able to expand the
6 width of the banks a little bit, and then we went a
7 little higher.

8 MR. KECK: There's three sections in here
9 that are closely tied together, the dynamic response
10 of reactor internals under transient and normal
11 operating conditions, the initial startup FIV
12 testing of reactor internals, and then the last one
13 listed, correlation of test and analysis results.
14 They're pretty closely tied.

15 And going on to the initial startup FIV
16 testing of reactor internals, and the purpose of
17 that was to verify the effect of the single and two-
18 face flow on the vibration response of internals.
19 And then we --

20 MR. WALLIS: Are you going to instrument
21 the reactor for all this FIV.

22 MR. KECK: Yes. And there's an Appendix
23 3.L where we discuss our instrumentation, and then
24 also, there's a table. There's a table within 3.9
25 where we list the sensors and their locations. And

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 I think the typical locations that we've had in the
2 past, and then the additional for the three
3 components side of the evaluation program, which is
4 the dryer, the chimney and the SLC, the SLC internal
5 piping.

6 And this section also talks about
7 compliance to Reg Guide 1.20.

8 MR. DEAVER: I might also mention we have
9 a topical report also that we prepared and submitted
10 last November which goes into all the details
11 regarding the analysis for reactor vessel vibration.

12 MEMBER BROWN: So you're going to
13 determine -- your instrumentation is to determine
14 what is the fluence vibration response, I take it.
15 Is that the intention of the instrumentation? You
16 said, you're going to instrument it, so I presume
17 there was a basis for --

18 MR. DEAVER: Well, we have Reg Guide
19 1.20, which really requires that any first-of-a-
20 kind-type plant, that we instrument it as a means
21 of, to confirm our analysis results.

22 So, we set up a criteria, and we
23 instrument, and then we basically have to confirm
24 that the vibration results are less than our
25 criteria, then the plant's acceptable to operate.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER BROWN: I think you've just
2 answered my question.

3 MR. DEEVER: And also, what's going to be
4 a little different here is that --

5 MEMBER BROWN: Could have said yes, it
6 would have been a lot --

7 (Laughter)

8 MEMBER BROWN: No, that, there was
9 nothing wrong with that. It's just you could have
10 blown it right past me if you'd have said yes.

11 MR. DEEVER: Also what we'll be doing is,
12 we'll be making correlation. We'll be instrumenting
13 the steam line and correlating the response on the
14 dryer as a means to better understand the dryer
15 vibration. So, that's part of our program also,
16 which hasn't been typical of past programs.

17 MEMBER BLEY: Can I ask you a naive
18 question? Why do we need the channels up in the
19 chimney region above the core?

20 MR. DEEVER: Okay. Well, that's
21 basically to keep the steam focused in a straight
22 line coming up above the core. We need the --

23 MEMBER BLEY: To simplify your
24 calculations, or you really need the uni-direction?

25 MR. DEEVER: Well, what will happen, if

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 you don't have it, it will start vortexing.

2 MEMBER BLEY: Up above. Okay.

3 MR. KECK: Up above.

4 MEMBER BLEY: Instead of going around.

5 Okay.

6 MR. DEEVER: Yes. And you'll get a whole
7 different dynamics going in with the steam that we
8 don't want.

9 MEMBER BLEY: Okay.

10 CHAIRMAN CORRADINI: Based on what? What
11 tells you you don't want it?

12 MEMBER ARMIJO: Well, there would be more
13 flow going through some of the channels, some of the
14 fuel assemblies.

15 MR. WALLIS: So it's a general fear of
16 vortexing isn't it? It's not that you know it's
17 going to happen.

18 MEMBER SHACK: The original design didn't
19 have those channels, right?

20 MR. DEEVER: The prior natural circ
21 plants did have partitions, okay. The Dodowaard
22 plant, had partitions that were about ten foot high.
23 These are more like 20 foot. But you know, so that
24 was a small plant.

25 CHAIRMAN CORRADINI: So the worry is a

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 sloshing problem?

2 MR. DEAVER: Well, it's really --

3 CHAIRMAN CORRADINI: Sloshing --

4 MEMBER BROWN: Steam sloshing?

5 MR. DEAVER: Steam water, you know, what
6 enters into the separators will be very
7 inhomogeneous, all right. And the performance of
8 the dryer, I mean, of the separators would probably
9 suffer. You know, you'd be, wrong quality water
10 possibly and those sorts of things.

11 CHAIRMAN CORRADINI: Thank you.

12 MEMBER BROWN: I have one other, how do
13 -- this is an education. How do you ensure that you
14 get balanced flow up through all of the partitions,
15 is it? Are they focused on particular channels in
16 the core itself, and those are where the heating is
17 not totally symmetrical?

18 MR. DEAVER: Well, if we were to show you
19 a plan view --

20 MEMBER BROWN: Loading across those
21 partitions.

22 MR. DEAVER: -- the top guide typically
23 has four fuel bundles, and a control blade in it.
24 But a chimney partition cell has actually got 16
25 bundles with four control blades in it. So, this is

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 an attempt to channel a larger flow stream up above
2 the top guide. But that's a convenient geometry to
3 focus the flow through.

4 MEMBER BROWN: Okay. This time you
5 didn't really answer.

6 MR. DEEVER: What, what -- maybe you need
7 to reiterate it.

8 MEMBER BROWN: I was just trying to --
9 now, I was just looking at uniformity of generation
10 of steam --

11 MR. DEEVER: Oh, okay.

12 MEMBER BROWN: -- across the entire
13 cross section.

14 MR. DEEVER: Okay.

15 MEMBER BROWN: And how do you get that
16 normally if you get asymmetry is, you like it to mix
17 up somewhere as you head up into the upper part of
18 the cell.

19 MR. DEEVER: Well, a lot of this is tied
20 to core dynamics and how you're generating steam and
21 the core performance side.

22 CHAIRMAN CORRADINI: But given a loading
23 pattern, I guess I thought you were going to tell
24 him, given a loading pattern, you already should
25 have the inlets orificed so that given a certain

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 pattern, they've orificed it so to --

2 MEMBER BROWN: So that they get balanced
3 steam coming from across the board.

4 MS. CUBBAGE: I think the thermal.
5 hydraulic -- I mean, as far as that's like more of a
6 chapter --

7 CHAIRMAN CORRADINI: Yes, yes.

8 MS. CUBBAGE: Different chapter,
9 different --

10 CHAIRMAN CORRADINI: We're taking you
11 where you don't want to go, but that's --

12 MEMBER BROWN: I'd like to find out
13 what --

14 MEMBER ARMIJO: We're taking you where
15 we're interested.

16 CHAIRMAN CORRADINI: Go ahead.

17 MR. DEAVER: The design tries to balance
18 the steam flow throughout there to flatten it. But
19 you know, it's not a perfect world either.

20 MR. KECK: Okay. And then the last
21 section is a dynamic analysis of reactor internals
22 under faulted conditions. And here, just load
23 combination as a result of faulted conditions, RPV
24 line break, earthquake, or SRV, or DBV discharge.

25 Then we start to discuss the structural

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 integrity of the pressure retaining components,
2 their supports, and of course, the core structures
3 in 3.9.3.

4 The first section, the load combinations
5 design transients and stress limits also covers the
6 methods. We see some details where we find info
7 within the DCD. Okay, this is again, it points to a
8 lot of locations within the DCD where you're going
9 to find the information. It also discusses the 60-
10 year lifetime. And you know, all components except
11 the vessel, are designed to be replaced.

12 Plant conditions, normal, upset,
13 emergency and fault are explained in this section,
14 and those event probabilities for each of those
15 occurrences. Safety-related functional criteria,
16 where normal and upset flow permanent deformation to
17 deteriorate the component's ability to perform its
18 safety function, or emergency unfolded where
19 capability of a safety-related component may be, may
20 have to be repaired.

21 Then we go over to component
22 information, related ASME code requirements, RPV,
23 piping, basically just, you know, other components
24 accumulators, valves, heat exchangers, and discusses
25 designs, the design of the component, an analysis

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 approach and acceptance criteria.

2 Then we go into the value operability
3 assurance, including actuators, your major active
4 valves, such as your MSIV, SRV or SLC injection,
5 your DPVs and your other active valves. And some
6 unique functional qualification for dynamic events
7 are covered for each one of those valves.

8 And the design installation of pressure
9 relief devices, your SRVs and your DPVs. And then
10 your ASME component support design, basically
11 subsection NF for piping, that would be your piping
12 supports, your spring hangers, your snubbers and
13 also your support for your RPV, your sliding
14 support, your floor mounted major equipment support.

15 And then finally the discussion on the
16 ASME threaded fastener design continuing material
17 related to SRP 3.13.

18 MEMBER BROWN: You said that the RPV
19 components were designed to be replaced.

20 MR. KECK: Designed to be replaced,
21 except for the vessel.

22 MEMBER BROWN: Is there -- except for the
23 vessel.

24 MR. KECK: But the intent is 60 years.

25 MEMBER BROWN: Is there some -- do you

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 have to then inspect them periodically during
2 refueling operations to determine that you don't
3 have to replace them? Is there some criteria?

4 MR. DEAVER: There will be a regular
5 inspection program for reactor internals. That's
6 been an ongoing program, you know, for operating
7 plants, that there's a --

8 MEMBER BROWN: For your existing DWRs?

9 MR. DEAVER: Yes. There's a VIP program,
10 vessels internal program, that they follow. And so,
11 there will have to be a separate committee, you
12 know, an owner's group that will look at the ESBWR.
13 We will be doing things quite differently as far as
14 the manufacture and installation of internals such
15 that we'll have a lot more resistance to cracking
16 and corrosion problems. And so they're have to set
17 appropriate inspection guidelines.

18 MEMBER BROWN: And who sets the standard
19 for those?

20 MR. DEAVER: Well, the owner's group
21 typically.

22 MEMBER BROWN: You guys, I mean you all
23 designed it.

24 MR. DEAVER: Well, we're involved, but
25 typically it's the owner's group presents the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 program to the NRC for approval in that area. So
2 there will be a regular program for visual
3 inspections and as needed, volumetric inspections.

4 Some of the components, the dryer,
5 separator, and so forth, they actually come out of
6 the vessel. And so there's opportunities to go in
7 the pools and look at those on a routine basis.

8 MEMBER ARMIJO: Now the chimney doesn't
9 come out during refuelings? Or, is that your plan?

10 MR. DEEVER: That's our plan now, is to
11 make it removable.

12 MR. KECK: That the partitions will be
13 removable. The barrel will stay.

14 MEMBER ARMIJO: Oh, okay.

15 CHAIRMAN CORRADINI: The what, I'm sorry?
16 Excuse me?

17 MEMBER ARMIJO: The chimney is going to
18 come out during the refueling, is your current plan?

19 MR. DEEVER: It has the capability to
20 come out every refueling outage and to make it more
21 accessible to do the refuel.

22 MEMBER ARMIJO: During refuel?

23 MR. DEEVER: Yes. The barrel part, the
24 outside part, will remain. But the partitions,
25 that's the difficulty that the customer saw, was

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 being able to get into the cells for core
2 verification and you know, moving up out of the cell
3 into another cell to do shuffles and so forth. So
4 we've done studies where we believe refueling can be
5 done much shorter without the partitions.

6 MEMBER ARMIJO: What's a likely time
7 period?

8 MR. DEAVER: A shorter time period. A
9 shorter time period, yes.

10 CHAIRMAN CORRADINI: Did you -- when you
11 say studies, curiosity, is it, do you have, like
12 full size mocks where you -- mockups where you --

13 MR. DEAVER: No, this was more of an
14 experience, you know, factor of how long it takes to
15 move a bundle. So it's mainly a time and distance
16 kind of study.

17 CHAIRMAN CORRADINI: I see.

18 MEMBER SHACK: But how would the
19 partition be located within the core barrel then, it
20 just slides in?

21 MR. DEAVER: No, it will have to be
22 accurately positioned at the base. We haven't done
23 all the detail design work. But I envision it being
24 locating pins that accurately place it with respect
25 to the top guide.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 And then, we're going to need particular
2 lateral support at the top to prevent vibration, you
3 know, motion at the top.

4 MEMBER SHACK: I just think it's going to
5 be pretty wiggly, actually. I mean, it's --

6 MR. KENT: The chimney barrel has lateral
7 restraints similar to the vessel itself. So, I mean,
8 this is a taller structure piled up on top of, you
9 know, it's our experience --

10 CHAIRMAN CORRADINI: It's seven meters,
11 isn't it?

12 MR. KENT: And before, we didn't have the
13 lateral restraints at the top. So, the chimney will
14 have the lateral restraints.

15 MEMBER SHACK: And how thick is that
16 barrel?

17 MR. DEAVER: It's like two inches. It's
18 similar to the shroud construction. But the
19 partitions themselves, we'll have to stabilize
20 those.

21 MR. KENT: Control rods, the CRD system,
22 you know, this is primarily discussed in 4.6.1. But
23 this section will discuss the applicable
24 regulations. Some of the components such as this FM
25 CRD mechanism, ATU assemblies, interconnecting

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 piping, instrumentation, things like that. And then
2 it also defines the design loads and stress limits.

3 The CRD performance assurance program
4 tests are described also in DCD Section 4.6, the
5 factory quality tests, functional tests, operational
6 tests and then the surveillance tests.

7 Yes, this is an eye chart. This is
8 typically each one of these sections start out with
9 you know, defining the loads, where the loads come
10 from, the events. And this chart itself is broken
11 up into the thermal hydraulic, transients, daily and
12 weekly reduction of 50 percent power, and then also
13 has your dynamic loading events, your faulted level
14 conditions. And from this, we derive our load
15 combinations.

16 MEMBER STETKAR: Dave, I'm curious. I
17 passed the eye test, 8A, things that I would call a
18 general transient-type scram, turbine trips, reactor
19 trips, reactor scrams, those types of things,
20 nonloss of heat water scrams, I notice you have 60
21 in there for a 60-year plant life, which if I do the
22 division correctly is one per year. Notice how I
23 can do that. I still do that in my head.

24 All of the other -- I did it on the -- I
25 have it written down here. All of the other

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 transients that you have in there seem, the numbers
2 seem quite conservative with respect to actual
3 operating experience in terms of numbers of events
4 per year.

5 MR. KECK: Yes.

6 MEMBER STETKAR: Even the loss of heat
7 water transients, given recent experience, except
8 for this one. This one is, might be numerically
9 conservative, but it's only one per year. So, if I
10 have three this year, I better not have any more
11 trips for the next two more years, or I might be
12 violating some design analysis input. Is that the
13 correct way to interpret this?

14 And if so, what's the basis for you
15 know, why did you use such a thin margin on that
16 particular transient?

17 MR. KECK: Well, we basically picked the
18 numbers based on experience. I think typical of
19 prior BWRs, in the early startup phase, there were
20 more transients and situations. But as time went
21 on, plants have tended to level out. Their
22 operation is more consistent. They don't have a lot
23 of these transients.

24 MEMBER STETKAR: They don't have a lot,
25 but one per year is not many.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 MEMBER ARMIJO: And this will be a new
2 plant.

3 MEMBER STETKAR: I happen to be pretty
4 familiar with the Leibstadt plant, and they tend to
5 come down roughly once a year. Sometimes, a couple
6 of times.

7 MR. KECK: They tend to have annual ones.

8 MEMBER STETKAR: No, no, no. I mean
9 trip. Actual trips. They're getting better, but
10 they still, you know, they have a wonderfully high
11 availability factor, but they still tend to trip,
12 turbine trips and things like that.

13 It's the only number that was so close
14 to experience out of this whole table, that I was
15 curious about why it was that close, or whether it
16 makes a big difference whether you double that
17 number in terms of --

18 MR. KECK: Well, we do have the A and B.

19 MEMBER STETKAR: You do, yes. And B in
20 fact, if I add the to together, you get two trips
21 per year.

22 MR. KECK: Right, yes.

23 MEMBER STETKAR: One feed water related,
24 which is probably a little more severe. And that's
25 probability a little bit on the high end. But it

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 was just more of a personal curiosity that that the
2 only number in this table that seemed pretty doggone
3 close to real operating experience. And that if
4 it's -- and doesn't leave much margin to going back
5 and analyzing things if you have, you know, three
6 trips in one year, it could be a problem.

7 MR. DEAVER: Well, yes, obviously in
8 plant operation, you're going to have to take track
9 of cycles of events.

10 MEMBER STETKAR: Yes, that's right. I
11 mean, if you get 30 years out and you've already had
12 40 trips, for example.

13 MR. DEAVER: There would be a need to go
14 back in and re-evaluate.

15 MEMBER STETKAR: And re-evaluate because
16 the term -- would it make a big difference to your
17 analysis if that number were doubled to 120? I
18 don't do design analysis work, so I have no idea
19 what the implications of these numbers like that,
20 that one in particular.

21 MR. DEAVER: Well, actually, item 7 also
22 has 60 cycles.

23 MEMBER STETKAR: Well, that's right. A
24 lot of the other ones -- and that's a very
25 conservative number compared to what you see.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. DEAVER: See, what I'm --

2 MEMBER STETKAR: My only curiosity is,
3 why that one and everything else that I looked at
4 said well, this is quite a conservative design
5 margin, except for this one.

6 MR. DEAVER: Yes. Well, what my memory
7 is that, see all those happen to be, B service limit
8 items.

9 MEMBER STETKAR: Yes, right.

10 MR. DEAVER: And they're all associated
11 with scrams, typically.

12 MEMBER STETKAR: Right.

13 MR. DEAVER: So it was the collective
14 number that we were looking at, more than just the
15 individual numbers.

16 MEMBER STETKAR: So the collective
17 numbers.

18 MR. KECK: The collective number
19 incorporate --

20 MR. DEAVER: Right, 180, and those
21 transients are quite similar when you look at
22 actually the loss feed water heaters is probably the
23 more limiting of the three.

24 MEMBER STETKAR: That's right. Yes, in
25 terms of the thermal. Okay. Thanks. That's

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 probably enough.

2 MR. KECK: Okay. So, Section 3.9.6 is
3 in-service testing of certain pumps and valves
4 performed in accordance with the ASME code. Since
5 ESBWR does not include any safety-related pumps,
6 none are included in the IST program.

7 It provides a full description of the
8 IST program for valves, including plan testing and
9 inspections. There is a rather large table at the
10 back that includes, the back of this Section 3.9,
11 that lists the valves that were part of the IST
12 program, including valve positions, test parameters,
13 test frequencies.

14 MR. DEEVER: Basically, what we've done
15 there is, we've expanded that table to include a lot
16 more material than we typically have in past
17 certifications, mainly to accommodate the COL
18 process. The idea being, to put as much as possible
19 into this program now to avoid further definition
20 later on where things are generic.

21 So, we think we've more than covered the
22 needs on the DCD basis for the IST program.

23 MR. KECK: That was Section 3.12. I
24 could just skip to 3.9.5.

25 MR. DEEVER: Well, we can talk about 3.12

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 though.

2 MR. DEEVER: Okay. Basically this is the
3 section that we don't have a 3.12.

4 CHAIRMAN CORRADINI: Yes, I noticed that
5 too.

6 MR. DEEVER: And it's because the SRP,
7 you know, came out in March of 2007. So, in the
8 course of the DCD review, we were getting 3.12
9 questions, and which I guess the NRC was
10 anticipating the SRP.

11 MS. CUBBAGE: Right. Well, we had always
12 planned on writing an SE Section 3.12. So, that's
13 how we numbered the RAIs.

14 MR. DEEVER: so, basically all those
15 RAIs, there were 38 of them, they basically all were
16 answered through either 3.7.3, or 3.9. So, all of
17 those were related to piping and their supports.
18 And those topics were fundamentally covered already
19 in those other sections. And so any adjustments or
20 changes to the DCD we made back in 3.7 or 3.9. And
21 we're pretty well resolved on most of those issues
22 at this point.

23 MR. KECK: Okay. And we were asked to --
24 or I was asked to present 3.9.5 last. This is the
25 RPV internals. And this -- there's an initial

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 section, provides a description of the support and
2 other internal components. The supports being the
3 shroud, the shroud support, the core plate, top
4 guide, fuel supports, control rod guide tubes and
5 then the internals, which is your chimney, your
6 steam separator assembly, dryer, spargers, SLC and
7 core guide tubes.

8 Your low conditions, including RPV line
9 break, accidents, earthquakes and internal pressure
10 differences, discuss the events evaluated and the
11 reactor internal pressure differences are also
12 evaluated.

13 And then the design basis related to
14 safety and power generation, safety-related
15 functions, power generation, internal arrangement
16 for coolant distribution and refueling, and then the
17 loadings for plant events and stress deformation and
18 fatigue limits. For deformation limits, we have
19 tables. For your deformation limits, your primary
20 stress limit, your buckling stability, your fatigue
21 limits, and the criteria was established based on
22 codes for similar equipment or established based on
23 field experience and testing.

24 MR. DEEVER: You need any more discussion
25 on the vessel?

1 MR. WALLIS: What is this vessel
2 stabilizer?

3 MR. KECK: We have a -- as far as the
4 vessel, the entire vessel sits as far as its
5 support?

6 MR. WALLIS: Well, it seems, it sits down
7 below doesn't it? It sits on the --

8 MR. KECK: About a third of the way up,
9 you'll see some supports. They're sliding type
10 supports.

11 MR. WALLIS: One of the supports seems to
12 have a hole through it. What is that?

13 MR. KECK: Okay. That's the GDCS
14 equalizing line.

15 MR. WALLIS: The GC line is supported, it
16 supports the reactor?

17 MR. KECK: No. There's an integral
18 forging and again, this is the way this cross
19 section is made. There's eight supports, and in
20 between some of the supports, we have this
21 equalizing line.

22 CHAIRMAN CORRADINI: But that's the flow
23 in for the GDCS?

24 MR. KECK: Yes.

25 MR. WALLIS: But that's not supported the

1 way its shown.

2 MR. KECK: No, no.

3 CHAIRMAN CORRADINI: No. No, no. It's
4 two things drawn on top of each other.

5 MR. KECK: It's to the left. The left
6 support is more -- the left is support is more
7 representative.

8 MR. WALLIS: Now the stabilizer at the
9 top, what is that doing?

10 MR. DEEVER: That's the typical
11 stabilizer we've had on all prior product lines,
12 except BWR-VI. This is just an upper support.

13 MR. WALLIS: Does it have seismic
14 purposes?

15 MR. DEEVER: Yes. For seismic only.

16 MR. WALLIS: It's just in one place, or
17 is it all the way around?

18 MR. DEEVER: No, there's eight.

19 MR. WALLIS: It's all the way around,
20 there's eight of them.

21 MR. DEEVER: Yes.

22 MR. WALLIS: Well, it would be nice if
23 you'd put something like, eight of, or something.
24 So we -- it looks funny just to see one. You really
25 should see it with the other view.

1 MEMBER SIEBER: When you cut it in half,
2 that's all you can see.

3 CHAIRMAN CORRADINI: So the weight of the
4 vessel sits on those eight pedestals.

5 MR. KECK: Yes.

6 CHAIRMAN CORRADINI: And those eight
7 pedestals fit into blocks which sit on a concrete
8 pad as the upper dry well narrows to the lower dry
9 well. Do I have -- is that correct in my memory?

10 MR. KECK: Well, there's a --

11 CHAIRMAN CORRADINI: The upper dry well,
12 it kind of narrows down with a concrete shelf, and
13 then it goes this, and these guys sit on abutments
14 that are sitting on that shelf.

15 MR. DEAVER: I think the later figure
16 will help.

17 CHAIRMAN CORRADINI: Okay, fine. Never
18 mind then.

19 MR. DEAVER: Well, we could look at it
20 now.

21 CHAIRMAN CORRADINI: Just point to it
22 when you're there.

23 MR. KECK: Okay, all right. Here's the
24 geometry.

25 MR. DEAVER: What you're referring to is

1 this lower area down here.

2 CHAIRMAN CORRADINI: Yes, it narrows.

3 MR. WALLIS: You're in the way, can't
4 see. You're standing in the way.

5 CHAIRMAN CORRADINI: He's fine for me,
6 Graham.

7 MR. DEAVER: The area we're talking about
8 is this --

9 CHAIRMAN CORRADINI: No, you're up a
10 little bit.

11 MR. DEAVER: Yes. This area right here
12 is the sliding support. And below it is basically
13 the pedestal arrangement. It does go towards the
14 vessel, and then you know, ultimately becomes the
15 lower dry well area down here.

16 CHAIRMAN CORRADINI: Those are like steel
17 girders that then sit on the concrete pad?

18 MR. DEAVER: Yes. This is basically a
19 steel structure. It's mainly steel as opposed to
20 any concrete.

21 CHAIRMAN CORRADINI: Right. But the
22 concrete is the wall it's sitting on below. Right
23 there, that shelf?

24 MR. DEAVER: Usually there's a composite
25 of steel and concrete, make up the pedestal

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 construction.

2 CHAIRMAN CORRADINI: Oh. Okay. Thank
3 you.

4 MR. DEAVER: Yes, there's all this
5 structure down here.

6 MR. WALLIS: there's a BiMAC underneath
7 this whole thing?

8 (Laughter)

9 CHAIRMAN CORRADINI: You had your chance.
10 You missed it.

11 MR. WALLIS: Understand the designer
12 wasn't there either.

13 MEMBER SIEBER: There is an imitation of
14 it.

15 CHAIRMAN CORRADINI: But yes, I think
16 it's down there, Graham. Right on the bottom.

17 MR. WAAL: All right. Any other
18 questions on 3.9?

19 CHAIRMAN CORRADINI: Keep on going.

20 MR. WAAL: Okay. Then Mr. P.K. Dey will
21 give us -- will talk about Section 3.6.

22 MR. DEY: Good afternoon. My name is
23 Pijush K. Dey. I'm GEH engineer. And I'll be
24 talking on the Section 3.6.

25 This section, the title is protection

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 against dynamic effects associated with a postulated
2 rupture of piping. And --

3 MEMBER SHACK: One surprising think I
4 found was no mention of anything like leak-before-
5 break to eliminate some postulated line breaks.

6 MR. WAAL: That's correct.

7 MEMBER SIEBER: They're not using it.
8 They've said that.

9 MR. WAAL: We're not taking any credit
10 for leak-before-break.

11 MEMBER SHACK: And why is that? Just you
12 don't want to debate with the staff?

13 MR. DEEVER: We chose -- we know that
14 that's a very involved, complicated technology that
15 you know, we just chose not to pursue that just
16 because of the complexity and the review time that
17 would be required.

18 MEMBER ARMIJO: But if you'd be using
19 better materials, the arguments have been thrashed
20 over and resolved. Couldn't you align with that.

21 MR. WAAL: I mean, we're not talking
22 about it for ECCS.

23 MEMBER ARMIJO: Yes.

24 MR. WAAL: I mean, we're just talking
25 about it for just dynamic loads here. But you --

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 okay, that's your decision.

2 MEMBER ARMIJO: I just didn't understand
3 why.

4 MR. DEY: In this section, we will,
5 Section 3.6, we'll talk about the, how we determine
6 the break locations and the mitigation for these
7 breaks and also finally, we do the as-built
8 inspection on the high-energy pipe break as part of
9 the mitigation features.

10 Section 3.6.1, plant design for
11 protection against postulated piping failures in
12 fluid systems inside and outside containment. This
13 section provides a description of the design bases,
14 criteria, objectives and the assumptions. And we
15 identify the piping which are the high energy and
16 the moderate energy lines inside and outside
17 containment.

18 Then design evaluation of pipe break
19 events and the features of, to provide the
20 protection against the effects of pipe break events.
21 The section also gives the protection methods
22 include physical separation, like barriers,
23 barriers, shields and enclosures and pipe whip
24 restraints.

25 The next section, Section 3.6.2, it

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 gives the pipe break locations and dynamic effects
2 with the postulated rupture of piping. And we
3 determine the pipe rupture, are postulated in
4 accordance with the BTP 3-4 branch technical
5 position, which was formally EME 3-1.

6 Then of course, for fatigue usage of .40
7 is used when we analyze for the environmental
8 fatigue, that is in accordance with Reg Guide 1.207.

9 ESBWR, our design intends to use, you
10 know, we're going to use BTP 3-4 limits and going to
11 maintain pipe stress locations, I mean the terminal
12 stress points, we want to do stress points in such a
13 way that we can avoid those intermediate break
14 locations. Therefore, we will end up having only
15 terminal end breaks.

16 MEMBER ARMIJO: I guess I don't
17 understand what that means, terminal end breaks
18 means, let's say attached to a vessel, or --

19 MR. DEY: Terminal end breaks is a pipe
20 that connects to the nozzle's, reactor nozzles, or
21 the treatment nozzles, like tank, heat exchangers,
22 the pipe terminus and --

23 MR. WALLIS: So you deliberately make it
24 weaker at its ends?

25 MR. DEY: No.

1 MR. DEEVER: Let me speak to the vessel
2 side.

3 MR. WALLIS: No, it's only going to break
4 there.

5 MR. DEEVER: On the vessel, the nozzle
6 and what we call the safe end that attaches to it,
7 is intentionally thicker and stronger than detached
8 piping.

9 MR. WALLIS: Usually that's stronger
10 there. Yes.

11 MR. DEEVER: But the piping you know,
12 isn't intentionally made weaker at that connection.
13 I think it's a recognition that typically the high
14 stress points occur at these rigid ends where the
15 piping is attached. So, the expectation is, that
16 the highest stresses will be at those locations.

17 MR. WALLIS: Because of the weld, some
18 residual stresses or something?

19 MR. DEEVER: No.

20 MR. DEY: It's the discontinuity.

21 MR. WALLIS: Oh, it's because that's
22 where the bending is?

23 MR. DEY: Bending and highest load comes
24 through the anchor location, axle and forces at
25 moments of you know, at anchor locations.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. WALLIS: But at a big valve, the
2 weld's attached to a big valve, those would not be
3 considered terminal ends?

4 MR. DEEVER: No. No.

5 MR. DEY: Because that valve is modeled
6 with the piping, we analyze them and the stress
7 levels at all locations from anchor to anchor,
8 nozzle from the tank, these are the terminal ends
9 that actually at the moment the forces that we have.

10 MR. DEEVER: It's a recognition of where
11 the rigid end points are, as opposed to in-line
12 components.

13 MR. WALLIS: But from the residual
14 stress, attaching a pipe to a big heavy valve might
15 bring some extra --

16 MEMBER SHACK: Residual stresses never
17 appear in these tolerances.

18 MR. WALLIS: Well --

19 MEMBER MAYNARD: If the valves that were
20 anchored, that would be an end point, though, right?

21 MEMBER SIEBER: Yes.

22 MEMBER MAYNARD: If a valve is well
23 within line, well then it's analyzed as part of the
24 line.

25 MR. DEEVER: Yes.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER MAYNARD: But if it was anchored,
2 then that would be it.

3 MR. DEY: That would be it.

4 MR. DEEVER: Right. So it would have to
5 be considered a terminal end.

6 MR. WALLIS: Well, this is, I guess it's
7 okay, but there are a lot of places where you have
8 thermal stresses and things which could make a pipe
9 break somewhere else other than its end.

10 MR. DEEVER: Well, that's why the
11 criteria, what we have to design to is, 80 percent
12 of the stress levels. So all these intermediate
13 locations have to be below 80 percent of the stress
14 limit, and we have to keep the fatigue usage lower.
15 You know, the normal limit is 1. So, we --

16 MR. WALLIS: So, not weaker at the end,
17 but you're ensuring that the loads are bigger at the
18 end, which is kind of the same thing.

19 MR. DEY: We will perform the stress
20 analysis, model the piping, and we will support it
21 in such a fashion that stresses on the piping in
22 between, I mean between the anchor and actual
23 location of the piping will remain less than the
24 threshold stress limit that is given in the BTP3-4.
25 And that is 80 percent for Class II and III type of

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 piping, 80 percent of the hot model by the stress
2 range, normal stress range.

3 And once you put that below are the IV
4 Class one, is less than .1 fatigue limit, then we do
5 not then to postulate the breaks.

6 MR. DEEVER: Now, the stress at these
7 terminal ends may not be any higher than the 80
8 percent criteria or anything, but that's the
9 standard we're required to.

10 MR. DEY: Yes. We are required to
11 postulate a break at the terminal end, regardless of
12 the stress level.

13 MR. WALLIS: What does BTP stand for?

14 MR. DEY: Branch Technical Position.

15 MS. CUBBAGE: Those are basically --

16 MR. DEY: Branch Technical Position.

17 MS. CUBBAGE: They're basically --

18 MR. WALLIS: Oh, so it's NRC.

19 MS. CUBBAGE: Yes. Those are like
20 appendices to the SRP.

21 MR. DEY: And then farther on this
22 section, it also provides the analytical methods to
23 define the blowdown forces that will be accounted
24 for in our analysis and will determine the, you
25 know, the jet impingement and pipe break loads onto

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 the structures on which it will impinge on and
2 provide the adequate protection where safety-related
3 structure is being interacted by jets.

4 MR. WALLIS: This is the standard that is
5 criticized by the ACRS, is that the one?

6 MR. WAAL: Yes.

7 MR. DEAVER: Yes.

8 MEMBER SHACK: Now see, if you had leak-
9 before-break, you wouldn't have to answer Ransom
10 Wallis.

11 MR. WALLIS: Did you say handsome Wallis?

12 CHAIRMAN CORRADINI: I think that's what
13 he said, yes.

14 (Laughter)

15 MR. DEAVER: I guess on that slide, we
16 did indicate that you know, a recognition of those
17 issues. So, one of our plans is to do CFD analysis
18 to account for those effects that are not
19 particularly accounted for by the NC standard.

20 MR. DEY: And the, you know, we will
21 analyze the jet forces and jet impingement on the --

22 MR. WALLIS: When you say CFD analysis,
23 this is CFD analysis of what? The jet? Or what?

24 MR. DEY: Yes. CFD analysis will do the
25 jet modeling, at the vibrate location and we'll

1 analyze to determine effects of jet and at a
2 distance of pressure compliance and delta P and on
3 an object on which it impinges on.

4 MR. WALLIS: So you can use CFD analysis
5 for two-phase flow?

6 MR. DEY: That is one question we have,
7 we're looking at it. But we -- our -- what we have
8 done, is we have selected our break locations in our
9 ESBWR piping. And we need to see exactly which
10 particular break would require a two-phase flow in a
11 modeling or not. And in that determination, we have
12 one mainstay that we do not need it. It's only
13 steam condition that will require only single flow.

14 MR. WALLIS: Well, safety analysis of
15 this sort of thing is not really state-of-the-art.
16 So you really need a verifying experiment or
17 something like that?

18 MR. DEY: We have got an analysis in
19 house right now that actually was modeled on the
20 main steam line break.

21 MR. WALLIS: It needs some validation,
22 doesn't it? You can't do just analysis alone with
23 two phase flow.

24 MR. DEEVER: What we'd like to do a
25 little later is show you the actual break locations

1 and the conditions that we have. I think that has a
2 bearing on the amount of analysis that's needed.

3 MR. DEY: And also, we recognize that,
4 you know, rupture, pipe rupture will also need to
5 address the blast rate on separated structures and
6 components on the rate. And we also perform the
7 calculation that shows the extent of the blast rate
8 and up to which distance that we need to analyze the
9 effect of the blast rates. Based on that
10 calculation, we will look for any sector items that
11 are located in those.

12 MR. WALLIS: Are we supposed to decide
13 that this is going to work?

14 CHAIRMAN CORRADINI: Of course it will
15 work.

16 MR. WALLIS: Or this is a preliminary
17 statement until we actually see what you do. It's a
18 statement of intent really.

19 MR. DEY: Here I'm showing the elevation
20 view of the, our containment, inside containment.
21 What I describe in the pipe rupture I that section
22 3.6.1 through 6.2, that our terminal end are located
23 between the reactor vessel wall and the dry shield
24 wall. All the nozzles are between in this confined
25 space. All the high-energy line, except for the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 main steam line, the nozzles would be outside of the
2 shield wall. So, as a result --

3 MR. DEEVER: Back up, P.K. so they can
4 see it here.

5 MR. DEY: As a result, what I said that
6 this piping at the terminal end break, as soon as it
7 breaks here, all the jet flows and jet actually
8 going to impinge on this shield wall here. The
9 shield wall is a six-inch thick stainless steel,
10 surrounding the entire reactor vessels.

11 And the distance is very short between
12 the two from the break nozzle to the shield wall is
13 around 2.5 feet only. So, jet is not going to
14 develop enough to have the reflection wave, or
15 feedback amplifications, et cetera.

16 And on top of that here, we do not have
17 any safety-related items. In the top right. The
18 majority of the breaks are this side. For the
19 reverse flow direction, the piping that connects to
20 these nozzles, piping will be restrained and we will
21 model those piping in the CFD analysis, if needed.

22 For most of the part, piping attached to
23 the reactor here, except down here, there is a two-
24 inch SLC line, standby liquid control, which I don't
25 think you need to have any CFD modeling.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 Other than that, all large flow piping
2 like main steam line, and the DPVIC and feed water
3 or the VCU, this will be modeled.

4 MEMBER ARMIJO: What are the sizes of
5 those lines? Main steam, and the largest?

6 MR. DEY: Main steam has the largest
7 diameter, 30-inches. But we have in the nozzles, we
8 have the venturi, which actually reduces the cross
9 section.

10 MEMBER ARMIJO: Yes.

11 CHAIRMAN CORRADINI: To what?

12 MR. DEEVER: It's roughly about 14-inches
13 diameter. So it --

14 CHAIRMAN CORRADINI: And that comes right
15 -- those orifices or venturi are right at the outlet
16 of the vessel, right?

17 MR. DEEVER: Right, built into the nozzle
18 in the vessel itself.

19 CHAIRMAN CORRADINI: Thank you.

20 MR. DEY: Okay. So, for the -- I know
21 that -- therefore from the nozzle side, from the
22 reactor side, we are -- our interactions to any
23 safety-related items almost none.

24 But from the reverse flows direction,
25 piping that attaches, it penetrates through the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 shield wall, and when we're supporting this piping,
2 rupture strength will be provided and the analysis
3 will show the piping separates from the nozzles, but
4 it does not completely disperse in a lateral
5 direction. So it will end up having flow -- I mean
6 the jetting on the reactor's surface.

7 So, from this type of, this break inside
8 dry well, except the main steam line, is pretty all
9 limited that there's no -- there will be no
10 interactions.

11 MR. DEEVER: Why don't we go down the
12 sizes of the nozzles.

13 MEMBER ARMIJO: Yes. What's your largest
14 diameter stainless steel pipe?

15 MR. DEY: Okay. The main steam nozzle is
16 30-inch diameter. And the depressurization valve
17 and IC, oscillation condenser, that the nozzle
18 connection is 18-inches, and then that's line
19 connects to this at the T, the 40-inch line.

20 Then we have feed water line, which is
21 12-inch diameter. And our WCU connects from both
22 sides, which is 12-inches diameter too. Then GDCS,
23 gravity driven cooling systems, that's two lines
24 coming. One is, the line goes, connects to and goes
25 to the tank, and from the tank, which is from a

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 suppression pool, comes to the equalizer line, which
2 are both six inches at the nozzle location.

3 And then there is a two-inch standby
4 liquid control, there are two nozzle's from both
5 ends at 180 degrees apart that are two-inch diameter
6 piping.

7 MEMBER ARMIJO: What is your largest
8 diameter stainless steel pipe? Or do you have any?

9 MR. DEY: With respect to pipe break?

10 MEMBER ARMIJO: Yes.

11 MR. DEEVER: Eight inch.

12 MEMBER ARMIJO: Eight inch, and which one
13 is that?

14 MR. DEY: No.

15 MR. DEEVER: You didn't point out the IC
16 return line. That is an eight-inch line right below
17 you, right there. The IC return line, all the
18 piping returning is stainless steel piping, and it's
19 an eight-inch pipe.

20 MEMBER SHACK: And the line to the IC is?

21 MR. DEEVER: Is carbon steel. It's a
22 steam line.

23 MEMBER SHACK: Water -- the water feed
24 lines are carbon or?

25 MR. WALLIS: So I think what you said was

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 all the pipes except the main steam line are in that
2 annular space?

3 MR. DEEVER: No, I --

4 MR. DEY: Right. Meaning the nozzles --

5 MR. WALLIS: They're all in that space.

6 MR. DEY: The main steam --

7 MR. WALLIS: Have you analyzed what
8 happens in that space?

9 MR. DEY: As soon as a pipe breaks, we
10 postulate the pipe break, the jets, you know, the
11 water from the reactor will jet onto the shield
12 wall.

13 And the distance between the nozzle to
14 the shield wall are approximately 2.5 feet. So,
15 therefore, you know, conditions, some of those
16 feedback amplification, resonance, et cetera, are
17 not important for these type of breaks, for breaks
18 from this side, from forward flow, if I say forward
19 flow from reactor to the pipe.

20 MR. DEEVER: I'd like to also point out
21 that beyond the shield wall, there's a vent wall.
22 The vent wall, you know, is the -- right in there.
23 That's another solid structure now. And when you
24 get out into that annular space between the shield
25 wall and the vent wall, there we have some squib

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 valves with GDCS, but we have a very limited amount
2 of safety-related equipment in that zone. But you
3 know, so there isn't much concern as far as breaks,
4 particularly for those nozzles that are below the --
5 you know, opposite the shield, the vent wall area.

6 MR. DEY: Then we have another pipe here,
7 the six-inch RWCU drain, that comes out in an angle
8 right here. And there are four piping like that at
9 19, 0918270 and two nozzles have a cone piping, that
10 pipe these out of these bottom, and it goes to the
11 heat exchangers.

12 So, those terminal in here, you know,
13 because of its own geometry, and there's a sharp
14 lane, it's so stiff, that piping, one nozzle breaks,
15 and it stays intact right there. It does not
16 rebound or anything.

17 So, this jet impingement here is very
18 limited. And also, there are no other safety-
19 related items. These are the --

20 MR. WALLIS: But how does it break if it
21 stays intact? I'm not quite sure. It cracks and
22 moves a little bit?

23 MR. DEY: Yes. It just opens up, of
24 course, but there is so steep piping there because
25 it's in a curvature also, too nozzles connect one

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 piping like that, as a result, its very steep
2 piping, and piping will not displace after the
3 rupture. That's what I'm saying.

4 MR. WALLIS: What's the shape of the
5 break when it breaks at the end? Does it break up
6 -- does it burst on one side of the pipe, or

7 MR. DEY: No we consider the total
8 guillotine break, meaning it's a full separation
9 from the nozzle.

10 MR. WALLIS: But that's not necessarily
11 how it will break.

12 MEMBER SHACK: Probably not, but that's
13 the most conservative.

14 MR. SIEBER: No, but that's what gives
15 you maximum --

16 MR. DEY: That is the assumption.

17 MR. WALLIS: Well, I'm not sure that it
18 is. If it opens up on the side of the pipe --

19 MEMBER ARMIJO: And it doesn't whip.

20 MR. WALLIS: Breaks off a -- I don't know
21 if I'm doing it right, but here's the pipe attached
22 here, and it breaks off the top, it peels off the
23 top of the plant, can it not do that besides just
24 breaking off the end of the pipe? Once it starts to
25 break, can't it progress down the pipe and break

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 off?

2 MR. DEAVER: I think in examples where
3 there's been failures, it's usually once -- say,
4 axial --

5 MR. WALLIS: Well, say it fails because
6 it has axial cramps, now presumably they can grow
7 and break off a piece of pipe rather than --

8 MR. DEAVER: Well, I think the experience
9 is, it doesn't usually break off a piece, it just
10 opens up.

11 MR. WALLIS: Yes.

12 MR. DEAVER: But typically, that's less
13 limiting, is you know, that --

14 MR. KEY: It's more conservative in the
15 analysis in jet impingement.

16 MR. WALLIS: If it breaks off a side,
17 then it won't impinge on the shield wall, it will
18 squirt up the gap, won't it.

19 MR. DEAVER: Exactly.

20 MR. WALLIS: So I'm not quite sure,
21 convinced about the shape of the break. Double-
22 ended guillotine is a kind of regulatory break.

23 MR. DEAVER: Yes, exactly.

24 MR. WALLIS: The real breaks don't
25 necessarily look like that.

1 MR. DEEVER: Well, yes, I think this is
2 all pretty highly theoretical all right.

3 MR. DEY: So, we have the, you know, at
4 the bottom, the reactor drain here, four nozzles,
5 two nozzles are connected to the carbon piping then
6 the pipe gets out of the -- from inside the
7 containment and finally connects with the heat
8 exchanger outside the containment.

9 So, we address all the terminal end
10 breaks for the high energy and the moderate-energy
11 lines inside and outside containment. Here is the
12 main steam line where our break will not be confined
13 inside the, between the RBB and the shield wall.

14 So, from the composite drawings that
15 we've reviewed so far, we don't see that this jet,
16 after breaking here, again, assuming the guillotine
17 break, the whole jet is you know, we plotted it, and
18 it tracks with the GDCS pool, which is a stainless
19 steel structure here. And don't see any -- don't
20 have any safety-related items.

21 But during install or relocate any
22 safety-related items here, we are going to design an
23 adequate protection and protective devices to have
24 known interaction of the jet.

25 MR. WALLIS: What's the other pipe we see

1 below the steam line there, what's that?

2 MR. DEAVER: Feed water.

3 MR. WALLIS: That's feed water there.

4 MR. DEAVER: But it's physically much
5 lower. It's not in the direct path.

6 CHAIRMAN CORRADINI: It's meters lower.

7 MR. DEAVER: Yes.

8 MR. DEY: But this is how the inside
9 containment will be addressed. And there will be a
10 separate report for rupture for inside containment
11 as well for the outside containment.

12 And outside containment, the same
13 criteria applies, break, you know, in the terminal
14 ends and the intermediate break, if there is one, we
15 will have to postulate that and there will be a
16 separate report and all the interactions from those
17 breaks we'll have to look into.

18 MR. WALLIS: The main steam line would
19 break at the isolation valve, or where is it going
20 to break?

21 MR. DEY: The main steam line will break
22 in the terminal building, another terminal end at
23 the TSV, terminal stop wall

24 MR. WALLIS: Stop wall.

25 MR. DEY: Right. And for the feed water,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 it would be at the feed water heaters. And again,
2 the feed water heaters are located in their own
3 separate compartments. And there again, we have
4 very limited interactions and there is none
5 absolutely, actually.

6 And so is the heat exchangers, RWCU,
7 they are located, and if I just assume, it's off of
8 here, right here outside in the compartments. And
9 the nozzles are very low towards the floor, a little
10 elevated over, just about a foot over the floor
11 level. And there shouldn't be any interactions
12 there also.

13 So, likewise, the moderate-energy piping
14 will be addressed for moderate-energy piping that is
15 200 degree or less in temperature, 275 psig or less.
16 And those piping, we do not postulate the guillotine
17 break, but crack will be postulation. And again,
18 the crack postulation stress fracture is also given
19 in Branch Technical Position 3-4. And based on that
20 stress limit, and by stress analysis results, we
21 have to see what are those breaks locations and that
22 will be addressed.

23 MR. WALLIS: So, you say you're going to
24 use CFD, but it looks as if you won't need it
25 anyway.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. DEAVER: Well, we think we have a
2 very favorable geometry you know, with the pipes in
3 the annular space where there is no safety-related
4 equipment. The only thing we need to do is look at
5 the blast wave with respect to an adjacent piping or
6 nozzle, which we've got a pretty decent spacing
7 between nozzles.

8 And then it's mainly the steam line, you
9 just have to keep the area clear between the, where
10 the end of the nozzle is to the GDCS pool wall. We
11 either have to put shields if we have any piping in
12 the area, or you know --

13 MR. WALLIS: So when the main steam line
14 breaks, do pieces of the dryer come out as well?

15 MR. DEAVER: No.

16 MR. WALLIS: The dryer doesn't break when
17 the steam line breaks? The forces on the dryer are
18 not enough to break it?

19 MR. DEAVER: I'm not familiar with --
20 well, part of the dryer design, in addition to the
21 supports, we have restraints at the top of the dryer
22 hood. So, if there's any tipping or forcing of the
23 dryer, typically, that helps provide support to the
24 dryer. And helps maintain its structural integrity.

25 MEMBER MAYNARD: Part of the reason for

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 the nozzle in the main steam line is to limit the
2 flow out of any one of those to where it also --

3 MEMBER SIEBER: Yes.

4 MR. DEAVER: Yes, it is. See, it's an
5 effectively, a 14-inch break, even though it's a 30-
6 inch pipe. So, that helps limit the forces that --

7 MR. WALLIS: Well, I guess when the pipe
8 breaks, there's some waves that go back into the
9 dryer which are fairly intense?

10 MR. DEAVER: Well, under these
11 circumstances, our design objective is just to be
12 able to shut down. We're not trying to maintain
13 structural integrity necessarily of the dryer under
14 these circumstances.

15 MR. WALLIS: I was wondering. Maybe
16 pieces of dryer come out the break.

17 MR. DEAVER: I don't think so.

18 MR. WALLIS: You don't think so. Well, I
19 don't know. You don't think so. You have a basis
20 for thinking, I have no basis for thinking. I just
21 suppose it might. So, anyway.

22 CHAIRMAN CORRADINI: How would -- I guess
23 to answer Graham's question differently, how is this
24 any different than current DWR?

25 MR. DEAVER: It's not. As a matter of

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 fact, most reactors have -- don't have the venturi
2 in the line. And so, they effectively have a 22 or
3 26-inch pipe that is you know, allows much more flow
4 and pressure grout to occur. So, it is no different
5 in that respect.

6 MR. DEY: And then Section 3.6.1.4, that
7 illustrates the as-built inspection of the high-
8 energy pipe break mitigation pictures. In this,
9 what we will do is, prior to plant's startup, an as-
10 built inspection will be done. And in the as-built
11 inspection, and as-designed condition will be looked
12 at, evaluate the differences.

13 If that forces us to re-analyze the
14 system again, based on the as-built condition, we'll
15 do it. And 99.9 percent that I have in my
16 experience is that vibrate locations do not change.
17 But should there be any change in the vibrate
18 location, and that requires us to re-evaluate, and
19 region analysis is not limiting, in that case, we'll
20 have to re-analyze that.

21 And if there is a new location of the
22 vibrate, we have to re-evaluate that. And that --
23 from the as-built analysis.

24 And during that inspection also, we will
25 include the inspection for the vibrate restraints

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 and jet shield installations for the design. And
2 we'll look into the physical separation distances
3 between the rupture location and the, all the
4 equipment that it was for the safe shutdown and all
5 the mitigation features can be planned.

6 MR. DEEVER: We're just on the summary
7 page.

8 MR. DEY: And in summary, Section 3.6 in
9 DCD tier II, it describes the complete pipe rupture,
10 how to perform the pipe rupture analysis on the
11 mitigation and the effects of pipe breaks in the
12 ESBWR standard plant. And Section 3.9 provides a
13 solid basis for the design of the safety-related
14 equipment, and you know, it fully complies with the
15 requirements of the ASME code.

16 CHAIRMAN CORRADINI: Questions.

17 MEMBER SHACK: Almost unrelated, but that
18 shield wall that you have, that's a couple of inches
19 of stainless steel?

20 MR. DEEVER: It's six inches thick.

21 MR. DEY: Six-inch.

22 MR. DEEVER: And it's carbon steel.

23 MEMBER SHACK: Carbon.

24 MR. DEEVER: I think stainless -- P.K.
25 said it was stainless, but it's carbon. In the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 past, we had a composite structure there. There was
2 a concrete steel. But in this design, we've gone to
3 a six-inch plate.

4 MEMBER SHACK: And there's -- there's
5 then insulation between that and the vessel?

6 MR. DEAVER: Yes, there is.

7 MEMBER SHACK: But that's removable so
8 you can expect the vessel.

9 MR. DEAVER: Right. Well, what we do is,
10 we hang the insulation off the shield wall such that
11 it leaves adequate space for remote inspection
12 equipment.

13 MEMBER SHACK: Inspection, okay.

14 CHAIRMAN CORRADINI: And this is in that
15 top part of the dry well? Or, I'm sorry, not the --
16 I said the word dry well, I shouldn't have said it.
17 It's in that, above the supports.

18 MR. WALLIS: It's in the annulus, but
19 it's not shown.

20 MEMBER SIEBER: Well, go put the picture
21 back up.

22 MR. DEAVER: The insulation?

23 MEMBER SIEBER: The shield wall.

24 MR. WALLIS: The shield wall.

25 CHAIRMAN CORRADINI: the shield wall is

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 there.

2 MR. WALLIS: It's not shown. No, that's
3 the concrete wall that's shown.

4 MR. DEAVER: No, this is the shield wall
5 there.

6 MR. WALLIS: That's the access to the --

7 MEMBER MAYNARD: It's real hard to tell
8 on that. It's a little, very thin.

9 CHAIRMAN CORRADINI: This is shown as
10 being quite thin. But it's six inches thick.
11 That's the shield wall goes up nearly to the top of
12 the containment area.

13 MR. WALLIS: You're right.

14 MEMBER BROWN: That's your radiation
15 shielding?

16 MR. DEAVER: Yes, it is.

17 CHAIRMAN CORRADINI: And so you hang the
18 insulation off of that.

19 MR. DEAVER: Yes. It lines the inside of
20 the shield wall. It has brackets that support it.

21 CHAIRMAN CORRADINI: That's fine. So,
22 that lane scale between the shield wall and the
23 vessel is what?

24 MR. DEAVER: The distance between the
25 two?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 CHAIRMAN CORRADINI: Yes.

2 MR. DEEVER: It's like two and a half,
3 three feet.

4 CHAIRMAN CORRADINI: Okay.

5 MEMBER ARMIJO: What's the primary reason
6 why the shield wall has to be so thick? Is it just
7 to mitigate this pipe whip, or the --

8 CHAIRMAN CORRADINI: No, no, radiation.
9 It's just radiation.

10 MR. DEEVER: Well, to a large extent, the
11 pipe break annulus pressurization are the primary
12 loads that seize, and so -- but it does act as a
13 shield for radiation during outages. So, that's the
14 -- you know, that was its initial design intent.

15 MEMBER ARMIJO: But other than the
16 insulation, it does support much, any other
17 structures, heavy structures?

18 MR. DEEVER: No. Here it shows the
19 stabilizer again. This is the upper support for the
20 vessel. That's the only other support structure.

21 MR. WALLIS: So, this jet comes out and
22 dislodges a lot of insulation when it comes out?

23 MR. DEEVER: Say again?

24 MR. WALLIS: The broken pipe, impinges on
25 the insulation?

1 MR. DEAVER: Yes. The insulation is in
2 close proximity to that break location. So --

3 MR. WALLIS: This is reflective metal or
4 something?

5 MR. DEAVER: Yes, it is.

6 MR. WALLIS: But it will be broken,
7 presumably, some of it?

8 MR. DEAVER: Typically, around nozzles,
9 we have shield wall openings, and that's where we
10 get access for inspections of the nozzles and vessel
11 seams. That's typically removable insulation that
12 has buckles and so forth. So, the expectation I
13 would have is that as soon as there's a pressure
14 wave from a break, it would tend to open up the
15 buckles.

16 MR. WALLIS: Well, I'm thinking you open
17 it then release pieces of insulation into this two-
18 phase mixture, which might be available to clog
19 something down stream.

20 CHAIRMAN CORRADINI: All stainless steel
21 insulation.

22 MR. WALLIS: Just a little piece of edge
23 stainless steel insulation in a vacuum breaker is
24 not desirable.

25 MR. DEAVER: Well, the vacuum breaker,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 which is up at --

2 MR. WALLIS: Well to get there --

3 MR. DEEVER: It's up on this floor here.

4 MR. WALLIS: All right.

5 MR. DEEVER: It has shields also in it.

6 It has four openings laterally and it has shields,
7 screens and stuff so you can adjust --

8 MR. WALLIS: Anyway, you're going to
9 analyze the effects on insulation of these jets?

10 MR. DEEVER: Yes. Well --

11 MR. WALLIS: What happens to the
12 insulation?

13 MR. DEEVER: Well, typically, you know,
14 the insulation doesn't have any structural support.
15 It's going to be torn loose in the vicinity of the
16 break.

17 MR. WALLIS: And the question is, where
18 does it go, what does it do?

19 CHAIRMAN CORRADINI: That is an
20 interesting question.

21 MR. DEEVER: Well, typically, like this
22 morning, we were talking about, these were the vent
23 walls were, let's say we have a break and it's a
24 steam break. This is where we're going to have
25 protection over this vent wall to prevent debris,

1 maybe insulation pieces, from actually getting down
2 into the suppression pool. But -- so the main
3 concerns would be clogging -- getting material into
4 the suppression pool, or what we have up here, this
5 is the GDCS pool.

6 We have a screen that limits the amount
7 of debris that could potentially get into the GDCS
8 pool.

9 MR. WALLIS: Now these breaks are
10 supposed to mix containment, but they wouldn't mix
11 containment if they're contained inside this box,
12 would they? They'd just go up like a chimney out of
13 this shield wall, and then the steam would spread
14 around the top of the dry well, presumably.

15 MR. DEEVER: Well, these openings in the
16 shield wall, you'll get a little escape of pressure
17 through the shield wall, but not --

18 MR. WALLIS: But the steam is going to
19 then flow up between the vessel and the shield wall.

20 MR. DEEVER: Yes.

21 MR. WALLIS: Like a chimney.

22 MR. DEEVER: Well, it will transition
23 around circumferentially. It will go up and down.
24 It --

25 MR. WALLIS: It will spread, it will be

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 directed up into the top of the dry well, the dome
2 there, presumably.

3 MR. SIEBER: The pressure is so high, it
4 will go everywhere.

5 MR. DEAVER: This is a relief point at
6 the top here.

7 MR. WALLIS: This is a course model
8 contained in your contained analysis?

9 MR. DEAVER: Right. The analysis, the
10 annulus pressurization all that, accounts for that.

11 MR. WALLIS: Well it raises some new
12 questions for the -- for me, for the analysis of
13 mixing and containment.

14 MR. DEAVER: Well, if you have a steam
15 break, it's not going to be directed into that
16 annulus. It's going to --

17 MR. WALLIS: No, not the steam line. The
18 other breaks.

19 MR. DEAVER: Well, the other breaks --

20 MR. WALLIS: DGCS line break.

21 MR. DEAVER: These will be predominantly
22 contained within the shield wall.

23 MR. WALLIS: But then the question is,
24 what happens to the flow pattern in the containment
25 when it comes out of the shield wall space.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 CHAIRMAN CORRADINI: Other questions? We
2 don't have the right people from GEH to answer some
3 of the things you're asking. We need a different
4 subcommittee meeting for that, I would say.

5 Is your worry the air steam mixing,
6 Graham? Is it the uniformity of the mixture.

7 MR. WALLIS: We had a lot of questions
8 about where do the noncondensibles go, where does
9 the steam go. And it's not as if we have a jet
10 issuing into containment. We have a confined jet
11 inside this shield wall which presumably tends to
12 fill that space with steam.

13 CHAIRMAN CORRADINI: That's one break,
14 right. There's a lot of breaks --

15 MR. WALLIS: And then it comes out in an
16 orderly fashion from there.

17 MR. DEAVER: Well, that's if you have a
18 break at the nozzle.

19 MR. WALLIS: Yes. That's where it's
20 supposed to be.

21 MS. CUBBAGE: I could be completely off
22 base, this is getting late, but I mean, are they not
23 going conservative in not assuming things are
24 mixing? I thought, wasn't that the issue? They
25 were assuming things not held up.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 CHAIRMAN CORRADINI: I think the issue
2 was, well, let's just back up a step. But the
3 calculation you saw, Graham, with TRACG, and the
4 audit calculations with MELCOR are a bit different.

5 MELCOR took, I think, one node, for all
6 of that.

7 MR. WALLIS: Which is very unrealistic.

8 CHAIRMAN CORRADINI: Right, but it then
9 mixes the noncondensibles, and it pushes into the
10 wet well, which essentially pumps up the overall
11 pressure.

12 MEMBER SIEBER: And that's the worst
13 case.

14 MR. WALLIS: Well, that's another
15 subcommittee, now, isn't it?

16 CHAIRMAN CORRADINI: It's another
17 subcommittee.

18 MR. WALLIS: Okay.

19 CHAIRMAN CORRADINI: Not these guys.

20 MS. CUBBAGE: I guess my --

21 CHAIRMAN CORRADINI: We don't want to
22 torture them just yet on that.

23 MS. CUBBAGE: I guess my point was that
24 because they weren't really able to model all this,
25 they went with a conservative approach, so we don't

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 really need to get into all of that right here right
2 now.

3 CHAIRMAN CORRADINI: For the DBA, I would
4 think that was the -- that was the audit calculation
5 in the staff's point, is that they were probably on
6 the high side.

7 MR. WALLIS: And the question was, while
8 you're conservative at one period in the accident,
9 are you then conservative later on.

10 MS. CUBBAGE: And these guys will not be
11 able to help you with that. No offense.

12 (Laughter)

13 MS. CUBBAGE: But that's not what they're
14 here for.

15 CHAIRMAN CORRADINI: Okay.

16 MS. CUBBAGE: They're here for jet
17 impingement.

18 CHAIRMAN CORRADINI: On the loading,
19 structural side, structural loading side, is there
20 any other questions for this team? None. Okay.
21 Let's take a break until 3:15.

22 (Off the record for break from 2:58 p.m.
23 until 3:15 p.m.)

24 MEMBER STETKAR: We'd like to get back
25 into session.

1 MR. PATEL: Thank you very much. My name
2 is Chandu Patel. I'm a lead project manager again,
3 for Chapter 3. I'm going to make a presentation for
4 some easy section in the beginning, and then we'll
5 turn to the other people.

6 First of all, I apologize for all this
7 shuffling. I'll go to slide number 7. We had some
8 personnel issues, so we had to shuffle around
9 people. But I think finally we have everybody
10 together. Please go to slide 7. Just after 3.9.1.

11 And I was comparing my slide, against
12 the GE slide, and I don't know who stole whose
13 slide, okay. They're essentially, but it is exactly
14 the same thing. So, I do not -- I guess we do not
15 need to repeat.

16 The basic issue is, in this section, we
17 do not have any open item. You know, I can repeat
18 the same thing, what they repeated, basically. It's
19 exactly, we're on the same, like you know. They
20 gave us the transients and number of cycles in the
21 table, and they gave component programs, and the
22 methodology. But, long and short of it, this
23 section was literally easy and we have no open
24 items. So, if there are no more questions, I can go
25 to the next.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 Now, I'm going to go 3.9.2.2, which is
2 slide number 11. This is related to safety analysis
3 and qualification of mechanical equipment.
4 Basically, we looked at the DCD information provided
5 in 3.9.2.2, and 3.7.2, 3.7.3 and B10, which was
6 related to the seismic analysis and qualification of
7 mechanical equipment and components.

8 What we, the area we reviewed was,
9 seismic analysis methodology, for equipment and
10 components, modeling of major component, number of
11 earthquake cycles, particular evaluation, a
12 combination of the model responses, damping values,
13 qualification of large mechanical component, effects
14 of rigidity of support anchorage and torque effects
15 of eccentric masses.

16 And in general, most of the areas that
17 were discussed are here. We had only two RAIs in
18 this section. The first open RAI was related to the
19 rigidity of the support anchorage to the building
20 and particularly for the heavy component. And this
21 item is closed. So, after we showed the safety-
22 relation, it is closed.

23 The second open item was related to the
24 CRD housing, and implementing the computer codes and
25 industry standard, which was kind of a you know, all

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 a type of an issue, and it wasn't significant. And
2 that issue is also closed.

3 So, basically in 3.9.2.2, also, we have
4 no open issue any more. And that's the end of
5 3.9.2.2, unless anybody has questions.

6 So now we are going to go to section
7 3.9.2.1, which has previous -- and Jay Rajan will
8 take it from there. That's slide number nine.

9 MR. RAJAN: I am Jay Rajan, and I'll be
10 discussing the piping vibration, thermal expansion
11 and dynamic pipes testing.

12 The staff reviewed the vibration and
13 dynamic effect testing, which included measurement
14 techniques, monitoring requirements, test evaluation
15 acceptance criteria, reconciliation and corrective
16 actions.

17 The staff also reviewed the methods for
18 determining the acceptability of steady state and
19 transient vibration for the effected systems. This
20 included wave observation, local measurements and
21 remotely monitored and recorded measurements.

22 Generally, the specifications which the
23 staff have accepted in the past, are identified in
24 ASME operation and maintenance standard, subgroup 3,
25 part 3, and the applicant has -- GEH has generally

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 complied with those -- with that standard. So the
2 staff finds it acceptable.

3 As for the requirements for thermal
4 expansion testing, the -- they have also complied
5 with the ASME OM standard part 7, which detail
6 specifications for this -- for such a program, and
7 in general, the staff asked a number of questions,
8 but they were responded to in a satisfactory manner,
9 so we do not have any open items in this section
10 3.9.2.1 (sic).

11 In 3.9.2.3, of the DCD, the staff
12 reviewed the major reactor internal components
13 within the vessel, which are subjected to extensive
14 testing, coupled with dynamic system analysis to
15 properly evaluate the resulting flow induced
16 vibration phenomena during --

17 MEMBER BROWN: Can I ask you a question
18 about, the other one first? You said they generally
19 compiled.

20 MR. RAJAN: Yes, sir.

21 MEMBER BROWN: That implies that they
22 didn't comply someplace, but yet, everything was
23 okay. Were your --

24 MR. RAJAN: Well, we asked a number of
25 questions, and the responses --

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER BROWN: Were they on their areas
2 of noncompliance?

3 MR. RAJAN: No, we found -- we found
4 their responses satisfactory and acceptable.

5 MEMBER BROWN: Let me go back to square
6 one. You said they were generally compliant with
7 the standards, which --

8 CHAIRMAN CORRADINI: Did you mean to say
9 that?

10 MEMBER BROWN: Did you mean to use the
11 word generally, or they do comply with the standards
12 and that you had some questions which they then
13 resolved.

14 MR. RAJAN: Based on the response of that
15 question, they did comply.

16 MEMBER BROWN: Okay.

17 MR. RAJAN: In the initial --

18 MEMBER BROWN: I quit.

19 (Laughter)

20 MR. RAJAN: The -- as I said, the
21 detailed analysis for and testing information is for
22 these -- for the reactor internal components, except
23 for the steam dryer, is provided in the licensing
24 technical report, NEDE-33259P Rev 1. And this will
25 be discussed later in 3.9.2.3.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 The major open items identified here all
2 in 3.9.2.3, all relate to the steam dryer load
3 definition. The current GE approach to steam dryer
4 load definition is defined as a plant-based load
5 evaluation method, or the PBLE method. And this
6 methodology is contained in LTR NEDC-33408B, which
7 is currently being reviewed under Section 3.9.5.

8 The review status and additional details
9 will be discussed in Section 3.9.5. At this point,
10 the ESBWR steam dryer load definition and the design
11 itself has not been finalized.

12 GE has, however, stated that it will be
13 similar to the ABWR steam dryer design. A detailed,
14 finite element model analysis will be used to
15 predict the steam dryer susceptibility to fatigue
16 under flowing boost vibration loadings. The open
17 items related to the prediction of stresses at
18 potential high-stress locations on the dryer, and
19 the stress limit curve, to be used during the
20 initial power ascension test can only be evaluated
21 and resolved when the steam dryer load definition
22 from the PBLE methodology and detailed finite
23 element analysis become available.

24 MEMBER ARMIJO: What is PBLE?

25 MR. RAJAN: That's the Plant-based Load

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 Evaluation methodology. It is discussed in a
2 technical report, 33408P, and is being currently
3 reviewed by the contractors and the staff under
4 Section 3.9.5.

5 MEMBER MAYNARD: That basically means,
6 once it gets installed, is that the test
7 methodology, to come up with the loads?

8 MEMBER BLEY: Is it a computer code.

9 MR. RAJAN: Very briefly, I can say that
10 it's based on --

11 MEMBER MAYNARD: I think somebody wants
12 to help you.

13 MS. CUBBAGE: Well, actually, I was going
14 to say, we have our contractors here. Yes, we'll
15 wait until 3.9.5.

16 MEMBER MAYNARD: Well, did GE -- GE never
17 mentioned this.

18 MEMBER STETKAR: Sure they did.

19 MS. CUBBAGE: Yes, they did.

20 MEMBER ARMIJO: Then I was asleep.

21 MEMBER SHACK: They didn't tell --

22 (Laughter)

23 MEMBER SHACK: They didn't use those
24 words. They had three topical reports.

25 MR. WAAL: This is Jeff Waal. I

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 mentioned PBLE in the presentation.

2 MEMBER ARMIJO: Okay, Jeff. I stand
3 corrected.

4 MS. CUBBAGE: And when the staff's
5 presenting 3.9.5, we'll elaborate.

6 MEMBER BLEY: But that has replaced what
7 the open items were here. They're covered in that.
8 That's the way I read this. These open items are
9 closed because they're superceded by these.

10 MEMBER BROWN: And you won't be able to
11 get an answer until you get the new stuff.

12 MEMBER SIEBER: Well, it's going to be a
13 different answer.

14 MEMBER SHACK: Well, they're not closed
15 until you accept the topical reports.

16 MS. CUBBAGE: That's right. GE's
17 addressing a number of RAIs by providing these topic
18 reports, which staff's reviewing and will generate
19 more RAIs.

20 MEMBER ARMIJO: So the only open items
21 aren't really closed.

22 MEMBER SHACK: Say that out loud.

23 MEMBER ARMIJO: The open items aren't
24 really closed then. They're just being addressed by
25 another methodology.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. RAJAN: They may or may not be
2 addressed, because if the PBLE methodology provides
3 the adequate response to the questions we have
4 raised, then they may or may not be raised there.
5 And they have sort of, they have asked prematurely
6 before the PBLE methodology was made available for
7 us to review.

8 MEMBER SHACK: I'm waiting for 3.9.5.

9 MR. RAJAN: In Section 3.9.4, the staff
10 review focused on the major reactor internal
11 components within the vessel, which are subjected to
12 extensive testing, coupled with dynamic system
13 analysis and evaluation of the resulting flow
14 induced vibration phenomenon.

15 These components include the chimney
16 head steam dryer assembly, shroud chimney assembly,
17 top guide, core plates, the standby liquid control
18 piping, et cetera.

19 The first open item that we have in this
20 relates to the classification of the ESBWR reactor
21 internals as a non-prototype Category II. In
22 accordance with the definition on reg guide 120,
23 non-prototype Category II reactor internals are
24 those which are the same as in the reference
25 prototype plan, in terms of design, size and

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 operating conditions, but, not necessarily the same
2 arrangement or configuration.

3 The ABWR is considered to be a prototype
4 reference plan for the ESBWR reactor internals,
5 based on the similarity of design, size and
6 operating conditions of the reactor internals.
7 Three ABWR plants are currently in operation in
8 Japan and the first plant completed a flow induced
9 vibration test program in accordance with reg guide,
10 NRC reg guide 120 Rev 2.

11 Extensive analysis, testing and full
12 inspection were conducted during the first plant
13 startup. A total of 46 sensors of different types
14 were used to obtain vibration data on 11 different
15 internal components.

16 The ABWR components monitored during the
17 startup, including the steam dryer, control lab
18 guide tubes, internal monitoring guide tubes and
19 housing and the top guide, and the shroud.

20 For the ESBWR, extensive instrumentation
21 of the chimney and the standby liquid control lines,
22 both of which are new components, is planned in
23 addition to the stream guide and a number of other
24 components.

25 Prior to the startup testing, extensive

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 analysis of these two components that are the
2 chimney and the standby liquid control lines, were
3 made to establish the acceptance criteria. The
4 acceptance criteria were set such that the maximum
5 stress anywhere on the structure was limited to 68.9
6 megaPascals. If the FIV response amplitudes were at
7 less than the acceptances criteria, damage to the
8 components is not likely to occur. Thus the startup
9 program will ensure that these non-prototype
10 components will not be subjected to unacceptable
11 flow induced vibration stresses during operation.

12 The staff determined that it needed more
13 information because the applicant response evaluated
14 only these new components which it considers as non-
15 prototypical. But the applicant was requested to
16 justify the non-prototype Category II Classification
17 for the ESBWR on a component by component basis.
18 And this they have done. They have provided an
19 item-by-item discussion of why each component was
20 considered to be prototypical and selected for
21 further analysis and testing, or why it was
22 considered adequate without further analysis or
23 testing and this is provided in revision 1 of this
24 license topical report.

25 This -- the revised LTR contains

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 detailed analytic methods used to determine the FIV
2 response of each item requiring further evaluation.
3 The results of the evaluation and comparison to
4 allowable stresses were testing and determined to be
5 required for a particular component. The revised
6 LCL also includes the types and locations of
7 sensors.

8 The remaining internal components that
9 are not specifically identified in their Appendix 3L
10 of the DCD or in this LTR, are basically proven by
11 best trouble-free BWR experience and have designs
12 and flow conditions that are similar to trial --

13 MEMBER SHACK: I think you've got your
14 papers on the microphone. It's driving him crazy.

15 MR. RAJAN: -- I'm sorry -- prior
16 operating BWR plants. The staff finds the applicant
17 response acceptable with respect to the issues
18 discussed above. But the review of the, this
19 revised LTR is still on-going, and further -- and
20 therefore, currently the review is being --
21 additional RAIs are being formulated as necessary.
22 And the classification issue of the ESBWR reactor
23 internals as a whole is still being kept as an open
24 item.

25 The other open item identified in this

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 section relates to the flow induced vibration
2 analysis of the ESBWR top guide based on the test
3 data obtained form the ABWR top guide.

4 In RAI 3.9-77, the staff requested that
5 the applicant describe the modifications made to the
6 vibration analysis at the ABWR top guide assembly,
7 the predicted response of the ESBWR top guide.

8 In its response, the applicant discussed
9 the overall -- stated that the overall thickness of
10 the top guide is the same as the ESBWR design and
11 also provided analytical results for the top guide.

12 To calculate the five year response of
13 the ESBWR shrouds and chimney separator structure,
14 measure time histories in the ABWR shroud, we have
15 to measure shrouds annulus, was suitable scaled to
16 define the pressure time histories in the ESBWR
17 shroud in the annulus.

18 The scale factors were computed as the
19 square of the reissue of the ESBWR annulus flow
20 velocity to the corresponding value in ABWR. And as
21 based on the results of this determination, the
22 highest to zero to peak stress intensity was
23 calculated and for the shroud chimney structure and
24 the top guide, both were determined to be well below
25 the allowable value of 68.9 megaPascals.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 The staff is primarily concerned not
2 just with the lateral stresses on the tope guide,
3 but rather the fact that the ESBWR, because the
4 ESBWR guide plate has more cut-outs and may create
5 greater stress concentration factors and stress
6 patterns related to the differences between the ABWR
7 and the ESBWR top guide, both of them need to be
8 very similar in order for the extrapolation from the
9 ABWR to the ESBWR to remain valid.

10 And so this remains an open item at this
11 point.

12 CHAIRMAN CORRADINI: And how would that
13 -- so the resolution of that would be test data, by
14 startup testing? I'm still trying to understand --
15 I listened to how you're describing all this. I'm
16 trying to understand.

17 MR. RAJAN: The ESBWR top guide supports
18 a very long structure that is the chimney --

19 CHAIRMAN CORRADINI: Right.

20 MR. RAJAN: -- which of course, the ABWR
21 does not have.

22 CHAIRMAN CORRADINI: right.

23 MR. RAJAN: And as a result of that, the
24 staff concern is that it supports it in a sort of a
25 cantilevered fashion. And the staff is concerned

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 that because of the differences in the stress
2 patter, the cut-outs, and it may create
3 concentration, stress concentration effects on the
4 plate itself. Which --

5 CHAIRMAN CORRADINI: On the bottom
6 support foot.

7 MR. RAJAN: On the top guide.

8 CHAIRMAN CORRADINI: Oh, the top guide.

9 MR. RAJAN: The top guide itself. So,
10 unless that's -- I believe unless the design of the
11 top guide progresses to the point where they can
12 model the exact cut-outs, this RAI cannot be
13 resolved. So, which has not been apparently, their
14 design activity has not apparently proceeded to that
15 level yet. So this remains an open item.

16 MEMBER BROWN: And the concern is it
17 could crash and block the passages of all the stuff
18 coming up and cooling the core? Is that the safety
19 concern on that thing, if you get cracks in it? A
20 crack is a crack. You worried about it coming
21 apart?

22 MR. RAJAN: Well, it -- we have not gone
23 into the consequences aspect of it. But it
24 certainly should be a -- we would certainly not like
25 that -- something like that to happen, a cracking or

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 anything. So, we would like that to be a
2 structurally sound structure. Integrity --
3 structural integrity should be verified in some
4 fashion.

5 CHAIRMAN CORRADINI: But can I just say
6 it back to you in a brief fashion? So, by going
7 with the scale of the square of the velocities,
8 you're below the peak stresses, but you're worried
9 about the physical geometry being weaker or
10 different even though it fits within that envelope?

11 MR. RAJAN: Exactly. That is true.

12 CHAIRMAN CORRADINI: And by analysis, one
13 could, at least if I understood the second part to
14 your answer, one could by detail analysis show that
15 if --

16 MR. RAJAN: A detail finite analysis of
17 the plate itself.

18 CHAIRMAN CORRADINI: And the plate is
19 sitting on top of the -- I'm still struggling here.

20 MR. RAJAN: No, it's -- the chimney sits
21 on top of it.

22 CHAIRMAN CORRADINI: Okay, that's what I
23 thought.

24 MR. RAJAN: Yes.

25 CHAIRMAN CORRADINI: That's what I

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 thought at the beginning, but the way you answered
2 me, okay, it sits on top of it. Okay, fine. Got
3 it.

4 MR. RAJAN: This is the top guide.

5 CHAIRMAN CORRADINI: Got it, thank you.

6 MEMBER ARMIJO: But the main support of
7 the chimney, isn't that around the circumference, or
8 is it all across the top plate?

9 MR. RAJAN: The top guide has some
10 support, it's connected with the vessel. And there
11 is also support, there's support in the bottom core
12 plate, also has connections with the vessel.

13 MEMBER ARMIJO: I know that.

14 MR. RAJAN: So they are interconnected
15 and it's --

16 MEMBER ARMIJO: But the chimney, I'm just
17 trying to get the support --

18 MR. RAJAN: Yes, the chimney is bolted
19 onto the top guide.

20 MEMBER ARMIJO: Bolted onto the top
21 guide.

22 MEMBER SHACK: Bolted, or just pins?

23 MR. RAJAN: No, it's bolted on.

24 MEMBER SHACK: Bolted on.

25 MR. RAJAN: Bolted on.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. SHACK: And the bolt path is on the
2 circumference or?

3 MR. DEEVER: Let me clarify that.

4 CHAIRMAN CORRADINI: Something doesn't
5 make sense. Because they just said they could undo
6 it.

7 MEMBER SIEBER: That's the partition.

8 MR. RAJAN: No, it's --

9 MR. DEEVER: This is Jerry Deever with
10 GEH. Let me clarify that. In going from revision 4
11 to revision 5, we were showing a bolted connection
12 of the partitions at the base. But because of the
13 removable chimney now, we now are not going to bolt
14 it down at the base.

15 But I would like to say that, you know,
16 from a loading perspective, we would like to
17 primarily load the partitions on the periphery, as
18 opposed to loading across the top guide. You know,
19 we don't want to induce a new load on the top guide
20 itself.

21 And in response to the RAI, we are doing
22 a fine element analysis right now to do exactly what
23 he was describing.

24 CHAIRMAN CORRADINI: Can I get you to
25 kind of expand what you just said? So, it's not

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 bolted, they're pinned. So they slide into
2 something.

3 MR. DEAVER: Exactly.

4 CHAIRMAN CORRADINI: And then you said
5 that you want it to be loaded from the outside. I
6 don't completely understand.

7 MEMBER SIEBER: It's along the
8 circumference.

9 CHAIRMAN CORRADINI: Yes, but you're
10 going to have partitions all the way through, so
11 they're going to be weighty in the middle. So I
12 don't understand it.

13 MEMBER BROWN: Well, they're all welded
14 together.

15 MR. DEAVER: Yes. The partitions are
16 welded together, but we're likely to have a ring at
17 the base also.

18 CHAIRMAN CORRADINI: Oh, okay. So the
19 partitions are almost like a -- kind of like a --
20 okay, fine. I misunderstood. So, it's almost like
21 a moveable screen. The whole thing's going to come
22 out in one --

23 MR. DEAVER: One piece.

24 CHAIRMAN CORRADINI: One piece. Excuse
25 me. I misunderstood that.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER BROWN: The whole chimney, I
2 missed that also. The whole chimney assembly?

3 MR. DEEVER: The partition --

4 MEMBER BROWN: The partition.

5 MR. DEEVER: -- is an assembly, and it
6 comes out in one piece.

7 CHAIRMAN CORRADINI: Okay. So, now I
8 want to ask you the question that I wanted to ask.
9 Which is, now I've got all this steam and water
10 coming out, and it's whizzing by all of this, and I
11 have maldistribution in the steam and water, and now
12 I've got this very big screen and seven meters tall
13 getting wiggled on it.

14 So, how are you -- I guess, I believe
15 that you can do a 3-dimensional final element, I'm
16 trying to figure out how you're going to give the
17 loading on it from this. Are you going to use ABWR
18 data to load it? I mean, I'm still going back to
19 your original discussion about --

20 MR. RAJAN: ABWR they measured only the
21 lateral motion.

22 CHAIRMAN CORRADINI: Yes. So that would
23 be the sort of loading you would expect to look and
24 see how it performs relative to that?

25 MR. DEEVER: Let me clarify one thing

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 here. Our fuel bundles sit in the top guide, but
2 the flow does not go by the top guide surfaces
3 itself. It -- you know, the top guide is a lateral
4 support for the top of the fuel.

5 CHAIRMAN CORRADINI: Right.

6 MR. DEEVER: So there's no flow in
7 between the structure in the top guide structure
8 itself. It's all within the channels of the fuel.

9 MEMBER SHACK: With some bypass.

10 MR. DEEVER: There's a little bypass that
11 occurs.

12 CHAIRMAN CORRADINI: Yes, okay. But I'm
13 just trying --

14 MEMBER SHACK: But the loading you're
15 going to get from your Hitachi tests on the channel,
16 to answer Mike's question.

17 CHAIRMAN CORRADINI: I'm trying to
18 understand the pressure --

19 MR. DEEVER: I'm not sure if we're
20 talking top --

21 CHAIRMAN CORRADINI: -- I'm trying to
22 understand the forcing function that you're going to
23 observe the 3-dimensional element analysis with.
24 And is it going to be test data?

25 MR. DEEVER: In the top guide, or the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 partitions, now.

2 CHAIRMAN CORRADINI: What he's worried
3 about.

4 MR. DEEVER: This topic is mainly the top
5 guide.

6 CHAIRMAN CORRADINI: The top guide.
7 Loaded with the partitions. And your point is, the
8 way you're going to load it, it'll be on the outside
9 ring.

10 MR. DEEVER: Exactly.

11 CHAIRMAN CORRADINI: Okay. All right.
12 Thank you, I get it.

13 MR. DEEVER: We're primarily in our
14 analysis trying to establish what natural
15 frequencies and stiffnesses are present across the
16 top guide to help.

17 CHAIRMAN CORRADINI: Okay. All right.
18 That helped. Thank you very much.

19 MR. DEEVER: Okay.

20 MR. RAJAN: So if there are no additional
21 questions, I'll proceed to 3.9.2.5. In this
22 section, the staff reviewed the dynamic system
23 analysis that were performed to confirm the
24 structural design adequacy and ability of the
25 reactor internals and the unbroken loops of the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 reactor internal piping to withstand with no loss of
2 function the loads from a local in combination with
3 a SSC.

4 The staff reviewed the methods of
5 analysis, the concentration in defining the
6 mathematical models, the descriptions of the forcing
7 functions, the calculational schemes, the acceptance
8 criteria and the interpretation of the analytical
9 results.

10 In DCD Section 3.9.2, the applicant
11 states that the analysis for the -- will be
12 determine -- will determine the reactor internals
13 pressure differentials resulting from an assumed
14 break in the main steam line and the feed water
15 line. To ensure that no significant dynamic
16 amplifications of the load occurs as a result of the
17 oscillatory nature of the blow down forces during an
18 accident, the periods of applied forces were
19 compared to the natural periods of the structures
20 being acted upon by the applied forces.

21 A comprehensive vertical dynamic model
22 of the RPV and the internals is used to determine
23 these periods. In RAI 3.9-81, the staff asked and
24 requested information that the applicant provide the
25 analytical results to demonstrate that there is no

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 significant dynamic amplification of the loads on
2 the reactor internal component structures as a
3 result of the postulated break in the main steam or
4 feed water line.

5 Those results have not been provided to
6 the staff so far, so this item, this RAI 3.9-81,
7 remains an open item. And that concludes my part of
8 the presentation.

9 MR. WALLIS: So the main steam line has a
10 break, does this result in significant loading on
11 the steam dryer?

12 MR. RAJAN: That is one of the concerns
13 on all the reactor in general, and the steam dryer
14 of course is part of the reactor internals.

15 MR. WALLIS: Does the staff know how to
16 calculate these forces?

17 MR. RAJAN: Well, it's based on, as they
18 pointed out, it's based on a detailed analytical
19 model of the reactor internals. And of course, with
20 -- we can make a simplified analysis, but for a
21 detailed, since GE has already done that, we are --
22 we have requested for the analytical results of that
23 analysis. And that apparently is being provided to
24 us in the near future. But so far to date, we have
25 not received those results.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. PATEL: Okay. I guess we'll go to
2 Section 3.9.3, it's on ASME code, Class I, II, III
3 component and component support and COL
4 superstructure.

5 I guess this is basically ASME code-type
6 of requirement, 10 CR 50.50 Part A. And GDC 124, 14
7 and 15. Basically, the ADWR review included loading
8 combination, design transient and stress limit used
9 for entering the structural integrity of the reactor
10 pressure vessel assembly and other mechanical
11 components, valve operability assurance, design and
12 installation of pressure devices and component
13 support.

14 In this area, we did not -- we had only
15 two open items when we issued the safety evaluation
16 for Revision 3. And then we had Revision 4, which
17 removed one of the correction items and we had to
18 issue one more RAI. So you know, we have three RAI
19 open. I will discuss a little bit in detail.

20 The first RAI was the effect of the
21 snubber fitting and the lost motion on equal load
22 setting of multiple support -- multiple snubber
23 support, which is RAI 3.9.1.14. And that was
24 resolved.

25 There was another RAI, which was

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 3.9.1.17, that also included description of the
2 snubbers production and qualification test program
3 and the compliance of the snubber design to ASME
4 code. And this one was resolved.

5 The third one is much kind of important
6 open RAI. Initially, they had in Rev 3, they had
7 the COL action item, which required them to make
8 available design specification and design report of
9 ASME Section 3, mechanical component to NRC.

10 And they removed that. And so right
11 now, we are still in discussion with GEH to figure
12 out what is the best way to handle it. So that is
13 still open item.

14 And there is one more COL information
15 item which is, still there. They will provide plan
16 for detail snubber in the testing and inspection
17 program.

18 So, basically, in this section, there is
19 one COL action item which is open, which we don't --
20 we have not decided exactly how we are going to
21 handle it. That completes 3.9.3.

22 Andrey Turilin will present the 3.9.4,
23 controller drive system.

24 MR. TURILIN: Thank you. Good afternoon.
25 Like he said, my name is Andrey Turilin. I'm going

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 to talk about 3.9.4, control rod drive system.
2 Basically Section 3.9.4 review says the design of
3 the control rod drive components pertaining to ASME
4 Section 3 code, primary the reactor coolant pressure
5 boundary components.

6 Additionally we, the staff, also looked
7 at other components such as the electro hydraulic
8 fine motion control rod drives mechanism, the
9 hydraulic control unit assemblies, supply system and
10 the power to the fine motion control rod drive
11 motors.

12 A review of the appropriate loadings and
13 stresses and information criteria was also
14 performed. Talking about the technical review
15 summary, the staff in its review of Section 3.9.4,
16 the staff evaluated the quality group classification
17 of control rod drive components, mainly to ensure
18 that reactor coolant pressure boundary components
19 are designed to ASME Section -- ASME code, Class I
20 requirements.

21 The staff also evaluated the structural
22 adequacy of the system by looking at the loading
23 combinations, which include normal, anticipated
24 operational occurrences and natural and accident
25 events.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 The staff also looked at the stress
2 limits and the deformation and fatigue limits, which
3 are of interest in the instances where a failure of
4 the movement, due to excessive deformation, could be
5 postulated and such movement would be unnecessary
6 for a safety-related function.

7 Additionally, the staff evaluated the
8 testing programs, which include factory quality
9 control tests, the functional, mechanical functional
10 test, operational tests, acceptance tests and
11 surveillance tests.

12 Originally there were five open -- there
13 were five RAIs issued to GE. And all five were
14 satisfactorily answered. There are no open items
15 and there are no COL information items. That pretty
16 much concludes Section 3.9.4 review.

17 CHAIRMAN CORRADINI: Thank you.

18 MR. PATEL: We have to just, one minute
19 please.

20 MEMBER ARMIJO: Changing the troops?

21 MR. PATEL: Yes. This is the most
22 important subject, I guess, for DBWR methodology,
23 all the questions you may have. This is the time.

24 MR. SEKERAK: You're really setting me up
25 here.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 (Laughter)

2 MR. PATEL: This is Pat Sekerak. He's
3 going to make the presentation on 3.9.5.

4 MR. SEKERAK: Good afternoon. My name is
5 Pat Sekerak, I'm with the engineering mechanics
6 branch of office of new reactors. And I'll discuss
7 chapter 3.9.5, RPP internals.

8 Before we begin, to begin, I'd like to
9 introduce individuals who continue to provide
10 invaluable specialized technical service for reactor
11 internals designs. And that includes Vikram Shah,
12 in the middle, principal investigator from Argonne
13 National Laboratory, Steven Hambrick, to my
14 immediate right, who is the head of Structural
15 Acoustics Department at Penn State University, and
16 to the far right, Thomas Mulcahy, who is a senior
17 technical investigator, also from Argonne National
18 Laboratory.

19 Regarding review guidance, the primary
20 objective for the design of the reactor vessel
21 internal structure is to provide support and
22 confinement of the reactor core with sufficient
23 design margin to ensure fuel performance and
24 reactivity control.

25 The core support function requires

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 application of the highest level of quality and
2 design criteria, as indicated by the general design
3 criteria referenced here. However, there is a
4 graded application of the GDC criteria focused on
5 those RPV internal structures identified as core
6 support structures.

7 Regarding the status of the review
8 summary, currently, the staff's technical review of
9 the basis for the RPV internals design is
10 concentrating on the design codes and standards
11 specified in the ESBWR design control document and
12 the analytical and testing methods used to implement
13 the rules of those standards.

14 The RPV internals have been classified
15 by GE into three different categories. First are
16 safety-related core support structures, which
17 include the core shroud, shroud supports, and core
18 plate.

19 Second, there is a category called
20 safety-related internal structures. These include
21 the SLC system header and piping and in core guide
22 tubes.

23 And finally, there is a category named
24 non-safety-related, albeit, important to safety
25 internal structures, which includes a steam dryer.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 The design criteria and quality
2 standards selected to meet the general design
3 criteria applicable to RPV core support structure
4 include the design and construction rules of ASME 3,
5 subsection NG, in its entirety. The core support
6 structures require ASME certification and code
7 stamping, and are constructed to meet the full
8 requirements of code subsection NG.

9 The design of so-called safety-related
10 internal structures and the non-safety, albeit
11 important to safety steam dryer, utilize a limited
12 application of ASME 3 requirements, including the
13 design by analysis rules of subsection NG 3000, and
14 the applicable ASME 3 allowable stress criteria
15 associated with that.

16 I think that the staff -- it's important
17 to indicate that the staff review has also indicated
18 the design process for the ESBWR steam dryer is also
19 incorporating many of the lessons learned from
20 operational failures of BWR steam dryers subjected
21 to power-up rate conditions in the operating fleet.

22 And examples of this include, close side
23 branch pipe intersections of the ESBWR steam, main
24 steam system, are being designed to minimize the
25 potential for acoustic resonance condition, and the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 resulting potential for fatigue degradation of the
2 steam dryer, excuse me, due to amplified acoustic
3 pressure loading.

4 This was one of the main causes of steam
5 dryer degradation identified in the -- some of the
6 beat up BWR 3 failures of the steam dryer recently
7 in the operating fleet.

8 Now secondly, an important consideration
9 is that the ABWR prototype for the ESBWR steam dryer
10 design is similar to the replacement steam dryers
11 installed in operating BWR plants which have
12 experienced steam dryer fatigue failures.

13 These replacement dryers use design
14 upgrades including thicker plate structure to
15 improve stiffness and structural response to
16 alternating pressure loads, and also introduced the
17 slated or curved hood design replacing the old
18 square hood design, which reduced the effects of
19 vortex shedding and turbulence of steam flows
20 flowing around the steam dryer.

21 Currently, although the staff review of
22 DCD Section 3.9.5 is proceeding in a positive
23 direction, the overall conclusion remains pre-
24 decisional at this time due to a number of open
25 items which still require resolution.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 Regarding the open items, the open items
2 currently remaining from previous review work fit
3 within the general technical categories listed here.
4 Progress has been made in resolving five of the 14
5 open items identified in the draft SER transmitted
6 to the ACRS in support of this meeting.

7 Most of the nine open items remaining
8 are expected to be resolved by the technical
9 revisions of the new set of GE topical reports
10 recently submitted and currently undergoing staff
11 review. And the work ahead of use is captured
12 primarily in the last bullet, on-going topical
13 report reviews.

14 There are four topical reports listed
15 here which are now being reviewed by the staff with
16 two primary goals in mind. First, is to develop an
17 understanding of the detailed methodology presented
18 for approval of the steam dryer design process. And
19 second, we hope to use these reports to assist in
20 closure of existing open items.

21 The first objective will produce a new
22 set of RAIs primarily due to the complex technical
23 methodology presented in NEDC-33408P report, which
24 GE refers to as PBLE, or Plant Based Load Evaluation
25 methodology.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 The PBLE method report describes an
2 analytical tool for definition of acoustic and
3 hydrodynamic pressure loads applicable to the steam
4 dryer design. This PBLE method will be applied to
5 both the new ESBWR steam dryer design, and to
6 evaluation of structural integrity of existing steam
7 dryers for BWR operating plants requesting extended
8 power-up rates.

9 The staff will issue a new set of RAIs
10 on these reports within the next month. The
11 resolution process for these new RAIs in addition to
12 closure of existing open items, is expected to
13 extend well into the later part of this year.

14 The point being, that there's been
15 significant amount of work done up to now, but
16 there's also a significant amount of work remaining
17 to close out existing open items and to review the
18 three topical reports that under report reviews
19 start with the steam dryer, primarily.

20 Those three topical reports, NEDC-33408,
21 NEDE-33312, and NEDE-33313, are intimately related.
22 And they all taken together, define the process for
23 design of the steam dryer, including the load
24 definition methodology, which probably is the most
25 important part of the design process in defining a

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 load system to be applied, and also, the structural
2 evaluation of the steam dryer, once the load
3 definition is fully defined.

4 And those three reports, which are
5 currently under staff review, will hopefully provide
6 the basis for the new steam dryer design. And I
7 will say that the most important and most complex of
8 all of those is the PBLE methodology, 33408P, which
9 is a computerized predictive tool used to define,
10 again, the flow induced loadings that will be
11 applied to the steam dryer under operational load
12 conditions.

13 MEMBER SHACK: From main steam line
14 measurements, or from ab initio?

15 MR. SHEMANSKI: No, this is a predictive
16 analytical tool. It will be verified. The results
17 -- it will be used for a predictive analysis. The
18 flow induced vibration program, defined in
19 Subsection 3.9.2, will provide the final
20 verification by testing to validate the predictive
21 analysis. Excuse me, go ahead Steve.

22 MR. HAMBRICK: Yes, the tool is a mix of
23 predictive technology as well as in plant
24 measurements. So, the instrument, the dryer, with
25 several transducers which they then apply the data

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 from, as boundary conditions to a numerical model of
2 the steam in the dome, which includes boundary
3 conditions with the steam, or the water interface
4 underneath, the walls and the inlets to the main
5 steam pipes. So, it's a curve fit, if you will, to
6 what's going on inside the actual plant. And
7 they're using --

8 CHAIRMAN CORRADINI: But they need data.

9 MR. HAMBRICK: They're using data from
10 ABWR, they're using data from existing dryers in
11 quad cities before the installation, they applied
12 site ranches, and also Susquehanna.

13 MS. CUBBAGE: We -- proprietary, yes, no?

14 MR. SHEMANSKI: I think --

15 CHAIRMAN CORRADINI: Proprietary, you're
16 not allowed to say what just was said?

17 MR. SHEMANSKI: Maybe GE -- if we start
18 to infringe on proprietary information that's in
19 these reports, would GE please step up. Because we
20 don't want to reveal anything that's proprietary in
21 a public forum. I'm hoping we're not.

22 MR. KINSEY: This is Jim Kinsey from GEH.
23 We're sensitive to that question and have been
24 listening closely. And we're closely approaching
25 the boundary.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 (Laughter)

2 MR. SHEMANSKI: So, I think we --

3 CHAIRMAN CORRADINI: So, we need to say
4 it's data with analysis based on the data for
5 boundary issues.

6 MS. CUBBAGE: But I believe this meeting
7 was noticed as the potential to close, so if the
8 committee would like to pursue that avenue, we
9 certainly can do that. And I believe -- you all
10 don't have a time line to leave, right? So, we
11 could do that at the end. We could come back to
12 that.

13 CHAIRMAN CORRADINI: Fine. Okay.

14 MEMBER SHACK: What is the difference
15 between the flow induced load definition and the
16 acoustic load? Is that -- is there a one sentence
17 distinction?

18 MR. KINSEY: We're probably going to jump
19 over the line on that.

20 MEMBER SHACK: Oh, okay.

21 MR. HAMBRICK: They're coming up with
22 loads based on existing measurements and then
23 applying them to their dryer design.

24 MR. KINSEY: And again, this is Jim
25 Kinsey from GEH. We're happy to address some of

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 these questions. We have the right people here
2 today. We'll just need to close the session to do
3 that, if that's convenient for the subcommittee.

4 MS. CUBBAGE: As a matter of fact, since
5 we were done with the prepared presentation here,
6 maybe we should go on to the others and then come
7 back in closed session. Is that okay?

8 MR. SHEMANSKI: Sure, whatever is
9 appropriate. That would be fine.

10 MS. CUBBAGE: Let's swap out teams, get
11 through the other slides real quick, and then we'll
12 get into this.

13 MR. SHEMANSKI: One final comment that
14 Pat made, they will indeed validate all this with in
15 plant measurements during startup, with the ESBWR.

16 MR. PATEL: Tom Scarbrough is going
17 present the 3.9.6.

18 MR. SCARBROUGH: Good afternoon. Tom
19 Scarbrough, and I'm in component performance branch
20 of NRO. I'm going to talk a little bit about 3.9.6,
21 which is the functional design qualification and
22 it's a recessing program.

23 The first slide there shows the
24 regulations and reg guidance that was applicable.
25 Part 52, Part 50, Appendix A, and the QA performance

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 of Appendix B, 10 CFR 50.55(a), the in service
2 testing requirements, and the guidance we use is the
3 standard review plan 396. It's been updated to
4 follow this new approach, and also commission paper
5 SECY-05-0197, which as we heard earlier, in service
6 testing is one of the operational programs, as well
7 as MOV testing, Motor Operable Valve testing is an
8 operational program. So it has a little bit of
9 different approach to it in terms of how to address
10 that. And I'll get into that in a couple of
11 minutes.

12 The technical review summary, the
13 information that we review in the DCD is spread
14 throughout the document in some cases. 3.9.3.5, is
15 valve operability assurance, which talks about the
16 qualification and testing analysis, and I'll talk a
17 little bit about that in a minute.

18 3.9.3.6, is the pressure relief devices,
19 and it covers the safe relief valve, the vacuum
20 breaker valves and the depressurization valves.
21 3.9.3.7, are compliment supports, and there it
22 refers to OM code Section ISTD, because that's the
23 new version, the new method of dealing with
24 snubbers.

25 And then 3.9.6 itself, is the functional

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 design qualification, in service testing, sort of
2 overall. And it indicates that there are no safety-
3 related pumps, which you heard earlier today, and
4 the valves themselves will be covered by OM code,
5 2001 edition and 2003 addendum.

6 Now, our technical, next slide. Our
7 technical review, how we went about it was, we used
8 the lessons learned from the functional design
9 qualification issues that we've had with valves over
10 the past, you know, 15 years or so, as part of the
11 review. In regard to valve performance, there also
12 is a whole body of operating experience that we use
13 in terms of looking at how they address that.

14 We had numerous RAIs requesting
15 information in these areas. We had a public meeting
16 on May 22nd, with GEH and also North Anna to talk
17 about what was the goal of the DCD in terms of
18 addressing this operational program for ISTD, and
19 how are they going to deal with that in terms of COL
20 applications.

21 And that was with the design center
22 working group, DCWG. And that was a very successful
23 meeting in dealing with that. And we've come to a
24 point where we think we're heading toward a success
25 path on that.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 In terms of the RAIs themselves, as I
2 said, there was -- there were numerous of them, a
3 number of them. One area that we had, and you've
4 sort of seen that somewhat today, where there are
5 references to COL applicant and references to COL
6 holder.

7 And in the early versions of the DCD, it
8 referred to the applicant would be doing this, the
9 COL applicant would be doing this. And then later,
10 as the revisions moved forward, some of those
11 references turned into COL holder would do that.

12 And part of our task is to prepare a
13 safety evaluation which provides a finding on the
14 adequacy of the program. And therefore, as
15 described in SECY paper 05-197, the COL applicant
16 has to provide a full description that fully
17 described the operational programs.

18 And so we had to determine, okay, where
19 are we going to have this information so we can
20 write the safety evaluation. And that's part of the
21 challenge that we had with the wording change. And
22 we think we're heading towards a solution on that.

23 Also, we have a lot of questions on the
24 functional capability qualification. Because in
25 that original summary of 3.9.3.5 of the DCD, it

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 talks about testing and qualification and testing
2 qualification analysis, it could be done by
3 combination of test or analysis. And you all talked
4 about that some today. But it was very general.

5 And one of the things we want to do is
6 try to provide some specificity to that. There is a
7 new ASME standard, QME1-2007, which was a result of
8 20 years of work to incorporate the lessons learned
9 from the valve qualification issues and the valve
10 performance issues into a very proscriptive
11 standard. And that's been issued, and the staff is
12 working on endorsing that in reg guide 1.100, which
13 should be hopefully out soon.

14 But we wanted to work that into our
15 discussions. Also pure audit verification of power
16 operative valves, there's a history there, there's
17 information from the operating plants, from generic
18 plate 8910, there's a joint owners group program on
19 both motor-operated valves and other power operative
20 valves, and we wanted to make sure that that was
21 incorporated.

22 And the last area of issue there was the
23 depressurization valve qualification program. There
24 was some work done with the SBWR, and they had
25 information from that. So, we were able to go down

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 and take a look at that information at the E offices
2 in Washington and look at how they did that
3 qualification program. They did quite a bit of
4 testing at Wiley, so we were able to look at that
5 data.

6 So, those were some of the areas that we
7 dealt with through the RAI process. And in terms of
8 the open items, a number of those areas, those RAIs
9 were addressed through either responses and there
10 was additional discussions, additional indications
11 of some adjustments that could be made to the DCD as
12 a result of the May 22nd meeting.

13 We did have one open item that remained
14 open from RAI 3.9-168. And it had to do with the
15 safety relief valves and their IST test frequency.
16 It didn't appear consistent with ASME code, and we
17 asked them to go back and take a look at that. And
18 they came back just recently and said, yes, there
19 were some changes they need to make to the DCD table
20 and they're in process of doing that.

21 And so that should show up in -- as we
22 do the review of Revision 5. So, that should work
23 out.

24 In terms of the COL item, we still need
25 to address the process by which the applicant is

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 going to ensure that IST program, MOV operational
2 test program is fully described per the SECY paper
3 05-197. And we're working on the wording of that.
4 Because what happens is, the COL applicant wants to
5 rely on DCD as much as possible, but there are some
6 areas where it's plant-specific for their
7 operational program. So they need to provide
8 information that's separate from that.

9 So, it really needs to be -- the COL
10 item really needs to be as a combination, the COL
11 applicant will provide through the DCD and through
12 it's own FSAR submittal, the full description. And
13 so we need to work that out with them. So, we're in
14 the process of doing that.

15 I did hear that you all had a question
16 on the MSIVs in terms of -- and there has been a
17 change in how they describe those. In Revision 3,
18 they were indicated to be a Y-pattern globe valves,
19 with air operators, with spring assist. And that's
20 a kind of a standard. We've looked at these quite a
21 bit, this sort of MSIVs, for the power-up rates.

22 Because we were concerned about the
23 higher flow rates might cause the valves to close
24 faster than allowed. So, they do have compensating
25 factors so they don't close too fast, say between

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 three and five seconds. And that was part of what
2 they had to do.

3 Also, they are part of the qualification
4 program, the 3.9.3.5 process where they have to
5 provide qualification, and that new Revision, in
6 Revision 5 of the DCD, indicates that these valves
7 need to be qualified through QME1 2007 if they're a
8 new design. If they're a previous design, they'll
9 have to follow some of the critical parts to
10 incorporate a lessons learned. That has to be done
11 as well.

12 They still have to do through that
13 process, plus they have to be a part of the IST
14 program, and they are listed in the IST program
15 table in the DCD. So, they have to go through that
16 process as well.

17 And also, there is a -- because this is
18 a specific valve, there are specific ITAACs for
19 valves for -- to make sure that they're able to
20 operate properly, and there's an ITAAC for this MSIV
21 as well to make sure they close under the proper
22 conditions.

23 So, that's the -- that's where they were
24 in terms of how describing Revision 3. Now,
25 Revision 5 has taken out the specific design

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 discussion in Chapter 5, but it still indicates they
2 are globe valves in the IST table, and their
3 operators, and so they have that sort of general
4 description of what types of valves they are. But
5 they don't have the sort of detailed internal
6 discussion that they had in Chapter 5. So, we'll be
7 talking to them about that and see where we go with
8 that change of description.

9 What they've done is, they've described
10 more functionally what has to happen, what the
11 design requirements are as opposed to saying
12 specifically what the valve type internal design is.
13 And so we'll be reviewing that as part of our review
14 of Revision 5.

15 That's basically all I had for 3.9.6.
16 Are there any questions.

17 MEMBER STETKAR: I guess I'm the source
18 of the question about the MSIVs and I've been trying
19 to follow it since last October. So, everything
20 you've just said I'm happy to hear that. I was just
21 curious why there's nothing about them written
22 anywhere in the SER other than in general terms in
23 Chapter 3. Why there's no evidence in Chapter 5 of
24 the SER, that you actually looked at them as
25 components and this kind of I'll call it story, but

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 discussion of why the design as at least presented
2 in DCD Rev 3, was reasonable because these are no
3 different than any other -- there's not even a
4 paragraph in there.

5 And there are long paragraphs and pages
6 about other valves in the plant.

7 MR. SCARBROUGH: Yes, I'm not sure why
8 that wasn't in there.

9 MEMBER STETKAR: And it's not. We were
10 told it was in Chapter 3, so that's why --

11 MR. SCARBROUGH: Okay.

12 MEMBER STETKAR: And it's not.

13 MS. CUBBAGE: Let's move on.

14 MEMBER BLEY: At least you'll find the
15 testing.

16 MEMBER STETKAR: Oh, on 14, yes.

17 MEMBER SHACK: A question on the
18 qualification on the depressurization valves. These
19 are identical to the ones that were done for the
20 SBWR, or?

21 MR. SCARBROUGH: Right. These are the
22 same size. They -- in terms of a qualification for
23 it.

24 MEMBER MAYNARD: And it's the same design
25 with the squib for the deluge system?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. SCARBROUGH: Well, they -- because of
2 the size differences, they were working on different
3 designs, size designs, because they wanted to make
4 sure that --

5 MEMBER MAYNARD: But the mechanism is
6 identical. It's the size of the valve which is
7 different?

8 MR. SCARBROUGH: No, there was a
9 different mechanism because one had a sort of a
10 plunger that got pushed out of the way, another one
11 had a cantilever that pushed over. And they were
12 trying to make sure that that cantilever stayed
13 over. They don't want to have a problem. So I
14 think they're still working on that design. They
15 went back and the last I heard they were rethinking
16 that design because they want to make sure that
17 there's no either the -- that both designs will
18 provide a pure flow area and it doesn't get hung up.

19 So, I think they're looking at both of
20 those types of designs. I'm not sure which one
21 they've settled on. But those -- they did have a
22 slightly different design because of the size and
23 they thought they could have a different approach to
24 it. But I think they're going to go back and look
25 at that, the last I heard on it.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. PATEL: I guess, next, John Fair is
2 going present Section 3.12.

3 MR. FAIR: Yes. I'm John Fair from NRR.
4 Originally 3.12 was developed at NRR with the
5 assistance of Brookhaven National Lab. And since
6 the transition to NRO, I've maintained a review of
7 the open item. So, I'm still reviewing the open
8 items for NRO.

9 As GEH pointed out earlier, there was no
10 SRP Section 3.12 to -- originally for them to write
11 the DCD to. So, what we used as guidance from
12 ABWR's SER which did have a section 3.12. I'd say
13 the only, the big difference between what we've done
14 in our 3.12 and what ABWR did in 3.12, is ABWR
15 lumped a lot of section 3.6 and a lot of section 3.2
16 in their 3.12.

17 But since we had separate reviewers and
18 separate branches doing section 3.6 and 3.2, we took
19 that out of the Section 3.12 for the ESBWR. Next
20 slide is on the review guidance.

21 I'll just point out that the second
22 bullet, we have a typo, which should be 10 CFR 52.47
23 for the ITAAC. Since I'm at NRR, you know, Part 50,
24 I can't think in 52 yet. But other than that, it's
25 regularly, it's the same GDCs that are used in

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 mechanical and 50.55(a) is just the codes and
2 standards.

3 And the SRP sections that we use for
4 acceptance criteria were 373 and 39, which were
5 existing at the time.

6 The next section, I just point out some
7 of the areas of interest in the SE. We did two
8 audits at GE's sites, the one in Wilmington and the
9 one in GE San Jose. I think at the time we did the
10 Wilmington audit, there was a lot of transition
11 going on with GEH. And so we found that a lot of
12 the documentation we were looking for to review at
13 the Wilmington audit, we really had to go back to
14 San Jose to get the information, and then have the
15 technical experts to discuss it with us.

16 So, at the first audit, there was a
17 little bit of a problem getting the documentation
18 together for some of the things that we wanted to
19 review which were some of the verification
20 documentation for computer programs and things like
21 that.

22 So, we looked at that in the second
23 audit, and they had pulled that together a little
24 better the second time we went around to GE San Jose
25 offices.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 The second item I want to point out was
2 ASME code addition. They're using 2001 through 2003
3 addenda, but they are maintaining the restriction
4 that the staff put in 50.55(a) for the use of the
5 seismic piping rules. They're maintaining the pre-
6 1994 seismic piping allowable stresses in their DCD.

7 The next item of interest is the single
8 earthquake design criteria. Now, what happens in
9 the single earthquake design criteria is, that you
10 eliminate the OBE and you eliminate some of the
11 loads that are evaluated in the fatigue analysis,
12 and you eliminate the evaluate for seismic anchor
13 motion loads.

14 So what was done in the ABWR in the
15 other design certifications was additional criteria
16 was provided to cover that area in terms of the
17 fatigue analysis where two SSC load cycles were used
18 for the fatigue analysis, and a separate allowable
19 for seismic anchor motions was added in to cover
20 those areas.

21 And the next item of interest is the
22 feed water nozzle thermal stratification evaluation.
23 GEH had developed some stratification loads based on
24 testing of, I think it was a Lung Min design, ABWR
25 and were going to use that for ESBWR evaluation on

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 the assumption that those were conservative load
2 definitions.

3 After some discussion, back and forth
4 with the staff, they committed to do some thermal
5 monitoring on the ESBWR to verify that they had
6 conservative load definitions for the stratification
7 evaluation.

8 MR. WALLIS: Are these fluctuations, or
9 are they just normal stratification, or is it a -0

10 MR. FAIR: It's a combination of --

11 MR. WALLIS: A fatigue-type thing is it?

12 MR. FAIR: It is related to a fatigue
13 analysis. It's design transients for the fatigue
14 analysis, and they're going to instrument
15 temperature, displacement and I believe strain gage
16 measurements to verify that they had a conservative
17 load definition.

18 MR. WALLIS: But they're close enough to
19 the existing plants, so that's okay, aren't they?
20 They're close enough are they to --

21 MR. FAIR: I'm not sure I --

22 MEMBER SHACK: The ABWR.

23 MR. WALLIS: The Japanese plant,
24 presumably, right?

25 MR. FAIR: Well, the original assumption

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 was that the load definition that they had developed
2 from the measurements on the Lung Min plant was
3 conservative for the ESBWR. The intent of this was
4 to verify that with testing on ESBWR. The next --

5 MEMBER SHACK: Just coming back to this,
6 John, so you're going to get two contributions. So
7 you're going to get a bending moment just because of
8 the thermal stratification, then you're going to get
9 to see --

10 MR. FAIR: Get some fluctuations, yes.
11 And we did not go into looking at the details of the
12 load definitions, because at the time of the audits,
13 they had not done the feed water line analysis. So
14 that's something that is a potential to be looking
15 at later down the line when they're complete with
16 the design.

17 The next item of interest is we had
18 Brookhaven do a confirmatory analysis on the main
19 steam line. We chose the main steam line because it
20 had a lot of different analysis associated with it.
21 It had seismic analysis of the steam line, it had
22 SRV lines, it had discharge loads, and it had a main
23 steam stop valve closure transient. So, we had
24 Brookhaven try to model that up, and do some
25 confirmatory analysis to see how well we matched

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 with GE's analysis.

2 When we did this, we ran into some
3 limitations with Brookhaven's piping analysis code
4 that we have used for years to do bench marking.
5 The model was fairly big that we selected from GE.
6 And GE was using some analysis methodologies out of
7 reg guide 1.92 that hadn't been built into the
8 Brookhaven PISYS pipe code.

9 So, what we had to wind up doing on that
10 is to do some bounding analysis with the PISYS safe
11 piping code to see if we could bound the GE results.
12 And after a lot of discussion back and forth, I
13 think pretty much we're happy with what we've got on
14 this confirmatory analysis. But we wish we could
15 have gotten a little better confirmatory analysis if
16 we had updated the GE PISYS, I mean, the BNL PISYS
17 safe code before we started this evaluation.

18 And again, the last thing I wanted to
19 bring up from the review was, the fatigue analysis
20 criteria. This is the first application that we're
21 asking an applicant to evaluate environment fatigue
22 on, and it's one of the issues down in the open item
23 issues I'll discuss in a second here.

24 As far as the open items, these are the
25 open items as discussed in the SE that was provided

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 to the ACRS. Most of these are now closed based on
2 follow-up submittals from GE. And I'll go over the
3 ones that are closed, and tell you which ones are
4 open.

5 The first one had to do with the
6 independent support motion. A combination of group
7 responses, GE and the DCD were proposing SRSS. The
8 staff position that we had in NUREG-1061, required
9 absolute sum. We asked GE to provide us some -- a
10 study to justify the use of SRSS in lieu of the
11 absolute sum that the staff guidance was requiring.

12 GE picked two fairly significant lines
13 to do an evaluation of. The feed water line, and
14 the main steam line, which ran through various
15 elevations and various buildings, at structure
16 locations.

17 The results of the evaluation show that
18 the -- and the evaluation was based on the
19 comparison of the SRSS with multi-support time
20 history, which is the methodology the staff
21 considers the most accurate method of doing the
22 calculation.

23 The results of the comparison show that
24 there were a few locations that exceeded the --
25 where the multi-support time history loads exceeded

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 the SRSS combination as proposed by GE for the ISM.
2 So, in order to resolve the issue, GE agreed to use
3 their SRSS with an additional ten percent increase
4 on the loads and the stresses to bound the results
5 of the comparison from the sample study. And we're
6 going to find that as an acceptable approach. It's
7 also consistent with other studies we've seen where
8 independent support motion studies were done and
9 compared the multi-support time histories.

10 The second issue that we had was the
11 bench marking of the PISYS computer code. When we
12 did the audit and looked at the benchmark for the
13 PISYS code, there were a couple of locations that
14 exceeded the acceptance criteria in the NRC's
15 benchmark new reg report.

16 And it appeared that the PISYS code also
17 was -- had been based on an earlier addition of the
18 Reg Guide 1.92, instead of the Reg Guide -- the
19 addition that was referenced in the DCD. GE has
20 subsequently gone back and redone the bench marking,
21 updated the code to meet the latest Reg Guide 1.92
22 criteria. And they've come in and said that they
23 were within the acceptance criteria of the benchmark
24 new reg, and so we find that acceptable.

25 The next issue had to do with a

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 decoupling criteria for small branch line piping.
2 What happens on the small branch line piping is when
3 you decouple from the large pipe, the original
4 proposal was to use the response spectra that's used
5 at the support to the -- of the large pipe for the
6 small pipe analysis.

7 However, if there's a significant
8 response of the large pipe, it gets amplified from
9 the supports and input into the small branch line
10 piping. So, in order to resolve the concern, GE
11 proposed a set of criteria which is essentially make
12 it rigid near the connection point, or have a big
13 overlap region between the branch piping where you
14 cut it off from the main piping, or to generate a
15 response spectra at the attachment point and pick up
16 the amplification from the big pipe to the small
17 pipe.

18 MR. WALLIS: Which is best? Which is most
19 realistic?

20 MR. FAIR: Well, the most technically
21 accurate way is to do a full coupled model. If you
22 develop a response spectra from the attachment
23 point, you tend to be over driving the small pipe.
24 Because some of the energy will reduce the large
25 pipe's response.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 The easiest method to do it is to put a
2 support right next to the attachment point so you
3 get no amplification.

4 The next issue we have, which is
5 unresolved at this point in time is the -- DCD has
6 SRSS combination for a lot of loads, including SRVs,
7 LOCAs and earthquakes. The staff has guidance in
8 new Reg 0484 for determining when you can use SRSS.
9 And it's essentially if you do some kind of a study
10 to justify that you have an 84 percent non-
11 exceedence probability, using the SRSS flow
12 combination. And we requested that GEH do an
13 evaluation to justify the places where they're using
14 this SRSS load combination.

15 The next issue that was open, was the
16 high frequency mode combination. As I discussed a
17 little bit earlier with the confirmatory analysis,
18 GE had not been using the latest edition of the Reg
19 Guide 1.92 for the high frequency mode combination.
20 They had referenced an earlier criteria that was out
21 of the SRP.

22 They've subsequently come in and
23 referenced the latest SRP -- Reg Guide. I'm sorry.
24 Reg Guide 1.92 criteria, and we find that
25 acceptable.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 The next issue was environmental
2 fatigue. As I said previously, this is the first
3 applicant that we're requesting that they meet the
4 environmental fatigue Reg Guide that was just
5 issued.

6 As part of coming into and agreeing to
7 meet the Reg Guide, they've requested to change the
8 pipe break criteria. Just a little correction of
9 what was said earlier, the fatigue usage factor
10 criteria for pipe break postulation was not in the
11 Reg Guide 1.207. This was a proposal by GEH because
12 of the fact that when you cranked in the
13 environmental fatigue, you raised the usage factor
14 of all the locations, and you would possibly cause a
15 lot of additional pipe support -- pipe break
16 postulations.

17 We discussed this, I think, when we
18 presented this Reg Guide to the ACRS. And that was
19 an industry concern. GEH did a study showing that
20 would increase the number of locations which you
21 would have to postulate pipe breaks. This criteria
22 was also referenced many years ago in the ANSI
23 standard 58.2. And at that time, there was an
24 effort to raise that pipe break postulation criteria
25 up to the .4 factor because of a concern of

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 excessive number of pipe rupture locations. At that
2 time, the staff didn't accept that proposal because
3 of the concern within environmental fatigue was just
4 developing.

5 Now that we've solved the concern with
6 environmental fatigue, we think it's appropriate to
7 accept that proposal to increase the criteria to .4.

8 And the last issue --

9 MEMBER SHACK: Are they doing this for
10 all their analysis, or they're still picking some
11 representative number of places to look at?

12 MR. FAIR: No, this is across the board.

13 MEMBER SHACK: Across the board.

14 MR. FAIR: This is, yes. And the last
15 issue I had was uniform support motion, combination
16 of inertia and SAM loads. Currently in our SRP 3.9,
17 it requires that combination be done by absolute
18 sum, which is the worst combination. GE and the DCD
19 put in a SRSS. We've requested them to either
20 justify it or commit to the SRP criteria.

21 It was my understanding that GE was not
22 using this methodology in the seismic. They were
23 using the ISM methodology. So, I didn't think it
24 was a big technical issue, but we have not resolved
25 it yet. Until they change the DCD and either give

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 us a justification or meet the SRP criteria, this
2 will remain open.

3 And that's the end of the issues.

4 CHAIRMAN CORRADINI: Questions. Is this
5 the time to go into closed session then about -- are
6 we going back?

7 MR. PATEL: We have one more.

8 CHAIRMAN CORRADINI: Okay, I apologize.

9 MS. CUBBAGE: We went out of order.

10 MR. PATEL: The thing is, I guess we
11 still have 3.6.1.

12 MS. CUBBAGE: Do it quickly.

13 CHAIRMAN CORRADINI: I didn't realize
14 that they're related, sorry.

15 MR. PATEL: Actually, 3.6.1 and 3.6.2 are
16 very -- so we'll just take a moment.

17 CHAIRMAN CORRADINI: I'm sorry. I didn't
18 realize it.

19 MR. PATEL: I'm sorry. No, that's our
20 fault. 3.6 is related to the protection against
21 postulated piping failure outside containment and
22 the regulatory requirements are given here in GDC 4
23 and SRV 3.6.1, and technical position.

24 Mainly, the protection is provided, you
25 know, for all the safety-related systems, which

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 require you know, process safe shutdown systems.
2 The protection is provided by separation, by barrier
3 seal, and closures, and also the piping restraints.
4 Those are the three methods they mainly used.

5 There was only one open item, actually,
6 it was related to RTNSS because there were no
7 discussion about RTNSS system protection. And we
8 had one COL action item. As of Rev 3, it was there,
9 but then in Revision 4 they have changed and made it
10 to -- it will go to the ITAAC. But basically the
11 description is still the same, so it has not changed
12 in the content. That's 3.6.1 in short.

13 So now, Renee will present in Section
14 3.6.2.

15 MS. LI: I'm Renee Li from engineer
16 mechanics branch two. I'm responsible for the
17 review of Chapter 3.6.2, which is the determination
18 of rupture location and their associated dynamic
19 effects.

20 As Chandu mentioned, that previously in
21 the other DCD review, this section of review was
22 included in the 3.12 review and you can see even in
23 his error in the Part 52.47 is carried over into my
24 slide. I apologize for that.

25 (Laughter)

1 MS. LI: So for the ITAAC, the aspect
2 that's pertaining to Chapter 3.6.2, is to have the
3 pipe break has analysis report available for NRC
4 inspection. And the report is to summarize the
5 results of the pipe break analysis and to
6 demonstrate that system, structure and the
7 components that protect from the dynamic effects of
8 the postulated pipe failure.

9 In DCD 4, the environmental and the
10 dynamic effects design basis, again, the aspect
11 that's pertaining to 3.6.2 is that SSCs important to
12 SECY should be designed to be compatible with the
13 environmental conditions resulting from the pipe
14 failure and be protected from the dynamic effects of
15 the postulated failure, such as jet impingement or
16 pipe whipping effects.

17 MEMBER SHACK: 3.6.1, then you'll have an
18 ITAAC that's really quite comparable to the one you
19 have here for the 3.6.2 --

20 MS. LI: Yes.

21 MEMBER SHACK: -- instead of the COL
22 action item.

23 MS. LI: Right. Now, of course we use
24 SRP section 3.6.2 including the branch technical
25 position 3-4, which contains all the detail,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 guideline for the criteria to postulate break and
2 their configuration.

3 And since the definition of high energy
4 line and moderate energy line is included in the
5 branch technical position 3-3, which is part of SRP
6 3.6.1, so our review interfaces with the Section
7 3.6.1 review.

8 The industry standard that's involved is
9 the ANSI/ANS 58.2-1988. I will cover -- I will talk
10 about this standard later in more detail, and I will
11 refer us ANSI/ANS 58.2.

12 The last is the 10 CFR 52, again,
13 Appendix S -- or, no. This is Appendix S. Single
14 earthquake design. In SECY paper 93-087, the staff
15 will command the elimination of OBE from the design
16 basis on the basis that it would not result in a
17 significant decrease in the over all plant safety
18 margin.

19 As far as the RAI status, originally,
20 there were 19 RAI associated with Section 3.6.2. At
21 the time of issuing the current SER as open items,
22 six RAI were resolved, and the one was partially
23 resolved. After the issuing of the SER until now,
24 there were five additional RAI resolved. And that
25 leaves eight open RAI, which I will talk about

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 later.

2 Next is, you know, SER item of interest.
3 One of the most important area that we review is the
4 criteria used to define the pipe break and the crack
5 location and the configuration. Then is the
6 evaluation of the dynamic effects that include jet
7 impingement and pipe whip effects.

8 Here I would like to make a note about
9 the ANS 58.2 standard. This standard has been
10 commonly used by industry for determining the jet
11 expansion modeling and for the jet impingement
12 assessment and has been accepted by the NRC.

13 However, during the GSI-191 issue
14 resolution, two SEIs member, Dr. Wallis and Dr.
15 Ransom has revealed there are several inaccuracies
16 and omissions in the standard. And even though the
17 GSI-191 was to address the containment sump
18 blockage, such as the insulation which would be you
19 know broken off during the pipe rupture event,
20 however, those come on, we believe, that may
21 directly impact the 3.6.2 jet impingement
22 evaluation.

23 Therefore, during the ESBWR review,
24 since ESBWR pipe break evaluation follows the
25 guideline of this standard, so with technical

NEAL R. GROSS
COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 assistance with a private lab, the staff has asked
2 several RAI, which are related to this ANS 58.2
3 standard. And those eight open items, they are all
4 in this area.

5 MR. WALLIS: Could I ask you about the
6 first bullet, this pipe and crack locations.

7 MS. LI: Yes.

8 MR. WALLIS: GEH said the pipes break at
9 the ends.

10 MS. LI: Okay.

11 MR. WALLIS: Did you accept that
12 statement?

13 MS. LI: If they can demonstrate the
14 resulting stress level within the piping system
15 below the threshold, providing the SRP section 2.

16 MR. WALLIS: Then you would accept that.

17 MS. LI: Yes.

18 MR. WALLIS: Now, what about the way it
19 breaks? I mean, it seems to me, that you don't
20 really know the shape of the break. So, it's rather
21 difficult to apply ANS 58.2 to a jet when you don't
22 know how it's coming out and what the shape of it
23 is.

24 MS. LI: The branch technical position,
25 3-4, give the guideline of under what situation you

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 will postulate circumferential break, under what
2 condition you will postulate the longitudinal break
3 along the axis. So there SRP 2 have the guideline
4 for those.

5 MR. WALLIS: So then you think that in a
6 circumferential break, that the two pipes separate
7 somehow?

8 MS. LI: Yes.

9 MR. WALLIS: I don't see how it's
10 possible. Because one pipe's coming through this
11 shield wall, and it's restrained from sideways
12 motion, isn't it?

13 MEMBER SIEBER: Worst case there.

14 MS. LI: Yes. Because as far as the
15 break, that gives you the worst case when you
16 totally separate.

17 MR. WALLIS: All right. It just seems to
18 me a realistic analysis is difficult.

19 MEMBER SHACK: That's why we call it a
20 postulated accident.

21 MR. WALLIS: Well, what is a postulated
22 accident have to do with reality?

23 MEMBER BLEY: The gap in there where the
24 break can occur is like, I thought I heard two to
25 two and a half feet. Is that right?

1 MEMBER SHACK: That's what they said.

2 MEMBER BROWN: so, from the RPV wall to
3 that shield is two and a half feet.

4 MEMBER BLEY: So, it's pretty hard to
5 imagine how you could get --

6 MEMBER ARMIJO: Well, there's jet
7 displacement in the two ends.

8 MS. LI: Okay. My last slide, as I
9 mentioned, we still have eight open items and since
10 they are all related to ANS 58.2, so I kind of
11 summarized in the four categories.

12 First is, it does not consider effects
13 of blast wave. But I think today in their
14 presentation, indicated that they would consider
15 blast wave if it, you know, applicable.

16 And next is the jet expansion modeling
17 and jet pressure distribution and also the feedback
18 amplification.

19 CHAIRMAN CORRADINI: So, if the ANS
20 standard -- I don't -- Professor Wallis will correct
21 me. So if the ANS standard is wrong, or has
22 omissions, what has the staff accepted in the past
23 if you don't follow the ANS standard?

24 MS. LI: In the past, we didn't know
25 about omissions that --

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 CHAIRMAN CORRADINI: So everybody else is
2 grandfathered into the omission? Is that what you
3 just told me?

4 MS. LI: No.

5 CHAIRMAN CORRADINI: Oh, okay.

6 MS. LI: Here, Dr. Wallis and Dr. Ransom
7 revealed those omissions. The staff you know,
8 stopped that ANS 58.2 standard provide a simplified,
9 acceptable methodology.

10 CHAIRMAN CORRADINI: Okay.

11 MS. LI: But as indicated -- actually,
12 the staff indicate in 2003 --

13 MS. CUBBAGE: Seven, March '07. March
14 '07.

15 MS. LI: They took original of SRP.

16 MS. CUBBAGE: March '07.

17 MS. LI: March '07, that staff is
18 evaluating those inaccuracies and for the time
19 being, the review will be on plant-specific case-by-
20 case evaluation. Therefore, that's why we asked
21 those RAI.

22 CHAIRMAN CORRADINI: So, I'm a little bit
23 off topic, so let's just go back to a couple of
24 certifications. So, for AP-1000, what is the staff
25 doing? Because I assume there's omissions there.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MS. LI: Yes, but -- okay. Because of --
2 CHAIRMAN CORRADINI: So is that going to
3 be taken up by any sort of changes to the
4 certification process? I'm just trying to
5 understand.

6 MS. LI: We don't think this -- because
7 we used the word, postulate value, and because of
8 the pipe break probability of pipe break is so low,
9 that we don't believe this will be a back fit, would
10 be proper to be a back fit issue. That's why for
11 ABWR, for AP-1000, which yes, they used that ANS
12 58.2 standard. But we do not plan to go back,
13 reopen the issue.

14 CHAIRMAN CORRADINI: Because this is a
15 low probability issue.

16 MS. LI: Yes. The consequence of course
17 is high, but you know, you have to consider the
18 probability and I think when you integrate both --

19 CHAIRMAN CORRADINI: So is this a design
20 basis issue?

21 MR. WALLIS: Well, the ANS standard
22 really talks about a free jet when it comes out of a
23 hole and it goes a long way. That's what the ANS
24 standard is about. And our criticisms had to do
25 with the -- seemed to be misunderstanding about how

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 supersonic flow behaves in a long jet.

2 MS. LI: Yes.

3 MR. WALLIS: These jets, most of them are
4 coming out into this shield wall at close range.
5 And I'm not sure how the ANS standard is relevant
6 for that.

7 MS. LI: Yes. Actually, today is the
8 first time I heard about the approach. They -- so
9 far, they haven't -- GE hasn't shown us the -- today
10 what they showed the configuration. So I think that
11 approach from now, is that we're going to have a
12 meeting with GEH for them to tell us those exact
13 locations. I was happy to hear that their intent
14 was to limit the location to the terminal end. So
15 we will have only limited case to look at.

16 And if they can indeed demonstrate the
17 separation, you know, from the break location, that
18 would be great.

19 MR. WALLIS: So then you'll come back to
20 us with something.

21 MR. HAMBRICK: Dr. Wallis, you'd asked
22 about the difference between free jets and jets
23 interacting with nearby surfaces. We do have RAIs
24 and they're asking about potential feedback
25 mechanisms and amplification of loading due to that.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. WALLIS: I was saying the ANS
2 standard really talks about a free jet. It doesn't
3 really say much about what happens if it's confined
4 in a space.

5 MR. HAMBRICK: And we address that with
6 RAIs.

7 MS. LI: That concludes my presentation.

8 MS. CUBBAGE: I think we're ready for
9 closed session.

10 CHAIRMAN CORRADINI: Further questions?

11 MR. PATEL: We are ready now. I guess we
12 are done.

13 CHAIRMAN CORRADINI: Why don't we call a
14 five minute recess and then we'll clear the room.

15 (Whereupon, the open session of
16 proceedings in the afore-mentioned matter was
17 concluded at 4:55 p.m.)

18

19

20

21

22

23

24

25

CERTIFICATE


This is to certify that the attached proceedings
before the United States Nuclear Regulatory Commission
in the matter of: Subcommittee on ESBWR: Open

Name of Proceeding: Advisory Committee on
Reactor Safeguards

Docket Number: n/a

Location: Rockville, MD

were held as herein appears, and that this is the
original transcript thereof for the file of the United
States Nuclear Regulatory Commission taken by me and,
thereafter reduced to typewriting by me or under the
direction of the court reporting company, and that the
transcript is a true and accurate record of the
foregoing proceedings.



Charles Morrison
Official Reporter
Neal R. Gross & Co., Inc.

NEAL R. GROSS
COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701



Presentation to the ACRS Subcommittee

ESBWR Design Certification Review
Chapter 3 – Design of Structures, Components,
Equipment, and Systems
(Sections 3.6, 3.9, and 3.12)

June 18, 2008

1



Presentation to the ACRS Subcommittee

ESBWR Design Certification Review
Chapter 3.6.1 – Plant Design for Protection Against Postulated
Piping Failures in Fluid Systems Outside Containment
Chandu Patel – NRO/DNRL/NGE1

June 18, 2008

2

**ACRS Subcommittee Presentation
ESBWR Design Certification Review
Chapter 3.6.1 –Protection Against Postulated Piping Failures
in Fluid Systems Outside Containment**

Regulatory Requirements and Guidance

- GDC 4
- Branch Technical Positions BTP SPLB 3-1, BTP EMEB 3-1
- SECY for RTNSS
- SRP 3.6.1

Technical Summary

- The ESBWR plant is designed for protection against piping failures outside containment, to ensure that such failures would not cause the loss of needed functions of safety-related systems or prevent the plant's safe shutdown capability.
- General protection methods:
 - By separation
 - By barriers, shields, and enclosures
 - By pipe whip restraints

Significant Open Items

- Protection of RTNSS systems against postulated piping failures in fluid systems outside of containment (RAI 22.5-5)

COL Action Item

- The COL applicant shall provide sketches of applicable piping systems showing the location, size, and orientation of postulated pipe breaks and the location of pipe whip restraints and jet impingement barriers.

3



Presentation to the ACRS Subcommittee

ESBWR Design Certification Review
Chapter 3.6.2 - Determination of Rupture Locations and
their Associated Dynamic Effects
Renee Li – NRO/DE/EMB2

June 18, 2008

4

**ACRS Subcommittee Presentation
ESBWR Design Certification Review
Chapter 3.6.2 – Determination of Rupture Locations**

Regulations and Regulatory Guidance

- 10 CFR 50.47(b)(1) - ITAAC
- GDC 4
- SRP Sections: 3.6.2 including BTP 3-4 and 3.6.1 including BTP 3-3
- Industry Standards: ANSI/ANS 58.2-1988
- 10 CFR 50 Appendix S (SECY-93-087)

RAI Status Summary

- Original number of RAIs = 19
- Number of RAIs resolved = 6
- Number of Additional RAIs resolved after issuance of SER with open items = 5
- Number of Open Items = 8

5

**ACRS Subcommittee Presentation
ESBWR Design Certification Review
Chapter 3.6.2 - Determination of Rupture Locations**

SER Items of Interest

- Criteria used to define pipe break and crack locations and configurations
- Evaluation of jet impingement and pipe whip effects
Potential nonconservative assessments of the jet impingement loads due to inaccuracies and omissions in ANS 58.2 identified by ACRS (Wallis-ADAMS ML 050830344, Ransom- ADAMS ML 050830341)

Significant Open Items (RAIs 3.6-6 and 3.6-11 thru 3.6-17)

Inaccuracies and Omissions in ANSI/ANS 58.2

- Effects of blast wave
- Jet expansion modeling
- Jet pressure distribution
- Jet dynamic loading and structural dynamic response including potential feedback amplification of blowdown force and jet resonant effects

6



Presentation to the ACRS Subcommittee

**ESBWR Design Certification Review
Chapter 3.9.1 – Special topics for
Mechanical Components
Chandu Patel – NRO/DNRL/NGE1**

June 18, 2008

7

ACRS Subcommittee Presentation ESBWR Design Certification Review Chapter 3.9.1 – Special Topics

Regulations and Regulatory Guidance

- General Design Criteria 1, 2, 14 and 15
- 10 CFR 50, Appendices B and S
- SRP Section 3.9.1

Technical Review Summary

- DCD Tier 2, Table 3.9-1 shows design transients and the number of cycles for each transient that are consistent with applicable SRP 3.9.1 guidelines.
- GEH identified computer programs in Tier 2 DCD Appendix 3D which are in accordance with requirements of Appendix B to 10CFR50.
- GEH evaluations of components under faulted loading conditions identified in Tables 3.9-1 and 3.9-2 are consistent with the guidance in SRP 3.9.1 and meet the requirements of ASME III Appendix F.
- GEH identified components (e.g., snubbers, reactor internals) that were tested to verify their design adequacy. The experimental stress analysis methods used in the design of ESBWR components are in compliance with ASME Section III, Appendix II, and are therefore acceptable.

Open Items

- None

8



Presentation to the ACRS Subcommittee

**ESBWR Design Certification Review
Chapter 3.9.2.1 – Piping Vibration, Thermal
Expansion, and Dynamic Effects
Jai Rajan – NRO/DC/EMB1**

June 18, 2008

9

ACRS Subcommittee Presentation ESBWR Design Certification Review Chapter 3.9.2.1 – Piping Vibration, Thermal Expansion, and Dynamic Effects

Regulations and Regulatory Guidance

- GDC 2
- ASME Code, Section III
- RG 1.68, "Initial Test Programs for Water-Cooled Nuclear Power Plants"
- ASME OM S/G- 2003 Standard, Part 3, "Requirements for Pre-operational and Initial Startup Testing of Nuclear Plant Piping Systems"
- ASME OM S/G- 2003 Standard, Part 7 "Requirements for Thermal Expansion Testing of Nuclear Plant Piping Systems"

Open Items

- None

10



Presentation to the ACRS Subcommittee

**ESBWR Design Certification Review
Chapter 3.9.2.2 – Seismic Analysis and Qualification
of Seismic Category I Mechanical Equipment
Chandu Patel – NRO/DNRL/NGE1**

June 18, 2008

11

ACRS Subcommittee Presentation ESBWR Design Certification Review Chapter 3.9.2.2 – Seismic Analysis and Qualification

Regulations and Regulatory Guidance

- General Design Criteria 1, 2, 4, 14, and 15
- 10 CFR Part 50, Appendix B
- 10 CFR Part 100, Appendix A

Technical Review Summary

- The review consists of an evaluation of DCD Tier 2, Section 3.9.2.2, and portions of Sections 3.7.2, 3.7.3, and 3.10, which are related to the seismic analysis and qualification of mechanical equipment and components.
- Areas reviewed include seismic analysis methodologies for equipment and components, modeling of major components, number of earthquake cycles and fatigue evaluation, combination of modal responses, damping values, qualification of large mechanical components, effects of rigidity of support anchorage, torsional effects of eccentric masses, etc.
- Two RAIs remained open during the preparation of the SER.

12

**ACRS Subcommittee Presentation
ESBWR Design Certification Review
Chapter 3.9.2.2 – Seismic Analysis and Qualification**

Open Items

- The effects of the assumed rigidity of the support anchorages to the building structure on the calculated seismic response of piping, equipment and components, especially heavy ones (RAI 3.9-35, closed after the SER was prepared)

- Qualification testing and analysis of control rod drive (CRD) housing (with enclosed CRD mechanism), including the computer codes and industry standard used (RAI 3.9-43, closed after the SER was prepared)

13



Presentation to the ACRS Subcommittee

ESBWR Design Certification Review
Chapter 3.9.2.3, 3.9.2.4, and 3.9.2.5
Jai Rajan – NRO/DC/EMB1

June 18, 2008

14

**ACRS Subcommittee Presentation
ESBWR Design Certification Review
Chapter 3.9.2.3 – Dynamic Response Analysis**

Regulations and Regulatory Guidance

- GDC 2 and 4
- Regulatory Guide 1.20
- SRP 3.9.2.3 and 3.9.5

Open Items (from staff review of ESBWR DCD, Rev. 3)

- Steam dryer load definition and methodology to predict stresses at locations to be monitored on the steam dryer during initial power ascension test. (RAIs 3.9-58, 61, & 63)
- Stress limit curve for ESBWR steam dryer to be used during the initial power ascension test. (RAI 3.9-68)
- Predicted and allowable stress amplitudes and potential high stress locations on the steam dryer. (RAI 3.9-71)

These open items are closed because they are superseded by the PBLE method.

15

**ACRS Subcommittee Presentation
ESBWR Design Certification Review
Chapter 3.9.2.4 – Preoperational Flow-Induced
Vibration Testing**

Regulations and Regulatory Guidance

- GDC 2 and 4
- Regulatory Guide 1.20, Rev. 3
- SRP Sections 3.9.2 and 3.9.5

Open Items

- Classification of ESBWR reactor internals as Non-Prototype Category II (RAIs 3.9-75 & 96)
- FIV Response of ESBWR Top Guide based on ABWR Test Data (RAI 3.9-77 S02)

16

**ACRS Subcommittee Presentation
ESBWR Design Certification Review
Section 3.9.2.5 – Dynamic System Analysis of
Reactor Internals Under Faulted Conditions**

Regulations and Regulatory Guidance

- GDC 2, 4, and 14
- Regulatory Guide 1.20, Rev. 3
- ASME Code, Section III

Open Item

- The analytical results to demonstrate that there is no significant dynamic amplification of the loads on the reactor internals as a result of the postulated break in the MSL or FW line (RAI 3.9-81)

17



Presentation to the ACRS Subcommittee

ESBWR Design Certification Review
Chapter 3.9.3 – ASME Code Class
1, 2, and 3 Components, and Component Supports,
and Core Support Structures
Chandu Patel – NRO/DNRL/NGE

June 18, 2008

18

**ACRS Subcommittee Presentation
ESBWR Design Certification Review
Chapter 3.9.3 – ASME Code Class 1, 2, & 3**

Regulations and Regulatory Guidance

- 10 CFR 50.55a
- GDC 1, 2, 4, 14, and 15

Technical Review Summary

- Areas of review include loading combinations, design transients, and stress limits used for ensuring the structural integrity of reactor pressure vessel assembly and other major mechanical components; valve operability assurance; design and installation of pressure-relief devices; and component supports
- The number of original RAIs is 30, of which two remained open during the preparation of the SER
- One additional RAI was identified after the SER was prepared. This is related to the requirement for component design information

19

**ACRS Subcommittee Presentation
ESBWR Design Certification Review
Chapter 3.9.3 – ASME Code Class 1, 2, & 3**

Open Items

- Effects of snubber end fitting clearance and lost motion on equal load sharing of multiple snubber supports (RAI 3.9-114, resolved)
- Description of snubber production and qualification test programs, and the compliance of snubber design to ASME Code, Section III, Subsection NF (RAI 3.9-117, resolved)
- Reinstatement of a COL information item, originally included in DCD Rev. 3 but was omitted in Rev. 4, regarding the requirement of making available design specifications and design reports of ASME Code Section III mechanical components for NRC audit (RAI 3.9-177)

COL Information Items

- COL holders will provide a plan for the detailed snubber inservice testing and inspection program in accordance with the ASME O&M Code

20



Presentation to the ACRS Subcommittee

ESBWR Design Certification Review
Chapter 3.9.4 – Control Rod Drive Systems
Andrey Turilin – NRO/DE/EMB1

June 18, 2008

21

ACRS Subcommittee Presentation ESBWR Design Certification Review Chapter 3.9.4 – Control Rod Drive Systems

Control Rod Drive System

- Design of ASME Section III B&PV code components, including pressure containing components, to the appropriate loadings and criteria

Technical Review Summary

- Quality group classification (RCPB components are ASME B&PV code Class 1)
- Loading combinations, stress and deformation limits during normal and postulated conditions
- Testing programs

Open Items

- GE satisfactory answered five RAIs
- No Open Items remaining
- No COL Information Items

22



Presentation to the ACRS Subcommittee

**ESBWR Design Certification Review
Chapter 3.9.5 – Reactor Pressure Vessel internals
Patrick Sekerak – NRO/DE/EMB1**

June 18, 2008

23

ACRS Subcommittee Presentation ESBWR Design Certification Review Chapter 3.9.5 – RPV Internals

Regulations and Regulatory Guidance

- GDC 1 - Quality standards commensurate with safety function.
- GDC 2 - Seismic resistant design
- GDC 4 - Design for operational environment and postulated accidents
- GDC 10 - Design margins to ensure fuel performance / reactivity control

Review Summary

The staff review is addressing the design basis for the RPV internals including; Application of ASME III, Subsection NG rules for design and construction of core support structures.

Use of design by analysis rules of ASME III, Subsection NG for design of safety-related internal structures, and use of Subsection NG allowable stress criteria for the steam dryer, a non-safety related RPV internals component.

Incorporation of lessons learned from operational failures of BWR steam dryers subjected to extended power uprate conditions.

24

**ACRS Subcommittee Presentation
ESBWR Design Certification Review
Chapter 3.9.5 – RPV Internals**

Open Items [14 Open Items, RAI no. in brackets, *indicates recent closure]

- Steam dryer flow-induced load definition and structural analysis [3.9-135, -136, -146*]
- Potential for acoustic resonance in main steam and other systems [3.9-134, -144]
- Core support structure primary stress and deformation limits [3.9-148, -149*, -150*]
- Flow-Induced Vibration Assessment Prog. for RPV internals [3.9-132*, -138, -143, -147*]
- Steam dryer instrumentation for start-up testing [3.9-133, -151]

Ongoing Topical Report Reviews

- RPV Internals Flow-Induced Vibration Program (*GEH NEDE-33259, Rev. 1*)
- Steam Dryer Flow-Induced Load Definition Methodology (*GEH NEDC-33408P*)
- Steam Dryer Acoustic Load Definition (*GEH NEDE-33312P*)
- Steam Dryer Structural Evaluation (*GEH NEDE-33313P*)

25



Presentation to the ACRS Subcommittee

ESBWR Design Certification Review
Chapter 3.9.6 – Functional Design,
Qualification, and Inservice Testing Programs for
Pumps, Valves, and Dynamic Restraints
Thomas Scarbrough – NRO/DE/CIB2

June 18, 2008

26

**ACRS Subcommittee Presentation
ESBWR Design Certification Review
Chapter 3.9.6 – Functional Design, Qualification,
and Inservice Testing Program**

Regulations and Regulatory Guidance

- 10 CFR Part 52
- 10 CFR Part 50, Appendix A, General Design Criteria, and Appendix B, Quality Assurance Criteria
- 10 CFR 50.55a, Inservice Testing
- NRC Standard Review Plan Section 3.9.6
- Commission Paper SECY-05-0197

Technical Review Summary

- Section 3.9.3.5, Valve Operability Assurance, specifies safety-related valves qualified by testing and analysis
- Section 3.9.3.6, Pressure Relief Devices, discusses safety-relief valves, vacuum breaker valves, and depressurization valves
- Section 3.9.3.7, Component Supports, specifies snubbers will meet ASME OM Code, Section ISTD
- Section 3.9.6, Inservice Testing, indicates no safety-related pumps in ESBWR design, and that valves meet OM Code 2001 Edition/2003 Addenda

27

**ACRS Subcommittee Presentation
ESBWR Design Certification Review
Chapter 3.9.6 – Functional Design, Qualification,
and Inservice Testing Program**

Technical Review Summary (Continued)

- Review of functional design and qualification provisions based on lessons learned from valve qualification issues
- Review of IST program based on lessons learned from valve performance issues at operating nuclear power plants
- RAIs prepared to obtain additional information
- May 22 public meeting held to discuss ESBWR IST program for COL applications referencing ESBWR design (ESBWR DCWG)

- COL applicant versus holder responsibility
- Functional capability qualification process for valves
- Periodic verification of power-operated valve design-basis capability
- Depressurization valve qualification program

28

**ACRS Subcommittee Presentation
ESBWR Design Certification Review
Chapter 3.9.6 – Functional Design, Qualification,
and Inservice Testing Program**

Open Items

- Numerous RAIs on Rev. 3 to ESBWR DCD addressed through RAI responses and latest DCD revision including May 22 meeting results
- One open item remains where staff is reviewing GEH May 14 response to RAI 3.9-168 to revise DCD IST table for specific safety relief valves and other valves to be consistent with ASME Code requirements
- COL Item needed for COL Applicant to ensure that IST program is fully described per SECY-05-0197 including applicable milestones

29



Presentation to the ACRS Subcommittee

ESBWR Design Certification Review
Chapter 3.12 - Piping Design
John Fair – NRR/ADES/DE/EMCB

June 18, 2007

30

**ACRS Subcommittee Presentation
ESBWR Design Certification Review
Chapter 3.12 – Piping Design**

Regulations and Regulatory Guidance

- 10 CFR 50.55a – Codes and Standards
- 10 CFR 50.47(b)(1) - ITAAC
- GDCs: 1, 2, 4, 14, 15
- SRP Sections: 3.7.3 and 3.9
- Regulatory Guides 1.29, 1.61, 1.84, 1.92, 1.199, 1.147, 1.207
- Industry Standards: ANSI, AS & ASME
- Other guidance (generic communications, NUREGs, and SECY's)

31

**ACRS Subcommittee Presentation
ESBWR Design Certification Review
Chapter 3.12 – Piping Design**

SER Items of Interest

- Staff audits
- ASME Code edition
- Single earthquake design criteria
- Feedwater nozzle thermal stratification
- Main steam piping confirmatory analysis
- Fatigue analysis criteria

Significant Open Items

- Independent support motion (ISM) combination of group responses (RAI 3.12-3, resolved)
- Benchmarking of PISYS computer code (RAI 3.12-11, resolved)
- Decoupling criteria for small branch piping (RAI 3.12-15, resolved)
- SRSS of dynamic loads (RAI 3.12-17)
- High frequency mode combination (RAI 3.12-21, resolved)
- Environmental fatigue (RAI 3.12-22, resolved)
- Uniform support motion (USM) combination of inertia and SAM loads (RAI 3.12-27)


32

ESBWR - Overview

DCD Chapter 3 Design of Structures,
Components, Equipment and Systems -
Sections 3.6 & 3.9

**Advisory Committee
on Reactor Safeguards**

Pijush Dey
Dave Keck
Jeffrey Waal
June 18-19, 2008



GE Hitachi Nuclear Energy

Overview of Section 3.9 - Mechanical Systems and Components

- Section 3.9 Provides Description Of:
 - > Special Topics for Mechanical Components
 - > Dynamic Testing and Analysis
 - > ASME Code Class 1, 2 and 3 Components and Supports
 - > Control Rod Drive System
 - > Reactor Pressure Vessel Internals
 - > Inservice Testing of Pumps and Valves

2



Section 3.9.1 – Special Topics

- This section includes the following topics:
 - > Design Transients – Normal and thermal transient events; and dynamic loading events are defined
 - > Computer Programs Used in Analysis are defined with details contained in Appendix 3D
 - > Experimental Stress Analysis – Limited to Piping Snubbers and Restraints
 - > Faulted Condition Evaluation Considerations – Seismic Category I equipment is individually discussed

3

Section 3.9.2 – Dynamic Testing and Analysis of Systems, Components and Equipment

- Provides description of:
 - > Piping vibration, thermal expansion and dynamic effects
 - > Seismic qualification of safety-related mechanical equipment
 - > Dynamic response of reactor internals under transient and normal operating conditions
 - > Initial startup FIV testing of reactor internals
 - > Dynamic analysis of reactor internals under faulted conditions
 - > Correlation of test and analysis results

4



Section 3.9.3 – ASME Code Components and Supports

- Provides Design Information related to:
 - > Loading combinations, design transients and stress limits
 - > Component information related to ASME Code requirements (RPV, piping, other)
 - > Valve operability assurance
 - > Design & installation of pressure relief devices
 - > ASME component support design
 - > ASME threaded fastener design – contains material related to SRP 3.13

5

Section 3.9.4 – Control Rod Drive System

- CRD system is primarily discussed in DCD Section 4.6.1; however Section 3.9.4 contains a discussion of:
 - > Applicable regulations
 - > CRD system components
 - > Design loads and stress limits
- CRD Performance Assurance program tests are described in DCD Section 4.6

6



Table 3.9-1
Plant Events

	ASME Code Service Limit ^(a)	No. of Cycles
A. Plant Operating Events^{(a), (b)}		
1. Bolting ^(c)	A	45
2. a. Hydraulic Test (two test cycles for each bolting cycle)	Testing	90
b. Hydraulic Test (slip and hold)	Testing	3
3. Startup (5.0°C/hr Heating Rate) ^(d)	A	180
4. Turbine Roll and Increase to Rated Power	A	180
5. Daily and Weekly Reduction to 50% Power ^(e)	A	20,200
6. Control Rod Pattern Change ^(d)	A	360
7. Loss of Feedwater Element	B	60
B. Scrams:		
a. Turbine Generator Trip, Feedwater On, and Other Scrams	B	60
b. Loss of Feedwater Flow, MSRV Closure	B	60
9. Reduction to 0% Power, Hot Standby, Shutdown (5.0°C/hr Cooling Rate) ^(d)	A	172
10. Refueling Shutdown and Unbolting ^(c)	A	45
11. Scrams:		
a. Reactor Overpressure with Delayed Scram (ATWS)	C	1 ^(f)
b. Automatic Shutdown	C	1 ^(f)
12. Improper Plant Startup	C	1 ^(f)
B. Dynamic Loading Events^{(a), (b), (g)}		
13. Safe Shutdown Earthquake (SSE) at Rated Power Operating Conditions	B ^(h)	20 ⁽ⁱ⁾
14. Safe Shutdown Earthquake (SSE) at Rated Power Operating Conditions	D ^(j)	1 ^(k)
15. Safety Relief Valve (SRV) Actuation (One) or single DPV actuation with depressurization (scram)	B	8
16. Loss-of-Coolant-Accident (LOCA): Worst of small break LOCA (SBL), intermediate break LOCA (IBL), or large break LOCA (LBL)	D ^(j)	1 ^(k)

7

Section 3.9.6 – Inservice Testing of Pumps and Valves

- Since ESBWR does not include any safety related pumps, none are included in the IST program
- Provides a full description of the ESBWR IST program for valves
- DCD Table 3.9-8 lists all valves that are part of the IST program including valve positions, test parameters, and test frequencies

8



Section 3.12 - ASME Code Class 1, 2 and 3 Piping Systems, Piping Components and Associated Supports

- The requirements for piping analysis and supports are covered in DCD Tier 2, sections 3.7.3 and 3.9.


9

Section 3.9.5 - Reactor Pressure Vessel Internals

- Provides Description of:
 - > Individual reactor core support and other internal components
 - > Load conditions including RPV line break accidents, earthquakes, and internal pressure differences
 - > Design bases related to safety and power generation, loadings, stress, deformation, and fatigue limits

10





Overview of Section 3.6 - Protection Against Dynamic Effects Associated With The Postulated Rupture of Piping

- Plant Design for Protection Against Pipe Failures
- Determination of Break Locations
- As-built Inspection of High-Energy Pipe Break Mitigation Features



Section 3.6.1 – Plant Design for Protection Against Postulated Piping Failures in Fluid Systems Inside and Outside of Containment

- Provides description of:
 - > Design Bases criteria, objectives and assumptions
 - > Piping identified as high and moderate energy
 - > Design evaluation of pipe break events and features to provide protection against the effects of pipe break events
 - > Protection methods include Physical Separation, Barriers, Shields and Enclosures, and Pipe Whip Restraints

13

Section 3.6.2 – Determination of Pipe Break Locations and Dynamic Effects Associated with the Postulated Rupture of Piping

- Pipe ruptures are postulated in accordance with BTP 3-4; however fatigue usage limit of 0.40 is used when environmental fatigue is applied in accordance with RG 1.207
- ESBWR intends to design piping below BTP 3-4 limits such that high energy pipe breaks need only be postulated at piping terminal ends
- Analytical methods, to define blowdown forces, will be determined using ANSI/ANS 58.2 Appendix B and CFD analysis, as applicable to fully characterize pipe breaks

14





Section 3.6.2 – Determination of Break Locations and Dynamic Effects Associated with the Postulated Rupture of Piping (continued)

- Determination of jet impingement and effects on safety related components will use the methods described in ANSI/ANS 58.2 Appendix C and D, and CFD analysis to fully evaluate the effects of fluid jets
- The effects of the initial pipe rupture blast wave on safety related structures and components will also be evaluated

15

Elevation View





Section 3.6.4 – As-built Inspection of High-Energy Pipe Break Mitigation Features


- Prior to plant startup, an as-built inspection of high-energy pipe break mitigation features will be performed
- This includes the inspection of pipe whip restraints and jet shield installations, physical separation distances, and the location of structures identified as pipe break mitigation features

Summary

- **Section 3.6** provides a full description of the program for mitigation of the effects of pipe breaks.
- **Section 3.9** provides a solid basis for design of safety related equipment that fully complies with the requirements of the ASME Code.

ESBWR - Overview
DCD Chapter 3 Design of Structures,
Components, Equipment and Systems -
Sections 3.10, 3.11 & 3.13
**Advisory Committee
on Reactor Safeguards**

Jerry Deaver
Kevin Baucom
Jeffrey Waal
June 18-19, 2008



GE Hitachi Nuclear Energy

Overview of Section 3.10 - Seismic and
Dynamic Qualification of Mechanical and
Electrical Equipment

- Provides the requirements for seismic and dynamic qualification of mechanical and electrical equipment.
- Qualification is performed by test, analysis, or a combination of test and analysis.
- Mechanical and electrical equipment are designed to withstand earthquake and other accident related loads.

2



Section 3.10.1 – Seismic and Dynamic Qualification Criteria

- Qualification in accordance with IEEE 323 and 344, as endorsed by RG 1.89 and 1.100
- Input motion is defined by Required Response Spectrum.

3

Section 3.10.2 – Methods for Equipment Qualification

- Provides description of:
 - > Qualification by test
 - > Qualification by analysis
 - > Qualification by combined test and analysis.
 - > Qualification by actual seismic experience is not used.

4



Section 3.10.3 – Electrical Equipment Supports

- Electrical supports are qualified by test with representative equipment installed, as practical.
- Designed using the floor response spectra.

5

Overview of Section 3.11 - Environmental Qualification of Mechanical and Electrical Equipment

- Provides the requirements for environmental qualification of mechanical and electrical equipment.
- Environmental requirements for EQ envelop the most limiting design conditions.

6



Section 3.11.1 – Equipment Identification

- Equipment in the EQ program includes all three categories (b)(1), (b)(2) and (b)(3) of 10 CFR 50.49(b).
- DCD Table 3.11-1 identifies specific equipment included in the EQ program.
- Equipment in a harsh environment must be able to function properly during design basis accident conditions.

7

Section 3.11.2 – Environmental Conditions

- Conditions considered in the EQ program include temperature, pressure, humidity, radiation, and chemical.
- Qualification is in accordance with IEEE-323 as endorsed by RG 1.89, and RG 1.209.

8



Section 3.11.3 – Loss of HVAC

- Loss of HVAC is considered in the design basis conditions for equipment qualification.
- Safety-related HVAC is not required.

9

Section 3.11.4 – Chemical and Radiation Environment

- EQ equipment subject to submergence, such as lower elevations, are qualified by test considering submergence, chemistry, pH and operability requirements.
- Radiation sources, and the resulting total integrated doses are included in the EQ program.

10



Section 3.13 - Threaded Fasteners for ASME components.

- The requirements for threaded fasteners are covered in DCD Tier 2, section 3.9.3.9.

11

Summary

- Sections 3.10 and 3.11 provide a solid basis for the qualification of equipment for seismic, dynamic, and environmental conditions, in accordance with the applicable regulations.


12



ESBWR DCD Chapter 3 Sections 3.1-3.5

Design of Structures Advisory Committee on Reactor Safeguards

Clement Rajendra
Jeffrey Waal
June 18-19, 2008



GE Hitachi Nuclear Energy

Presentation Content

- Chapter 3, Sections 3.1-3.5 Overview
- Section Descriptions
- Summary

2



Chapter 3, Sections 3.1 – 3.5 Overview

- Chapter 3 describes the design of structures, components, equipment and systems.
 - > Section 3.1 describes the conformance of the ESBWR with NRC General Design Criteria.
 - > Section 3.2 provides the seismic and safety classifications of structures, systems and components.
 - > Section 3.3 describes wind and tornado loadings.
 - > Section 3.4 describes the flood protection design basis.
 - > Section 3.5 describes the missile protection design basis.

3

Section 3.1 – Conformance With NRC General Design Criteria

- Section 3.1 provides an evaluation of the ESBWR design versus the NRC General Design Criteria (GDC) and refers to specific DCD sections for the further discussion of the criteria.
- The criteria are addressed in the following groups:
 - Group I – Overall Requirements (Criteria 1 - 5)
 - Group II – Protection by Multiple Fission Product Barriers (Criteria 10 - 19)
 - Group III – Protection and Reactivity Control Systems (Criteria 20 - 29)
 - Group IV – Fluid Systems (Criteria 30 - 46)
 - Group V – Reactor Containment (Criteria 50 - 57)
 - Group VI – Fuel and Radioactivity Control (Criteria 60 -64)

4



Section 3.2 – Classification of SSCs

- Section 3.2.1 – Seismic Classification
 - > Based on RG 1.29 and SRP 3.2.1.
 - > Seismic Category I required for all safety-related SSCs.
 - > Seismic Category II required for nonsafety-related SSCs whose failure could degrade performance of safety-related SSCs.
 - > Some nonsafety-related SSCs assigned to Seismic Category I when required by regulations.
 - > Remaining SSCs assigned to Seismic Category NS.

5

Section 3.2 – Classification of SSCs

- Section 3.2.2 – System Quality Group Classification
 - > Based on RG 1.26 and SRP 3.2.2.
 - > Quality Group A – Pressure-retaining portions and supports for Reactor Coolant Pressure Boundary.
 - > Quality Group B – Pressure-retaining portions and supports not in Quality Group A for safety-related containment isolation, ECCS and residual heat removal functions.
 - > Quality Group C – Pressure-retaining portions and supports for other safety-related functions not included in Quality Groups A and B.
 - > Quality Group D – Pressure-retaining portions and supports for other systems that contain or may contain radioactive material.

6



Section 3.2 – Classification of SSCs

- Section 3.2.3 – Safety Classification
 - > Consistent with safety classifications used in ABWR DCD.
 - > Very closely tied to Quality Group classifications for safety-related SSCs.
 - > Safety Class 1 – RCPB components and supports.
 - > Safety Class 2 – Mechanical SSCs involved in containment isolation functions not included in Safety Class 1, ECCS and RHR functions.
 - > Safety Class 3 – All other mechanical safety-related SSCs not included in Safety Classes 1 and 2. All safety-related electrical/I&C SSCs are Safety Class 3.
 - > Safety Class N – Nonsafety-related SSCs.

7

Section 3.2 – Classification of SSCs

- Table 3.2-1 – Classification summary table grouped by system (excerpt shown below for System B11)

Table 3.2-1

Classification Summary

Principal Components ¹	Safety Class ²	Location ³	Quality Group ⁴	QA Req. ⁵	Seismic Category ⁶	Notes
B NUCLEAR STEAM SUPPLY SYSTEMS						
B11 Reactor Pressure Vessel System						
1. Reactor pressure vessel	1	CV	A	B	I	
2. Reactor vessel appurtenances – reactor coolant pressure boundary (RCPB) portions	1	CV	A	B	I	
3. Control Rod Drive housing and in-core housing	1	CV	A	B	I	
4. Control rods	2	CV	—	B	I	
5. Standby Liquid Control (SLC) system header and spargers	2	CV	—	B	I	
6. Reactor vessel support and stabilizer	1	CV	A	B	I	
7. Other safety-related reactor internals, including core support structures (Subsection 3.9.5)	3	CV	B	B	I	
8. Reactor internals – Nonsafety-Related components (Subsection 3.9.5)	N	CV	—	E	II	

8



Section 3.2 – Classification of SSCs

- Table 3.2-2 defines minimum Quality Group, Seismic, Electrical and QA requirements classifications for each Safety Class

Table 3.2-2
Minimum Safety Class Requirements

Safety Class	Minimum Design Requirements for Specific Safety Class				
	Quality Group	ASME Section III Code Class	Seismic Category ¹	Electrical Classification ²	Quality Assurance ⁴
1	A	1	I	N/A	10 CFR 50 Appendix B
2	B	2	I	N/A	10 CFR 50 Appendix B
3	C	3	I	Class 1E	10 CFR 50 Appendix B
N	D ³	N	II or NS	Non-Class 1E	—

9

Section 3.2 – Classification of SSCs

- Table 3.2-3 defines applicable codes and standards for design based on Quality Group classification

Table 3.2-3
Quality Group Designations – Codes and Industry Standards


Quality Group Classification	ASME Section III Code Classes	Pressure Vessels and Heat Exchangers ⁴	Pipes, Valves, and Pumps	Storage Tanks (0-103 kPaG)	Storage Tanks Atmospheric	ASME Section III Component Supports	Non-ASME Section III Component Supports	Core Support Structures and Reactor Internals	Containment Boundary
A	1	NCA and NB TEMA C	NCA and NB	—	—	NCA and NF	—	—	—
B	2	NCA and NC TEMA C	NCA and NC	NCA and NC	NCA and NC	NCA and NF	—	—	—
	CC ¹ and MC	—	—	—	—	—	—	—	NCA, CC ¹ , and NE
	CS	—	—	—	—	—	—	NCA and NG	—
C	3	NCA and ND TEMA C	NCA and ND	NCA and ND	NCA and ND	NCA and NF	—	—	—
D	—	ASME Sect. VIII Division I TEMA C	ASME B31.1 for piping and valves ⁵	API-620 or equivalent ⁶	API-650 AWWA-D100 ASME B96.1 or equivalent ⁷	—	Manufacturer's Standards, e.g., ASME B31.1, AISC	—	—

10



Section 3.2 – Classification of SSCs


- Figure 3.2-1 shows classification boundaries for power conversion system



11

Section 3.2 – Classification of SSCs

- Figure 3.2-2 shows classification boundaries for feedwater system



Note: See Figure 3.2-1 for Legend.

12



Section 3.3 – Wind and Tornado Loadings

- Seismic Category I and II structures designed to withstand 150 mph wind (3-sec gust).
 - > The design wind is converted to a velocity pressure for determining the building loads.
 - > Methodology in ASCE Standard 7-02 used with Exposure Category D.

13

Section 3.3 – Wind and Tornado Loadings

- Seismic Category I & II buildings are designed to withstand the effects of a design basis tornado with maximum winds of 330 mph.
 - > Tornado design loads include wind loads, differential pressure loads and missile loads.
- Control Building Emergency Filtration Unit air intake openings are provided with tornado dampers.
- Remainder of plant structures designed to not adversely impact Seismic Category I structures, systems or components.

14



Section 3.4 – Water Level (Flood) Design

- Section 3.4 describes flood protection design basis.
- Methods provided for protection from external flood sources include:
 - > Design plant grade elevation is to be at least 1 ft above the design flood level.
 - > Walls below flood level are designed for hydrostatic loads.
 - > Water stops installed in joints below flood and ground water levels.
 - > External surfaces waterproofed below grade.
 - > Water seals installed at pipe penetrations below grade.
 - > Roofs are designed to prevent pooling.

15

Section 3.4 – Water Level (Flood) Design

- Internal Flooding due to pipe breaks and cracks, fire hose discharges and other water sources.
- Protective features provided to mitigate or eliminate consequences of internal flooding include:
 - > Structural enclosures or barriers

Curbs and sills

- > Leakage detection components
- > Floor Drainage systems (No credit taken in evaluation)
- > Safety-related equipment is located above the maximum flood level or qualified for flood conditions.

16



Section 3.5 – Missile Protection

- Section 3.5 describes Missile Protection design basis.
- Seismic Category I structures are designed for missile protection.
- Systems requiring missile protection are safety-related systems and Offgas Charcoal Bed Adsorbers.


17

Section 3.5 – Missile Protection

- Rotating equipment examined for possible source of credible and significant missiles.
- Main steam turbine missiles.
 - > Favorable location relative to containment location.
 - > Quality assurance in design, fabrication, maintenance and inspections (See Section 10.2)
 - > COL Applicant provides Turbine Maintenance and Inspection Program and Turbine Missile Generation Probability Calculation.
- Missiles from pressurized component failures are evaluated.

18





Section 3.5 – Missile Protection

- Tornado generated missiles are the limiting natural phenomena hazard.
 - > Seismic Category I buildings are designed to resist tornado missiles.
- The site proximity missiles for the ESBWR Standard Plant are assumed to be statistically insignificant. (COL Applicant addresses site-specific hazards.)



Section 3.5 – Missile Protection

- Aircraft hazards are also considered to be statistically insignificant. (COL Applicant addresses site-specific aircraft impact hazard)
- Barrier design procedures to prevent local and overall damage due to missiles are provided.

21

Summary

- Chapter 3, Sections 3.1 – 3.5 provides design basis of structures, components, equipment and systems.

22







Presentation to the ACRS Subcommittee

ESBWR Design Certification Review Chapter 3 – Design of Structures, Components, Equipment, and Systems (Sections 3.1 through 3.5, 3.10, 3.11, and 3.13)

June 18, 2008

1

ESBWR Design Certification Chapter 3 Outline

- | | |
|---|--|
| 3.2.1 Seismic Classification | 3.8.1 Concrete Containment |
| 3.2.2 System Quality Group Classification | 3.8.2 Steel Containment |
| 3.3.1 Wind Loadings | 3.8.3 Concrete and Steel Internal Structures of Steel or Concrete Containments |
| 3.3.2 Tornado Loadings | 3.8.4 Other Seismic Category I Structures |
| 3.4.1 Internal Flood Protection for Onsite Equipment Failures | 3.8.5 Foundations |
| 3.4.2 Analysis Procedures | 3.9.1 Special Topics for Mechanical Components |
| 3.5.1.1 Internally Generated Missiles (Outside Containment) | 3.9.2 Dynamic Testing and Analysis of Systems, Structures, and Components |
| 3.5.1.2 Internally-Generated Missiles (Inside Containment) | 3.9.3 ASME Code Class 1, 2, and 3 Components, and Component Supports, and Core Support Structures |
| 3.5.1.3 Turbine Missiles | 3.9.4 Control Rod Drive Systems |
| 3.5.1.4 Missiles Generated by Tornadoes and Extreme Winds | 3.9.5 Reactor Pressure Vessel Internals |
| 3.5.1.5 Site Proximity Missiles (Except Aircraft) | 3.9.6 Functional Design, Qualification, and Inservice Testing Programs for Pumps, Valves, and Dynamic Restraints |
| 3.5.1.6 Aircraft Hazards | 3.9.7 Risk-Informed Inservice Testing |
| 3.5.2 Structures, Systems, and Components to be Protected from Externally-Generated Missiles | 3.9.8 Risk-Informed Inservice Inspection of Piping |
| 3.5.3 Barrier Design Procedures | 3.10 Seismic and Dynamic Qualification of Mechanical and Electrical Equipment |
| 3.6.1 Plant Design for Protection Against Postulated Piping Failures in Fluid Systems Outside Containment | 3.11 Environmental Qualification of Mechanical and Electrical Equipment |
| 3.6.2 Determination of Rupture Locations and Dynamic Effects Associated with the Postulated Rupture of Piping | 3.12 ASME Code Class 1, 2, and 3 Piping Systems, Piping Components and their Associated Supports |
| 3.6.3 Leak-Before-Break Evaluation Procedures | 3.13 Threaded Fasteners - ASME Code Class 1, 2, and 3 |
| 3.7.1 Seismic Design Parameters | |
| 3.7.2 Seismic System Analysis | |
| 3.7.3 Seismic Subsystem Analysis | |
| 3.7.4 Seismic Instrumentation | |

2

**ACRS Subcommittee Presentation
ESBWR Design Certification Review
Chapter 3 Sections & Reviewers**

<u>Richard McNally</u> 3.2	<u>S. Rao Tammara</u> 3.5.1.5 3.5.1.6	<u>Arnold Lee</u> 3.9.2.2 3.9.3
<u>Mohamed Shams</u> 3.3.1 3.3.2 3.4.2	<u>Renee Li</u> 3.6.2	<u>Andrey Turlin</u> 3.9.4
<u>David Shum</u> 3.4.1 3.5.1.1 3.5.1.2 3.5.1.4 3.6.1	<u>David Jeng</u> 3.7.	<u>Patrick Sekerak</u> 3.9.5
<u>George Georgiev</u> 3.5.1.3 3.13	<u>Samir Chakrabarti</u> 3.8	<u>Thomas Scarbrough</u> 3.9.6 3.11
	<u>John Wu</u> 3.9.1	<u>P.Y. Chen</u> 3.10
	<u>Jai Rajan</u> 3.9.2	<u>Amar Pal</u> 3.11
		<u>John Fair</u> 3.12

3

**ACRS Subcommittee Presentation
ESBWR Design Certification Review
Chapter 3 RAI Status**

Total RAIs Issued – 583

Open RAIs – 57

Open RAI Details

- 3.8 – 19
- 3.9 – 15
- 3.6 – 8
- 3.11 - 7

4



Presentation to the ACRS Subcommittee

ESBWR Design Certification Review
Chapter 3.2 – Classification of Structures, Systems,
and Components
Chandu Patel – NRO/DNRL/NGE

June 18, 2008

5

ACRS Subcommittee Presentation ESBWR Design Certification Review Section 3.2 – Classification of Structures, Systems, and Components

Regulations and Regulatory Guidance

- GDC 1 and 2
- Regulatory Guides 1.26, 1.29, 1.143, 1.151
- SECY for RTNSS SSCs
- SRP 3.2.1 and 3.2.2

Technical Summary

- Seismic classification consistent with RG 1.29
 - Quality grouping consistent with RG 1.26
 - Classification Boundaries are identified
- Nonsafety-related SSCs evaluated by the RTNSS process

Significant Open Items

- Electrical Systems Supporting Post 72-Hour Functions (RAI 3.2-63)
- QA for Seismic II SSCs, and Graded QA for Risk Significant RTNSS Systems (RAI 3.2-6)
- Turbine Building Reclassified From Seismic II to NS (RAI 3.2-66)

6

**ACRS Subcommittee Presentation
ESBWR Design Certification Review
Section 3.3 – Wind and Tornado Loadings**

Regulations and Regulatory Guidance

- GDC 2
- Regulatory Guide 1.76
- SRP 3.3

Technical Summary

- Cat I structures design criteria includes:
 - o Extreme Wind Speed – 150 mph
 - o Maximum Tornado Wind Speed – 330 mph
- Tornado design loads include wind pressure, pressure drop and missiles
- Adverse interaction between NS and seismic Cat I structures is precluded

Significant Open Items

- Address potential adverse interaction between the Radwaste Building and adjacent seismic Cat I structures under tornado loads – RAI 3.3-3
 - o Applicant will design Radwaste building for full tornado wind – issue is now closed.

7

**ACRS Subcommittee Presentation
ESBWR Design Certification Review
Section 3.4.1 – External and Internal Flood Protection**

Regulatory Requirements and Guidance

- GDC 2
- Regulatory Guides 1.59, 1.102
- Section IV.C of 10 CFR Part 50, Appendix S
- SECY for RTNSS
- SRP 3.4.1

Technical Summary

- GEH discussed the flood protection measures that are applicable to the ESBWR design for postulated external flooding resulting from natural phenomena, as well as for internal flooding from system and component failures.
- GEH conducted an analysis based on the site envelope parameters to identify the safety-related SSCs that require protection against flooding from both external and internal sources.

Significant Open Items

- Emergency operating procedures as an external flood condition develops. (RAI 3.4-12)
- Protection of RTNSS systems from external and internal flooding (RAI 22.5-5)
- Calculation for the maximum volume of floodwater in each area (RAI 3.4-9)

8

**ACRS Subcommittee Presentation
ESBWR Design Certification Review
Section 3.4.2 – Analysis Procedures**

Regulations and Regulatory Guidance

- GDC 2
- SRP 3.4.2

Technical Summary

- Highest flood and ground water levels are below finished grade – no flood hydrodynamic effects considered
- Hydrostatic pressure is considered in the design of embedded structural elements.

Significant Open Items

- None

9

**ACRS Subcommittee Presentation
ESBWR Design Certification Review
Section 3.5.1.1 - Internally Generated Missiles
(Outside Containment)**

Regulatory Requirements and Guidance

- GDC 4
- SECY for RTNSS
- SRP 3.5.1.1

Technical Summary

- GEH, described the criteria for identifying missiles and protecting SSCs from their effects.
- GEH evaluated the potential internally generated missiles that could result from failure of the plant equipment located outside the containment.
- GEH categorized the potential internally generated missiles into two groups:
 - Internally generated missiles resulting from in-plant rotating equipment overspeed failures.
 - Internally generated missiles resulting from in-plant high-pressure system ruptures

Significant Open Items

- Protection of RTNSS systems from protected from internally generated missiles outside containment. (RAI 22.5-5)

10

**ACRS Subcommittee Presentation
ESBWR Design Certification Review
Section 3.5.1.2 - Internally Generated Missiles
(Inside Containment)**

Regulatory Requirements and Guidance

- GDC 4
- SECY for RTNSS
- SRP 3.5.1.2

Technical Summary

- GEH categorized the potential internally generated missiles within the containment into three groups:
 - Missiles generated by rotating equipment (e.g., pump impellers, compressors, and fan blades).
 - Missiles generated by pressurized components (e.g., valve bonnets, thermowells, nuts, bolts, studs, valve stems, and accumulators).
 - Gravitational missiles

Significant Open Items

- Protection of RTNSS systems from internally generated missiles inside containment. (RAI 22.5-5)

11

**ACRS Subcommittee Presentation
ESBWR Design Certification Review
Section 3.5.1.3 - Turbine Missiles**

Regulations and Regulatory Guidance

- GDC 4
- Regulatory Guides 1.115
- ASME Code, Section III and XI
- SRP 3.5.1.3

Technical Summary

- ESBWR turbine generator is favorably oriented.
- For favorably oriented turbines, the probability of turbine missile generation, P1, should be less than 1×10^{-4}
- The turbine ITAAC specifies that turbine missile probability analysis confirm that probability of turbine missile generation, P1, is less than 1×10^{-4} per year.

Open Items

- None

12

**ACRS Subcommittee Presentation
ESBWR Design Certification Review
Section 3.5.1.4 – Missiles Generated by
Natural Phenomena**

Regulatory Requirements and Guidance

- GDC 2, 4
- Regulatory Guides 1.76, 1.117
- SECY for RTNSS
- SRP 3.5.1.4

Technical Summary

- Tomado-generated missiles, which have been determined to be the limiting natural phenomena hazard in the design of all structures required for the safe shutdown of the nuclear power plant, are used in the design basis for the ESBWR design.

Significant Open Items

- None

13

**ACRS Subcommittee Presentation
ESBWR Design Certification Review
Section 3.5.1.5 – Site Proximity Missiles
(Except Aircraft)**

Regulatory Guidance

- GDC 4
- Regulatory Guides 1.206, 1.91

Technical Summary

- Nature and proximity of man-related hazards
- Establish the risk of hazard is very low
- Reviewing event probability for which the expected rate of occurrence of potential exposure in excess of the 10 CFR 100 guideline is estimated to be less than order of magnitude of 10^{-7} per year

The envelope of ESBWR Standard Plant Site Design Parameters in DCD are provided in Tier 2 Table 2.0-1. The site is selected such that the probability of occurrence of the Site Proximity Missiles (except aircraft) is less than 10^{-7} per year. Since the information regarding Site Proximity Missiles (Except aircraft) in the site vicinity is site-specific, the review needs to be performed at the time of COL stage, based on the COL applicant's address of site-specific information in accordance with SRP Section 3.5.1.5.

14

**ACRS Subcommittee Presentation
ESBWR Design Certification Review
Section 3.5.1.6 – Aircraft Hazards**

Regulatory Guidance

- GDC 3, GDC 4
- Regulatory Guides 1.206

Technical Summary

- Nature and proximity of man-related hazards (airports)
- Establish the risk of hazard is very low
- Reviewing event probability for which the expected rate of occurrence of potential exposure in excess of the 10 CFR 100 guideline is estimated to be less than order of magnitude of 10^{-7} per year

The envelope of ESBWR Standard Plant Site Design Parameters in DCD are provided in Tier 2 Table 2.0-1. The probability of aircraft hazards impacting the ESBWR Standard plant and causing consequences greater than 10 CFR Part 100 (and 10 CFR 50.34(a)(1) exposure is less than 10^{-7} per year. Since the information regarding potential aircraft hazards in the vicinity of the site is site-specific, the review needs to be performed at the time of COL stage, based on the COL applicant's address of site-specific information in accordance with SRP Section 3.5.1.6.

15

**ACRS Subcommittee Presentation
ESBWR Design Certification Review
Section 3.5.2 – Structures, Systems, and Components
To Be Protected from Externally Generated Missiles**

Regulatory Requirements and Guidance

- GDC 2, 4
- Regulatory Guides 1.13, 1.27, 1.115, 1.117
- SECY for RTNSS
- SRP 3.5.2

Technical Summary

- GEH discussed the SSCs to be protected from externally generated missiles, including all safety-related SSCs on a plant site that have been provided to support the reactor facility.

Significant Open Items

- Protection of RTNSS systems against externally generated missiles. (RAI 22.5-5)

16

**ACRS Subcommittee Presentation
ESBWR Design Certification Review
Section 3.5.3 – Barrier Design Procedures**

Regulations and Regulatory Guidance

- GDC 2 and 4
- Regulatory Guides 1.76 and 1.142
- SRP 3.5.3

Technical Summary

- Concrete barrier thicknesses are conservative for design basis tornado.
- Analysis procedures for tornado missile effects are consistent with SRP 3.5.3 guidance.

Significant Open Items

- None

17



Presentation to the ACRS Subcommittee

ESBWR Design Certification Review
Chapter 3.10 – Seismic and Dynamic Qualification of
Mechanical and Electrical Equipment
Mohammed Abid – NRO/DE/EMB1

June 18, 2008

18

**ACRS Subcommittee Presentation
ESBWR Design Certification Document Review
Section 3.10 – Seismic and Dynamic Qualification**

Seismic and Dynamic Qualification of Mechanical and Electrical Equipment

- The staff reviews the applicant's methods of test and analysis employed to ensure the structural integrity and the operability of Seismic Category I mechanical and electrical equipment (including instrumentation and control) under the full range of normal and accident loading (including seismic and reactor building vibration).

Regulatory Guidance

- GDC 1, GDC 2, GDC 4, GDC 14, and GDC 30
- Appendix S and Appendix B to 10 CFR Part 50
- Regulatory Guide 1.29, 1.60, 1.61, 1.63, 1.92, 1.97, 1.100, and 1.122
- SRP Chapter 3.10
- Interim Staff Guidance on Addressing Seismic Issues Associated with High-Frequency Ground Motion Evaluations

Industry Standard

- IEEE 344-1987

19

**ACRS Subcommittee Presentation
ESBWR Design Certification Document Review
Section 3.10 – Seismic and Dynamic
Qualification**

SER Items of Interest

3 RAIs remain open in the SER with Open Items sent to the ACRS (i.e., RAI 3.10-5, RAI 3.10-6 and RAI 3.10-8). All RAIs are closed.

RAI 3.10-5

Requested General Electric-Hitachi (GEH) to revise the COL information to require COL applicant to provide a milestone for submitting an implementation schedule for seismic and dynamic qualification of ESBWR mechanical and electrical equipment.

In its response, GEH stated that DCD Tier 2, Section 3.10.4 will be revised accordingly in Revision 5.

The staff confirms revised DCD Section provides the necessary COL information. RAI 3.10-5 is closed.

20

**ACRS Subcommittee Presentation
ESBWR Design Certification Document Review
Section 3.10 – Seismic and Dynamic
Qualification**

RAI 3.10-6

Requested GEH to provide basis for the assumed number of SRV actuation events and the total SRV test duration stated in DCD.

In its response, GEH stated that ESBWR design (with isolation condenser system (ICS) and its larger steam volume) results in ZERO SRV openings during design basis anticipated operational occurrences (AOO), because ICS is sized to prevent SRV actuations with 3 of 4 trains in operation (Sect. 5.4.6.3). GEH concluded that the number of SRV actuation events and the total SRV test duration stated in the DCD is conservative.

The staff finds GEH response satisfactory for the assumed SRV Actuation events and test durations. RAI 3.10-6 is closed.

21

**ACRS Subcommittee Presentation
ESBWR Design Certification Document Review
Section 3.10 – Seismic and Dynamic
Qualification**

RAI 3.10-8

Requested GEH to address the adequacy of the seismic qualification of ESBWR mechanical and electrical equipment for plant site with High-Frequency seismic excitations.

In its response, GEH stated that ESBWR certified seismic design response spectra (CSDRS) uses a single ENVELOPE ground motion, containing both Low- and High-Frequency ground motion (North Anna ESP site- specific spectra), to generate in-structure response spectra for use in seismic qualification of mechanical and electrical equipment. The seismic qualification of ESBWR mechanical and electrical equipment meets IEEE 344-1987.

The staff concludes that ESBWR design is adequate for plant site with High- Frequency seismic excitations. RAI 3.10-8 is closed.

22



Presentation to the ACRS Subcommittee

**ESBWR Design Certification Review
Chapter 3.11 – Environmental Qualification
of Mechanical and Electrical Equipment
Amar Pal – NRO/DE/EEB**

June 18, 2008

23

ACRS Subcommittee Presentation ESBWR Design Certification Review Chapter 3.11 – Environmental Qualification

Regulations and Regulatory Guidance

- 10 CFR 50.49
- 10 CFR 52.47 (b)(1)- ITAAC
- GDCs: 1, 2, 4, 23 of Appendix A and III, XI, XVII of Appendix B of Part 50.
- Regulatory Guides 1.89, 1.97, 1.209, and 1.180
- Industry Standards: IEEE
- Other Guidance – SECY – 05-0197

Technical Summary

- Equipment Covered Under EQ Program
 - o Safety-related mechanical equipment in harsh environment (GDCs)
 - o Electrical equipment important to safety in harsh environment (10 CFR 50.49)
 - Safety-related electrical equipment
 - Non-safety-related electrical equipment whose failure could prevent satisfactory accomplishment of safety-function
 - Certain post-accident monitoring equipment
 - o Safety-related digital and non-digital I&C equipment in mild environment. (GDCs)

24

**ACRS Subcommittee Presentation
ESBWR Design Certification Review
Chapter 3.11 – Environmental Qualification**

Technical Summary (Cont'd)

- EQ PROGRAM SUMMARY
 - o The equipment is designed to have the capability to perform its design safety functions under all anticipated operational occurrences and normal, accident, and post-accident environments, and for length of time for which its functions are required.
 - o The environmental capability of the equipment is demonstrated by appropriate testing and analyses.
 - o A QA program meeting the requirements of Appendix B to 10 CFR Part 50 is established and implemented to provide assurance that all requirements have been satisfactorily accomplished
 - o EQ of mechanical, electrical, and I&C equipment meets the relevant requirements of 10 CFR 50.49, GDC 1, 2, 4, and 23 in Appendix A to 10 CFR Part 50; Criteria III, XI, and XVII in Appendix B to 10 CFR Part 50.
 - o The qualified life is verified using methods and procedures of qualification and documentation as stated in IEEE-323-1974.
 - o EQ Program is an Operational Program per SECY-05-0197
 - o GEH has proposed an ITAAC to verify EQ equipment has been qualified per NRC regulations.
 - o EQ records will be maintained in an auditable form for the entire period during which the EQ equipment is installed

25

**ACRS Subcommittee Presentation
ESBWR Design Certification Review
Chapter 3.11 – Environmental Qualification**

Open Items

- Use of IEEE Standard 323-1974 vs IEEE 323-2003 (Review ongoing) (RAI 3.11-11)
- RAI responses related to environmental parameters (radiation and temperature) needed for staff to complete its review. (RAIs 3.11-18, 20, 23 through 27)

COL Item

- COL Applicant will provide a full description and milestone for program implementation of the EQ program that includes completion of the plant-specific Equipment Qualification Document (Based on Rev. 5)

26



Presentation to the ACRS Subcommittee

**ESBWR Design Certification Review
Chapter 3.13 – Threaded Fasteners – ASME
Code Class 1, 2, and 3
Chandu Patel – NRO/DNRL/NGE**

June 18, 2008

27

ACRS Subcommittee Presentation ESBWR Design Certification Review Section 3.13 - Threaded Fasteners for ASME Code Class 1, 2 and 3

Regulations and Regulatory Guidance

- GDC 1, 4, 14, 30, 31
- 10 CFR Part 50, Appendix B and G
- ASME Code, Section III
- Regulatory Guide 3.13
- SRP 3.13

Technical Summary

- Threaded fasteners complies with the requirements ASME Code Section III, and, therefore, meets 10 CFR 50, Appendix A and GDC 1, 14, 30 and 31.
- Lubricants containing halogens, sulfur, lead or molybdenum sulfide are avoided and controls to avoid contamination conforms to the recommendations of RG 1.37 and, therefore, meet 10 CFR 50, Appendix B, Criterion XIII
- Threaded fasteners are preservice and inservice inspected in accordance with the requirements ASME Code Section XI and, therefore, meet 10 CFR 50.55a

Open Items

- None

28