



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555-0001

December 30, 2005

SECRETARY

COMMISSION VOTING RECORD

DECISION ITEM: SECY-05-0227

TITLE: FINAL RULE -- AP1000 DESIGN CERTIFICATION

The Commission (with all Commissioners agreeing) approved the final rule as noted in an Affirmation Session and recorded in the Staff Requirements Memorandum (SRM) of December 30, 2005.

This Record contains a summary of voting on this matter together with the individual vote sheets, views and comments of the Commission. Commissioner Jaczko's signed vote sheet will be added to the Voting Record when it is available.

A handwritten signature in black ink, appearing to read "Annette L. Vietti-Cook", written over a horizontal line.

Annette L. Vietti-Cook
Secretary of the Commission

Attachments:

1. Voting Summary
2. Commissioner Vote Sheets

cc: Chairman Diaz
Commissioner McGaffigan
Commissioner Merrifield
Commissioner Jaczko
Commissioner Lyons
OGC
EDO
PDR

VOTING SUMMARY - SECY-05-0227

RECORDED VOTES

	APRVD	DISAPRVD	ABSTAIN	NOT PARTICIP	COMMENTS	DATE
CHRM. DIAZ	X				X	12/19/05
COMR. McGAFFIGAN	X				X	12/20/05
COMR. MERRIFIELD	X				X	12/22/05
COMR. JACZKO	X				X	12/28/05
COMR. LYONS	X				X	12/27/05

COMMENT RESOLUTION

In their vote sheets, all Commissioners approved the final rule as noted in an Affirmation Session. Subsequently, the comments of the Commission were incorporated into the guidance to staff as reflected in the SRM issued on December 30, 2005.

AFFIRMATION ITEM

RESPONSE SHEET

TO: Annette Vietti-Cook, Secretary
FROM: CHAIRMAN DIAZ
SUBJECT: **SECY-05-0227 - FINAL RULE - AP1000 DESIGN
CERTIFICATION**

Approved ^{w/edits} xx ~~18~~ Disapproved _____ Abstain _____
Not Participating _____

COMMENTS:

See attached.



SIGNATURE

Dec 19, 05

DATE

Entered on "STARS" Yes No _____

**Chairman Diaz's edit to Federal Register Notice
Final Rule - AP1000 Design Certification**

the term "investment protection," the proposed term "non-safety-related severe accident equipment" would not be an acceptable replacement.

The NRC agrees that the bracketed values in the investment protection short-term availability controls have the same status as the bracketed values in the generic TS. As a result, NRC amended the discussion in Section III.H of the Supplementary Information (70 FR 20069) of this *Federal Register* notice to refer to the availability controls.

Comment Summary. NEI recommends that the phrase "or licensees" be deleted from the rule language in Section VIII.C.2 of the AP1000 DCR.

Response. The NRC agrees with this comment and Section VIII.C.2 of the DCR has been amended as suggested by NEI. The Commission will consider amending the other DCRs to adopt the language recommended by NEI as part of the ongoing part 52 rulemaking.

Comment Summary. NEI recommends amending the rule language in Section VIII.C.6 of the AP1000 DCR to delete the requirement that plant-specific TS be treated as license amendments. Changes to the

Response. The NRC disagrees with this request. The requirement that changes to the plant-specific TS be treated as license amendments is correct. It is unlikely that the

Commission will adopt NEI's proposed change for the other DCRs in the ongoing part 52 rulemaking. However, if the Commission decides to clarify this issue for the other DCRs in the ongoing part 52 rulemaking, the NRC will also clarify the AP1000 DCR accordingly as part of that rulemaking. extra
rule

Comment Summary. NEI recommends amending Section VIII.B.6.a of the AP1000 DCR to be consistent with Section VI.B.5 regarding plant-specific departures.

Response. The NRC disagrees with this request. It was determined during the first two design certification rulemakings that departures from Tier 2* information would not receive finality or be treated as a resolved issue within the meaning of Section VI of the DCR. The NRC notes that NEI submitted the same comment during the 2003 proposed rule to amend 10 CFR part 52. It is unlikely that the Commission will adopt NEI's proposed language for the other DCRs in the ongoing part 52 rulemaking. However, if the Commission decides to adopt NEI's proposed language for the other DCRs in the ongoing part 52 rulemaking, the NRC will also amend the AP1000 DCR accordingly as part of that rulemaking.

Comment Summary. NEI recommends amending Section VIII.C.3 of the AP1000 DCR to require the NRC to meet the backfit requirements of § 50.109 in addition to the special circumstances in § 2.758(b) for plant-specific departures from operational requirements.

Response. The NRC disagrees with this request. In the first two design certification rulemakings, the Commission decided on different standards for changes made under Section VIII.C (see the discussion at 62 FR 25800). The NRC notes that NEI submitted the same comment during the 2003 proposed rule to amend 10 CFR part 52. It is unlikely that the Commission will adopt NEI's proposed language for the other DCRs in the ongoing part 52 rulemaking. However, if the Commission decides to adopt NEI's proposed language for the other DCRs in the ongoing part 52 rulemaking, the NRC will also amend the AP1000 DCR accordingly as part of that rulemaking.

Comment Summary. NEI recommends amending Section VIII.C.4 of the AP1000 DCR to revise the standards for making changes to operational requirements.

Response. The NRC disagrees with this request. In the first two DCRs, the Commission decided on different standards for changes made under Section VIII.C (see the discussion at 62 FR 25800; May 12, 1997). In addition, the Commission determined that exemptions from operational requirements would not receive finality or be treated as a resolved issue within the meaning of Section VI of the DCR. The NRC notes that NEI submitted the same comment during the 2003 proposed rule to amend 10 CFR part 52. It is unlikely that the Commission will adopt NEI's proposed language for the other DCRs in the ongoing part 52 rulemaking. However, if the Commission decides to adopt NEI's proposed language for the other DCRs in the ongoing part 52 rulemaking, the NRC will also amend the AP1000 DCR accordingly as part of that rulemaking.

Comment Summary. NEI recommends amending Section IX.B.1 of the AP1000 DCR to specify the type of action to be performed by the NRC staff regarding ITAAC.

Response. The NRC disagrees with this request and has decided to maintain the original rule language for this provision because it does not believe that individual DCRs should address the scope of the NRC staff's activities with respect to ITAAC verification. This is a generic matter that, if it is to be addressed in a rulemaking, is more appropriate for inclusion in subpart C of part 52 dealing generally with combined licenses.

The NRC notes that NEI submitted the same comment during the 2003 proposed rule to amend 10 CFR part 52. It is unlikely that the Commission will adopt NEI's proposed language for the other DCRs in the ongoing part 52 rulemaking. However, if the Commission decides to

adopt NEI's proposed language for the other DCRs in the ongoing part 52 rulemaking, the NRC will also amend the AP1000 DCR accordingly as part of that rulemaking.

Comment Summary. NEI recommends amending Section IX.B.3 of the AP1000 DCR to clarify the rule language.

Response. The NRC disagrees with this editorial request and has decided to maintain the original rule language for this provision. The NRC notes that NEI submitted the same comment during the 2003 proposed rule to amend 10 CFR part 52. It is unlikely that the Commission will adopt NEI's proposed language for the other DCRs in the ongoing part 52 rulemaking. However, if the Commission decides to adopt NEI's proposed language for the other DCRs in the ongoing part 52 rulemaking, the NRC will also amend the AP1000 DCR accordingly as part of that rulemaking.

Comment Summary. NEI recommends amending Sections X.B.1 and X.B.3 of the AP1000 DCR to clarify the rule language regarding DCDs.

Response. The NRC agrees with this comment, ^{and} Section X.B of the AP1000 DCR has been amended to ^{clarify the language} be consistent with the other DCRs in the proposed part 52 rule. The NRC notes that NEI submitted the same comment during the 2003 proposed rule to amend 10 CFR part 52. The Commission ^{will consider amending the} ~~intends to amend~~ existing DCRs to make them consistent with the AP1000 DCR ^{as part of the ongoing Part 52 rulemaking}.

III. Section-by-Section Analysis.

The following discussion sets forth the purpose and key aspects of each section and paragraph of the final AP1000 DCR. All section and paragraph references are to the provisions in appendix D to 10 CFR part 52. The final DCR for the AP1000 standard plant design is nearly identical to the AP600 DCR, which the NRC previously codified in 10 CFR part 52, appendix C (Design Certification Rule for the AP600 Design, 64 FR 72015, December 23, 1999). Many of the procedural issues and their resolutions for the AP600 DCR, as well as the initial two design certification rules for the ABWR and ABB-CE System 80+, (e.g., the two-tier structure, Tier 2*, the scope of issue resolution) were developed after extensive discussions with public stakeholders, including Westinghouse. Also, Westinghouse requested that policy resolutions for the AP600 design review be applied to the AP1000. Accordingly, the NRC has modeled the AP1000 DCR on the existing DCRs, with certain departures. These departures are necessary to account for differences in the AP1000 design documentation, design features, and environmental assessment (including severe accident mitigation design alternatives (SAMDA)).

A. Introduction.

The purpose of Section I of appendix D to 10 CFR part 52 (this appendix) is to identify the standard plant design that is approved by this DCR and the applicant for certification of the standard design. Identification of the design certification applicant is necessary to implement this appendix, for two reasons. First, the implementation of 10 CFR 52.63(c) depends on whether an applicant for a COL contracts with the design certification applicant to provide the generic DCD and supporting design information. If the COL applicant does not use the design certification applicant to provide this information, then the COL applicant must meet the

(paragraph II.G), which is appropriate to include in this rulemaking so that the eight criteria in paragraph VIII.B.5.b of the final rule will be implemented as intended.

C. Scope and Contents.

The purpose of Section III of this DCR is to describe and define the scope and contents of this design certification and to set forth how documentation discrepancies or inconsistencies are to be resolved. Paragraph A is the required statement of the Office of the *Federal Register* (OFR) for approval of the incorporation by reference of Tier 1, Tier 2, and the generic TS into this appendix. Paragraph B requires COL applicants and licensees to comply with the requirements of this appendix. The legal effect of incorporation by reference is that the incorporated material has the same legal status as if it were published in the *Code of Federal Regulations*. This material, like any other properly-issued regulation, has the force and effect of law. Tier 1 and Tier 2 information, as well as the generic TS, have been combined into a single document called the generic DCD, in order to effectively control this information and facilitate its incorporation by reference into the rule. The generic DCD was prepared to meet the requirements of the OFR for incorporation by reference (CFR part 51). One of the requirements of the OFR for incorporation by reference is that the design certification applicant must make the generic DCD available upon request after the final rule becomes effective. Therefore, paragraph III.A of this appendix identifies a Westinghouse representative to be contacted in order to obtain a copy of the generic DCD.

Paragraphs A and B also identify the investment protection short-term availability controls in Section 16.3 of the generic DCD as part of the Tier 2 information. During its review of the AP1000 design, the NRC determined that residual uncertainties associated with passive

Paragraph A identifies the regulations in 10 CFR parts 20, 50, 73, and 100 that are applicable to the AP1000 design. After the NRC staff issued its FSER for the AP1000 design (NUREG-1793, September 2004), the Commission amended several existing regulations and adopted new regulations. The Commission reviewed these regulations to determine if they are applicable to this design and, if so, to determine if the design meets these regulations. The Commission finds that ^{none} ~~any~~ of these new regulations are ~~not~~ applicable to the AP1000 design. The Commission's determination of the applicable regulations was made as of the date specified in paragraph V.A of this appendix, which is the date that this appendix was approved by the Commission and signed by the Secretary of the Commission.

In paragraph B of this appendix, the Commission identifies the regulations that do not apply to the AP1000 design. The Commission has determined that the AP1000 design should be exempt from portions of 10 CFR 50.34, 50.62, and Appendix A to part 50, as described in the FSER (NUREG-1793) and summarized below:

(1) Paragraph (f)(2)(iv) of 10 CFR 50.34 - Plant Safety Parameter Display Console.

Under 10 CFR 52.47(a)(ii), an applicant for design certification must demonstrate compliance with any technically relevant Three Mile Island (TMI) requirements in 10 CFR 50.34(f). The requirement in 10 CFR 50.34(f)(2)(iv) states that an application must provide a plant safety parameter display console that will display a minimum set of parameters defining the safety status of the plant, be capable of displaying a full range of important plant parameters and data trends on demand, and be capable of indicating when process limits are being approached or exceeded. Westinghouse addresses this requirement, in Section 18.8.2 of the DCD, with an integrated design rather than a stand-alone, add-on system, as is used at most current operating plants. Specifically, Westinghouse integrated the safety parameter display system (SPDS) requirements into the design requirements for the alarm and display

**Chairman Diaz's edits on the Environmental Assessment
Final Rule - AP1000 Design Certification**

required. The basis for this determination, as documented in this EA, is that the amendment to 10 CFR Part 52 would not authorize the siting, construction, or operation of a facility referencing the AP1000 design; it would only codify the AP1000 design in a rule. Therefore, the NRC staff did not issue the EA for comment specifically by Federal, other State, and local agencies. The NRC's finding of no significant environmental impact was published in the *Federal Register* on April 18, 2005 (70 FR 20062), with the proposed design certification rule and draft EA for the AP1000 design. The NRC will evaluate the environmental impacts and issue an EIS, as appropriate, in accordance with NEPA as part of any application(s) for the siting, construction, or operation of a facility that would reference the AP1000 design. 

X

7.0 PUBLIC COMMENTS AND NRC RESPONSES

On April 18, 2005 (70 FR 20062), the Commission issued the draft EA for public comment. The comment period expired on July 5, 2005. The comments are summarized below and responses are provided; the comments did not result in a change in the technical analyses, findings, or conclusions in the EA.

Comment summary. Three severe accident mitigation design alternatives (SAMDA) were inappropriately dismissed in the EA on the basis that they do not affect the likelihood of an accident. These SAMDA involve filtered containment vents and self-actuating containment isolation valves.

Response. The NRC disagrees that these three SAMDA were inappropriately dismissed. The noted SAMDA were assessed in terms of their respective benefits and implementation costs, and dismissed on the basis that they would not be cost-beneficial. In assessing benefits, SAMDA were divided into two groups—those that impact core damage

Commission recognizes that it cannot rule out the possibility of a terrorist threat to nuclear facilities, but finds that the possibility of a terrorist attack is speculative and simply too far removed from the natural or expected consequences of agency action to require a study under NEPA. As a practical matter, attempts to evaluate that threat even in qualitative terms are likely to be meaningless and consequently of no use in the agency's decision making. Moreover, although one of the purposes of NEPA is to inform the public of the environmental impacts of a regulatory action, the results of any attempted analysis of terrorism could not be made available to the public, for reasons associated with safeguards and physical security.

The Commission is devoting substantial time and agency resources to combating the potential for terrorism involving nuclear facilities and materials. In response to the September 11 attacks, the NRC staff is conducting a comprehensive review of its security and safeguards measures, and have instituted interim upgrades in security requirements for its licensees. The Commission is also working with numerous other government agencies to meet and minimize the threat of terrorism. Thus, although the Commission declines to consider terrorism in the context of NEPA, it is devoting significant attention to terrorism-related matters.

Comment summary. How can anyone do an "Environmental Assessment" or an FSER on a plant design that exists only on paper and has never been constructed completely to scale and operated anywhere in the world?

Response. The logical outgrowth of this argument is that no plant of new design could ever be built; the argument is circular. The purpose of an FSER and EA is to assess a nuclear plant design before it is constructed. The FSER is based on an evaluation of design information and the safety analyses of postulated accidents for that particular plant design. The SAMDA portion of the EA considers alternatives to the plant design that was evaluated in the

AFFIRMATION ITEM

RESPONSE SHEET


TO: Annette Vietti-Cook, Secretary
FROM: COMMISSIONER MCGAFFIGAN
SUBJECT: **SECY-05-0227 - FINAL RULE - AP1000 DESIGN
CERTIFICATION**

Approved Disapproved _____ Abstain _____

Not Participating _____

COMMENTS:

See attached comments and edits.



SIGNATURE
December 20, 2005

DATE

Entered on "STARS" Yes No _____

Commissioner McGaffigan's Comments on SECY-05-0227

To ensure clarity when referencing a paragraph of the Appendix, always include the corresponding section reference. Cites to the Code of Federal Regulations should be consistent and always include "10 CFR" before the relevant regulatory part or section. The Staff should also be consistent and determine whether or not to use the § symbol after "10 CFR" and before a specific section cite. Finally, when referencing "10 CFR Part" the staff should capitalize "Part." See also attached edits.

E. Mc Gaffigan
12/20/05

storage tank specified in TS 3.6.6, "Passive Containment Cooling System - Operating," of greater than or equal to -40 °F and less than or equal to 120 °F. If the water temperature is at or below 50 °F, or at or above 100 °F, the surveillance frequency to check the temperature is reduced from 7 days to 24 hours. The operational limits and the site parameters provide reasonable assurance that the AP1000 can be operated without undue risk to the public health and safety. Conservative evaluations of the potential effect of solar radiation on the operation and performance of the AP1000 PCS show that the AP1000 TS provide reasonable assurance that off-normal conditions can be detected and appropriate actions taken to preclude operations outside the current design-base assumptions. Based on the estimated time needed to exceed the current operational temperature limits (10 days of uninterrupted extreme environmental conditions), it is reasonable to conclude that the AP1000 operational limits will not be exceeded even for sites with high solar radiation. In the unlikely event that the shield building might heat up, a containment response analysis showed the pressure increase to be small, 0.75 pounds per square inch (psi), and based on the current margin of 1.2 psi (DCD Table 6.2.1.1-1), the design pressure limit of 73.7 pounds per square inch absolute (psia) would not be exceeded. Therefore, the effect of heat of solar radiation on the performance of the PCS has been resolved.

Comment summary. The accelerated schedule for the AP1000 led to cutting regulatory corners and was further accelerated by granting the FDA before the FSR was made available to the public.

Response. The NRC disagrees with this comment. In a letter to Mr. W. E. Cummins (Westinghouse), dated July 12, 2002, the NRC provided an expected schedule for the AP1000 review, which was significantly shorter than previous ~~design certification rulemakings~~.

DCR₅

shorter schedule was due to expected efficiencies that would be gained as a result of the similarities between the AP600 and AP1000 designs. Also, the AP1000 FSER was made available to the public on September 20, 2004, the same day that the FDA was made available to the public.

B. Design Certification Rule.

It is the Commission's goal to maintain as much consistency as possible in the rule language for all of the DCRs. Many of the following comments from NEI appear to be applicable to all of the DCRs but some repeat comments NEI submitted previously during the 2003 proposed rule to amend 10 CFR part 52.

Comment Summary. NEI recommends that Section III.B of the Supplementary Information (70 FR 20064) be revised to delete the phrase "not just incorporate by reference."

Response. The NRC disagrees with this request. The NRC does agree that the plant-specific DCD should be part of the final safety analysis report (FSAR) for a combined license (COL) application. The NRC believes that the generic DCD should also be part of the FSAR, not just incorporated by reference, in order to facilitate the NRC staff's review of any departures or exemptions. However, any changes made to existing DCRs ^{if} in the ongoing part 52 *is revised* rulemaking with respect to this issue would also be made to the AP1000 DCR.

Comment Summary. NEI recommends clarification of the review status of "operational requirements" in Section III.F of the Supplementary Information (70 FR 20067).

Response. The NRC agrees that the special backfit provisions of § 52.63 do not apply to operational requirements in the DCD. However, the NRC believes that the discussion in

Section III.F of the Supplementary Information section of the proposed rule document accurately states the review status of operational requirements and does not need to be revised.

Comment Summary. NEI recommends modification of the definition of generic TS in Section II.B of the AP1000 DCR.

Response. The NRC disagrees with this comment. The NRC stated in the Supplementary Information (70 FR 20063) that the values in brackets are neither part of the AP 1000 DCR nor are they binding. The NRC believes that amending the definition of generic TS is not necessary and also wants to maintain consistent rule language for all DCRs.

Comment Summary. NEI recommends replacement of the term "investment protection" in Section II.E of the AP1000 DCR and elsewhere in the DCD by the term "non-safety-related severe accident equipment." In addition, NEI recommends that the DCR and Supplementary Information be revised so that bracketed information in the investment protection short-term availability controls will be treated like bracketed information in generic TS. ✓

Response. The NRC disagrees with NEI's request to change this terminology. Use of the term "investment protection short-term availability controls" was requested by the applicant (Westinghouse Electric Company, LLC) and was also used in the AP600 DCR. Furthermore, the origin of investment protection short-term availability controls comes from implementing the regulatory treatment of non-safety systems process, which typically results in requirements to achieve higher reliability for certain active, non-safety systems. These systems are not limited to severe accident design features. Therefore, even if the NRC agreed to a generic change to

the term "investment protection," the proposed term "non-safety-related severe accident equipment" would not be an acceptable replacement.

The NRC agrees that the bracketed values in the investment protection short-term availability controls have the same status as the bracketed values in the generic TS. As a result, NRC amended the discussion in Section III.H of the Supplementary Information (70 FR 20069) ~~of this Federal Register notice~~ to refer to the availability controls.

the proposed rule's

Comment Summary. NEI recommends that the phrase "or licensees" be deleted from the rule language in Section VIII.C.2 of the AP1000 DCR.

AP1000

Response. The NRC agrees with this comment and Section VIII.C.2 of the DCR has been amended as suggested by NEI. The Commission ~~will~~ *may* consider amending the ~~other~~ DCRs to adopt the language recommended by NEI ~~as part of the ongoing part 52 rulemaking.~~

if DCFR Part 52 is revised.

Comment Summary. NEI recommends amending the rule language in Section VIII.C.6 of the AP1000 DCR to delete the requirement that plant-specific TS be treated as license amendments.

changes to the

Response. The NRC disagrees with this request. The requirement that changes to the plant-specific TS be treated as license amendments is correct. ~~It is unlikely that the~~

~~Commission will adopt NEI's proposed change for the other DCRs in the ongoing part 52 rulemaking. However, if the Commission decides to clarify this issue for the other DCRs in the~~

~~ongoing part 52 rulemaking,~~ the NRC will also clarify the AP1000 DCR accordingly as part of that rulemaking.

*in any poten
revision
10 CFR
Part 5:*

Comment Summary. NEI recommends amending the rule language in Section IX.B.1 of the AP1000 DCR to restore the phrase "based solely thereon."

Response. The NRC agrees to amend Section IX.B.1 of the AP1000 DCR, in order to make all of the DCRs consistent. However, the NRC notes that inclusion of the phrase "based solely thereon," does not change the meaning of Section IX.B.1. The determination of inspection, test, analysis, and acceptance criteria (ITAAC) completion will always be based on information that is material to the acceptance criteria.

Comment Summary. NEI recommends amending the rule language in Section X.A.1 of the AP1000 DCR to require the design certification applicant to include all generic changes to the generic TS and other operational requirements in the generic DCD.

Response. The NRC agrees with this comment, Section X.A.1 of the AP1000 DCR has been amended as suggested by NEI. The Commission ^{may} will consider amending the ~~other~~ DCRs to adopt the language recommended by NEI ~~as part of the ongoing part 52 rulemaking.~~
if 10 CFR Part 52 is revised.

Comment Summary. NEI recommends that Sections IV.A.2 and IV.A.3 of the AP1000 DCR be amended to be consistent with respect to inclusion of information in the plant-specific DCD or explain the difference between the terms "include" and "physically include" in Section IV.A (70 FR 20076).

Response. ^{of the AP1000 DCR} The NRC agrees that use of the terms "include" and "physically include" in Section IV.A should be clarified. The Commission ^{may} will consider amending all of the DCRs to clarify this issue ~~as part of the ongoing part 52 rulemaking.~~
if 10 CFR Part 52 is revised. ✓

Comment Summary. NEI recommends amending the definition of Tier 2 in Section II.E.1 of the AP1000 DCR to exclude the design-specific PRA and the evaluation of SAMDAs.

Response. The NRC agrees with this comment, Section II.E.1 of the AP1000 DCR has been amended as suggested by NEI. The NRC notes that NEI submitted the same comment during the 2003 proposed rule to amend 10 CFR Part 52. The Commission ^{may} will consider amending the other ~~DCRs~~ to adopt the language recommended by NEI as part of the ongoing ~~part 52 rulemaking~~. *If DCR Part 52 is revised.*

Comment Summary. NEI recommends amending the rule language in Section III.E of the AP1000 DCR to use the terminology for "site characteristics" consistently.

Response. The NRC agrees with this comment, Section III.E of the AP1000 DCR has been amended to be consistent with the other DCRs in the proposed part 52 rule. The NRC notes that NEI submitted the same comment during the 2003 proposed rule to amend 10 CFR part 52.

Comment Summary. NEI recommends clarifying the rule language in Section IV.A.2 of the AP1000 DCR regarding "same" information and "generic DCD."

Response. The NRC agrees with this comment, Section IV.A.2 of the AP1000 DCR has been amended to be consistent with the other DCRs in the proposed part 52 rule. The NRC notes that NEI submitted the same comment during the 2003 proposed rule to amend 10 CFR part 52.

Comment Summary. NEI recommends amending Section VIII.B.6.a of the AP1000 DCR to be consistent with Section VI.B.5 regarding plant-specific departures.

Response. The NRC disagrees with this request. It was determined during the first two ^{DCRs} ~~design certification rulemakings~~ that departures from Tier 2* information would not receive finality or be treated as a resolved issue within the meaning of Section VI of the DCR. The NRC notes that NEI submitted the same comment during the 2003 proposed rule to amend 10 CFR part 52. ~~It is unlikely that the Commission will adopt NEI's proposed language for the other DCRs in the ongoing part 52 rulemaking.~~ However, ^{If} if the Commission decides to adopt ^{any potential revision to 10 CFR Part 52} NEI's proposed language for the other ~~DCRs~~ DCRs in the ongoing part 52 rulemaking, the NRC will also amend the AP1000 DCR accordingly as part of that rulemaking.

Comment Summary. NEI recommends amending Section VIII.C.3 of the AP1000 DCR to require the NRC to meet the backfit requirements of § 50.109 in addition to the special circumstances in § 2.758(b) for plant-specific departures from operational requirements.

Response. The NRC disagrees with this request. In the first two ~~design certification~~ ^{DCRs} ~~rulemakings~~, the Commission decided on different standards for changes made under Section VIII.C ^{of the DCRs} (see the discussion at 62 FR 25800). The NRC notes that NEI submitted the same comment during the 2003 proposed rule to amend 10 CFR part 52. ~~It is unlikely that the Commission will adopt NEI's proposed language for the other DCRs in the ongoing part 52 rulemaking.~~ However, ^I if the Commission decides to adopt NEI's proposed language for the ~~other DCRs in the ongoing part 52 rulemaking,~~ ^{any potential revision to 10 CFR Part 52} the NRC will also amend the AP1000 DCR accordingly as part of that rulemaking.

Comment Summary. NEI recommends amending Section VIII.C.4 of the AP1000 DCR to revise the standards for making changes to operational requirements.

Response. The NRC disagrees with this request. In the first two DCRs, the Commission decided on different standards for changes made under Section VIII.C (see the discussion at 62 FR 25800; May 12, 1997). In addition, the Commission determined that exemptions from operational requirements would not receive finality or be treated as a resolved issue within the meaning of Section VI of the DCR. The NRC notes that NEI submitted the same comment during the 2003 proposed rule to amend 10 CFR part 52. ~~It is unlikely that the Commission will adopt NEI's proposed language for the other DCRs in the ongoing part 52 rulemaking.~~ However, ^I if the Commission decides to adopt NEI's proposed language for the ~~other DCRs in the ongoing part 52 rulemaking,~~ ^{any potential revision of 10 CFR Part 52} the NRC will also amend the AP1000 DCR accordingly as part of that rulemaking.

Comment Summary. NEI recommends amending Section IX.B.1 of the AP1000 DCR to specify the type of action to be performed by the NRC staff regarding ITAAC.

Response. The NRC disagrees with this request and has decided to maintain the original rule language for this provision because it does not believe that individual DCRs should address the scope of the NRC staff's activities with respect to ITAAC verification. This is a generic matter that, if it is to be addressed in a rulemaking, is more appropriate for inclusion in subpart C of part 52 dealing generally with combined licenses.

The NRC notes that NEI submitted the same comment during the 2003 proposed rule to amend 10 CFR part 52. ~~It is unlikely that the Commission will adopt NEI's proposed language for the other DCRs in the ongoing part 52 rulemaking.~~ However, ^I if the Commission decides to

adopt NEI's proposed language for the other DCRs in the ~~ongoing part 52 rulemaking~~, the NRC will also amend the AP1000 DCR accordingly as part of that rulemaking. *any potential revision to Part 52*

Comment Summary. NEI recommends amending Section IX.B.3 of the AP1000 DCR to clarify the rule language.

Response. The NRC disagrees with this editorial request and has decided to maintain the original rule language for this provision. The NRC notes that NEI submitted the same comment during the 2003 proposed rule to amend 10 CFR part 52. ~~It is unlikely that the Commission will adopt NEI's proposed language for the other DCRs in the ongoing part 52 rulemaking.~~ However, ^I if the Commission decides to adopt NEI's proposed language for the other ~~DCRs in the ongoing part 52 rulemaking~~, *any potential revision to 10 CFR Part 52* the NRC will also amend the AP1000 DCR accordingly as part of that rulemaking.

Comment Summary. NEI recommends amending Sections X.B.1 and X.B.3 of the AP1000 DCR to clarify the rule language regarding DCDs.

Response. The NRC agrees with this comment, Section X.B of the AP1000 DCR has been amended to be consistent with the other DCRs in the proposed part 52 rule. The NRC notes that NEI submitted the same comment during the 2003 proposed rule to amend 10 CFR part 52. The Commission ~~intends to amend existing DCRs to make them consistent with the AP1000 DCR.~~ *may consider -ing the*

III. Section-by-Section Analysis.

✓ The following discussion sets forth the purpose and key aspects of each section and paragraph of the final AP1000 DCR. All section and paragraph references are to the provisions in appendix D to 10 CFR part 52. The final DCR for the AP1000 standard plant design is nearly identical to the AP600 DCR, which the NRC previously codified in 10 CFR part 52, appendix C (Design Certification Rule for the AP600 Design, 64 FR 72015, December 23, 1999). Many of the procedural issues and their resolutions for the AP600 DCR, as well as the initial two design ^{DCRs} ~~certification rules~~ for the ABWR and ABB-CE System 80+, (e.g., the two-tier structure, Tier 2*, the scope of issue resolution) were developed after extensive discussions with public stakeholders, including Westinghouse. Also, Westinghouse requested that policy resolutions for the AP600 design review be applied to the AP1000. Accordingly, the NRC has modeled the AP1000 DCR on the existing DCRs, with certain departures. These departures are necessary to account for differences in the AP1000 design documentation, design features, and environmental assessment (including severe accident mitigation design alternatives (SAMDA)).

A. Introduction.

The purpose of Section I of appendix D to 10 CFR part 52 (this appendix) is to identify the standard plant design that is approved by this DCR and the applicant for certification of the standard design. Identification of the design certification applicant is necessary to implement this appendix, for two reasons. First, the implementation of 10 CFR 52.63(c) depends on whether an applicant for a COL contracts with the design certification applicant to provide the generic DCD and supporting design information. If the COL applicant does not use the design certification applicant to provide this information, then the COL applicant must meet the

appendix. Therefore, this appendix would define both a generic DCD and a plant-specific DCD.

Also, the Commission decided to treat the TS in Section 16.1 of the generic DCD as a special category of information and to designate them as generic TS in order to facilitate the special treatment of this information under this appendix. A COL applicant must submit plant-specific TS that consist of the generic TS, which may be modified under paragraph VIII.C of this appendix, and the remaining plant-specific information needed to complete the TS. The FSAR that is required by § 52.79(b) will consist of the plant-specific DCD, the site-specific portion of the FSAR, and the plant-specific TS.

The terms Tier 1, Tier 2, Tier 2*, and COL action items (license information) are defined in this appendix because these concepts were not envisioned when 10 CFR part 52 was developed. The design certification applicants and the NRC used these terms in implementing the two-tiered rule structure that was proposed by representatives of the nuclear industry after issuance of 10 CFR part 52. Therefore, appropriate definitions for these additional terms are included in this appendix. The nuclear industry representatives requested a two-tiered structure for the DCRs to achieve issue preclusion for a greater amount of information than was originally planned for the DCRs, while retaining flexibility for design implementation. The Commission approved the use of a two-tiered rule structure in its staff requirements memorandum (SRM), dated February 14, 1991, on SECY-90-377, "Requirements for Design Certification Under 10 CFR Part 52," dated November 8, 1990. This document and others are available in the Regulatory History of Design Certification (see Section IV, Availability of Documents). *of this Statement of Consideration (SOC)*

The Tier 1 portion of the design-related information contained in the DCD is certified by this appendix and, therefore, is subject to the special backfit provisions in paragraph VIII.A of this appendix. An applicant who references this appendix is required to incorporate by reference and comply with Tier 1, under paragraphs III.B and IV.A.1 of this appendix. This

information consists of an introduction to Tier 1, the system based and non-system based design descriptions and corresponding ITAAC, significant interface requirements, and significant site parameters for the design. The design descriptions, interface requirements, and site parameters in Tier 1 were derived from Tier 2, but may be more general than the Tier 2 information. The NRC staff's evaluation of the Tier 1 information is provided in Section 14.3 of the FSER. Changes to or departures from the Tier 1 information must comply with Section VIII.A of this appendix.

The Tier 1 design descriptions serve as commitments for the lifetime of a facility referencing the design certification. The ITAAC verifies that the as-built facility conforms with the approved design and applicable regulations. Under 10 CFR 52.103(g), the Commission must find that the acceptance criteria in the ITAAC are met before authorizing operation. After the Commission has made the finding required by 10 CFR 52.103(g), the ITAAC do not constitute regulatory requirements for licensees or for renewal of the COL. However, subsequent modifications to the facility must comply with the design descriptions in the plant-specific DCD unless changes are made under the change process in Section VIII of this appendix. The Tier 1 interface requirements are the most significant of the interface requirements for systems that are wholly or partially outside the scope of the standard design. Tier 1 interface requirements were submitted in response to 10 CFR 52.47(a)(1)(vii) and must be met by the site-specific design features of a facility that references this appendix. An application that references this appendix must demonstrate that the site parameters (both Tier 1 and Tier 2) are met at the proposed site (refer to paragraph III.D of this ~~statement of~~ ~~consideration~~ ~~(SOC)~~). ✓

Tier 2 is the portion of the design-related information contained in the DCD that is approved by this appendix but not certified. Tier 2 information is subject to the backfit

design features. The availability controls may be changed if the associated design feature is changed under paragraph VIII.B of this appendix. For additional discussion, see ~~Section C.~~ ^{paragraph III, C} of this S

Certain Tier 2 information has been designated in the generic DCD with brackets and italicized text as "Tier 2*" information and, as discussed in greater detail in the section-by-section explanation for Section H, a plant-specific departure from Tier 2* information requires prior NRC approval. However, the Tier 2* designation expires for some of this information when the facility first achieves full power after the finding required by 10 CFR 52.103(g). The process for changing Tier 2* information and the time at which its status as Tier 2* expires is set forth in paragraph VIII.B.6 of this appendix. Some Tier 2* requirements concerning special pre-operational tests are designated to be performed only for the first plant or first three plants referencing the AP1000 DCR. The Tier 2* designation for these selected tests will expire after the first plant or first three plants complete the specified tests. However, a COL action item requires that subsequent plants also perform the tests or justify that the results of the first-plant-only or first-three-plants-only tests are applicable to the subsequent plant.

In an earlier rulemaking (64 FR 53582; October 4, 1999), the Commission revised 10 CFR 50.59 to incorporate new thresholds for permitting changes to a plant as described in the FSAR without NRC approval. For consistency and clarity, the Commission proposes to use these new thresholds in the proposed AP1000 DCR. Inasmuch as § 50.59 is the primary change mechanism for operating nuclear plants, the Commission believes that future plants referencing the AP1000 DCR should utilize thresholds as close to § 50.59 as is practicable and appropriate. Because of some differences in how the change control requirements are structured in the DCRs, certain definitions contained in § 50.59 are not applicable to 10 CFR part 52 and are not being included in this rule. One definition that the Commission is including is the definition from the new § 50.59 for a "departure from a method of evaluation,"

✓ (paragraph II.G) ^{of this SOC}, which is appropriate to include in this rulemaking so that the eight criteria in paragraph VIII.B.5.b of the final rule will be implemented as intended.

C. Scope and Contents.

✓ The purpose of Section III of this ~~DCR~~ ^{appendix} is to describe and define the scope and contents of this design certification and to set forth how documentation discrepancies or inconsistencies are to be resolved. Paragraph A is the required statement of the Office of the *Federal Register* (OFR) for approval of the incorporation by reference of Tier 1, Tier 2, and the generic TS into this appendix. Paragraph B requires COL applicants and licensees to comply with the requirements of this appendix. The legal effect of incorporation by reference is that the incorporated material has the same legal status as if it were published in the *Code of Federal Regulations*. This material, like any other properly-issued regulation, has the force and effect of law. Tier 1 and Tier 2 information, as well as the generic TS, have been combined into a single document called the generic DCD, in order to effectively control this information and facilitate its incorporation by reference into the rule. The generic DCD was prepared to meet the requirements of the OFR for incorporation by reference ¹⁰ (CFR part 51). One of the requirements of the OFR for incorporation by reference is that the design certification applicant must make the generic DCD available upon request after the final rule becomes effective. Therefore, paragraph III.A of this appendix identifies a Westinghouse representative to be contacted in order to obtain a copy of the generic DCD.

✓ Paragraphs A and B also identify the investment protection short-term availability controls in Section 16.3 of the generic DCD as part of the Tier 2 information. During its review of the AP1000 design, the NRC determined that residual uncertainties associated with passive

safety system performance increased the importance of non-safety-related active systems in providing defense-in-depth functions that back-up the passive systems. As a result, Westinghouse developed administrative controls to provide a high level of confidence that active systems having a significant safety role are available when challenged. Westinghouse named these additional controls "investment protection short-term availability controls." The Commission included this characterization in Section III ^{of this appendix} to ensure that these availability controls are binding on applicants and licensees that reference this appendix and will be enforceable by the NRC. The NRC's evaluation of the availability controls is provided in Chapter 22 of the FSER.

The generic DCD (master copy) for this design certification will be electronically accessible in NRC's Agencywide Documents Access and Management System (ADAMS) and at the OFR. Copies of the generic DCD will also be available at the NRC's Public Document Room (PDR). Questions concerning the accuracy of information in an application that references this appendix will be resolved by checking the master copy of the generic DCD in ADAMS. If a generic change (rulemaking) is made to the DCD by the change process provided in Section VIII of this appendix, then at the completion of the rulemaking the NRC would request approval of the Director, OFR, for the changed incorporation by reference and change its copies of the generic DCD and notify the OFR and the design certification applicant to change their copies. The Commission is requiring that the design certification applicant maintain an up-to-date copy under paragraph X.A.1 of this appendix because it is likely that most applicants intending to reference the standard design will obtain the generic DCD from the design certification applicant. Plant-specific changes to and departures from the generic DCD will be maintained by the applicant or licensee that references this appendix in a plant-specific DCD under paragraph X.A.2 of this appendix.

In addition to requiring compliance with this appendix, paragraph B clarifies that the conceptual design information and Westinghouse's evaluation of SAMDAs are not considered to be part of this appendix. The conceptual design information is for those portions of the plant that are outside the scope of the standard design and are contained in Tier 2 information. As provided by 10 CFR 52.47(a)(1)(ix), these conceptual designs are not part of this appendix and, therefore, are not applicable to an application that references this appendix. Therefore, the applicant is not required to conform with the conceptual design information that was provided by the design certification applicant. The conceptual design information, which consists of site-specific design features, was required to facilitate the design certification review. Conceptual design information is neither Tier 1 nor Tier 2. Section 1.8 of Tier 2 identifies the location of the conceptual design information. Westinghouse's evaluation of various design alternatives to prevent and mitigate severe accidents does not constitute design requirements. The Commission's assessment of this information is discussed in Section VII of this ~~Statement of Consideration (SOC)~~ on environmental impacts.

Paragraphs C and D set forth the way potential conflicts are to be resolved.

Paragraph C establishes the Tier 1 description in the DCD as controlling in the event of an inconsistency between the Tier 1 and Tier 2 information in the DCD. Paragraph D establishes the generic DCD as the controlling document in the event of an inconsistency between the DCD and the FSER for the certified standard design.

Paragraph E makes it clear that design activities that are wholly outside the scope of this design certification may be performed using site-specific design parameters, provided the design activities do not affect Tier 1 or Tier 2, or conflict with the interface requirements in the DCD. This provision applies to site-specific portions of the plant, such as the administration

building. Because this statement is not a definition, this provision has been located in Section III of this appendix.

D. Additional Requirements and Restrictions.

Section IV of this appendix sets forth additional requirements and restrictions imposed upon an applicant who references this appendix. Paragraph IV.A sets forth the information requirements for these applicants. This ~~appendix~~^{paragraph} distinguishes between information and/or documents which must actually be included in the application or the DCD, versus those which may be *incorporated by reference* (i.e., referenced in the application as if the information or documents were included in the application). Any incorporation by reference in the application should be clear and should specify the title, date, edition, or version of a document, the page number(s), and table(s) containing the relevant information to be incorporated. ✓

Paragraph A.1 requires an applicant who references this appendix to incorporate by reference this appendix in its application. The legal effect of such an incorporation by reference is that this appendix is legally binding on the applicant or licensee. Paragraph A.2.a requires that a plant-specific DCD be included in the initial application. This ensures that the applicant commits to complying with the DCD. This paragraph also requires that the plant-specific DCD uses the same format as the generic DCD and reflects the applicant's proposed departures and exemptions from the generic DCD as of the time of submission of the application. The Commission expects that the plant-specific DCD will become the plant's FSAR, by including information, i.e., site-specific information, for the portions of the plant outside the scope of the referenced design, including related ITAAC, and other matters required to be included in an FSAR by 10 CFR 50.34 and 52.79. Integration of the plant-specific DCD and remaining

systems. The NRC staff has determined that the function of a separate SPDS may be integrated into the overall control room design. Therefore, the Commission has determined that the special circumstances for allowing an exemption as described in 10 CFR 50.12(a)(2)(ii) exist because the requirement for an SPDS console need not be applied in this particular circumstance to achieve the underlying purpose because Westinghouse has provided an acceptable alternative that accomplishes the intent of the regulation. On this basis, the Commission concludes that an exemption from the requirements of 10 CFR 50.34(f)(2)(iv) is authorized by law, will not present an undue risk to public health and safety, and is consistent with the common defense and security.

(2) Paragraph (c)(1) of 10 CFR 50.62 - Auxiliary Feedwater System.

The AP1000 design relies on the passive residual heat removal system (PRHR) in lieu of an auxiliary or emergency feedwater system as its safety-related method of removing decay heat. Westinghouse requested an exemption from a portion of 10 CFR 50.62(c)(1), which requires auxiliary or emergency feedwater as an alternate system for decay heat removal during an anticipated transient without scram (ATWS) event. The NRC staff concluded that Westinghouse met the intent of the rule by relying on the PRHR system to remove the decay heat and, thereby, met the underlying purpose of the rule. Therefore, the Commission has determined that the special circumstances for allowing an exemption described in 10 CFR 50.12(a)(2)(ii) exist because the requirement for an auxiliary or emergency feedwater system is not necessary to achieve the underlying purpose of 10 CFR 50.62(c)(1). This is because Westinghouse has adopted acceptable alternatives that accomplish the intent of this regulation, and the exemption is authorized by law, will not present an undue risk to public health and safety, and is consistent with the common defense and security.

(3) Appendix A to 10 CFR part 50, GDC 17 - ~~Offsite Power Sources.~~

Second Offsite Power Supply Circuit

italicize

✓ situations, use the phrase "but only for that plant" (emphasis added). Paragraph B.4 describes how issues associated with a design certification rule are resolved when an exemption has been granted for a plant referencing the design certification rule. Paragraph B.5 describes how issues are resolved when a plant referencing the design certification rule obtains a license amendment for a departure from Tier 2 information.

✓ Paragraph B.6 describes how issues are resolved when the applicant or licensee departs from the Tier 2 information on the basis of paragraph VIII.B.5, which will waive the requirement for NRC approval. In all three situations, after a matter (e.g., an exemption in the case of paragraph B.4) is addressed for a specific plant referencing a design certification rule, the adequacy of that matter *for that plant* will not ordinarily be subject to challenge in any subsequent proceeding or action for that plant (~~such as~~ ^{e.g.} an enforcement action) listed in the introductory portion of paragraph IV.B. There will not, by contrast, be any issue resolution on that subject matter for any other plant.

✓ Paragraph B.7 provides that, for those plants located on sites whose site parameters do not exceed those assumed in Westinghouse's evaluation of SAMDAs, all issues with respect to SAMDAs arising under the National Environmental Policy Act of 1969, ^{as amended (NEPA)} associated with the information in the environmental assessment for this design and the information regarding SAMDAs in Appendix 1B of the generic DCD are also resolved within the meaning and intent of § 52.63(a)(4). If an exemption from a site parameter is granted, the exemption applicant has the initial burden of demonstrating that the original SAMDA analysis still applies to the actual site parameters but; if the exemption is approved, requests for litigation at the COL stage must meet the requirements of § 2.309 and present sufficient information to create a genuine controversy in order to obtain a hearing on the site parameter exemption.

Paragraph C reserves the right of the Commission to impose operational requirements on applicants that reference this appendix. This provision reflects the fact that operational requirements, including generic TS in Section 16.1 of the DCD, were not completely or comprehensively reviewed at the design certification stage. Therefore, the special backfit provisions of § 52.63 do not apply to operational requirements. However, all design changes will be controlled by the appropriate provision in Section VIII of this appendix. Although the information in the DCD that is related to operational requirements is necessary to support the NRC's safety review of this design, the review of this information was not sufficient to conclude that the operational requirements are fully resolved and ready to be assigned finality under § 52.63. As a result, if the NRC wanted to change a temperature limit and that operational change required a consequential change to a design feature, then the temperature limit backfit would be controlled by Section VIII (paragraph A or B) of this appendix. However, changes to other operational issues, such as inservice testing and inservice inspection programs, post-fuel load verification activities, and shutdown risk that do not require a design change would not be restricted by § 52.63 (see VIII.C of this appendix).

Paragraph C allows the NRC to impose future operational requirements (distinct from *design matters*) on applicants who reference this design certification. Also, license conditions for portions of the plant within the scope of this design certification, e.g., start-up and power ascension testing, are not restricted by § 52.63. The requirement to perform these testing programs is contained in Tier 1 information. However, ITAAC cannot be specified for these subjects because the matters to be addressed in these license conditions cannot be verified prior to fuel load and operation, when the ITAAC are satisfied. Therefore, another regulatory vehicle is necessary to ensure that licensees comply with the matters contained in the license conditions. License conditions for these areas cannot be developed now because this requires

the type of detailed design information that will be developed during a combined license review. In the absence of detailed design information to evaluate the need for and develop specific post-fuel load verifications for these matters, the Commission is reserving the right to impose license conditions by rule for post-fuel load verification activities for portions of the plant within the scope of this design certification.

Paragraph D reiterates the restrictions (contained in Section VIII of this appendix) placed upon the Commission when ordering generic or plant-specific modifications, changes or additions to structures, systems, or components, design features, design criteria, and ITAAC (VI.D.3 would address ITAAC) within the scope of the certified design.

✓ Paragraph E provides the procedure for an interested member of the public to obtain access to proprietary or safeguards information for the AP1000 design, in order to request and participate in proceedings identified in paragraph VI.B of this appendix, viz., proceedings involving licenses and applications which reference this appendix. Paragraph E, specifies that access must first be sought from the design certification applicant. If Westinghouse refuses to provide the information, the person seeking access shall request access from the Commission or the presiding officer, as applicable. Access to the proprietary or safeguards information may be ordered by the Commission, but must be subject to an appropriate non-disclosure agreement.

G. Duration of this Appendix.

The purpose of Section VII of this appendix is in part, to specify the period during which this design certification may be referenced by an applicant for a COL, under 10 CFR 52.55. This section also states that the design certification remains valid for an applicant or licensee

that references the design certification until the application is withdrawn or the license expires. Therefore, if an application references this design certification during the 15-year period, then the design certification will be effective until the application is withdrawn or the license issued on that application expires. Also, the design certification will be effective for the referencing licensee if the license is renewed. The Commission intends for this appendix to remain valid for the life of the plant that references the design certification to achieve the benefits of standardization and licensing stability. This means that changes to, or plant-specific departures from, information in the plant-specific DCD must be made under the change processes in Section VIII of this appendix for the life of the plant.

H. Processes for Changes and Departures.

The purpose of Section VIII of this appendix is to set forth the processes for generic changes to or plant-specific departures (including exemptions) from the DCD. The Commission adopted this restrictive change process in order to achieve a more stable licensing process for applicants and licensees that reference this ^{DCR} design certification rule. Section VIII is divided into three paragraphs, which correspond to Tier 1, Tier 2, and operational requirements. The language of Section VIII ^{of this appendix} distinguishes between generic *changes to* the DCD versus plant-specific *departures from* the DCD. Generic *changes* must be accomplished by rulemaking because the intended subject of the change is the ^{DCR} design certification rule itself, as is contemplated by 10 CFR 52.63(a)(1). Consistent with 10 CFR 52.63(a)(2), any generic rulemaking changes are applicable to all plants, absent circumstances which render the change ["modification" in the language of § 52.63(a)(2)] "technically irrelevant." By contrast, plant-specific *departures* could be either a Commission-issued order to one or more applicants or

licensees; or an applicant or licensee-initiated departure applicable only to that applicant's or licensee's plant(s), similar to a § 50.59 departure or an exemption. Because these plant-specific departures will result in a DCD that is unique for that plant, Section X of this appendix requires an applicant or licensee to maintain a plant-specific DCD. For purposes of brevity, this discussion refers to both generic changes and plant-specific departures as "change processes."

✓ Section ^S VIII of this ~~appendix~~ ^{appendix} and Section XI of this ~~SEC~~ refer to an ~~exemption~~ from one or more requirements of this appendix and the criteria for granting an exemption. The Commission cautions that when the exemption involves an underlying substantive requirement (applicable regulation), then the applicant or licensee requesting the exemption must also show that an exemption from the underlying applicable requirement meets the criteria of 10 CFR 50.12.

Tier 1 information

The change processes for Tier 1 information are covered in paragraph VIII.A. Generic changes to Tier 1 are accomplished by rulemakings that amend the generic DCD and are governed by the standards in 10 CFR 52.63(a)(1). This provision provides that the Commission may not modify, change, rescind, or impose new requirements by rulemaking except when necessary either to bring the certification into compliance with the Commission's regulations applicable and in effect at the time of approval of the design certification or to ensure adequate protection of the public health and safety or common defense and security. The rulemakings must provide for notice and opportunity for public comment on the proposed change, as required by 10 CFR 52.63(a)(1). Departures from Tier 1 may occur in two ways: (1) the Commission may *order* a licensee to depart from Tier 1, as provided in paragraph A.3; or (2) an

applicant or licensee may request an *exemption* from Tier 1, as provided in paragraph A.4. If the Commission seeks to order a licensee to depart from Tier 1, paragraph A.3 requires that the Commission find both that the departure is necessary for adequate protection or for compliance, and that special circumstances are present. Paragraph A.4 provides that exemptions from Tier 1 requested by an applicant or licensee are governed by the requirements of 10 CFR 52.63(b)(1) and 52.97(b), which provide an opportunity for a hearing. In addition, the Commission will not grant requests for exemptions that may result in a significant decrease in the level of safety otherwise provided by the design.

Tier 2 information

The change processes for the three different categories of Tier 2 information, namely, Tier 2, Tier 2*, and Tier 2* with a time of expiration, are set forth in paragraph VIII.B. The change process for Tier 2 has the same elements as the Tier 1 change process, but some of the standards for plant-specific orders and exemptions are different. As stated in Section III, of this ~~preamble~~^{SOC}, it is the Commission's intent that this appendix emulates ~~appendix C~~^A to 10 CFR part 52. However, the Commission has revised the § 50.59-like change process in paragraph VIII.B.5 of this appendix to be commensurate with the new 10 CFR 50.59 (64 FR 53613, October 4, 1999). ✓

The process for generic Tier 2 changes (including changes to Tier 2* and Tier 2* with a time of expiration) tracks the process for generic Tier 1 changes. As set forth in paragraph B.1, generic Tier 2 changes are accomplished by rulemaking amending the generic DCD and are governed by the standards in 10 CFR 52.63(a)(1). This provision provides that the Commission may not modify, change, rescind, or impose new requirements by rulemaking except when necessary, either to bring the certification into compliance with the Commission's regulations ✓

applicable and in effect at the time of approval of the design certification or to ensure adequate protection of the public health and safety or common defense and security. If a generic change is made to Tier 2* information, then the category and expiration, if necessary, of the new information would also be determined in the rulemaking and the appropriate change process for that new information would apply.

Departures from Tier 2 may occur in five ways: (1) the Commission may order a plant-specific departure, as set forth in paragraph B.3; (2) an applicant or licensee may request an exemption from a Tier 2 requirement as set forth in paragraph B.4; (3) a licensee may make a departure without prior NRC approval under paragraph B.5 [the "§ 50.59-like" process]; (4) the licensee may request NRC approval for proposed departures which do not meet the requirements in paragraph B.5 as provided in paragraph B.5.d; and (5) the licensee may request NRC approval for a departure from Tier 2* information under paragraph B.6. *Similar to the process in 10 CFR 50.5*

Similar to Commission-ordered Tier 1 departures and generic Tier 2 changes, Commission-ordered Tier 2 departures cannot be imposed except when necessary either to bring the certification into compliance with the Commission's regulations applicable and in effect at the time of approval of the design certification or to ensure adequate protection of the public health and safety or common defense and security, as set forth in paragraph B.3. However, the special circumstances for the Commission-ordered Tier 2 departures do not have to outweigh any decrease in safety that may result from the reduction in standardization caused by the plant-specific order, as required by 10 CFR 52.63(a)(3). The Commission determined that it was not necessary to impose an additional limitation similar to that imposed on Tier 1 departures by 10 CFR 52.63(a)(3) and (b)(1). This type of additional limitation for standardization would unnecessarily restrict the flexibility of applicants and licensees with respect to Tier 2 information.

✓ operating experience during its licensing review of the plant-specific TS. The process for
petitioning to intervene on a TS or operational requirement is similar to other issues in a
licensing hearing, except that the petitioner must also demonstrate why special circumstances
are present ~~(paragraph VIII.C.5)~~ *(contained in paragraph VIII.C.5)*.

Finally, the generic TS will have no further effect on the plant-specific TS after the issuance of a license that references this appendix. The bases for the generic TS will be controlled by the change process in paragraph VIII.C of this appendix. After a license is issued, the bases will be controlled by the bases change provision set forth in the administrative controls section of the plant-specific TS.

I. Inspections, Tests, Analyses, and Acceptance Criteria (ITAAC).

The purpose of Section IX of this appendix is to set forth how the ITAAC in Tier 1 of this design certification rule are to be treated in a license proceeding. Paragraph A restates the responsibilities of an applicant or licensee for performing and successfully completing ITAAC, and notifying the NRC of such completion. Paragraph A.1 clarifies that an applicant may proceed at its own risk with design and procurement activities subject to ITAAC, and that a licensee may proceed at its own risk with design, procurement, construction, and preoperational testing activities subject to an ITAAC, even though the NRC may not have found that any particular ITAAC has been successfully completed. Paragraph A.2 requires the licensee to notify the NRC that the required inspections, tests, and analyses in the ITAAC have been completed and that the acceptance criteria have been met.

Paragraph B.3.b also requires that the reports required by paragraph X.B.1 be submitted semi-annually. This increase in reporting frequency during the period of construction and application review is consistent with Commission guidance. Also, more frequent reporting of design changes during the period of detailed design and construction is necessary to closely monitor the status and progress of the facility. In order to make the finding under 10 CFR 52.103(g), the NRC must monitor the design changes made under proposed Section VIII of this appendix. Frequent reporting of design changes would be particularly important when the number of design changes could be significant, such as during the procurement of components and equipment, detailed design of the plant before and during construction, and during preoperational testing. After the facility begins operation, the frequency of reporting will revert to the requirement in paragraph B.3.c, which is consistent with the requirements for plants licensed under 10 CFR 50.57.

IV. Availability of Documents.

The NRC is making the documents identified below available to interested persons through one or more of the following:

✓ Public Document Room (PDR). The NRC's Public Document Room is located at 11555 Rockville Pike, Public File Area O-1 F21, Rockville, Maryland ²⁰⁸⁵²~~20852~~. Copies of publicly available documents related to this rulemaking can be viewed electronically on public computers in the PDR. The PDR reproduction contractor will make copies of documents for a fee.

The National Technology Transfer and Advancement Act of 1995 (Act), Public Law 104-113, requires that Federal agencies use technical standards that are developed or adopted by voluntary consensus standards bodies unless using such a standard is inconsistent with applicable law or is otherwise impractical. In this final rule, the NRC is approving the AP1000 standard plant design for use in nuclear power plant licensing under 10 CFR parts 50 or 52. Design certifications are not generic rulemakings establishing a generally applicable standard with which all parts 50 and 52 nuclear power plant licensees must comply. Design certifications are Commission approvals of specific nuclear power plant designs by rulemaking. Furthermore, design certifications are initiated by an applicant for rulemaking, rather than by the NRC. For these reasons, the NRC concludes that the Act does not apply to this final rule.

VII. Finding of No Significant Environmental Impact: Availability.

✓ The Commission has determined under the ~~National Environmental Policy Act of 1969,~~
~~as amended (NEPA),~~ and the Commission's regulations in 10 CFR part 51, ^S subpart A, that this
design certification rule is not a major Federal action significantly affecting the quality of the
human environment and, therefore, an environmental impact statement (EIS) is not required.
✓ The basis for this determination, as documented in the environmental assessment, is that this
^(EA)
amendment to 10 CFR part 52 does not authorize the siting, construction, or operation of a
facility using the AP1000 design; it only codifies the AP1000 design in a rule. The NRC will
evaluate the environmental impacts and issue an EIS as appropriate under NEPA as part of the
application(s) for the construction and operation of a facility referencing the AP1000 design
certification rule.

In addition, as part of the environmental assessment for the AP1000 design, the NRC reviewed Westinghouse's evaluation of various design alternatives to prevent and mitigate severe accidents in ^A appendix 1B of the AP1000 DCD Tier 2. Based upon review of Westinghouse's evaluation, the Commission finds that: (1) Westinghouse identified a reasonably complete set of potential design alternatives to prevent and mitigate severe accidents for the AP1000 design; (2) none of the potential design alternatives are justified on the basis of cost-benefit considerations; and (3) it is unlikely that other design changes would be identified and justified in the future on the basis of cost-benefit considerations, because the estimated core damage frequencies for the AP1000 are very low on an absolute scale. These issues are considered resolved for the AP1000 design. ✓

The ~~environmental assessment (EA)~~, upon which the Commission's finding of no significant impact is based, and the AP1000 DCD are available for examination and copying at the NRC Public Document Room, One White Flint North, 11555 Rockville Pike, Rockville, Maryland, ^{20852.} The NRC sent a copy of the EA and proposed rule to every State Liaison Officer and no comments were received. Single copies of the EA are also available from Lauren M. Quinones-Navarro, Mailstop O-4D9A, Office of Nuclear Reactor Regulation, U.S. Nuclear Regulatory Commission, Washington, D.C. 20555. ✓

VIII. Paperwork Reduction Act Statement.

This final rule contains new or amended information collection requirements that are subject to the Paperwork Reduction Act of 1995 (44 U.S.C. 3501 et seq.). These requirements were approved by the Office of Management and Budget, approval number 3150-0151. ✓

the design certification applicant, nor prospective nuclear power plant licensees who reference this design certification rule, fall within the scope of the definition of "small entities" set forth in the Regulatory Flexibility Act, or the Small Business Size Standards set out in regulations issued by the Small Business Administration in 13 CFR part 121. Thus, this rule does not fall within the purview of the Act.

✓
^
Regulatory Flexibility

XI. Backfit Analysis.

The Commission has determined that this final rule does not constitute a backfit as defined in the backfit rule (10 CFR 50.109), because this design certification does not impose new or changed requirements on existing 10 CFR part 50 licensees, nor does it impose new or change requirements on existing DCRs in appendices A-C of part 52. Therefore, a backfit analysis was not prepared for this rule.

XII. Congressional Review Act.

In accordance with the Congressional Review Act of 1996, the NRC has determined that this action is not a major rule and has verified this determination with the Office of Information and Regulatory Affairs of OMB.

List of Subjects in 10 CFR Part 52

Administrative practice and procedure, Antitrust, Backfitting, Combined license, Early site permit, Emergency planning, Fees, Incorporation by reference, Inspection, Limited work authorization, Nuclear power plants and reactors, Probabilistic risk assessment,

I. Introduction

Appendix D constitutes the standard design certification for the AP1000³ design, in accordance with 10 CFR part 52, ~~Subpart~~^S B. The applicant for certification of the AP1000 design is Westinghouse Electric Company LLC.

II. Definitions

A. *Generic design control document* (~~generic~~ DCD) means the document containing the Tier 1 and Tier 2 information and generic technical specifications that is incorporated by reference into this appendix.

B. *Generic technical specifications* means the information required by 10 CFR 50.36 and 50.36a for the portion of the plant that is within the scope of this appendix.

C. *Plant-specific DCD* means the document maintained by an applicant or licensee who references this appendix consisting of the information in the generic DCD as modified and supplemented by the plant-specific departures and exemptions made under Section VIII of this appendix.

D. *Tier 1* means the portion of the design-related information contained in the generic DCD that is approved and certified by this appendix (Tier 1 information). The design descriptions, interface requirements, and site parameters are derived from Tier 2 information.

Tier 1 information includes:

1. Definitions and general provisions;
2. Design descriptions;

³AP1000 is a trademark of Westinghouse Electric Company LLC.

F. *Tier 2** means the portion of the Tier 2 information, designated as such in the generic DCD, which is subject to the change process in paragraph VIII.B.6 of this appendix. This designation expires for some Tier 2* information under paragraph VIII.B.6.

G. *Departure from a method of evaluation described in the plant-specific DCD used in establishing the design bases or in the safety analyses* means:

1. Changing any of the elements of the method described in the plant-specific DCD unless the results of the analysis are conservative or essentially the same; or
2. Changing from a method described in the plant-specific DCD to another method unless that method has been approved by the NRC for the intended application.

H. All other terms in this appendix have the meaning set out in 10 CFR 50.2, 10 CFR 52.3, or Section 11 of the Atomic Energy Act of 1954, as amended, as applicable.

III. *Scope and Contents*

A. Tier 1, Tier 2 (including the investment protection short-term availability controls in Section 16.3), and the generic TS in the AP1000 DCD (Revision 15) are approved for incorporation by reference by the Director of the Office of the *Federal Register* on [date of approval] under 5 U.S.C. 552(a) and ✓¹⁰ CFR part 51. Copies of the generic DCD may be obtained from Ronald P. Vijuk, Manager, Passive Plant Engineering, Westinghouse Electric Company, P.O. Box 355, Pittsburgh, Pennsylvania 15230-0355. A copy of the generic DCD is also available for examination and copying at the NRC Public Document Room, One White Flint ✓ North, 11555 Rockville Pike, Rockville, Maryland, ²⁰⁸⁵² Copies are available for examination at the NRC Library, Two White Flint North, 11545 Rockville Pike, Rockville, Maryland, telephone (301) 415-5610, e-mail LIBRARY@NRC.GOV or at the National Archives and Records

Administration (NARA). For information on the availability of this material at NARA, call (202) 741-6030 or go to

http://www.archives.gov/federal_register/code_of_federal_regulations/ibr_locations.html.

B. An applicant or licensee referencing this appendix, in accordance with Section IV of this appendix, shall incorporate by reference and comply with the requirements of this appendix, including Tier 1, Tier 2 (including the investment protection short-term availability controls in Section 16.3 of the DCD), and the generic TS except as otherwise provided in this appendix. Conceptual design information in the generic DCD and the evaluation of SAMDAs in Appendix 1B of the generic DCD are not part of this appendix. ✓

C. If there is a conflict between Tier 1 and Tier 2 of the DCD, then Tier 1 controls.

D. If there is a conflict between the generic DCD and either the application for design certification of the AP1000 design or NUREG-1793, "Final Safety Evaluation Report Related to Certification of the AP1000 Standard Design," (FSER), then the generic DCD controls.

E. Design activities for structures, systems, and components that are wholly outside the scope of this appendix may be performed using site characteristics, provided the design activities do not affect the DCD or conflict with the interface requirements.

IV. Additional Requirements and Restrictions

A. An applicant for a license that wishes to reference this appendix shall, in addition to complying with the requirements of 10 CFR 52.77, 52.78, and 52.79, comply with the following requirements:

1. Incorporate by reference, as part of its application, this appendix.
2. Include, as part of its application:

extra
space

- ✓
- a. A plant-specific DCD containing the same type of information and using the same organization and numbering as the generic DCD for the AP1000 design, as modified and supplemented by the applicant's exemptions and departures;
 - b. The reports on departures from and updates to the plant-specific DCD required by paragraph X.B of this appendix;
 - c. Plant-specific TS, consisting of the generic and site-specific TS that are required by 10 CFR 50.36 and 50.36a;
 - d. Information demonstrating compliance with the site parameters and interface requirements;
 - e. Information that addresses the COL action items; and
 - f. Information required by 10 CFR 52.47(a) that is not within the scope of this appendix.
3. Physically include, in the plant-specific DCD, the proprietary and safeguards information referenced in the AP1000 DCD.
- B. The Commission reserves the right to determine in what manner this appendix may be referenced by an applicant for a construction permit or operating license under Part 50.

V. Applicable Regulations

A. Except as indicated in paragraph B of this section, the regulations that apply to the AP1000 design are in 10 CFR parts 20, 50, 73, and 100, codified as of [date final rule signed], that are applicable and technically relevant, as described in the FSER (NUREG-1793) and Supplement No. 1.

B. The AP1000 design is exempt from portions of the following regulations:

- ✓
- 1. Paragraph (f)(2)(iv) of 10 CFR 50.34 - Plant Safety Parameter Display Console;

(lowercase)

2. Paragraph (c)(1) of 10 CFR 50.62 - Auxiliary (or emergency) feedwater system; and
3. Appendix A to 10 CFR Part 50, GDC 17 - Offsite ^Power _Sources. ✓

VI. Issue Resolution (lowercase)

A. The Commission has determined that the structures, systems, components, and design features of the AP1000 design comply with the provisions of the Atomic Energy Act of 1954, as amended, and the applicable regulations identified in Section V of this appendix; and therefore, provide adequate protection to the health and safety of the public. A conclusion that a matter is resolved includes the finding that additional or alternative structures, systems, components, design features, design criteria, testing, analyses, acceptance criteria, or justifications are not necessary for the AP1000 design.

B. The Commission considers the following matters resolved within the meaning of 10 CFR 52.63(a)(4) in subsequent proceedings for issuance of a COL, amendment of a COL, or renewal of a COL, proceedings held under to 10 CFR 52.103, and enforcement proceedings involving plants referencing this appendix:

1. All nuclear safety issues, except for the generic TS and other operational requirements, associated with the information in the FSER, Tier 1, Tier 2 (including referenced information, which the context indicates is intended as requirements, and the investment protection short-term availability controls in Section 16.3 of the DCD), and the rulemaking record for certification of the AP1000 design;

2. All nuclear safety and safeguards issues associated with the information in proprietary and safeguards documents, referenced and in context, are intended as requirements in the generic DCD for the AP1000 design;

3. All generic changes to the DCD under and in compliance with the change processes in Sections VIII.A.1 and VIII.B.1 of this appendix;

4. All exemptions from the DCD under and in compliance with the change processes in Sections VIII.A.4 and VIII.B.4 of this appendix, but only for that plant;

5. All departures from the DCD that are approved by license amendment, but only for that plant;

6. Except as provided in paragraph VIII.B.5.f of this appendix, all departures from Tier 2 under and in compliance with the change processes in paragraph VIII.B.5 of this appendix that do not require prior NRC approval, but only for that plant;

✓ 7. All environmental issues concerning SAMDAs associated with the information in the NRC's EA for the AP1000 design and ^A appendix 1B of the generic DCD, for plants referencing this appendix whose site parameters are within those specified in the SAMDA evaluation.

C. The Commission does not consider operational requirements for an applicant or licensee who references this appendix to be matters resolved within the meaning of 10 CFR 52.63(a)(4). The Commission reserves the right to require operational requirements for an applicant or licensee who references this appendix by rule, regulation, order, or license condition.

D. Except under the change processes in Section VIII of this appendix, the Commission may not require an applicant or licensee who references this appendix to:

1. Modify structures, systems, components, or design features as described in the generic DCD;

2. Provide additional or alternative structures, systems, components, or design features not discussed in the generic DCD; or

change to a design feature in the generic DCD are governed by the requirements in 10 CFR 50.109. Generic changes that require a change to a design feature in the generic DCD are governed by the requirements in paragraphs A or B of this section.

2. Generic changes to generic TS and other operational requirements are applicable to all applicants who reference this appendix, except those for which the change has been rendered technically irrelevant by action taken under paragraphs C.3 or C.4 of this section.

3. The Commission may require plant-specific departures on generic TS and other operational requirements that were completely reviewed and approved, provided a change to a design feature in the generic DCD is not required and special circumstances as defined in 10 CFR 2.335 are present. The Commission may modify or supplement generic TS and other operational requirements that were not completely reviewed and approved or require additional TS and other operational requirements on a plant-specific basis, provided a change to a design feature in the generic DCD is not required.

4. An applicant who references this appendix may request an exemption from the generic TS or other operational requirements. The Commission may grant such a request only if it determines that the exemption will comply with the requirements of 10 CFR 50.12(a). The grant of an exemption must be subject to litigation in the same manner as other issues material to the license hearing.

✓ 5. A party to an adjudicatory proceeding for either the issuance, amendment, or renewal of a license, or for operation under 10 CFR 52.103(a), who believes that an operational requirement approved in the DCD or a TS derived from the generic TS must be changed may petition to admit such a contention into the proceeding. The petition must comply with the general requirements of 10 CFR 2.309 and must demonstrate why special circumstances as defined in 10 CFR 2.335 are present, or demonstrate compliance with the Commission's

UNITED STATES NUCLEAR REGULATORY COMMISSION
ENVIRONMENTAL ASSESSMENT AND FINDING OF
NO SIGNIFICANT IMPACT
RELATING TO THE CERTIFICATION OF THE
AP1000 STANDARD PLANT DESIGN
DOCKET NO. 52-006

The U.S. Nuclear Regulatory Commission (NRC) has issued a design certification for the Advanced Passive 1000 (AP1000) design in response to an application submitted on March 28, 2002, by Westinghouse Electric Company, LLC (hereinafter referred to as Westinghouse). A design certification is a rulemaking; the Commission has decided to adopt design certification rules as appendices to Part 52 of Title 10 of the *Code of Federal Regulations* (10 CFR Part 52).

The NRC has performed an environmental assessment (EA) of the environmental impacts of the proposed new rule and has documented its findings of no significant impact in accordance with the requirements of 10 CFR 51.21 and the National Environmental Policy Act of 1969 (NEPA), as amended. This EA also addresses the severe accident mitigation design alternatives (SAMDAs), that the NRC has considered as part of this EA for the AP1000 design. This EA does not address the site-specific environmental impacts of constructing and operating a facility, which references the AP1000 design certification at a particular site; such impacts will be evaluated as part of any application or applications for the siting, construction, or operation of a facility.

As discussed in detail in Section 4.0 of this EA, the NRC determined that issuing this design certification does not constitute a major Federal action significantly affecting the quality

2.0 THE NEED FOR THE PROPOSED ACTION

The NRC has long sought the safety benefits of commercial nuclear power plant standardization and early final resolution of design issues. The NRC plans to achieve these benefits by certifying nuclear plant designs. Subpart B to 10 CFR Part 52 allows for certification in the form of rulemaking of an essentially complete nuclear plant design.

The proposed action would amend 10 CFR Part 52 to certify the AP1000 design. The amendment would allow prospective licensees to reference the certified AP1000 design as part of a COL application under 10 CFR Part 52 or may allow for a CP application under 10 CFR Part 50. Those portions of the AP1000 design included in the scope of the certification rulemaking would not be subject to further safety review or approval in a COL proceeding. In addition, the design certification rule would eliminate the need to consider SAMDAs for any future facilities that reference the certified AP1000 design.

3.0 THE ENVIRONMENTAL IMPACT OF THE PROPOSED ACTION

Issuing an amendment to 10 CFR Part 52 to certify the AP1000 standard plant design would not constitute a significant environmental impact. The amendment would merely codify the NRC's approval of the AP1000 design (refer to NUREG-1793). Furthermore, because the amendment is a rule, it involves no resources that have alternative uses. *AP1000 Design Improvements as Result of Probabilistic Risk Assessment Study*

As described in Section 4.0 of this EA, the NRC reviewed alternatives to the design certification rulemaking and alternative design features for preventing and mitigating severe accidents. NEPA requires consideration of alternatives to show that the design certification rule is the appropriate course of action and to ensure that the design referenced in the rulemaking

does not exclude any cost-beneficial design changes related to the prevention and mitigation of severe accidents. The NRC concludes that, unlike the proposed design certification rule, the alternatives to certification do not provide for resolution of issues.

Design certification is in keeping with the Commission's intent to make future plants safer than the current generation of plants, to achieve early resolution of licensing issues, and to achieve the safety benefits of standardization (refer to the Advanced Reactor (51 FR 24643), Standardization (52 FR 348803), and Severe Accident Policy Statements (50 FR 32138), and to 10 CFR Part 52). Through its own independent analysis, the NRC also concludes that Westinghouse adequately considered an appropriate set of SAMDAs and that none were cost-beneficial. Although Westinghouse made no design changes as a result of reviewing the SAMDAs, Westinghouse had already incorporated certain features in the AP1000 design on the basis of the probabilistic risk assessment (PRA) results. Section 4.2 of this EA gives examples of these features. These design features relate to severe accident prevention and mitigation, but were not considered in the SAMDA evaluation because they were already part of the AP1000 design (refer to Section 19.1.6.2 of NUREG-1793, ~~AP1000 Design Improvement as a Result of Probabilistic Risk Assessment Studies~~).

Finally, the design certification rule by itself would not authorize the siting, construction, or operation of a nuclear power plant. The issuance of a CP, early site permit (ESP), COL, or OL which references the AP1000 design will require a prospective applicant to address the environmental impacts of construction and operation at a specific site. The NRC will then evaluate the environmental impacts and issue an EIS in accordance with 10 CFR Part 51. However, the SAMDA analysis has been completed as part of this EA and can be incorporated by reference into an EIS related to siting, construction, or operation of a nuclear plant that references the AP1000 design.

Part 50, and with a court ruling related to NEPA. These requirements can be summarized as follows:

- 10 CFR 52.79 and 10 CFR 50.34(f)(1)(i)⁽ⁱ⁾ requires the applicant to perform a plant/site-specific PRA, the aim of which is to seek such improvements in the reliability of core and containment heat removal systems as are significant and practical and do not impact excessively on the plant.
- The U.S. Court of Appeals decision, in *Limerick Ecology Action v. NRC*, 869 F.2d 719 (3rd Cir. 1989), effectively requires the NRC to consider certain SAMDAs in the environmental impact review performed under Section 102(2)(c) of NEPA with respect to the licensing for operation of nuclear power plants.

Although these requirements are not directly related, they share a common purpose to consider alternatives to the proposed design, to evaluate whether potential alternative improvements in the plant design might increase safety performance during severe accidents, and to prevent reasonable alternatives from being foreclosed. It should be noted that the Commission is not required to consider alternatives to the design in this EA. However, as a matter of discretion, the Commission has determined that considering SAMDAs concomitant with the rulemaking is consistent with the intent of 10 CFR Part 52 for early resolution of issues, finality for resolved design issues, and achieving the benefits of standardization.

In its decision in *Limerick Ecology Action v. NRC*, the Court of Appeals for the Third Circuit expressed its opinion that it would likely be difficult to evaluate SAMDAs for NEPA purposes on a generic basis for all nuclear power plants then licensed by the NRC. However, the NRC has determined that generic evaluation of SAMDAs for the AP1000 standard design is both practical and warranted for two significant reasons. First, the design and construction of

⁽ⁱ⁾ Although 10 CFR 50.34(f)(1)(i) by its terms does not apply to new construction permits (CP), the Commission's policy is that a CP applicant will be required to comply with 50.34(f)(1)(i).

4.3 NRC Evaluation

The set of potential design improvements considered for the AP1000 is the same as those considered for the AP600. As part of the review for the AP600, the NRC reviewed the set of potential design improvements identified by Westinghouse and found it to be reasonably complete. The activity was accomplished by reviewing design alternatives associated with the following plants: ^{← designs} Limerick, Comanche Peak, CE System 80+, Watts Bar, and the advanced boiling water reactor (ABWR). The NRC also reviewed accident management strategies described in (NUREG/CR-5474) and alternatives identified through the Containment Performance Improvement (CPI) Program (NUREG/CR-5567, -5575, -5630, and -5562). The results of this assessment are summarized in Appendix A to "Review of Severe Accident Mitigation Design Alternatives (SAMDA) for the Westinghouse AP600 Design," Science and Engineering Associates, Inc., (SEA 97-2708-010-A;1, August 29, 1997). Given the similarity between the AP1000 and the AP600 design features and risk profile, the NRC considers this prior evaluation for the AP600 to be applicable to the AP1000 as well. ✓

The NRC notes that the AP1000 design is less tolerant of equipment failures than the AP600 because the large LOCA success criterion for the AP1000 requires operation of two of two accumulators whereas only one of two accumulators is required for the AP600, and because the LOCA success criterion for the AP1000 requires operation of three of four automatic depressurization system (ADS) Stage 4 valves whereas only two of four ADS Stage 4 valves are required for the AP600. At the NRC's request, Westinghouse performed an evaluation of the two additional design alternatives:

- (1) Larger accumulators: An increase in the size of the accumulators sufficient to change the large LOCA success criterion from two of two accumulators to one of two

systems interactions. Although improvements in the modeling of these areas may introduce additional contributors to CDF and risk, the NRC does not expect that additional contributions would change the conclusions in absolute terms.

The NRC concludes that none of the potential design modifications evaluated are justified on the basis of cost-benefit considerations. The NRC further concludes that it is unlikely that any other design changes would be justified in the future on the basis of person-rem exposure because the estimated CDFs are very low on an absolute scale.

5.0 ALTERNATIVE USE OF RESOURCES

No resources, such as land, water, or physical materials, will be affected by the promulgation of this proposed rule. This proposed rule would codify the AP1000 design in the *Code of Federal Regulations* but would not authorize the siting, construction, or operation of any nuclear power plant.

6.0 STATES CONSULTED AND SOURCES USED

✓ The NRC sent a copy of the proposed rule and draft EA to ^{every} the State Liaison Officers and specifically requested their comments on the EA. In addition, the draft EA was issued for public comment; comments and responses are discussed in Section 7.

✓ The Commission has determined under the NEPA of ~~1969~~ as amended and the NRC's regulations in 10 CFR Part 51, Subpart A, that this rule is not a major Federal action significantly affecting the quality of the human environment. Therefore, the NRC has determined that preparation of an environmental impact statement for this rulemaking is not

required. The basis for this determination, as documented in this EA, is that the amendment to 10 CFR Part 52 would not authorize the siting, construction, or operation of a facility referencing the AP1000 design; it would only codify the AP1000 design in a rule. Therefore, the NRC staff did not issue the EA for comment specifically by Federal, other State, and local agencies. The NRC's finding of no significant environmental impact was published in the *Federal Register* on April 18, 2005 (70 FR 20062), with the proposed design certification rule and draft EA for the AP1000 design. The NRC will evaluate the environmental impacts and issue an EIS, as appropriate, in accordance with NEPA as part of any application(s) for the siting, construction, or operation of a facility that would reference the AP1000 design.

7.0 PUBLIC COMMENTS AND NRC RESPONSES

On April 18, 2005 (70 FR 20062), the Commission issued the draft EA for public comment. The comment period expired on July 5, 2005. The comments are summarized below and responses are provided; the comments did not result in a change in the technical analyses, findings, or conclusions in the EA.

Comment summary. Three severe accident mitigation design alternatives (SAMDA) were inappropriately dismissed in the EA on the basis that they do not affect the likelihood of an accident. These SAMDA involve filtered containment vents and self-actuating containment isolation valves.

Response. The NRC disagrees that these three SAMDA were inappropriately dismissed. The noted SAMDA were assessed in terms of their respective benefits and implementation costs, and dismissed on the basis that they would not be cost-beneficial. In assessing benefits, SAMDA were divided into two groups—those that impact core damage

frequency (CDF), and those that impact containment performance but not CDF (including the SAMDAs in question). Although containment-related SAMDAs do not offer any benefits associated with reducing CDF (such as averted replacement power costs), the applicant conservatively assumed that all SAMDAs would completely eliminate all severe accident risk. More realistically, the CDF would not be impacted and the benefits would be much lower. Accordingly, these SAMDAs would not be cost-beneficial.

Comment summary. One SAMDA was inappropriately dismissed in the EA on the basis that it is not consistent with the AP1000 design objective of relying on passive systems. This SAMDA involves an active high-pressure safety injection system that would be capable of preventing a core melt for all but two types of events.

Response. The NRC disagrees that the SAMDA was inappropriately dismissed. Although the noted SAMDA was screened out on the basis that it is inconsistent with AP1000 design objectives, it would also have been eliminated on cost-benefit considerations. Specifically, even if this SAMDA were to eliminate all severe accident risk, the estimated costs of the SAMDA (at least \$1 million, given the significant hardware and ongoing maintenance costs) would exceed the estimated benefits by several orders of magnitude.

Comment summary. The EA contains no assessment of the impact of an accidental or deliberate external rupture of the AP1000's unreinforced containment structure.

Response. For the reasons the Commission stated in detail in *Private Fuel Storage, L.L.C. (I 56 NRC 340 (2002)* ~~CLI-02-25, 12/18/2002~~, the NRC has no obligation under the ~~National Environmental Policy Act~~ *Spent F. Storage Install* ~~NEPA~~ to consider intentional malevolent acts, such as those directed against the United States on September 11, 2001, in conjunction with a licensing action. In short, the

Commission recognizes that it cannot rule out the possibility of a terrorist threat to nuclear facilities, but finds that the possibility of a terrorist attack is speculative and simply too far removed from the natural or expected consequences of agency action to require a study under NEPA. As a practical matter, attempts to evaluate that threat even in qualitative terms are likely to be meaningless and consequently of no use in the agency's decision making. Moreover, although one of the purposes of NEPA is to inform the public of the environmental impacts of a regulatory action, the results of any attempted analysis of terrorism could not be made available to the public, for reasons associated with safeguards and physical security. ✓

The Commission is devoting substantial time and agency resources to combating the potential for terrorism involving nuclear facilities and materials. In response to the September 11 attacks, the NRC staff ^{has} ~~is~~ ^{ed and continues to conduct} a comprehensive review of its security and safeguards measures, and ^{the Commission has} ~~have~~ instituted ^{interim} ~~interim~~ upgrades in security requirements for its licensees. The Commission is also working with numerous other government agencies to meet and minimize the threat of terrorism. Thus, although the Commission declines to consider terrorism in the context of NEPA, it is devoting significant attention to terrorism-related matters.

Comment summary. How can anyone do an "Environmental Assessment" or an FSER on a plant design that exists only on paper and has never been constructed completely to scale and operated anywhere in the world?

Response. The logical outgrowth of this argument is that no plant of new design could ever be built; the argument is circular. The purpose of an FSER and EA is to assess a nuclear plant design before it is constructed. The FSER is based on an evaluation of design information and the safety analyses of postulated accidents for that particular plant design. The SAMDA portion of the EA considers alternatives to the plant design that was evaluated in the

-33-
The Commission has issued a proposed rule to amend 10 CFR Part 73 and the design basis threat (70 FR 67380, Nov. 7, 2005) and is planning to issue a series of security-related rulemakings over the next three years.

objective is to identify significant and practical improvements in plant design that do not impact excessively on the plant cost.

8.0 FINDING OF NO SIGNIFICANT IMPACT:

On the basis of the environmental assessment, the NRC concludes that the proposed action will not have a significant effect on the quality of the human environment. Accordingly, the NRC has decided not to prepare an environmental impact statement for the proposed action.

For further details with respect to the proposed action, see the design certification rule and the documents referenced in the statement of consideration for the final rule. Documents may be examined, and/or copied for a fee, at the NRC's Public Document Room (PDR), located at One White Flint North, 11555 Rockville Pike (first floor), Rockville, Maryland, ^{20852.} Publicly available records will be accessible electronically from the Agencywide Documents Access and Management System (ADAMS) Public Electronic Reading Room on the NRC Web site at <http://www.nrc.gov/reading-rm/adams.html>. Persons who do not have access to ADAMS or who encounter problems in accessing the documents in ADAMS should contact the NRC PDR reference staff at 1-800-397-4209 or 301-415-4737 or send an e-mail to pdr@nrc.gov.

AFFIRMATION ITEM


RESPONSE SHEET

TO: Annette Vietti-Cook, Secretary
FROM: COMMISSIONER MERRIFIELD
SUBJECT: **SECY-05-0227 - FINAL RULE - AP1000 DESIGN
CERTIFICATION**

Approved Disapproved Abstain
Not Participating

COMMENTS:

See attached comments.



SIGNATURE

12/22/05

DATE

Entered on "STARS" Yes No

Response. The NRC disagrees with this comment. The NRC required tests of the new passive safety systems to demonstrate that they will perform as predicted in the safety analysis (see Chapter 21 of the AP1000 FSER). The NRC also required higher availability for certain active backup systems to compensate for any remaining uncertainties in the performance of the passive safety systems (see Chapter 22 of the AP1000 FSER). As a result of these reviews, the NRC concluded that the use of passive safety systems in the AP1000 design is acceptable.

Comment summary. The AP1000 is an unnecessary and unsafe variation on AP600.

Response. The NRC disagrees with the comment. The NRC has determined that the AP1000 design can be built and operated safely (see AP1000 FSER). The NRC does not determine which designs are necessary for future deployment.

Comment summary. The AP1000 DCD referenced in the proposed rule does not meet the requirement of 10 CFR part 52 that the plant design be complete except for site-specific elements and other specific exemptions.

Response. The NRC disagrees with this comment. The requirement for a complete scope of design [§ 52.47(b)(2)(i)(A)(4)] was met by the applicant (see discussion in

~~section 1.2.1 of AP1000 FSER). The comment appears to be directed at the requirement for application to contain a sufficient level of design information [§ 52.47(a)(2)], which was also met by the applicant (see discussion in section 1.5 of AP1000 FSER).~~ *for the Commission to reach a conclusion on all safety questions associated with the design*

Comment summary. The appropriateness of the process used to derive the AP1000 design from the AP600 design has not been given sufficient attention in the NRC's review.

storage tank specified in TS 3.6.6, "Passive Containment Cooling System - Operating," of greater than or equal to -40 °F and less than or equal to 120 °F. If the water temperature is at or below 50 °F, or at or above 100 °F, the surveillance frequency to check the temperature is reduced from 7 days to 24 hours. The operational limits and the site parameters provide reasonable assurance that the AP1000 can be operated without undue risk to the public health and safety. Conservative evaluations of the potential effect of solar radiation on the operation and performance of the AP1000 PCS show that the AP1000 TS provide reasonable assurance that off-normal conditions can be detected and appropriate actions taken to preclude operations outside the current design-base assumptions. Based on the estimated time needed to exceed the current operational temperature limits (10 days of uninterrupted extreme environmental conditions), it is reasonable to conclude that the AP1000 operational limits will not be exceeded even for sites with high solar radiation. In the unlikely event that the shield building might heat up, a containment response analysis showed the pressure increase to be small, 0.75 pounds per square inch (psi), and based on the current margin of 1.2 psi (DCD Table 6.2.1.1-1), the design pressure limit of 73.7 pounds per square inch absolute (psia) would not be exceeded. Therefore, the effect of heat of solar radiation on the performance of the PCS has been resolved.

Comment summary. The accelerated schedule for the AP1000 led to cutting regulatory corners and was further accelerated by granting the FDA before the FSER was made available to the public.

Response. The NRC disagrees with this comment. In a letter to Mr. W. E. Cummins (Westinghouse), dated July 12, 2002, it is true that the NRC provided an expected schedule for the AP1000 review, which was significantly shorter than previous design certification rulemakings. ^{However,} The

the NRC expected to achieve

shorter schedule was due to ~~expected~~ efficiencies that would be gained as a result of the similarities between the previously-approved AP600 and AP1000 designs. Also, the AP1000 FSR was made available to the public on September 20, 2004, the same day that the FDA was made available to the public.

B. Design Certification Rule.

It is the Commission's goal to maintain as much consistency as possible in the rule language for all of the DCRs. Many of the following comments from NEI appear to be applicable to all of the DCRs but some repeat comments NEI submitted previously during the 2003 proposed rule to amend 10 CFR part 52.

Comment Summary. NEI recommends that Section III.B of the Supplementary Information (70 FR 20064) be revised to delete the phrase "not just incorporate by reference."

Response. The NRC disagrees with this request. The NRC does agree that the plant-specific DCD should be part of the final safety analysis report (FSAR) for a combined license (COL) application. The NRC believes that the generic DCD should also be part of the FSAR, not just incorporated by reference, in order to facilitate the NRC staff's review of any departures or exemptions. However, any changes made to existing DCRs in the ongoing part 52 rulemaking with respect to this issue would also be made to the AP1000 DCR.

Comment Summary. NEI recommends clarification of the review status of "operational requirements" in Section III.F of the Supplementary Information (70 FR 20067).

Response. The NRC agrees that the special backfit provisions of § 52.63 do not apply to operational requirements in the DCD. However, the NRC believes that the discussion in

the term "investment protection," the proposed term "non-safety-related severe accident equipment" would not be an acceptable replacement.

The NRC agrees that the bracketed values in the investment protection short-term availability controls have the same status as the bracketed values in the generic TS. As a result, NRC amended the discussion in Section III.H of the Supplementary Information (70 FR 20069) of this *Federal Register* notice to refer to the availability controls.

Comment Summary. NEI recommends that the phrase "or licensees" be deleted from the rule language in Section VIII.C.2 of the AP1000 DCR.

Response. The NRC agrees with this comment and Section VIII.C.2 of the DCR has been amended as suggested by NEI. The Commission will consider amending the other DCRs to adopt the language recommended by NEI as part of the ongoing part 52 rulemaking.

Comment Summary. NEI recommends amending the rule language in Section VIII.C.6 of the AP1000 DCR to delete the requirement that plant-specific TS be treated as license amendments.

Response. The NRC disagrees with this request. The requirement that changes to the plant-specific TS be treated as license amendments is correct. It is unlikely that the Commission will adopt NEI's proposed change for the other DCRs in the ongoing part 52 rulemaking. However, if the Commission decides to clarify this issue for the other DCRs in the ongoing part 52 rulemaking, the NRC will also clarify the AP1000 DCR accordingly as part of that rulemaking.

delete
space

Comment Summary. NEI recommends amending Section VIII.C.4 of the AP1000 DCR to revise the standards for making changes to operational requirements.

Response. The NRC disagrees with this request. In the first two DCRs, the Commission decided on different standards for changes made under Section VIII.C (see the discussion at 62 FR 25800; May 12, 1997). In addition, the Commission determined that exemptions from operational requirements would not receive finality or be treated as a resolved issue within the meaning of Section VI of the DCR. The NRC notes that NEI submitted the same comment during the 2003 proposed rule to amend 10 CFR part 52. It is unlikely that the Commission will adopt NEI's proposed language for the other DCRs in the ongoing part 52 rulemaking. However, if the Commission decides to adopt NEI's proposed language for the other DCRs in the ongoing part 52 rulemaking, the NRC will also amend the AP1000 DCR accordingly as part of that rulemaking.

Comment Summary. NEI recommends amending Section IX.B.1 of the AP1000 DCR to specify the type of action to be performed by the NRC staff regarding ITAAC.

Response. The NRC disagrees with this request, and has decided to maintain the original rule language for this provision because it does not believe that individual DCRs should address the scope of the NRC staff's activities with respect to ITAAC verification. This is a generic matter that, if it is to be addressed in a rulemaking, is more appropriate for inclusion in subpart C of part 52 dealing generally with combined licenses. *not*

The NRC notes that NEI submitted the same comment during the 2003 proposed rule to amend 10 CFR part 52. It is unlikely that the Commission will adopt NEI's proposed language for the other DCRs in the ongoing part 52 rulemaking. However, if the Commission decides to

adopt NEI's proposed language for the other DCRs in the ongoing part 52 rulemaking, the NRC will also amend the AP1000 DCR accordingly as part of that rulemaking.

Comment Summary. NEI recommends amending Section IX.B.3 of the AP1000 DCR to clarify the rule language.

Response. The NRC disagrees with this editorial request and has decided to maintain the original rule language for this provision. The NRC notes that NEI submitted the same comment during the 2003 proposed rule to amend 10 CFR part 52. It is unlikely that the Commission will adopt NEI's proposed language for the other DCRs in the ongoing part 52 rulemaking. However, if the Commission decides to adopt NEI's proposed language for the other DCRs in the ongoing part 52 rulemaking, the NRC will also amend the AP1000 DCR accordingly as part of that rulemaking.

Comment Summary. NEI recommends amending Sections X.B.1 and X.B.3 of the AP1000 DCR to clarify the rule language regarding DCDs.

Response. The NRC agrees with this comment. Section X.B of the AP1000 DCR has been amended to be consistent with the other DCRs in the proposed part 52 rule. The NRC notes that NEI submitted the same comment during the 2003 proposed rule to amend 10 CFR part 52. The Commission intends to amend existing DCRs to make them consistent with the AP1000 DCR.

III. Section-by-Section Analysis.

The following discussion sets forth the purpose and key aspects of each section and paragraph of the final AP1000 DCR. All section and paragraph references are to the provisions in appendix D to 10 CFR part 52. The final DCR for the AP1000 standard plant design is nearly identical to the AP600 DCR, which the NRC previously codified in 10 CFR part 52, appendix C (Design Certification Rule for the AP600 Design, 64 FR 72015, December 23, 1999). Many of the procedural issues and their resolutions for the AP600 DCR, as well as the initial two design certification rules for the ABWR and ABB-CE System 80+, (e.g., the two-tier structure, Tier 2*, the scope of issue resolution) were developed after extensive discussions with public stakeholders, including Westinghouse. Also, Westinghouse requested that policy resolutions for the AP600 design review be applied to the AP1000. Accordingly, the NRC has modeled the AP1000 DCR on the existing DCRs, with certain departures^{where} ~~These departures are necessary,~~ to account for differences in the AP1000 design documentation, design features, and environmental assessment (including severe accident mitigation design alternatives (SAMDAs)).

A. Introduction.

The purpose of Section I of appendix D to 10 CFR part 52 (this appendix) is to identify the standard plant design that is approved by this DCR³ and the applicant for certification of the standard design. Identification of the design certification applicant is necessary to implement this appendix, for two reasons. First, the implementation of 10 CFR 52.63(c) depends on whether an applicant for a COL contracts with the design certification applicant to provide the generic DCD and supporting design information. If the COL applicant does not use the design certification applicant to provide this information, then the COL applicant must meet the

requirements in 10 CFR 52.63(c). Also, paragraph X.A.1 of this appendix requires the design certification applicant to maintain the generic DCD throughout the time this appendix may be referenced.

B. Definitions.

During development of the first two DCRs, the Commission decided that there would be both generic (master) DCDs maintained by the NRC and the design certification applicant, as well as individual plant-specific DCDs maintained by each applicant and licensee that reference ~~this~~ ^{relevant} appendix. This distinction is necessary in order to specify the plant-specific requirements applicable to applicants and licensees referencing the appendix. The master DCDs would include generic changes to the version of the DCD approved in this design certification rulemaking. These changes would occur as the result of generic rulemaking by the Commission, under the change criteria in Section VIII of this appendix. The Commission also requires each applicant and licensee referencing this appendix to submit and maintain a plant-specific DCD.

This plant-specific DCD would contain (not just incorporate by reference) the information in the generic DCD. The plant-specific DCD would be updated as necessary to reflect the generic changes to the DCD that the Commission may adopt through rulemaking, ~~any~~ plant-specific departures from the generic DCD that the Commission imposed on the licensee by order, and any plant-specific departures that the licensee chooses to make in accordance with the relevant processes in Section VIII of this appendix. Thus, the plant-specific DCD would function like an updated FSAR because it would provide the most complete and accurate information on a plant's licensing basis for that part of the plant within the scope of this

(paragraph II.G), which is appropriate to include in this rulemaking so that the eight criteria in paragraph VIII.B.5.b of the final rule will be implemented as intended.

C. Scope and Contents.

The purpose of Section III of this DCR is to describe and define the scope and contents of this design certification and to set forth how documentation discrepancies or inconsistencies are to be resolved. Paragraph A is the required statement of the Office of the *Federal Register* (OFR) for approval of the incorporation by reference of Tier 1, Tier 2, and the generic TS into this appendix. Paragraph B requires COL applicants and licensees to comply with the requirements of this appendix. The legal effect of incorporation by reference is that the incorporated material has the same legal status as if it were published in the *Code of Federal Regulations*. This material, like any other properly-issued regulation, has the force and effect of law. Tier 1 and Tier 2 information, as well as the generic TS, have been combined into a single document called the generic DCD, in order to effectively control this information and facilitate its incorporation by reference into the rule. The generic DCD was prepared to meet the requirements of the OFR for incorporation by reference (CFR ¹⁰ part 51). One of the requirements of the OFR for incorporation by reference is that the design certification applicant must make the generic DCD available upon request after the final rule becomes effective. Therefore, paragraph III.A of this appendix identifies a Westinghouse representative to be contacted in order to obtain a copy of the generic DCD.

Paragraphs A and B also identify the investment protection short-term availability controls in Section 16.3 of the generic DCD as part of the Tier 2 information. During its review of the AP1000 design, the NRC determined that residual uncertainties associated with passive

building. Because this statement is not a definition, this provision has been located in Section III of this appendix.

D. Additional Requirements and Restrictions.

Section IV of this appendix sets forth additional requirements and restrictions imposed upon an applicant who references this appendix. Paragraph IV.A sets forth the information requirements for these applicants. This appendix distinguishes between information and/or documents which must actually be included in the application or the DCD, versus those which may be *incorporated by reference* (i.e., referenced in the application as if the information or documents were included in the application). Any incorporation by reference in the application should be clear and should specify the title, date, edition, or version of a document, the page number(s), and table(s) containing the relevant information to be incorporated.

Paragraph A.1 requires an applicant who references this appendix to incorporate by reference this appendix in its application. The legal effect of such an incorporation by reference is that this appendix is legally binding on the applicant or licensee. Paragraph A.2.a requires that a plant-specific DCD be included in the initial application ^{to} ~~This ensure~~ that the applicant commits to complying with the DCD. This paragraph also requires ~~that the~~ plant-specific DCD ~~to~~ ~~use~~ the same format as the generic DCD and reflect~~s~~ the applicant's proposed departures and exemptions from the generic DCD as of the time of submission of the application. The Commission expects that the plant-specific DCD will become the plant's FSAR, by including information, i.e., site-specific information, for the portions of the plant outside the scope of the referenced design, including related ITAAC, and other matters required to be included in an FSAR by 10 CFR 50.34 and 52.79. Integration of the plant-specific DCD and remaining

applicant or licensee may request an *exemption* from Tier 1, as provided in paragraph A.4. If the Commission seeks to order a licensee to depart from Tier 1, paragraph A.3 requires that the Commission find both that the departure is necessary for adequate protection or for compliance, and that special circumstances are present. Paragraph A.4 provides that exemptions from Tier 1 requested by an applicant or licensee are governed by the requirements of 10 CFR 52.63(b)(1) and 52.97(b), which provide an opportunity for a hearing. In addition, the Commission will not grant requests for exemptions that may result in a significant decrease in the level of safety otherwise provided by the design.

Tier 2 Information

The change processes for the three different categories of Tier 2 information, namely, Tier 2, Tier 2*, and Tier 2* with a time of expiration, are set forth in paragraph VIII.B. The change process for Tier 2 has the same elements as the Tier 1 change process, but some of the standards for plant-specific orders and exemptions are different. As stated in Section III, of this preamble, it is the Commission's intent that this appendix emulates appendix C to 10 CFR part 52. However, the Commission has revised the § 50.59-like change process in paragraph VIII.B.5 of this appendix to be commensurate with the new 10 CFR 50.59 (64 FR 53613, October 4, 1994).

The process for generic Tier 2 changes (including changes to Tier 2* and Tier 2* with a time of expiration) tracks the process for generic Tier 1 changes. As set forth in paragraph B.1, generic Tier 2 changes are accomplished by rulemaking amending the generic DCD and are governed by the standards in 10 CFR 52.63(a)(1). This provision provides that the Commission may not modify, change, rescind, or impose new requirements by rulemaking except when necessary, either to bring the certification into compliance with the Commission's regulations

Paragraphs B.1 and B.2 reiterate the NRC's responsibilities with respect to ITAAC as set forth in 10 CFR 52.99 and 52.103(g)¹. Finally, paragraph (B.3)d states that ITAAC do not, by virtue of their inclusion in the DCD, constitute regulatory requirements after the licensee has received authorization to load fuel or has been granted a renewal of its license. However, subsequent modifications to the terms of the COL must comply with the design descriptions in the DCD unless the applicable requirements in 10 CFR 52.97 and Section VIII of this appendix have been met. As discussed in paragraph III.D of this SOC, the Commission will defer a determination of the applicability of ITAAC and its effect in terms of issue resolution in 10 CFR part 50 licensing proceedings until a part 50 applicant decides to reference this appendix.

delete space

J. Records and Reporting.

The purpose of Section X of this appendix is to set forth the requirements that will apply to maintaining records of changes to and departures from the generic DCD, which are to be reflected in the plant-specific DCD. Section X also sets forth the requirements for submitting reports (including updates to the plant-specific DCD) to the NRC. This section of the appendix is similar to the requirements for records and reports in 10 CFR part 50, except for minor differences in information collection and reporting requirements.

CHECK ALL INSTANCES -
EITHER CAPITALIZE OR NOT,
BUT BE CONSISTENT IN
SECY PAPER, FRN, & ENV
ASSESSMENT

Paragraph X.A.1 of this appendix requires that a generic DCD and the proprietary and safeguards information referenced in the generic DCD be maintained by the applicant for this rule. The generic DCD was developed, in part, to meet the requirements for incorporation by reference, including availability requirements. Therefore, the proprietary and safeguards information could not be included in the generic DCD because they are not publicly available.

¹ For discussion of the verification of ITAAC, see SECY-00-0092, "Combined License Review Process," dated April 20, 2000.

The National Technology Transfer and Advancement Act of 1995 (Act), Public Law 104-113, requires that Federal agencies use technical standards that are developed or adopted by voluntary consensus standards bodies unless using such a standard is inconsistent with applicable law or is otherwise impractical. In this final rule, the NRC is approving the AP1000 standard plant design for use in nuclear power plant licensing under 10 CFR parts 50 or 52. Design certifications are not generic rulemakings establishing a generally applicable standard with which all parts 50 and 52 nuclear power plant licensees must comply. Design certifications are Commission approvals of specific nuclear power plant designs by rulemaking. Furthermore, design certifications are initiated by an applicant for rulemaking, rather than by the NRC. For these reasons, the NRC concludes that the Act does not apply to this final rule.

VII. Finding of No Significant Environmental Impact: Availability.

The Commission has determined under the National Environmental Policy Act of 1969, as amended (NEPA), and the Commission's regulations in 10 CFR part 51, subpart A, that this design certification rule is not a major Federal action significantly affecting the quality of the human environment and, therefore, an environmental impact statement (EIS) is not required. The basis for this determination, as documented in the environmental assessment, is that this amendment to 10 CFR part 52 does not authorize the siting, construction, or operation of a facility using the AP1000 design; it only codifies the AP1000 design in a rule. The NRC will evaluate the environmental impacts and issue an EIS as appropriate under NEPA as part of the application(s) for the construction and operation of a facility referencing the AP1000 design certification rule.

in whole body person-rem per year received by the total population within a 80.5-km (50-mile) radius of the AP1000 plant site. Westinghouse used the cost-benefit methodology of NUREG/BR-0184 to calculate the maximum attainable benefit of completely eliminating all risk for the AP1000. This methodology includes consideration of replacement power costs. Westinghouse estimated the present worth of eliminating all risk to be \$21,000. This value is an upper bound because in practice no design alternative, if implemented, would reduce the plant CDF to zero. Westinghouse also provided additional sensitivity analyses of the impacts of the following:

- a 3-percent discount rate rather than the 7-percent discount rate assumed in the base case
- a factor of 10 increase in the population dose used in the base case
- a more realistic reduction in CDF (i.e., each SAMDA reduces CDF by 50 percent rather than 100 percent, as assumed in the base case)
- a factor of 2 increase in the base case CDF
- a factor of 10 increase in the maximum attainable benefit

DCD Tier 2, Table 1B-4, summarizes the results for these cases. With the exception of the last sensitivity case, the calculated maximum attainable benefit was no more than \$43,000. Even when the AP1000 CDF and LRF were increased by a factor of 10, the maximum attainable benefit of eliminating all risk for the AP1000 would only increased to about \$200,000.

The applicant found that none of the 14 design alternatives and neither of the two additional alternatives related to the PRA success criteria would be cost beneficial. Only one alternative has an implementation cost close to \$21,000, namely, SAMDA 3, self-actuating CIVs, which has an estimated cost of \$33,000. All of the remaining alternatives have estimated implementation costs at least a factor of 20 greater than the maximum attainable benefit of

Commission recognizes that it cannot rule out the possibility of a terrorist threat to nuclear facilities, but finds that the possibility of a terrorist attack is speculative and simply too far removed from the natural or expected consequences of agency action to require a study under NEPA. As a practical matter, attempts to evaluate that threat even in qualitative terms are likely to be meaningless and consequently of no use in the agency's decision making. Moreover, although one of the purposes of NEPA is to inform the public of the environmental impacts of a regulatory action, the results of any attempted analysis of terrorism could not be made available to the public, for reasons associated with safeguards and physical security.

The Commission is devoting substantial time and agency resources to combating the potential for terrorism involving nuclear facilities and materials. In response to the September 11 attacks, the NRC ~~staff~~ ^{has upgraded many of the} is conducting a comprehensive review of its security and safeguards measures, and ~~have instituted interim upgrades in~~ security requirements for its licensees. The Commission is also working with numerous other government agencies to meet and minimize the threat of terrorism. Thus, although the Commission declines to consider terrorism in the context of NEPA, it is devoting significant attention to terrorism-related matters.

Comment summary. How can anyone do an "Environmental Assessment" or an FSER on a plant design that exists only on paper and has never been constructed completely to scale and operated anywhere in the world?

Response. The logical outgrowth of this argument is that no plant of new design could ever be built; the argument is circular. The purpose of an FSER and EA is to assess a nuclear plant design before it is constructed. The FSER is based on an evaluation of design information and the safety analyses of postulated accidents for that particular plant design. The SAMDA portion of the EA considers alternatives to the plant design that was evaluated in the

NRC review of the design certification ^{application} includes a review of generic environmental parameters submitted ³³⁻ by the reactor vendor. If a COL applicant references the certified design, it is up to that applicant to demonstrate that the site-specific environmental ^{parameters} are bounded by the generic environmental parameters, or provide a basis for deviations from those parameters.

AFFIRMATION ITEM

RESPONSE SHEET

TO: Annette Vietti-Cook, Secretary
FROM: COMMISSIONER LYONS
SUBJECT: **SECY-05-0227 - FINAL RULE - AP1000 DESIGN
CERTIFICATION**

Approved Disapproved _____ Abstain _____
Subject to attached edits.
Not Participating _____

COMMENTS:

I also support~~t~~ the edits of the Chairman and Commissioner McGaffigan.


Peter B. Lyons

SIGNATURE

12/27 /05

DATE

Entered on "STARS" Yes No _____

situations, use the phrase "but only for that plant" (~~emphasis added~~). Paragraph B.4 describes how issues associated with a design certification rule are resolved when an exemption has been granted for a plant referencing the design certification rule. Paragraph B.5 describes how issues are resolved when a plant referencing the design certification rule obtains a license amendment for a departure from Tier 2 information.

Paragraph B.6 describes how issues are resolved when the applicant or licensee departs from the Tier 2 information on the basis of paragraph VIII.B.5, which will waive the requirement for NRC approval. In all three situations, after a matter (e.g., an exemption in the case of paragraph B.4) is addressed for a specific plant referencing a design certification rule, the adequacy of that matter *for that plant* will not ordinarily be subject to challenge in any subsequent proceeding or action for that plant (such as an enforcement action) listed in the introductory portion of paragraph IV.B. There will not, by contrast, be any issue resolution on that subject matter for any other plant.

Paragraph B.7 provides that, for those plants located on sites whose site parameters do not exceed those assumed in Westinghouse's evaluation of SAMDAs, all issues with respect to SAMDAs arising under the National Environmental Policy Act of 1969 associated with the information in the environmental assessment for this design and the information regarding SAMDAs in Appendix 1B of the generic DCD are also resolved within the meaning and intent of § 52.63(a)(4). If an exemption from a site parameter is granted, the exemption applicant has the initial burden of demonstrating that the original SAMDA analysis still applies to the actual site parameters but; if the exemption is approved, requests for litigation at the COL stage must meet the requirements of § 2.309 and present sufficient information to create a genuine controversy in order to obtain a hearing on the site parameter exemption.

Paragraph C reserves the right of the Commission to impose operational requirements on applicants that reference this appendix. This provision reflects the fact that operational requirements, including generic TS in Section 16.1 of the DCD, were not completely or comprehensively reviewed at the design certification stage. Therefore, the special backfit provisions of § 52.63 do not apply to operational requirements. However, all design changes will be controlled by the appropriate provision in Section VIII of this appendix. Although the information in the DCD that is related to operational requirements is necessary to support the NRC's safety review of this design, the review of this information was not sufficient to conclude that the operational requirements are fully resolved and ready to be assigned finality under § 52.63. As a result, if the NRC wanted to change a temperature limit and that operational change required a consequential change to a design feature, then the temperature limit backfit would be controlled by Section VIII (paragraph A or B) of this appendix. However, changes to other operational ^{requirements} issues, such as inservice testing and inservice inspection programs, post-fuel load verification activities, and ^{requirements governing} shutdown risk that do not require a design change would not be restricted by § 52.63 (see VIII.C of this appendix).

Paragraph C allows the NRC to impose future operational requirements (distinct from design matters) on applicants who reference this design certification. Also, license conditions for portions of the plant within the scope of this design certification, e.g., start-up and power ascension testing, are not restricted by § 52.63. The requirement to perform these testing programs is contained in Tier 1 information. However, ITAAC cannot be specified for these subjects because the matters to be addressed in these license conditions cannot be verified prior to fuel load and operation, when the ITAAC are satisfied. Therefore, another regulatory vehicle is necessary to ensure that licensees comply with the matters contained in the license conditions. License conditions for these areas cannot be developed now because this requires

the type of detailed design information that will be developed during a combined license review. In the absence of detailed design information to evaluate the need for and develop specific post-fuel load verifications for these matters, the Commission is reserving the right to impose license conditions by rule for post-fuel load verification activities for portions of the plant within the scope of this design certification.

Paragraph D reiterates the restrictions (contained in Section VIII of this appendix) placed upon the Commission when ordering generic or plant-specific modifications, changes or additions to structures, systems, or components, design features, design criteria, and ITAAC (VI.D.3 would address ITAAC) within the scope of the certified design.

Paragraph E provides the procedure for an interested member of the public to obtain access to proprietary or safeguards information for the AP1000 design, in order to request and participate in proceedings identified in paragraph VI.B of this appendix, viz., proceedings involving licenses and applications which reference this appendix. Paragraph E specifies that access must first be sought from the design certification applicant. If Westinghouse refuses to provide the information, the person seeking access shall request access from the Commission or the presiding officer, as applicable. Access to the proprietary or safeguards information may be ordered by the Commission, but must be subject to an appropriate non-disclosure agreement.

G. Duration of this Appendix.

The purpose of Section VII of this appendix is in part, to specify the period during which this design certification may be referenced by an applicant for a COL, under 10 CFR 52.55. This section also states that the design certification remains valid for an applicant or licensee

applicant or licensee may request an *exemption* from Tier 1, as provided in paragraph A.4. If the Commission seeks to order a licensee to depart from Tier 1, paragraph A.3 requires that the Commission find both that the departure is necessary for adequate protection or for compliance, and that special circumstances are present. Paragraph A.4 provides that exemptions from Tier 1 requested by an applicant or licensee are governed by the requirements of 10 CFR 52.63(b)(1) and 52.97(b), which provide an opportunity for a hearing. In addition, the Commission will not grant requests for exemptions that may result in a significant decrease in the level of safety otherwise provided by the design.

Tier 2 Information

The change processes for the three different categories of Tier 2 information, namely, Tier 2, Tier 2*, and Tier 2* with a time of expiration, are set forth in paragraph VIII.B. The change process for Tier 2 has the same elements as the Tier 1 change process, but some of the standards for plant-specific orders and exemptions are different. As stated in Section III, of *Statements of Consideration (SOC)* this preamble, it is the Commission's intent that this appendix emulates appendix C to 10 CFR part 52. However, the Commission has revised the § 50.59-like change process in paragraph VIII.B.5 of this appendix to be commensurate with the new 10 CFR 50.59 (64 FR 53613, October 4, 1994).

The process for generic Tier 2 changes (including changes to Tier 2* and Tier 2* with a time of expiration) tracks the process for generic Tier 1 changes. As set forth in paragraph B.1, generic Tier 2 changes are accomplished by rulemaking amending the generic DCD and are governed by the standards in 10 CFR 52.63(a)(1). This provision provides that the Commission may not modify, change, rescind, or impose new requirements by rulemaking except when necessary, either to bring the certification into compliance with the Commission's regulations

the increased uncertainty in severe accident issue resolutions, the Commission has adopted separate criteria in paragraph B.5.c for determining if a departure from information that resolves severe accident issues would require a license amendment. For purposes of applying the special criteria in paragraph B.5.c, severe accident resolutions are limited to design features *when* the intended function of the design feature is relied upon to resolve postulated accidents when the reactor core has melted and exited the reactor vessel, and the containment is being challenged. These design features are identified in Section 1.9.5 and Appendix 19B of the DCD, with other issues, and are described in other sections of the DCD. Therefore, the location of design information in the DCD is not important to the application of this special procedure for severe accident issues. However, the special procedure in paragraph B.5.c does not apply to design features that resolve so-called "beyond design-basis accidents" or other low-probability events. The important aspect of this special procedure is that it is limited to severe accident design features, as defined above. Some design features may have intended functions to meet "design basis" requirements and to resolve "severe accidents." If these design features are reviewed under paragraph VIII.B.5, then the appropriate criteria from either paragraphs B.5.b or B.5.c are selected depending upon the function being changed.

An applicant or licensee that plans to depart from Tier 2 information, under paragraph VIII.B.5, is required to prepare an evaluation which provides the bases for the determination that the proposed change does not require a license amendment or involve a change to Tier 1 or Tier 2* information, or a change to the TS, as explained above. In order to achieve the Commission's goals for design certification, the evaluation needs to consider all of the matters that were resolved in the DCD, such as generic issue resolutions that are relevant to the proposed departure. The benefits of the early resolution of safety issues would be lost if departures from the DCD were made that violated these resolutions without appropriate review.

approved in the design certification rulemaking is based upon the extent to which an NRC safety conclusion in the FSER is being modified or changed. If it cannot be determined that the TS or operational requirement was comprehensively reviewed and finalized in the design certification rulemaking, then there is no backfit restriction under 10 CFR 50.109 because no prior position was taken on this safety matter. Generic changes made under proposed paragraph VIII.C.1 are applicable to all applicants or licensees (refer to paragraph VIII.C.2), unless the change is irrelevant because of a plant-specific departure.

Some generic TS and investment protection short-term availability controls contain values in brackets []. The brackets are placeholders indicating that the NRC's review is not complete, and represent a requirement that the applicant for a combined license referencing the AP1000 DCR must replace the values in brackets with final plant-specific values. The values in brackets are neither part of the design certification rule nor are they binding. Therefore, the replacement of bracketed values with final plant-specific values does not require an exemption from the generic TS or investment protection short-term availability controls.

Plant-specific departures may occur by either a Commission order under paragraph VIII.C.3 or an applicant's exemption request under paragraph VIII.C.4. The basis for determining if the TS or operational requirement was completely reviewed and approved for these processes is the same as for paragraph VIII.C.1 above. If the TS or operational requirement is comprehensively reviewed and finalized in the design certification rulemaking, then the Commission must demonstrate that special circumstances are present before ordering a plant-specific departure. If not, there is no restriction on plant-specific changes to the TS or operational requirements, prior to the issuance of a license, provided a design change is not required. Although the generic TS were reviewed by the NRC staff ^{and approved in support of} ~~to facilitate~~ the design certification review, the Commission intends to consider the lessons learned from subsequent

Rulemaking Web site (Web). The NRC's interactive rulemaking Web site is located at <http://ruleforum.llnl.gov>. Selected documents may be viewed and downloaded electronically via this Web site.

Public Electronic Reading Room (ADAMS). The NRC's Public Electronic Reading Room (PERR) is located at <http://www.nrc.gov/reading-rm/adams.html>. Through this site, the public can gain access to ADAMS, which provides text and image files of NRC's public documents.

Document	PDR	Web	ADAMS
AP1000 Design Certification Final Rule SECY paper	X	X	ML053250288
AP1000 Environmental Assessment	X	X	ML053250292
AP1000 Design Control Document	X	ML053460400
NUREG-1793, "AP1000 Final Safety Evaluation Report"	X	ML043570339
Supplement 1, NUREG-1793, "AP1000 Final Safety Evaluation Report"	X	ML053410203
Regulatory History of Design Certification ²	X	ML003761550

V. Plain Language.

The Presidential memorandum entitled "Plain Language in Government Writing" (63 FR 31883; June 10, 1998), directed that the Government's writing be in plain language. The NRC requests comments on the proposed rule specifically with respect to the clarity and effectiveness of the language used. Comments should be submitted using one of the methods detailed under the ADDRESSES heading of the preamble to this proposed rule.

delete and re-number sections

VI. Voluntary Consensus Standards.

² The regulatory history of the NRC's design certification reviews is a package of 100 documents that is available in NRC's PERR and in the PDR. This history spans a 15-year period during which the NRC simultaneously developed the regulatory standards for reviewing these designs and the form and content of the rules that certified the designs.

** (and containing changes to any other occurrence of the word "preamble")*

Prototype, Reactor siting criteria, Redress of site, Reporting and recordkeeping requirements, Standard design, Standard design certification. *

For the reasons set out in ~~the~~ ^{this SOE} preamble and under the authority of the Atomic Energy Act of 1954, as amended; the Energy Reorganization Act of 1974, as amended; and 5 U.S.C. 552 and 553; the NRC is adopting the following amendments to 10 CFR part 52.

**PART 52 - EARLY SITE PERMITS; STANDARD DESIGN CERTIFICATIONS; AND
COMBINED LICENSES FOR NUCLEAR POWER PLANTS**

1. The authority citation for 10 CFR part 52 continues to read as follows:

AUTHORITY: Secs. 103, 104, 161, 182, 183, 186, 189, 68 Stat. 936, 948, 953, 954, 955, 956, as amended, sec. 234, 83 Stat. 444, as amended (42 U.S.C. 2133, 2201, 2232, 2233, 2236, 2239, 2282); secs. 201, 202, 206, 88 Stat. 1242, 1244, 1246, as amended (42 U.S.C. 5841, 5842, 5846); sec. 1704, 112 Stat. 2750 (44 U.S.C. 3504 note).

2. In § 52.8, paragraph (b) is revised to read as follows:

§ 52.8 Information collection requirements: OMB approval.

* * * * *

(b) The approved information collection requirements contained in this part appear in §§ 52.15, 52.17, 52.29, 52.35, 52.45, 52.47, 52.51, 52.57, 52.63, 52.75, 52.77, 52.78, 52.79, 52.89, 52.91, 52.99, and appendices A, B, C, and D.

3. A new appendix D to 10 CFR part 52 is added to read as follows:

Appendix D To Part 52 - Design Certification Rule for the AP1000 Design

4.0 ALTERNATIVES TO THE PROPOSED ACTION

The NRC has identified two alternatives to certifying the AP1000 design. The first alternative would be to take no action to approve the design under Subpart B of 10 CFR Part 52. As with the proposed action, this alternative would not have a significant impact on the quality of the human environment because it would not authorize the siting, construction, or operation of a facility.

In the second alternative, the NRC would approve the design, but would not certify the AP1000 design in a rulemaking. The NRC issued a final design approval for AP1000 under Appendix O to 10 CFR Part 52 on September 13, 2004. Therefore, although the NRC has approved the design, the design would not have finality in proceedings under 10 CFR Part 50 or 10 CFR Part 52, Subpart C and could be modified. As a result, the design could require re-evaluation as part of each application to construct and operate a facility of an AP1000 design at a particular site. This alternative would provide for early internal NRC resolution of design issues to the extent that the design would remain unchanged at the facility application stage, but may not obtain all of the benefits of standardization nor permit overall finality for the resolved design issues.

The NRC sees no advantage in these alternatives compared to the design certification rulemaking proposed for the AP1000 design. Although neither ~~the~~ alternative nor the proposed action (design certification rulemaking) would significantly affect the quality of the human environment, the proposed action achieves the benefits of standardization, permits early resolution of design issues, and provides finality in licensing proceedings for the resolved design issues (including SAMDAs) that are within the scope of the design certification.

Therefore, the NRC concludes that neither of the alternatives to rulemaking would achieve the

and normal shutdown conditions). The design alternative would provide for self-actuation in the event that containment conditions are indicative of a severe accident. Closed systems inside and outside containment, such as the normal residual heat removal system (RNS) and component cooling, would be excluded from this design alternative. The actuation of CIVs would be automatically initiated in the event that containment conditions are indicative of a severe accident.

(4) **Passive containment sprays:** This SAMDA involves adding a passive safety-related spray system and all associated piping and support systems to the AP1000 design (in lieu of the non-safety-related active containment spray capability currently incorporated in the AP1000 design). Installation of the safety-grade containment spray system could result in an increase in the following three risk benefits:

- scrubbing of fission products, primarily for containment isolation failure
- alternative means for flooding the reactor vessel (in-vessel retention)
- control of containment pressure if the PCS fails

(5) **Active high-pressure safety injection (HPSI) system:** A safety-related active HPSI system could be added that would be capable of preventing a core melt for all events except the large-break LOCA and ATWS. ~~Note, however, that this design alternative is not consistent with the AP1000 design objectives.~~ The AP1000 would change from a plant with passive systems to a plant with passive and active systems.

NOT
a
NEPA
criteria
(cost-benefit)

(6) **Steam generator (SG) shell-side heat removal system:** This design alternative would involve the installation of a passive safety-related heat removal system to the secondary side of the SGs. This enhancement would provide closed-loop secondary-system cooling by means of natural circulation and stored water cooling, thereby preventing the

loss of the primary heat sink given the loss of startup feedwater (SFW) and the passive residual heat removal (RHR) heat exchanger (HX).

- (7) Direct SG relief flow to the IRWST: To prevent fission product release from bypassing containment during a steam generator tube rupture (SGTR) event (or to reduce the amount released), flow from the SG safety and relief valves could be directed to the IRWST. An alternative, lower cost option would be to redirect flow only from the first-stage safety valve to the IRWST.
- (8) Increased SG pressure capability: As an alternative to design alternative (7) above, another method ~~could be used~~ to prevent fission product release from bypassing containment during an SGTR event (or to reduce the amount). ~~This alternative method~~ would involve an increase of the SG secondary-side pressure capability and safety valve pressure setpoint to a level high enough to not allow an SGTR to cause the secondary-system safety valve to open. Although detailed analyses have not been performed, it is estimated that the secondary-side design pressure would have to be increased by several hundred pounds per square inch (psi).
- (9) Secondary containment filtered ventilation: This design alternative involves the installation of a passive charcoal and high-efficiency particulate air filter system for the middle- and lower-annulus region of the secondary concrete containment (below elevation 135'-3"). Drawing a partial vacuum on the middle annulus via an eductor with motive power from compressed gas tanks would operate the filter system. This design alternative would reduce particulate fission product release from any failed containment penetrations.
- (10) Diverse IRWST injection valves: In the current design, a squib valve in series with a check valve (CV) isolates each of the four IRWST injection paths. To provide diversity,

Same comment
as on pg 22.



4.3 NRC Evaluation

The set of potential design improvements considered for the AP1000 is the same as ~~those~~ ^{that} considered for the AP600. As part of the review for the AP600, the NRC reviewed the set of potential design improvements identified by Westinghouse and found it to be reasonably complete. The activity was accomplished by reviewing design alternatives associated with the following plants: Limerick, Comanche Peak, CE System 80+, Watts Bar, and the advanced boiling water reactor (ABWR). The NRC also reviewed accident management strategies described in (NUREG/CR-5474) and alternatives identified through the Containment Performance Improvement (CPI) Program (NUREG/CR-5567, -5575, -5630, and -5562). The results of this assessment are summarized in Appendix A to "Review of Severe Accident Mitigation Design Alternatives (SAMDA) for the Westinghouse AP600 Design," Science and Engineering Associates, Inc., (SEA 97-2708-010-A;1, August 29, 1997). Given the similarity between the AP1000 and the AP600 design features and risk profile, the NRC considers this prior evaluation for the AP600 to be applicable to the AP1000 as well.

The NRC notes that the AP1000 design is less tolerant of equipment failures than the AP600 because the large LOCA success criterion for the AP1000 requires operation of two of two accumulators whereas only one of two accumulators is required for the AP600, and because the LOCA success criterion for the AP1000 requires operation of three of four automatic depressurization system (ADS) Stage 4 valves whereas only two of four ADS Stage 4 valves are required for the AP600. At the NRC's request, Westinghouse performed an evaluation of the ^{following} two additional design alternatives:

- (1) Larger accumulators: An increase in the size of the accumulators sufficient to change the large LOCA success criterion from two of two accumulators to one of two

4.4 Risk Reduction Potential of SAMDAs

4.4.1 Westinghouse Evaluation

In its evaluation, Westinghouse assumed that each design alternative would work perfectly to completely eliminate all severe accident risk from evaluated internal, external, and shutdown events. This assumption is conservative, since it maximizes the benefit of each design alternative. The design alternative benefits were estimated on the basis of the reduction of risk expressed in terms of ^{avoided} whole body person-rem per year received by the total population within a 80.5-km (50-mile) radius of the AP1000 plant site, as discussed in Section 19.4.2 of the AP1000 FSER.

Westinghouse used the cost-benefit methodology of NUREG/BR-0184 to calculate the maximum attainable benefit of completely eliminating all risk for the AP1000. This methodology includes consideration of replacement power costs. The applicant estimated the present worth of eliminating all risk to be \$21,000. Even if the AP1000 CDF and large release frequency (LRF) were a factor of 10 higher, this value would only increase to about \$200,000.

4.4.2 NRC Evaluation

NRC reviewed Westinghouse's bases for estimating the risk reduction for the various SAMDAs, and concluded that Westinghouse used bounding and conservative assumptions as the bases for the risk reduction estimates for each design alternative.

Westinghouse's risk reduction estimates are based on point-estimate (mean) values, and do not consider uncertainties in CDF or offsite consequences. Although this is consistent

with the approach taken in previous design alternative evaluations, further consideration of

these factors could lead to significantly higher risk reduction values, given the extremely small

CDF and risk estimates in the baseline PRA. In assessing the risk reduction potential of design

alternatives for the AP1000, the NRC has based its evaluation on a review of the applicant's risk

reduction estimates for the various design alternatives, in conjunction with an assessment of

the potential impact of uncertainties on the results. This assessment is discussed further in

Section 19.4.6 of the AP1000 FSER and in Section 4.6 of this EA.

4.5 Cost Impacts of Candidate SAMDAs

4.5.1 Westinghouse Evaluation

DCD Tier 2, Section 1B.1.8, "Evaluation of Potential Improvements," discusses capital

cost estimates for the design alternatives evaluated by Westinghouse for the AP1000. DCD

Tier 2, Table 1B-5, presents the results of the cost evaluations. The cost evaluations did not

account for the costs of design engineering, testing, and maintenance for each design

alternative. Including these costs would increase the overall costs and decrease the benefits of

each alternative. Thus, the Westinghouse approach is conservative.

4.5.2 NRC Evaluation

Staff may wish to consider clarifying this sentence to acknowledge the status of the additional 3 SAMDAs discussed in 4.2 and 4.3

As mentioned previously, the set of SAMDAs considered for the AP1000 is the same as the set considered for the AP600. As part of the AP600 review, the NRC compared the capital costs for the AP600 design alternatives with those evaluated for the ABWR and CE System 80+ designs. The purpose of this comparison was to determine the reasonableness of the cost estimates presented by the applicant. The design alternatives among the reactor designs, did not exactly match, so only rough comparisons were possible. Based on these comparisons, the NRC concluded that the cost estimates for the AP600 design alternatives are in reasonable agreement with the costs for roughly similar design alternatives evaluated for other plants. Given the similarity between the AP1000 and the AP600 design features and risk profile, the NRC considers this prior evaluation for the AP600 to be applicable to the AP1000 as well. This is reasonable, considering uncertainties in the cost estimates, ~~and the level of precision necessary, given the greater uncertainty inherent on the benefit side with which these costs were compared.~~

4.6 Cost-Benefit Comparison

4.6.1 Westinghouse Evaluation

After considering the risk reduction potential and cost impact of the various SAMDAs, Westinghouse did a cost-benefit comparison to determine whether any of the potential severe accident design features would be justified. To do so, Westinghouse evaluated the benefits of each design alternative in terms of potential risk reduction, which was defined as the reduction

materials from a severe accident, and the effects of external events. Given the similarities between the AP1000 and AP600 design features and risk profiles and the sets of SAMDAs relevant to each design, the NRC considers this prior evaluation for the AP600, summarized below, to be applicable to the AP1000 as well.

The staff estimated the maximum benefits that could be achieved with the AP600 design alternatives, assuming that a design alternative can either completely eliminate all core damage events or completely eliminate offsite releases of radioactive materials in the event of a severe accident. The estimates of benefits were calculated using the NRC-developed FORECAST code (NUREG/CR-5595, Revision 1, "FORECAST: Regulatory Effects Cost Analysis Software Manual, Version 4.1," Science and Engineering Associates, Inc., July 1996). FORECAST allows the use of uncertainty ranges for all key parameters and provides a means for combining uncertainties in these parameters. For the purposes of estimating the maximum potential benefit from the AP600 design alternatives, the staff assumed that external events and accident sequences not yet accounted for in the PRA increased the reference CDF by two orders of magnitude (i.e., a factor of 100).

The results of the analysis indicated that design alternatives which prevent accidents (i.e., reduce the accident frequency to zero) are much more cost effective than design alternatives which reduce or eliminate offsite releases, but which have no effect on accident frequency. This is because of the fairly large benefits of averting onsite cleanup and decontamination costs and avoiding replacement energy costs. ~~Neither of these costs are assumed to be impacted by design alternatives which do not reduce accident frequency.~~ The staff divided the design alternatives into two groups: those that impact the CDF and those that impact containment performance, but not CDF. Benefits were estimated by taking the fractional

This point was already made, more clearly, earlier in the paragraph.

reduction in risk for each design alternative (compared to the AP600 baseline risk as defined by the applicant) and applying that fraction to the mean benefits.

Design alternatives that were within a decade of meeting a benefit cost criterion of \$5000/person-rem were subjected to further probabilistic and deterministic considerations. None of the design alternatives had a cost-benefit ratio of less than \$5000/person-rem. The only design alternatives which came within a decade of the \$5000/person-rem criterion were SAMDA 10, diverse IRWST injection valves, and SAMDA 3, self-actuating CIVs. The NRC concludes, on the basis of further probabilistic and deterministic evaluations, that these design alternatives are not cost beneficial and need not be further pursued.

Given the similarities between the AP1000 and the AP600 design features and risk profiles and the sets of SAMDAs relevant to each design, the NRC considers the results of this prior evaluation for the AP600 to be applicable to the AP1000 as well. Accordingly, the NRC further evaluated these two SAMDAs for the AP1000, as discussed below.

4.7 Further Considerations

4.7.1 Self-Actuating Containment Isolation Valves

This design alternative would reduce the likelihood of containment isolation failure by adding self-actuating valves or enhancing the existing CIVs for automatic closure when containment conditions indicate a severe accident has occurred. Conceptually, the design would either be an independent valve or an appendage to an existing fail-closed valve that would respond to post-accident containment conditions. For example, a fusible link would melt in response to elevated ambient temperatures, venting the air operator of a fail-closed valve,

10 percent) reduction of the at-power internal events CDF. In the absence of a comprehensive external events PRA for the AP1000 plant, it is difficult to estimate the effectiveness of this design alternative in reducing the risk from external events such as seismic events. However, it appears likely that failure to inject coolant to the reactor would remain a contributor to the CDF from external events, in which case diversity in the IRWST injection valves should help to reduce the risk from both external and internal events.

Alternate vendors are available for the CVs. However, it is questionable if CVs of different vendors would be sufficiently varied to be considered diverse unless the type of CV was changed from the current swing-disk check valve type to another type. The swing-disk type is preferred for this application and other types are considered less reliable.

Adding diversity to the injection line squib valves would require additional spares at the plant and some additional training for plant operations and maintenance staff, but would not appear to add significantly to the operational ^{costs for} aspects of the AP1000. However, a greater issue concerns the availability and costs of acquiring diverse valves from a second vendor. Squib valves are specialized valve designs for which there are few vendors. The applicant claimed that a vendor might not be willing to design, qualify, and build a reasonable squib valve design for this application, considering that the vendor would only supply two valves per plant. The cost estimate for this design alternative assumes that a second squib valve vendor exists and that the vendor only provides the two diverse IRWST squib valves per plant. The cost estimate does not include the additional first-time engineering and qualification testing costs that will be incurred by the second vendor. The applicant estimated that those costs could be more than \$1 million dollars. As a result, the applicant concluded that this design alternative would not be practicable because of the uncertainty in the availability of a second squib valve design/vendor and the uncertainty about the reliability of another type of CV. The NRC considers the rationale