

# **ACRS MEETING WITH THE U.S. NUCLEAR REGULATORY COMMISSION**

**G. E. Apostolakis  
July 10, 2002**

# Overview

- **Core Power Updates**
- **License Renewals**
- **Future Committee Activities**

# Core Power Upgrades

- **Recommended 5 approvals:**
  - **Duane Arnold Energy Center (15.3%)**
  - **Dresden Units 2 & 3/Quad Cities Units 1 & 2 (17%/17.8%)**
  - **Arkansas Nuclear One Unit 2 (7.5%)**
  - **Clinton Power Station Unit 1 (20%)**
  - **Brunswick Steam Electric Plant Units 1 & 2 (14.3%)**

# Upgrades (Cont'd)

- **ACRS reviewed GE Topical Report**  
“Constant Pressure Power Upgrade”  
**(CPPU) (4/02)**
  - **CPPU methodology applied to BWR**  
**upgrades up to 20% nominal power**
  - **Committee found CPPU**  
**methodology acceptable**

# **Uprates (Cont'd)**

- **Committee anticipates review of 4-5 uprate applications each in 2003 & 2004. Several other licensees are evaluating the feasibility of uprate applications.**

# Uprates (Cont'd)

- **Committee Review Issues:**
  - **Lack of adequate documentation in staff safety evaluation reports – issue is being addressed via steadily improving documents**
  - **Need for staff guidance document on future uprate reviews–pursuant to SRM, staff is developing proposed “Review Standard”**

# **Upgrades (Cont'd)**

- Core reload safety analyses – NRR performing audits to confirm appropriate use of approved methodology**
- Need for staff audit calculations/detailed T/H Models - Staff to consider as part of “Review Standard” development and related activities.**

# **License Renewal Activities**

- **Current Status**
  - **Turkey Point review complete**
  - **Reviews completed for at least one plant from each vendor**
  - **Interim letters only as needed**

# **License Renewal (Cont'd)**

- **Upcoming Reviews**
  - **McGuire and Catawba (1<sup>st</sup> Ice Condensers)**
  - **Fort Calhoun (1<sup>st</sup> Using Generic Guidance Documents)**
  - **North Anna/Surry/Peach Bottom/  
St. Lucie**
- **Two License Renewal Subcommittees**

# **Future Committee Activities**

- **Risk-Informed Performance-Based Regulations**
- **Reactor Operations (including Reactor Oversight Process, Plant Operating Events)**
- **Safety Research (focus on Advanced Reactors)**
- **Reactor Fuel (High-Burnup & MOX)**

# **Activities (Cont'd)**

- **Safeguards/Security**
- **Fire Protection**
- **Transient & Accident Code Reviews**
- **Human Factors**
- **Safety Culture**
- **Naval Reactors**

# Briefing Topics

- **Advanced Reactors - T. S. Kress**
- **Risk-Informing Special Treatment**
- **Requirements of Part 50-  
G. E. Apostolakis**
- **Pressurized Thermal Shock  
Technical Basis Re-evaluation  
Project- F. P. Ford**

# **ADVANCED REACTORS: A STATUS REPORT**

**T. S. Kress  
July 10, 2002**

# **ACRS Activities**

- **Two members participated in the NRC workshop on high temperature gas-cooled reactor safety and research issues**
- **Main topic at the 2001 ACRS retreat**
- **ACRS sponsored a workshop on future reactors**
  - **Identified 24 potential technical issues**

# **ACRS Activities (Cont'd)**

- **Developing a task action plan to focus Committee review**
- **Advanced reactors; a main area in the next ACRS research report**
- **Completed review of policy and technical issues identified by Office of Regulatory Research**

# **Overarching Policy Issues:**

- Implementation of Commission’s “expectation” that advanced reactors will provide enhanced margins of safety**
- Relationship of NRC safety requirements to international safety requirements**

# **Staff Technical Issues**

- **Event selection and safety classification**
- **Fuel performance and qualification**
- **Source term**
- **Containment versus confinement**
- **Emergency evacuation**

# Possible Impediments

- **Lack of high-level risk-acceptance criteria other than Core Damage Frequency (CDF) and Large Early Release Frequency (LERF)**
- **Lack of criteria for selecting design basis accidents**
- **The appropriate role of defense in depth**

# **Current Activities**

- **Priority is AP1000**
- **Working to resolve potential impediments**
- **Planning to develop “strawman” positions on various issues**

**Risk-Informing Special  
Treatment  
Requirements of  
10 CFR Part 50**

**G. E. Apostolakis  
July 10, 2002**

# **Risk-Informed Categorization Scheme**

	<b>Safety Related</b>	<b>Non-Safety Related</b>
<b>Safety Significant</b>	<b>RISC-1</b>	<b>RISC-2</b>
<b>Not Safety Significant</b>	<b>RISC-3</b>	<b>RISC-4</b>

# **Previous Comments**

## **October 12, 1999 Report**

- **Terminology of “safety-related” Systems Structures and Components (SSCs) should be preserved**
- **Significance of importance measures and their limitations**
- **Recommended guidance to the expert panel**

# March 19, 2002 Report

**Reviewed NEI 00-04/Rev. B**

***Option 2 Implementation Guideline***

**Recommendations**

- **The criteria used by Integrated Decision-making Panel (IDP) should be explicit and include risk metrics that supplement CDF and LERF (late containment failure; inadvertent radionuclide release)**

# **March Report (Cont'd)**

- **A more complete set of risk metrics may allow the elimination of special treatment requirements for class RISC-3.**
  - **Difficulty in treatment of RISC-3 because risk concerns cannot be completely addressed by CDF and LERF**
  - **Materials degradation should be considered by IDP**

# **March Report (Cont'd)**

- **Guidance to IDP should include:**
  - **Whether SSC acts as barrier to fission product release during severe accidents**
  - **Whether the SSC is relied upon in Emergency Operating Procedures or Severe Accident Mitigation guidelines**

# **March Report (Cont'd)**

- Whether failure of SSC results in an inadvertent radionuclide release**

# **March Report (Cont'd)**

- **Treatment of uncertainties in PRA results should be made consistent with the current capabilities of PRA software and data.**
- **When simplified methods are used, comparison with more rigorous analyses should be available to demonstrate the adequacy of these methods**

# March Report (Cont'd)

- **Use of risk information in regulations is still viewed with skepticism by some groups**
- **Rigor would contribute to building confidence**
- **Substituting “sensitivity” analysis for uncertainty analysis does not contribute to confidence building**

# March Report (Cont'd)

- **Assessing the impact on CDF and LERF of changing the failure rates by factors ranging from 2 to 5 (in lieu of the South Texas Project factor of 10) needs better justification**

**PRESSURIZED  
THERMAL SHOCK (PTS)  
RULE (10CFR50.61)  
RE-EVALUATION**

**F. Peter Ford  
July 10, 2002**

# PTS Re-evaluation

- **Need For Re-evaluation:**
  - **Less frequent/better Operator performance**
  - **Tougher reactor vessel**
  - **Smaller cracks**
  - **Original criterion overly conservative**

# **PTS Re-evaluation (Cont'd)**

- **Integrated Approach**
  - **Probabilistic Risk Assessment (PRA)**
  - **Thermal Hydraulics (T-H)**
  - **Probabilistic Fracture Mechanics (PFM)**

# **PTS Re-evaluation (Cont'd)**

- **Application of integrated analytical process**
  - **Oconee Unit 1**
  - **Beaver Valley Unit 1**
  - **Palisades**
  - **Calvert Cliffs Unit 1**

# **PTS Re-evaluation (Cont'd)**

- **Current process versus 1980's analysis**
  - **Latest PRA/human reliability data**
  - **More refined binning**
  - **Operator action/Acts of commission**
  - **External events**
  - **More T-H sequences modeled**

# **PTS Re-evaluation (Cont'd)**

- **Current versus 1980's analysis  
(continued)**
  - **Conservative bias in toughness  
model removed**
  - **Spatial variation influence**
  - **Smaller embedded flaws**
  - **Non-conservatisms removed**

# **PTS Re-evaluation (Cont'd)**

- **Observations**
  - **Primary system LOCAs dominant**
  - **Realistic operator action**
  - **Main steamline/steam generator tube rupture no longer dominant**
  - **Safety relief valve closure time**

# **PTS Re-evaluation (Cont'd)**

- **Ongoing work**
  - **Complete internal events analysis**
  - **External Events**
  - **Containment Integrity**
  - **Source Terms**

# **PTS Re-evaluation (Cont'd)**

- **ACRS Conclusions**
  - **Extensive/technically sound project**
  - **Preliminary results of Oconee reactor pressure vessel (RPV) analysis indicate that the current PTS screening criterion may be overly conservative.**