



Briefing on the Progress of the Task Force Review of NRC Processes and Regulations Following the Events in Japan

Bill Borchardt
Executive Director for Operations
May 12, 2011

Agenda

- **Overview**

Martin Virgilio

- **Task Force Activities**

Dr. Charles Miller

Actions to Date

- **Status of event in Japan and NRC response**
- **Information Notice 2011-05, “Tohoku-Taiheiyou-Oki Earthquake Effects on Japanese Nuclear Power Plants”**

Actions to Date (Cont'd)

- **Temporary Instruction (TI) 2515/183**
 - **Extensive damage mitigation guidelines (EDMGs)**
 - **Station blackout (SBO)**
 - **Seismic and flooding**
- **TI 2515/184 on severe accident management guidelines (SAMGs)**

Tasking Memorandum and Charter

- **Tasking Memorandum – COMGBJ-11-0002, “NRC Actions Following the Events in Japan”**
 - **March 23, 2011**
- **Task force charter**
 - **March 30, 2011**

Review Strategy

- **Near-term review**
 - **Formulate recommendations for near-term action**
 - **Identify a framework and topics for longer-term review**
 - **Provide report in July 2011**

Task Force Activities 30-Day Update

**Dr. Charles L. Miller, Lead
NRC Task Force**

Current Assessment

- **To date the task force has not identified any issues that undermine our confidence in the continued safety and emergency planning of U.S. plants**
- **Task force review likely to recommend actions to enhance safety and preparedness**

Task Force Review Approach

- **Systematic and methodical**
 - **Insights from past lessons learned efforts**
 - **Focused on Fukushima-related issues**
- **Defense-in-depth approach**
 - **Prevention, mitigation, emergency preparedness (EP)**

Task Force Decisionmaking

- **Recommendations will be informed by:**
 - **Safety goals**
 - **Defense-in-depth philosophy**
 - **NRC Principles of Good Regulation**
 - **Existing technical requirements**
 - **Regulatory analysis guidelines**

Prompt Actions

- **Task force requested an inspection of SAMG implementation**
- **Task force encouraged public release of guidance for developing EDMGs**

Scope of Review

- **U.S. power reactors and their spent fuel pools**
- **Near-term and longer-term recommendations**

Areas of Focus

- **Protection from design basis natural phenomena**
- **Consideration of beyond design basis natural phenomena**
- **Mitigation for long-term SBO**
 - **Including multiple unit events**
- **Emergency preparedness**
- **NRC programs**

Protection From Design Basis Natural Phenomena

- **Evaluation of the design basis and safety margins for seismic, flooding, and other external events that could cause long-term SBO or loss of ultimate heat sink**
- **Consideration of related design basis external events**

Consideration of Beyond Design Basis Natural Phenomena

- **Survivability of AC power during beyond design basis external events**
 - **Evaluation of emergency AC power and distribution**
 - **Evaluation of alternative sources of AC to power safety equipment in the event normal sources are lost**

Mitigation

- **Mitigating the consequences of long-term SBO to:**
 - **Prevent core damage and containment failure**
 - **Prevent spent fuel damage and mitigate releases**

Considerations for Preventing Core Damage and Containment Failure

- **Heat removal capability**
- **PWR reactor coolant pump seals**
- **Containment venting**
- **Hydrogen control measures**

Considerations for Preventing Spent Fuel Damage and Mitigating Releases

- **Heat removal capability**
 - **Water cooling**
 - **Air cooling**
 - **Fuel inventory**
- **Hydrogen control measures**
- **Filtering, monitoring, and scrubbing releases**

Cross-Cutting Considerations for Mitigation

- **Emergency operating procedures, SAMGs, and EDMGs**
 - **Integration**
 - **Training and exercises**
- **Personnel availability and safety**
- **Instrumentation**
- **Decision-making and command and control**

Considerations for Emergency Preparedness

- **Evaluation of emergency plans considering:**
 - **Infrastructure damage**
 - **Multi-unit events**
 - **Long-term SBO**
- **Licensee dose projection and radiation monitoring**
- **Appropriate use of potassium iodide**

NRC Program Considerations

- **Regulatory framework, including beyond design basis events**
- **Reactor licensing**
- **Operator licensing**
- **Reactor inspection**
- **Operating experience**
- **Information access/integration**

Information Gathering Examples

- **Agency expertise**
- **NRC Operations Center and Japan site teams**
- **Inspection results**
- **Stakeholder input**
- **International cooperation**

Next Steps

- **Evaluate TI 2515/183 and 184 results**
- **Commission meetings**
 - **June 15, 2011 status briefing**
 - **July 19, 2011 final briefing**
- **Near-term task force report in July 2011**

Acronym List

- **AC – Alternating Current**
- **EDMG – Extensive Damage Mitigation Guideline**
- **EP – Emergency Preparedness**
- **NRC – Nuclear Regulatory Commission**
- **PWR – Pressurized Water Reactor**

Acronym List (Cont'd)

- **SAMG – Severe Accident Management Guideline**
- **SBO – Station Blackout**
- **SFP – Spent Fuel Pool**
- **TI – Temporary Instruction**