



BRIEFING ON DIGITAL INSTRUMENTATION AND CONTROL

Commission Meeting May 14, 2019



On the Road to Digital Modernization




Speakers

- Margaret Doane, Executive Director for Operations (EDO)
- Ho Nieh, Director, Office of Nuclear Reactor Regulation (NRR)
- Eric Benner, Director, Division of Engineering (DE), NRR
- Brian Thomas, Director, DE, Office of Nuclear Regulatory Research (RES)

NRC has Addressed High Priority Challenges

ISG-06, Rev. 2 Explained




Concept and NRC pre- application meetings	Initial system design and planning	Detailed hardware & software design and fabrication	Implementation, software validation/verification, and factory testing	Onsite installation and site acceptance testing		
Licensee activities						

Current NRC Guidance is Enabling Safe Digital Upgrades via 50.59



Chiller Controls




Diesel Generator Controls



Feedwater/Turbine Control System


Evaluation of an Issue with NEI 96-07 Appendix D is in Progress



10 CFR 50.59(c)(2)(vi)

A license amendment is required if the change would "create a possibility for a malfunction of an SSC important to safety with a different result than any previously evaluated in the final safety analysis report (as updated)."

Where else can we improve the regulatory framework?



Proactively Addressing Additional Common Cause Failure Concerns

Propose Risk-Informed Graded Approach for BTP 7-19

	Safety-Related	Not Safety-Related
Safety-Significant	A1 D3 Analysis	B1 Defense-in- Depth/Qualitative Assessment
Low-Safety-Significant	A2 Defense-in- Depth/Qualitative Assessment	B2 Assessment May be Needed

Perceptions vs. Reality

Common Perceptions	Reality
A diverse analog system is mandatory to backup all DI&C safety systems	No. There are many options to accomplish the intended safety function, including ATWS and operator actions.
100% testing is required of the digital system to address CCF	100% testing is NOT required to address CCF in digital systems and may not be practical.
BTP 7-19 is applicable to DI&C modifications under 10 CFR 50.59	No, a licensee is NOT required to follow BTP 7-19 for digital modifications under 10 CFR 50.59.


Pursuing Alternative Regulatory Approaches and Safety Standards

- Broader use of IEC standards as an alternative way to meet the requirements of IEEE 279 and 603-1991
- Ready to evaluate proposed industry guidance for commercial grade dedication

Research is Supporting the Success of Future Regulatory Modernization

User Needs

- Embedded Digital Devices
- Common Cause Failure
- Risk-Informing
- Operational Experience



NRC is Coordinating with other Domestic Research Activities






Domestic research activities are focused on using digital technologies to improve safety and reliability



NRC's International Collaboration is Focused on Safe Use of Digital I&C







What does success look like?



Shippingport control room circa 1957



Typical control room today > 60 years from Shippingport



Success is expanding the safe use of digital

We're Making Progress on Achieving an Efficient and Effective Digital I&C Framework

- Continue our efforts to:
 - Modernize our decision making in the use of DI&C systems
 - Effectively communicate with all stakeholders to understand their challenges, priorities, and potential solutions
 - Transform with risk-informed and innovative approaches

Acronyms

- BTP Branch Technical Position
- CCF Common Cause Failure
- CFR Code of Federal Regulations
- D3 Diversity and Defense-in-Depth
- DI&C Digital Instrumentation and Control
- I&C Instrumentation and Control
- IEEE Institute of Electrical and Electronics Engineers
- IAEA International Atomic Energy Agency

- IEC International Electrotechnical Commission
- ISG Interim Staff Guidance
- NEI Nuclear Energy Institute
- RIS Regulatory Issue Summary
- NEA Nuclear Energy Agency
- SSC Safety Systems, Structures, and Components
- EPRI Electric Power Research Institute
- TR Topical Report