

December 12, 1996

MEMORANDUM TO: James M. Taylor
Executive Director for Operations

FROM: John C. Hoyle, Secretary /s/

SUBJECT: STAFF REQUIREMENTS - BRIEFING ON SPENT FUEL POOL
STUDY, 2:00 P.M., THURSDAY, NOVEMBER 14, 1996,
COMMISSIONERS' CONFERENCE ROOM, ONE WHITE FLINT
NORTH, ROCKVILLE, MARYLAND (OPEN TO PUBLIC
ATTENDANCE)

The Commission was briefed by the NRC staff on the spent fuel pool study. The staff should provide an explanation for the apparent discrepancy of the curve of "hours to boil" versus "days to offload" for the Outage 3 data on Slide 13 (i.e., 29 hours to boil seems to be too high when compared to the hours since offload values for the other outages.)

(EDO) (SECY Suspense: 1/10/97)

There were no other requirements identified for staff action.

cc: Chairman Jackson
Commissioner Rogers
Commissioner Dicus
Commissioner Diaz
Commissioner McGaffigan
OGC
OCA
OIG
Office Directors, Regions, ACRS, ACNW, ASLBP (via E-Mail)
PDR - Advance
DCS - P1-24