

10/05/2001

U.S. Nuclear Regulatory Commission Operations Center Event Report

Page 1

P21 m1330

Event # 38353

General Information or Other (PAR)

<b>Rep Org:</b> ABB INC.		<b>Notification Date / Time:</b> 10/05/2001 14:26 (EDT)	
<b>Supplier:</b> ABB INC.		<b>Event Date / Time:</b> 10/05/2001 (EST)	
		<b>Last Modification:</b> 10/05/2001	
<b>Region:</b>	<b>Docket #:</b>		
<b>City:</b>	<b>Agreement State:</b> No		
<b>County:</b>	<b>License #:</b>		
<b>State:</b>			
<b>NRC Notified by:</b> RUSS GONNAM	<b>Notifications:</b> VERN HODGE (FAX)	NRR	
<b>HQ Ops Officer:</b> FANGIE JONES	RICHARD CONTE	R1	
<b>Emergency Class:</b> NON EMERGENCY	FRANK JAPE	R2	
<b>10 CFR Section:</b>	DAVID HILLS	R3	
21.21 UNSPECIFIED PARAGRAPH	CLAUDE JOHNSON	R4	

10 CFR 21 REPORT CONCERNING A CLASS 1E RELAY

The following is the faxed report:

Subject: Initial Notification of Potential Defect per 10 CFR Part 21 Type CVE/CVE-1 Relays

Provided By: ABB Inc., Substation Automation & Protection Division

This letter is the initial notification of a deviation concerning our Class 1E relay type CVE/CVE-1. The deviation concerns the difference between the original zero period acceleration value and the recent zero period acceleration value as reported to us by an independent dedicating entity.

Details will be provided in our written notification forthcoming within the next thirty days.

\*\*\*\*\*



p2) m1330

October 5, 2001

NRC Operations Center  
Fax 301-816-5151


Subject Initial Notification of Potential Defect per 10CFR Part 21  
Type CVE / CVE-1 Relays

Provided By ABB Inc.  
Substation Automation & Protection Division  
4300 Coral Ridge Drive  
Coral Springs, FL 33065

This letter is the initial notification of a deviation concerning our Class 1E relay type CVE / CVE-1. The deviation concerns the difference between the original zero period acceleration value and the recent zero period acceleration value as reported to us by an independent dedicating entity.

Details will be provided in our written notification forthcoming within the next thirty days.

  
Russ W. Gonnam  
Quality Manager

  
Marilinda Ruiz  
Site Manager

**ABB Automation Inc.**

Substation Automation & Protection Division

4300 Coral Ridge Drive  
Coral Springs, FL 33065

Telephone: (954) 752-6700  
Telefax: (954) 345-5329